

**western union**

**Telegram**

1975 JAN -6 PM 4:31

VE3252(1726)(2-031479E006)PD 01/06/75 1726

ICS IPMBNGZ CSP

8159424449 TDBN MORRIS IL 109 01-06 0526P EST

PMS JAMES G KEPPLER, REGIONAL DIRECTOR

DIRECTORATE OF REGULATORY OPERATIONS-REGION III WUX U S ATOMIC  
ENERGY COMMISSION 799 ROOSEVELT RD

GLEN ELLYN IL 60137

SUBJECT: DPR-25, DRESDEN NUCLEAR POWER STATION UNIT 3.

THIS WILL CONFIRM A CONVERSATION WITH PHIL JOHNSON OF YOUR OFFICE  
AT 1445 HOURS THIS DATE CONCERNING EXCESS CHLORIDE CONTENT IN  
UNIT 3 REACTOR COOLANT WATER DURING A EXTENDED REACTOR CLEANUP  
SYSTEM MAINTENANCE OUTAGE. AT THE TIME OF THE OCCURANCE AT 1330  
HOURS ON 3 JANUARY 75 A REACTOR WATER SAMPLE REVEALED CHLORIDE  
CONTENT AT 0.6PPM. THE UNIT WAS AT 376MWE AT THE TIME OF THE  
OCCURANCE AND WAS SUBSEQUENTLY SHUT DOWN AND BROUGHT TO A COLD

SF-1201 (R5-69)

SHUTDOWN CONDITION BY 0925 ON 4 JANUARY 75. REACTOR COOLANT  
CHLORIDE CONTENT WAS RETURNED TO WITHIN LIMITS BY 0415 HOURS  
ON 4 JANUARY 75.

B B STEPHENSON, SUPERINTENDENT DRESDEN NUCLEAR POWER STATION,  
COMMONWEALTH EDISON CO RR 1 MORRIS ILLINOIS 60450.

NNNN

TELEPHONE NO. 312-858-2660  
TELEPHONE NO. P. 9 BY 94  
DATE 1/9 930A  
MAIL

SF-1201 (R5-69)

JAN

9 1975