

Reg. File Cy DR Central File



Telegram

445P EST OCT 24 72 DEB873 DE
DEH187(1350)(1-024222C298)PD 10/24/72 1547

1972 OCT 24 PM 4 54 50-277

ICS IPMVEJE MVN
ZCZC 00051 PD TDVE MORRIS ILL 150 10-24 1100 CDT
TELEGRAMS (OTHER THAN MONEY ORDERS)
IS PHYSICAL DELIVERY requested? *No* (YES-AGENT, NO-ADDRESSEE)
PMS MR BOYCE GREER ~~DLV 150~~ DIRECTOR DIV OF COMPLIANCE SEE SECTION
REGION 3 US ATOMIC ENERGY COMMISSION 799 ROOSEVELT RD Nor. 312-858-2660
GLEN ELLYN ILL 60137 Date did *10/25* Time did *10AM* To *NY* By *J*
SUBJECT DPR-25 To be mailed or filed *mail copy*
Attempts to deliver (Indicate DA or BY)

DES DEN NUCLEAR POWER STATION UNIT 3

THIS WILL CONFIRM A CONVERSATION WITH MR H DANCE OF YOUR OFFICE AT 1100 HOURS THIS DATE CONCERNING NO. 1 OFF GAS MONITOR BEING OUT OF CALIBRATION ON 10-20-72 THE INSTRUMENT MECHANICS WHILE MAKING A MONTHLY SURVALANCE CALIBRATION ON UNIT 3 OFF GAS MONITOR FOUND THE TRIP SETTING ON ONE MONITOR GREATER THAN SPECIFIED IN THE TECHNICAL SPECIFICATIONS SECTIONS 3.2.D.A OF THE TECHNICAL SPECIFICATION STATE THAT THE TRIP SETTING FOR

SF-1201 (R5-69)

MONITOR SHALL BE SET AT A VALUE NOT TO EXCEED THE EQUIVILANT OF STACK RELEASE LIMIT SPECIFIED IN SPECIFICATION 3.8 THE STACK RELEASE LIMIT UNDER OPERATING CONDITIONS AT THE TIME WAS 0.7 CI/2ND THE TRIP SETTING ON NO. 1 OFF GAS MONITOR WAS FOUND TO BE 1.0CI/2ND THESE MONITORS DO NOT HAVE A HISTORY OF PREVIOUS FAILURES THE STATION WILL REVIEW THE PRESENT TRIP SETTING TO DETERMINE OF A LOWER LIMIT CAN BE USED

W. P. WORDEN
SUPT DRESDEN NUCLEAR POWER STATION
COL DPR-25 3 1100 1 10-20-72 3 3.2.D. 1 3.8 0.7 CI/2ND 1 1.0CI/2ND

OCT 27 1972

SF-1201 (R5-69)

aw