



Telegram


1974 APR 29 PM 2:57

VEB199(1551)(1-027835C119)PD 04/29/74 1549 312-858-2660

IC5 IPMVEIA MVN TELEGRAMS (OTHER THAN MONEY ORDERS)  
 01176 TDVE MORRIS IL 910 04/29/74 357 CDT (YES-AGENT, NO-ADDRESSEE)  
 PMS JAMES G KEPPLER DIRECTOR, DIRECTORATE OF REGULATORY OPERATIONS  
 REGION 3 WUX US ATOMIC ENERGY COMM. 799 ROOSEVELT RD. To CH By TP  
 GLEN ELLYN IL 60137  
 attempts to deliver (Indicate DA or BY)

SUBJECT DPR-25 DRESDEN NUCLEAR POWER STATION UNIT 3,  
 THIS WILL CONFIRM A CONVERSATION WITH H. DANCE OF YOUR  
 OFFICE AT 1105 HOURS THIS DATE CONCERNING LOW LEVEL  
 IN THE TORUS DUE TO FAULTY INDICATION WHILE PUMPING THE  
 LEVEL DOWN. AT THE TIME OF THE OCCURANCE, THE REACTOR WAS IN  
 THE REFUEL MODE AND REFUELING OPERATIONS WERE IN PROGRESS.  
 THE ACTUAL TORUS LEVEL WAS FOUND TO BE APPROXIMATELY TWO INCHES  
 BELOW THE LOW LEVEL LIMIT. IT WAS AT THIS CONDITION FOR A  
 PERIOD OF 5 HOURS 50 MINUTES UNTIL THE LEVEL INDICATION MAY 1 1974

8F-1201



Telegram

WAS CORRECTED. THIS NOTIFICATION WILL BE FOLLOWED BY A TEN DAY LETTER

B B STEPHENSON, SUPERINTENDENT  
 DRESDEN NUCLEAR POWER STATION COMMONWELATH EDISON COMPANY  
 ROUTE 1 MORRIS ILLINOIS

NNNN