

December 31, 1984

Docket No. 50-244
LS05-84-12-024

DISTRIBUTION

Docket File
NRC PDR
Local PDR
NSIC
ORB #5 Reading
JZwolinski
CJamerson

OELD
ELJordan
PFMcKee
ACRS (10)
JShea
ASingh

Mr. Roger W. Kober, Vice President
Electric and Steam Production
Rochester Gas & Electric Corporation
89 East Avenue
Rochester, New York 14649

Dear Mr. Kober:

SUBJECT: SINGLE FAILURE PROOF MODIFICATIONS TO THE AUXILIARY BUILDING CRANE

Re: R. E. Ginna Nuclear Power Plant

By letter dated January 18, 1984, Rochester Gas and Electric Corporation (RG&E) informed us of its intention to modify the Auxiliary Building crane to be single failure proof. Additional information was provided in letters of July 31, and September 7, 1984. The modified crane will be in conformance with NUREG-0554, "Single Failure Proof Cranes for Nuclear Power Plants," and Appendix B to NUREG-0612, "Control of Heavy Loads at Nuclear Power Plants."

We have reviewed your proposed modifications and find them acceptable. Our Safety Evaluation is enclosed.

RG&E's letter of January 18, 1984 also requested a change to the Ginna Technical Specifications which would remove the restriction on movement of spent fuel casks with the Auxiliary Building crane. That change can be approved upon written confirmation the crane has been modified to be single failure proof.

Sincerely,

Original signed by

John A. Zwolinski, Chief
Operating Reactors Branch #5
Division of Licensing

8501020317 841231
PDR ADOCK 05000244
P PDR

Enclosure:
Safety Evaluation

cc w/enclosure:
See next page

DL: ORB #5
CJamerson:cs
12/27/84

JShea
DL: ORB #5
JShea
12/27/85

χ
DL: ORB #5
JZwolinski
12/31/85

SEOL
1/1
Ev(OR)
Add: A Singh

Mr. Roger W. Kober

- 2 -

December 31, 1984

cc

Harry H. Voigt, Esquire
LeBoeuf, Lamb, Leiby and MacRae
1333 New Hampshire Avenue, N.W.
Suite 1100
Washington, D.C. 20036

Ezra Bialik
Assistant Attorney General
Environmental Protection Bureau
New York State Department of Law
2 World Trade Center
New York, New York 10047

Resident Inspector
R.E. Ginna Plant
c/o U.S. NRC
1503 Lake Road
Ontario, New York 14519

Stanley B. Klimberg, Esquire
General Counsel
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Dr. Thomas E. Murley
Regional Administrator
Nuclear Regulatory Commission
Region I Office
631 Park Avenue
King of Prussia, Pennsylvania 19406

Supervisor of the Town of Ontario
1850 Ridge Road
Ontario, New York 14519

Jay Dunkleberger
Division of Policy Analysis & Planning
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

U. S. Environmental Protection Agency
Region II Office
ATTN: Regional Radiation Representative
26 Federal Plaza
New York, New York 10007