



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

ROCHESTER GAS AND ELECTRIC CORPORATION

DOCKET NO. 50-244

R. E. GINNA NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 6  
License No. DPR-18

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Rochester Gas and Electric Corporation (the licensee) dated December 3, 1984 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public; and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8506280012 850625  
PDR ADDCK 05000244  
P PDR



1950


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C(2) of Facility Operating License No. DPR-18 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 6, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John A. Zwolinski, Chief  
Operating Reactors Branch #5  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: June 25, 1985

ATTACHMENT TO LICENSE AMENDMENT NO. 6

FACILITY OPERATING LICENSE NO. DPR-18

DOCKET NO. 50-244

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

3.11-2

INSERT

3.11-2

e. Charcoal adsorbers shall be installed in the ventilation system exhaust from the spent fuel storage pit area and shall be operable.

3.11.2 Radiation levels in the spent fuel storage area shall be monitored continuously.

3.11.3 A load in excess of one fuel assembly and its handling tool shall never be stationed or permitted to pass over storage racks containing spent fuel.

3.11.4 The spent fuel pool temperature shall be limited to 150°F.

3.11.5 The spent fuel shipping cask shall not be carried by the auxiliary building crane, pending the evaluation of the spent fuel cask drop accident and the crane design by RG&E and NRC review and approval.

Basis:

Charcoal adsorbers will reduce significantly the consequences of a refueling accident which considers the clad failure of a single irradiated fuel assembly. Therefore, charcoal adsorbers should be employed whenever irradiated fuel is being handled. This requires that the ventilation system should be operating and drawing air through the adsorbers.

The desired air flow path, when handling irradiated fuel, is from the outside of the building into the operating floor area, toward the spent fuel storage pit, into the area exhaust ducts, through the adsorbers, and out through the ventilation system exhaust to the facility vent. Operation of a