

Attachment A

Make the following changes in the Technical Specification.

Remove

Insert

Page 3.11-1 to 3.11-4

Page 3.11-1 to 3.11-4

Page 4.11-1

Page 4.11-1

8510220283 851009
PDR ADDCK 05000244
P PDR



11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

3.11

Fuel Handling in the Auxiliary Building

Applicability

Applies to limitations while moving irradiated fuel in the operating floor area of the auxiliary building.

Objective

To limit doses in the event an irradiated fuel assembly is damaged significantly.

Specification

3.11.1

During handling of fuel assemblies in the auxiliary building when either the fuel being handled or the fuel stored in the spent fuel storage pool has decayed less than 60 days since irradiation, the following conditions shall be satisfied:

- a. One auxiliary building main exhaust fan shall be operating.
- b. The auxiliary building exhaust fan 1C, which takes suction from the spent fuel storage pool area, shall be operating.
- c. All doors, windows, and other direct openings between the operating floor area and the outside shall be closed except that the personnel door may be opened for access as required.
- d. Roughing filters shall be installed at the inlet to the adsorbers.



1. The first part of the document

2. The second part of the document

3. The third part of the document

4. The fourth part of the document

5. The fifth part of the document

6. The sixth part of the document

7. The seventh part of the document

8. The eighth part of the document

9. The ninth part of the document

10. The tenth part of the document

11. The eleventh part of the document

12. The twelfth part of the document

13. The thirteenth part of the document

14. The fourteenth part of the document

15. The fifteenth part of the document

16. The sixteenth part of the document

17. The seventeenth part of the document

18. The eighteenth part of the document

19. The nineteenth part of the document

20. The twentieth part of the document

21. The twenty-first part of the document

22. The twenty-second part of the document

23. The twenty-third part of the document

24. The twenty-fourth part of the document

25. The twenty-fifth part of the document

26. The twenty-sixth part of the document

27. The twenty-seventh part of the document

28. The twenty-eighth part of the document

29. The twenty-ninth part of the document

30. The thirtieth part of the document

31. The thirty-first part of the document

32. The thirty-second part of the document

33. The thirty-third part of the document

34. The thirty-fourth part of the document

35. The thirty-fifth part of the document

36. The thirty-sixth part of the document

37. The thirty-seventh part of the document

38. The thirty-eighth part of the document

39. The thirty-ninth part of the document

40. The fortieth part of the document

41. The forty-first part of the document

42. The forty-second part of the document

43. The forty-third part of the document

44. The forty-fourth part of the document

45. The forty-fifth part of the document

46. The forty-sixth part of the document

47. The forty-seventh part of the document

48. The forty-eighth part of the document

49. The forty-ninth part of the document

50. The fiftieth part of the document

51. The fifty-first part of the document

e. Charcoal absorbers shall be installed in the ventilation system exhaust from the spent fuel storage pool area and shall be operable.

3.11.2 Radiation levels in the spent fuel storage area shall be monitored continuously.

3.11.3 A load in excess of one fuel assembly and its handling tool shall never be stationed or permitted to pass over storage racks containing spent fuel.

3.11.4 The spent fuel pool temperature shall be limited to 150°F.

Basis:

Charcoal adsorbers will reduce significantly the consequences of a refueling accident which considers the clad failure of a single irradiated fuel assembly. Therefore, charcoal adsorbers should be employed whenever recently irradiated fuel is being handled. This requires that the ventilation system should be operating and drawing air through the adsorbers. The only exception to the requirement occurs when the fuel being handled, or any fuel in the storage pool, has decayed at least 60 days since irradiation. The consequences of a fuel handling accident in this case without operation of the charcoal absorbers is significantly less than the guidelines of 10CFR100.³

The desired air flow path, when handling irradiated fuel, is from the outside of the building into the operating floor area, toward the spent fuel storage pool, into the area exhaust ducts, through the adsorbers, and out through the ventilation system exhaust to the facility vent. Operation of a main auxiliary building exhaust fan assures that air discharged into the main ventilation system exhaust duct will go through a HEPA and be discharged to the facility vent. Operation of the exhaust fan for the spent fuel storage pool area causes air movement on the operating floor to be toward the pool. Proper operation of the fans and setting of dampers would result in a negative pressure on the operating floor which will cause air leakage to be into the building. Thus, the overall air flow is from the location of low activity (outside the building) to the area of highest activity (spent fuel storage pit). The exhaust air flow would be through a roughing filter and charcoal before being discharged from the facility. The roughing filter protects the adsorber from becoming fouled with dirt; the adsorber removes iodine, the isotope of highest radiological significance, resulting from a fuel handling accident. The effectiveness of charcoal for removing iodine is assured by having a high throughput and a high removal efficiency. The throughput is attained by operation of the exhaust fans. The high removal efficiency is attained by minimizing the amount of iodine that bypasses the charcoal and having charcoal with a high potential for removing the iodine that does pass through the charcoal.



Faint, illegible text at the top of the page.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

Faint, illegible text in the upper section.

The spent fuel pool temperature is limited to 150°F because if the spent fuel pool cooling system is lost at that temperature, sufficient time (approximately 7 hours) is available to provide back-up cooling, assuming the maximum anticipated heat load (full core discharge & previously stored fuel), until a temperature of 180°F is reached, the temperature at which the structural integrity of the pool was analyzed and found acceptable.

References

- (1) FSAR - Section 9.3-1
- (2) ANS-5.1 (N 18.6), October 1973
- (3) Letter, J.A. Zwolinski, (USNRC) to R.W. Kober, (RG&E),
November 14, 1984.



The page contains extremely faint and illegible text, likely bleed-through from the reverse side of the document. The text is scattered across the page and cannot be transcribed accurately.

4.11 Refueling

Applicability

Applies to refueling and to fuel handling in the spent fuel pool.


Specification

4.11.1 Spent Fuel Pit Charcoal Absorber System

4.11.1.1 Within 60 days prior to any operation of the spent fuel pool charcoal absorber system as required by Section 3.11, the following conditions shall be demonstrated.

After the conditions have been demonstrated, the occurrence of painting, fire, or chemical release in any ventilation zone communicating with the spent fuel pool charcoal absorber system shall require that the following conditions be redemonstrated, before fuel handling may continue, if operation of the spent fuel fuel pool charcoal absorber system is required per section 3.11

- a. The total air flow rate from the charcoal absorbers shall be at least 75% of that measured with a complete set of new absorbers.
- b. In-place Freon testing, under ambient conditions, shall show at least 99% removal.
- c. The results of laboratory analysis on a carbon sample shall show 90% or greater radioactive methyl iodide removal when tested at least 150°F and 95% RH and at 1.5 to 2.0 mg/m³ loading with tagged CH₃I.




Attachment B

The proposed change to the Technical Specification deletes the requirement for operation of the charcoal filters when moving fuel in the auxiliary building when the fuel has decayed 60 days since irradiation, and when fuel stored in the pool has decayed at least 60 days.

In response to a request for expansion of the spent fuel storage pool capacity, the NRC SER⁽¹⁾ documented the NRC staff evaluation of the radiological consequences of a tornado missile impact on Region 2 of the spent fuel storage racks. In this analysis, a cooldown time of 60 days and damage to nine fuel assemblies was assumed. No credit was taken for operation of charcoal filters. For this case the offsite radiological consequences were calculated to be 2 rem thyroid and 0.1 rem whole body.

Adjusting these calculated results for damage to only one fuel assembly corresponding to a fuel handling accident, yields resulting doses of approximately 0.2 rem thyroid and 0.01 rem whole body. These consequences are well within the guidelines of 10CFR100 and are significantly less than doses previously considered by the NRC to be acceptable.



Attachment C

In accordance with 10CFR 50.91 this change to the Technical Specifications has been evaluated against three criteria to determine if the operation of the facility in accordance with the proposed amendment would:

1. involve a significant increase in the probability or consequences of an accident previously evaluated; or
2. create the possibility of a new or different kind of accident from any accident previously evaluated; or
3. involve a significant reduction in a margin of safety.

Reference 1 provides an evaluation by the NRC of the limiting thyroid dose that would result from damage to fuel that had decayed 60 days since irradiation. As discussed in Attachment B, these results can be used to evaluate the consequences of a fuel handling accident inside the auxiliary building with no credit for iodine removal due to operation of the charcoal filters. The resulting thyroid dose of 0.2 Rem is well within the guidelines of 10CFR 100 and is less than that which was previously considered to be acceptable by the NRC.

Therefore, a no significant hazards finding is warranted because:

- 1) the probability of a fuel handling accident is unchanged and the consequences are less than those previously evaluated,
- 2) the possibility of a new or different kind of accident is not created, and
- 3) the margin of safety is not reduced due to the resulting dose being less than that previously considered acceptable.

References

- (1) Letter, Mr. J.A. Zwolinski, NRC, to Mr. R.W. Kober, RG&E, November 14, 1984.

