



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ROCHESTER GAS AND ELECTRIC CORPORATION

DOCKET NO. 50-244

R. E. GINNA NUCLEAR POWER PLANT

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 65
License No. DPR-18

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Rochester Gas and Electric Corporation (the licensee) dated April 2, 1984 and supplemented by letter dated June 12, 1984 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public; and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8411200353 841114
PDR ADDCK 05000244
P PDR

THE UNIVERSITY OF CHICAGO
LIBRARY


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C(2) of Provisional Operating License No. DPR-18 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 65, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


John A. Zwolinski, Chief
Operating Reactors Branch #5
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 14, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 65

PROVISIONAL OPERATING LICENSE NO. DPR-18

DOCKET NO. 50-244

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages contain the captioned amendment number and marginal lines which indicate the area of changes.

REMOVE

5.4-1

INSERT

5.4-1

5.4-2

5.4-3

5.4-4

5.4-5

5.4 Fuel Storage

Specification

- 5.4.1 The new and spent fuel pit structures are designed to withstand the anticipated earthquake loadings as Class I structures. The spent fuel pit has a stainless steel liner to ensure against loss of water.
- 5.4.2 The new and spent fuel storage racks are designed so that it is impossible to insert fuel assemblies in other than the prescribed locations. The spent fuel storage racks are divided into two regions as depicted on Figure 5.4-1. The fuel is stored vertically in an array with sufficient center-to-center distance between assemblies to assure $K_{eff} \leq 0.95$ for (1) unirradiated fuel assemblies delivered prior to January 1, 1984 (Region 1-15) containing no more than 39.0 gms U-235 per axial cm, and (2) unirradiated fuel assemblies delivered after January 1, 1984 containing no more than 41.9 gms U-235 per axial cm. Both cases assume unborated water used in the pool.
- 5.4.3 In Region 2 of the spent fuel storage racks, fuel is stored in a close packed array utilizing fixed neutron poisons in each of the stored locations. For discharged fuel assemblies to be stored in Region 2, (1) 60 days must have elapsed since the core reached hot shutdown prior to discharge and (2) the combination of assembly average burnup and initial U-235 enrichment must be such that the point identified by these two parameters on Figure 5.4-2 is above the line applicable to the particular fuel assembly design, therefore assuring that $K_{eff} \leq 0.95$.

5.4.4 The spent fuel storage pit is filled with borated water at a concentration to match that used in the reactor cavity and refueling canal during refueling operations whenever there is fuel in the pit.

Basis

The center to center spacing of Region 1 insures that $K_{eff} < 0.95$ for the enrichment limitations specified in 5.4.2¹, and for a postulated missile impact the resulting dose at the EAB would be within the guidelines of 10CFR100².

In Region 2, $K_{eff} < 0.95$ is insured by the addition of fixed neutron poison (boraflex) in each of the Region 2 storage locations, and a minimum burnup requirement as a function of initial enrichment for each fuel assembly design. The 60 day cooling time requirement insures that for a postulated missile impact the resulting dose at the EAB would be within the guidelines of 10CFR100.

The two curves of Figure 5.4-2 divide the fuel assembly designs into two groups. The first group is all fuel delivered prior to January 1, 1984. This incorporates all Exxon and Westinghouse HIPAR designs used at Ginna⁴. The second curve is for the Westinghouse Optimized Fuel Assembly design delivered to Ginna beginning in February 1984³.

The assembly average burnup is calculated using INCORE generated power sharing data and the actual plant operating history. The calculated assembly average burnup should be reduced by 10% to account for uncertainties. An uncertainty of 4% is associated with the measurement of power sharing. The additional 6% provides additional margin to bound the burnup uncertainty


associated with the time between measurements and updates of core burnup. The curves of Figure 5.4-2 incorporate the uncertainties of the calculation of assembly reactivity.³

The calculations of fuel assembly burnup for comparison to the curves of Figure 5.4-2 to determine the acceptability for storage in Region 2 shall be independently checked. The records of these calculations shall be kept for as long as fuel assemblies remain in the pool.

References

1. Letter, J.E. Maier to H.R. Denton, January 18, 1984.
2. Letter J.E. Maier to H.R. Denton, January 18, 1984.
3. Criticality Analysis of Region 2 of the Ginna MDR Spent Fuel Storage Rack, Pickard, Lowe and Garrick, Inc.
March 8, 1984.
4. Letter, T.R. Robbins, Pickard, Lowe and Garrick, Inc. to J.D. Cook, RG&E March 15, 1984.


FIGURE 5.4-1
SPENT FUEL STORAGE RACKS



TOTAL CAPACITY 1016

FIGURE 5.4-2.

REGIONS OF ACCEPTABILITY AND UNACCEPTABILITY
FOR STORAGE OF SPENT FUEL IN REGION 2



5.4-5
BURNUP - 103 MWD/MTU

Amendment No. 65