



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ROCHESTER GAS AND ELECTRIC CORPORATION

DOCKET NO. 50-244

R. E. GINNA NUCLEAR POWER PLANT

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 59
License No. DPR-18

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Rochester Gas and Electric Corporation (the licensee) dated August 1, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public; and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8402010075 840130
PDR ADOCK 05000244
P PDR




2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C(2) of Provisional Operating License No. DPR-18 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 59, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: January 30, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 59

PROVISIONAL OPERATING LICENSE NO. DPR-18

DOCKET NO. 50-244

Revise Appendix A Technical Specifications by removing the page 3.5-5 and inserting the enclosed page 3.5-5. This revised page contains the captioned amendment number and marginal lines which indicate the area of change.

TABLE 3.5-2
EMERGENCY COOLING

NO. FUNCTIONAL UNIT	1 NO. OF CHANNELS	2 NO. OF CHANNELS TO TRIP****	3 MIN. OPERABLE CHANNELS	4 MIN. DEGREE OF REDUNDANCY	5 PERMISSIBLE BYPASS CONDITIONS	6 OPERATOR ACTION IF CONDITIONS OF COLUMN 3 OR 5 CANNOT BE MET
1. SAFETY INJECTION						
a. Manual	2	1	1	1		Hot Shutdown***
b. High Containment Pressure	3	2	2	1		Hot Shutdown***
c. Steam Generator Low Steam Pressure/Loq.	3	2	2	1	Primary pressure less than 2000 psig	Hot Shutdown***
d. Pressurizer Low Pressure	3	2	2	1	Primary pressure less than 2000 psig	Hot Shutdown***
2. CONTAINMENT SPRAY						
a. Manual	2	2	2	---**		Hot Shutdown***
b. Hi-Hi Containment Pressure (Containment Spray)	2 sets of 3	2 of 3 in ea. set	2 per set	1/set		Hot Shutdown***

** Must actuate 2 switches simultaneously.

*** If minimum conditions are not met within 24 hours, steps shall be taken on the affected unit to place the unit in cold shutdown conditions.

**** If a functional unit is operating with the minimum operable channels the number of channels to trip the reactor will be column 3 less column 4.