

Facility : BYR

Doc Nbr : 3C8-0282-001

Sheet :

Maj Rev : 003

Min Rev :

Doc Date : 1996-10-22

SRRS ID : 3A.101

Title : MAIN STEAM TUNNEL PRESSURE STUDY FOR MAIN STEAM LINE BREAK THIS
RECORD CONTAINS CORRECTED SCAN. INCLUDES ALL PAGES THRU B42

Doc Type : CALC

Sub Type : ENG

Addl Type :

R Obj ID : 0900e54e81df06a1

This Record Cover Sheet data is an aid for initial department handling and records turnover purposes.

***The data shown may not reflect the Records Index system data due to further editing and refinement by
Records Management.***

PROJECT FILE NO. 13.6

Page No. i

[illegible]

COMMONWEALTH EDISON COMPANY
CALCULATION REVISION PAGE

CALCULATION NO. 3C8-0282-001			PAGE NO.: II
REV: 3	STATUS: <i>Verified</i>	QA SERIAL NO. OR CHRON NO.	DATE:
PREPARED BY: <i>Thomas J. Kane</i> <u>Thomas J. Kane</u> DATE: <u>10/21/96</u>			
REVISION SUMMARY: <i>Revised Page 2</i> <i>Added Pages ii, B1 through B42</i> <i>Revised to Incorporate Mass and Energy Release Data from FTI 32-1258100-00 for RSG.</i>			
CALCULATION FILES REVISED: (Name ext/size/date/hour: min/verification method/remarks)			
DO ANY ASSUMPTIONS IN THIS CALCULATION REQUIRE LATER VERIFICATION ☐ YES ☒ NO			
REVIEWED BY: <i>K. Chan</i> <u>K. Chan</u> DATE: <u>10/22/96</u>			
REVIEW METHOD: <i>Detailed Review</i>		COMMENTS (C, NC or CI): <i>NC</i>	
APPROVED BY: <i>Robert J. Peterson</i> <u>Robert J. Peterson</u> DATE: <u>10/22/96</u> <i>(CI)</i>			
REV:	STATUS:	QA SERIAL NO. OR CHRON NO.	DATE:
PREPARED BY _____ DATE: _____			
REVISION SUMMARY:			
CALCULATION FILES REVISED: (Name ext/size/date/hour: min/verification method/remarks)			
DO ANY ASSUMPTIONS IN THIS CALCULATION REQUIRE LATER VERIFICATION: ☐ YES ☐ NO			
REVIEWED BY: _____ DATE: _____			
REVIEW METHOD:		COMMENTS (C, NC or CI):	
APPROVED BY: _____ DATE: _____			

TABLE OF CONTENTS

<u>SECTION</u>		<u>PAGE</u>
	LIST OF TABLES	3
	LIST OF FIGURES	4
I	UNAPPROVED DATA	7
II	INTRODUCTION	8
III	ANALYTICAL MODELS AND COMPUTER PROGRAMS	10
IV	ASSUMPTIONS	11
V	METHOD OF ANALYSIS	12
VI	RESULTS*	13
VII	CONCLUSIONS*	14
VIII	REFERENCES	16
	TABLES	17
	FIGURES	27
	Table of Contents for Computer Output	65
	Microfiche	68
	Review Method Sheet	69
	Appendix A	A1
	Appendix B Revised Main Steam Tunnel Pressure For Byron/Braidwood Unit 1 Based on Mass and Energy Release from FTI 32-1258100-00 For RSG	B1

* See Appendix B for Unit 1 results based on FTI 32-1258100-00 for RSG

Calc. No. 3C8-0282-001
Revision: 2
Page: 3
Project No. 4391-00

LIST OF TABLES

	<u>PAGE</u>	
1. Subcompartment Nodal Description	17	
2. Subcompartment Vent Flow Path Description	20	
3. Blowdown Rates and Enthalpy For Ruptured Main Steam Line	24	2
4. Summary of Peak Pressures and Design Margins Between the Valve Rooms and Main Steam Tunnel	25	
5. Summary of Maximum Temperatures for the Main Steam Tunnel and Valve Rooms	26	

LIST OF FIGURES

FIG. NO.	DESCRIPTION	PAGE
1.	Main Steam Tunnel Plan View	27
2.	Nodalization Schematic	28
3.	Pressure Transient For Nodes 2, 3, 4, & 5 (Steam Line Break in Lower 2nd Quadrant Valve Room)	29
4.	Pressure Transient For Nodes 6, 7, 8, 13, & 14 (Steam Line Break in Lower 2nd Quadrant Valve Room)	30
5.	Pressure Transient For Nodes 9, 10, 11, & 12 (Steam Line Break in Lower 2nd Quadrant Valve Room)	31
6.	Pressure Transient For Nodes 2, 3, 4, & 5 (Steam Line Break in 2nd Quadrant Tunnel)	32
7.	Pressure Transient For Nodes 6, 7, 8, 13, & 14 (Steam Line Break in 2nd Quadrant Tunnel)	33
8.	Pressure Transient For Nodes 9, 10, 11, & 12 (Steam Line Break in 2nd Quadrant Tunnel)	34
9.	Pressure Transient For Nodes 2, 3, 4, & 5 (Steam Line Break in Tunnel Connecting 2nd & 1st Quadrants)	35
10.	Pressure Transient For Nodes 6, 7, 8, 13, & 14 (Steam Line Break in Tunnel Connecting 2nd & 1st Quadrants)	36
11.	Pressure Transient For Nodes 9, 10, 11, & 12 (Steam Line Break in Tunnel Connecting 2nd & 1st Quadrants)	37
12.	Pressure Transient For Nodes 2, 3, 4, & 5 (Steam Line Break in 1st Quadrant Tunnel - Node 8)	38
13.	Pressure Transient For Nodes 6, 7, 8, 13, & 14 (Steam Line Break in 1st Quadrant Tunnel - Node 8)	39
14.	Pressure Transient For Nodes 9, 10, 11, & 12 (Steam Line Break in 1st Quadrant Tunnel - Node 8)	40
15.	Pressure Transient For Nodes 2, 3, 4, & 5 (Steam Line Break in 1st Quadrant Tunnel - Node 13)	41
16.	Pressure Transient For Nodes 6, 7, 8, 13, & 14 (Steam Line Break in 1st Quadrant Tunnel - Node 13)	42

LIST OF FIGURES (Cont'd)

FIG. NO.	DESCRIPTION	PAGE
17.	Pressure Transient For Nodes 9, 10, 11, & 12 (Steam Line Break in 1st Quadrant Tunnel - Node 13)	43
18.	Pressure Transient For Nodes 2, 3, 4, & 5 (Steam Line Break in 1st Quadrant Tunnel - Node 14)	44
19.	Pressure Transient For Nodes 6, 7, 8, 13, & 14 (Steam Line Break in 1st Quadrant Tunnel - Node 14)	45
20.	Pressure Transient For Nodes 9, 10, 11, & 12 (Steam Line Break in 1st Quadrant Tunnel - Node 14)	46
21.	Temperature Transient For Nodes 2, 3, 4, & 5 (Steam Line Break in Lower 2nd Quadrant Valve Room)	47
22.	Temperature Transient For Nodes 6, 7, 8, 13, & 14 (Steam Line Break in Lower 2nd Quadrant Valve Room)	48
23.	Temperature Transient For Nodes 9, 10, 11, & 12 (Steam Line Break in Lower 2nd Quadrant Valve Room)	49
24.	Temperature Transient For Nodes 2, 3, 4, & 5 (Steam Line Break in 2nd Quadrant Tunnel)	50
25.	Temperature Transient For Nodes 6, 7, 8, 13, & 14 (Steam Line Break in 2nd Quadrant Tunnel)	51
26.	Temperature Transient For Nodes 9, 10, 11, & 12 (Steam Line Break in 2nd Quadrant Tunnel)	52
27.	Temperature Transient For Nodes 2, 3, 4, & 5 (Steam Line Break in Tunnel Connecting 2nd & 1st Quadrants)	53
28.	Temperature Transient For Nodes 6, 7, 8, 13, & 14 (Steam Line Break in Tunnel Connecting 2nd & 1st Quadrants)	54
29.	Temperature Transient For Nodes 9, 10, 11, & 12 (Steam Line Break in Tunnel Connecting 2nd & 1st Quadrants)	55
30.	Temperature Transient For Nodes 2, 3, 4, & 5 (Steam Line Break in 1st Quadrant Tunnel)	56
31.	Temperature Transient For Nodes 6, 7, 7, 13, & 14 (Steam Line Break in 1st Quadrant Tunnel)	57
32.	Temperature Transient For Nodes 9, 10, 11, & 12 (Steam Line Break in 1st Quadrant Tunnel)	58

LIST OF FIGURES (Cont'd)

<u>FIG. NO.</u>	<u>DESCRIPTION</u>	<u>PAGE</u>
33.	Temperature Transient For Nodes 2, 3, 4, & 5 (Steam Line Break in 1st Quadrant Tunnel - Node 13)	59
34.	Temperature Transient For Nodes 6, 7, 8, 13, & 14 (Steam Line Break in 1st Quadrant Tunnel - Node 13)	60
35.	Temperature Transient For Nodes 9, 10, 11, & 12 (Steam Line Break in 1st Quadrant Tunnel - Node 13)	61
36.	Temperature Transient For Nodes 2, 3, 4, & 5 (Steam Line Break in 1st Quadrant Tunnel - Node 14)	62
37.	Temperature Transient For Nodes 6, 7, 8, 13, & 14 (Steam Line Break in 1st Quadrant Tunnel - Node 14)	63
38.	Temperature Transient For Nodes 9, 10, 11, & 12 (Steam Line Break in 1st Quadrant Tunnel - Node 14)	64

I. UNAPPROVED DATA

All information used in this design calculation was obtained from the Byron/Braidwood FSAR or was received from PMD and is therefore considered by NSLD to be approved data except for the following:

None

II. INTRODUCTION

A very important design criteria for the main steam tunnel and valve room subcompartments involves retaining functional integrity indefinitely which includes withstanding peak transient differential pressures under a postulated accident mode.

A previous calculation (Reference 1) addressed this criteria by determining design pressures for the main steam tunnel and valve rooms. At the time that the calculation was performed, the NRC required (Reference 2) a factor equal to 1.4 be applied to the calculated peak differential pressures for use as design pressures. The factor was to provide a design margin to accommodate possible plant modifications in the future. At the operating licensing stage, though, the NRC only requires that the calculated peak differential pressures be less than the design pressures. Since the Byron project has reached this stage, the 1.4 factor is not used in the calculation of the peak pressures.

It is evident if no design changes occurred since the construction permit stage, the 40% margin would still hold true, thus satisfying the requirements in Reference 2. But modifications have been made since the calculation per Reference 1 was performed. The primary modification involved isolating the auxiliary feedwater line tunnel from the valve rooms. As a result, less volume is available for expansion of steam coming from a main steam line break.

Therefore, the purpose of this study is to calculate peak pressures using the as-built specifications from which a new set of design margins can be determined. It is noted that temperature is not a primary concern in this calculation, but for convenience corresponding temperature profiles will also be presented for each of the pressure profiles.

Reference 1 as well as Revisions 0 and 1 of this calculation considered four break locations which included: the second quadrant lower valve room; the second quadrant main steam tunnel next to the valve room; the main steam tunnel connecting the first and second quadrants; and the first quadrant main steam tunnel next to the valve room. In addition to the four break locations, this calculation also considers two break locations in the last segment of the main steam tunnel which opens into the turbine building.

III. ANALYTICAL MODELS AND COMPUTER PROGRAMS

The analytical models and computer programs used in this analysis are filed and documented in the Computer Software Library. The program names used are:

REL 09.8.026-5.70

PPP 09.8.099-1.1I

PPP 0.9.099-1.2I

IV. ASSUMPTIONS

1. The initial conditions in the steam tunnel and the valve rooms are 14.7 psia pressure at a temperature of 90°F and a relative humidity of 30%.
2. Only one break occurred per analysis.
3. The Moody choke flow multiplier of 0.6 was used as required by the Nuclear Regulatory Commission (NRC) (Reference 2) for choked flow check between nodes.
4. The area of a flow path is the effective area (i.e., the cross sectional area of the path excluding areas occupied by grating, pipes, louvers, etc.).
5. The mass and energy release rates for the postulated main steam line rupture were taken from Reference 6.
6. The doors and HVAC louvers/panels in the upper chambers of the valve rooms are initially assumed closed or intact. A differential pressure equal to 1.5 psi will blow open the doors and panels to atmosphere.

V. METHOD OF ANALYSIS

The main steam line rupture was assumed to be a doubled-ended guillotine break. The RELAP4/MOD5 (Reference 3) computer code was used to determine pressure transients for six cases, each having a different break location. In the first case, the break was located in the second quadrant lower valve room (See Figure 1). The second case involved locating the break in the second quadrant main steam tunnel next to the valve room. The break for the third case was located in the main steam tunnel connecting the second and first quadrants. The fourth case involved locating the break in the first quadrant tunnel next to the valve room. The break for the fifth case was located in the last 90° section of the tunnel before entering the turbine building. The last break was located in the straight section of the tunnel which opens into the turbine building.

The steam tunnel was modeled using five nodes and each of the valve rooms were modeled using four nodes. When including atmosphere, the entire model consisted of 14 nodes as seen in Figure 2 which shows the entire nodalization scheme of the main steam tunnel and valve rooms. The initial conditions presented in Table 1 for these nodes were taken from Reference 1. The remaining input data were determined in Appendix A.

The areas of the 21 junctions (flow paths), which connect the nodes (See Figure 2), are presented in Table 2. The areas are equivalent to the minimum vent areas between the nodes and were determined in Appendix A as were the remaining input data. The Moody flow multiplier was taken to be .6 as required by the NRC.

Table 3 shows the blowdown rates and properties versus time from a postulated ruptured main steam line as provided by Reference 6. This table was used in all six cases as input to RELAP4/MOD5

It is finally noted that throughout the analysis, heat transfer out of the tunnel and valve rooms was not considered for conservatism.

VI. RESULTS

A summary of the resulting peak differential pressures is presented in Table 1. Also included in the table are the design pressures previously calculated and the resulting design margins for each of the subcompartments (nodes). Table 4 presents a summary of the resulting peak differential pressures for interior walls in the valve rooms and for walls separating the main steam tunnel and valve room. Previously determined design pressures and design margins are also presented in this table.

Figures 3 thru 20 present the pressure transients for each of the nodes for all six break locations. Specifically, Figures 4, 7, 10, 13, 16, and 19 refer to the main steam tunnel (main steam tunnel is made up of nodes 6, 7, 8, 13, and 14) and the remaining figures refer to the two valve rooms. | 2

Figures 21 thru 38 present the corresponding temperature transients for each of the nodes for all six break locations. A summary of the maximum temperatures obtained in the one-second duration is presented in Table 5. | 2

VII. CONCLUSIONS

With one exception, all of the calculated peak pressures for the exterior boundaries of the main steam tunnel and safety valve rooms as presented in Table 1 are less than the design pressures presented in Exhibit 30 of Reference 1. The design margins for these boundaries varied from 25 to 61 percent. The exception concerns the last segment of tunnel (node 14) which opens into the turbine building. The calculated peak pressure is approximately 8% higher than the design pressure presented in Exhibit 30 of Reference 1. It is noted that a break location in this segment of the tunnel was not considered previously in Reference 1 and Revisions 0 and 1 of this calculation. Revision 2 of this calculation did assume a line break in the last segment of the tunnel and has shown higher calculated pressure. As a result, the structural integrity of the last calculated section of the tunnel (node 14) may require re-evaluation for the higher pressure. The differential pressures used for the design of the remaining sections of the main steam tunnel and valve room boundaries, however, are still conservative. 2

The elimination of the auxiliary feedwater line tunnel from the model reduced the total available volume by no more than $\frac{1}{2}$ of one percent. Therefore, the design margins as determined for nodes 7 and 9 are reasonable. However, the large design margins determined for the boundaries of the valve rooms and node 6 appeared, at first, to be excessive. The primary reason for this change is believed to be a known error in the computer program used for the calculation of Reference 1. This program, WARLOC, was found to produce node pressures that are too high when treating superheated vapor. This effect is described in Reference 4. 2

For the interior walls, all the differential pressures as presented in Table 4 were less than the design pressures presented in Exhibit 31 of Reference 1 except for the wall separating

the upper chambers of the valve room. The calculated peak pressure for this wall was .2 psi higher than the design pressure. It is anticipated, though, that a difference of this magnitude will not present a problem. It is typical to include further conservatisms when designing reinforced concrete walls which, in this case, would allow the wall to absorb the additional .2 psi and still maintain a safety margin, but this would need to be verified. For the remaining interior walls, the design margins varied from 4.3 to 31.7 percent.

2

With regard to the temperature transients presented in Figures 21 thru 38, it is noted that for nodes 7 and 8, the maximum temperatures presented in Table 5 do not represent peak temperatures. For each of these nodes, the bounding temperature transient was still on the rise after one second. But for nodes 2 thru 5, and 9 thru 12, a peak temperature of 333°F was obtained. After one second, the temperatures for these nodes were either decreasing or leveling off. Now considering that heat transfer will begin to become a factor after a few minutes and the mass blowdown rate is decreasing with time, it can be reasonably concluded the 333°F temperature will be the limiting peak for all nodes, but, this would have to be looked at in a more detailed analysis which would include heat sinks and a longer blowdown duration.

2

2

VIII. REFERENCES

1. Sargent & Lundy Calculation No. MAD-75717, "Main Steam Line Break In Main Steam Tunnel," July 1976. (Approved)
2. Standard Review Plan (NUREG-0800), Section 6.2.1.2 entitled, "Subcompartment Analysis," Revision 2, July 1981.
3. RELAP4/MOD5 (REL 09.8.026-5.70), "A Computer Program For Transient Thermal-Hydraulic Analysis of Nuclear Reactors and Related Systems," ANCR-NUREG-1335, September 1976.
4. Inter-Office Memorandum from Igor Domashovetz to R. H. Jason, entitled, "Comparative Study Between the RELAP4/MOD5 and WARLOC Computer Codes for a Main Steam Tunnel Temperature Transient," November 23, 1981.
5. Sargent & Lundy Drawings;

<u>Drawing No.</u>	<u>Revision</u>	<u>Sheet No.</u>	<u>Date</u>
M-159	H	1	11-27-79
M-159	G	3	11-27-79
M-160	G	1	11-27-79
M-187	H	1	11-27-79
M-188	G	1	11-27-79
M-536	N	2	02-20-80
M-536	P	5	04-16-79
S-688	R	1	08-02-78
S-758	G	1	11-29-76
S-762	L	1	06-05-81
S-765	H	1	03-16-78
S-895	N	1	07-17-78
S-896	M	1	05-25-78
S-899	L	1	05-25-78
S-900	P	1	08-29-80
S-1056	R	1	08-29-80
S-1057	W	1	08-29-80
S-1061	K	1	08-29-80
S-1062	K	1	03-31-78

6. Table 6.2-15a, page 6.2-37C, B/B PSAR, Amendment 11, April 1975.

Calc. No. 3C8-0282-001
Revision: 2
Page: 17
Project No. 4391-00

2

TABLE 1

SUBCOMPARTMENT NODAL DESCRIPTION

MAIN STEAM LINE BREAK IN MAIN STEAM TUNNEL OR VALVE ROOMS

VOLUME NO.	DESCRIPTION	HEIGHT, ft	CROSS- SECTIONAL AREA, ft ²	VOLUME ft ³	INITIAL CONDITIONS			DBA BREAK CONDITIONS				CALC. PEAK PRESS DIFF. psid	DESIGN PEAK PRESS DIFF. psid	DESIGN MARGIN %
					TEMP. °F	PRESS. psia	HUMID.* %	BREAK LOC. VOL. NO.	BREAK LINE	BREAK AREA ft ²	BREAK TYPE			
1	Atmosphere	5x10 ³	1x10 ³	10 ⁷	90	14.7	30	-	-	-	-	-	-	-
2	2nd Quadrant Upper Valve Chamber	12.33	133.25	4895.7	90	14.7	30	5	Main Steam	1.4	Double- ended Guillo- tine	17.4	26.2	51
3	2nd Quadrant Upper Valve Chamber	12.33	183.7	4895.7	90	14.7	30	5	Main Steam	1.4	Double- ended Guillo- tine	17.4	26.2	51
4	2nd Quadrant Lower Valve Chamber	24.00	213.0	6007.0	90	14.7	30	5	Main Steam	1.4	Double- ended Guillo- tine	19.7	28.6	45
5	2nd Quadrant Lower Valve Chamber	24.00	213.0	6007.0	90	14.7	30	5	Main Steam	1.4	Double- ended Guillo- tine	19.7	28.6	45
6	2nd Quadrant Main Steam Tunnel	19.00	317.0	13695.0	90	14.7	30	6	Main Steam	1.4	Double- ended Guillo- tine	16.4	26.5	61

* Relative humidity.

TABLE 1 (Cont'd)

SUBCOMPARTMENT MODAL DESCRIPTION

MAIN STEAM LINE BREAK IN MAIN STEAM TUNNEL OR VALVE ROOMS

VOLUME NO.	DESCRIPTION	HEIGHT, ft	CROSS- SECTIONAL AREA, FT ²	VOLUME ft ³	INITIAL CONDITIONS			DBA BREAK CONDITIONS				CALC. PEAK PRESS DIFF. psid	DESIGN PEAK PRESS DIFF. psid	DESIGN MARGIN %
					TEMP. °F	PRESS. psia	HUMID.* %	BREAK LOC. VOL. NO.	BREAK LINE	BREAK AREA ft ²	BREAK TYPE			
7	Main Steam Tunnel	19.00	203.0	34865.0	90	14.7	30	7	Main Steam	1.4	Double- ended Guillo- tine	15.5	21.3	38
8	1st Quadrant Main Steam Tunnel	20.00	432.0	35016.0	90	14.7	30	8	Main Steam	1.4	Double- ended Guillo- tine	8.8	11.2	28
9	1st Quadrant Upper Valve Chamber	12.33	133.25	4895.7	90	14.7	30	5**	Main Steam	1.4	Double- ended Guillo- tine	17.4	26.2	51
10	1st Quadrant Upper Valve Chamber	12.33	183.7	4895.7	90	14.7	30	5**	Main Steam	1.4	Double ended Guillo- tine	17.4	26.2	51
11	1st Quadrant Lower Valve Chamber	24.00	213.0	6007.0	90	14.7	30	5**	Main Steam	1.4	Double- ended Guillo- tine	19.7	28.6	45

* Relative humidity.

** Differential pressures calculated for 1st Quadrant valve chambers are also applicable to corresponding 2nd Quadrant valve chambers.

Calc. No. 3C8-0282-001
Revision: 2
Page: 19
Project No. 4391-00

TABLE 1 (Cont'd)

SUBCOMPARTMENT NODAL DESCRIPTION

MAIN STEAM LINE BREAK IN MAIN STEAM TUNNEL OR VALVE ROOMS

VOLUME NO.	DESCRIPTION	HEIGHT, ft	CROSS- SECTIONAL AREA, ft ²	VOLUME ft ³	INITIAL CONDITIONS			LBA BREAK CONDITIONS				CALC. PEAK PRESS DIFF. psid	DESIGN PEAK PRESS DIFF. psid	DESIGN MARGIN %
					TEMP. °F	PRESS. psia	HUMID.* %	BREAK LOC. VOL. NO.	BREAK LINE	BREAK AREA ft ²	BREAK TYPE			
12	1st Quadrant Lower Valve Chamber	24.00	213.0	6007.0	90	14.7	30	5**	Main Steam	1.4	Double- ended Guillo- tine	19.7	28.6	45
13	1st Quadrant Main Steam Tunnel	29.00	432.0	17388.4	90	14.7	30	13	Main Steam	1.4	Double- ended Guillo- tine	10.6	13.2	25
14	1st Quadrant Main Steam Tunnel	19.00	280.0	13529.9	90	14.7	30	14	Main Steam	1.4	Double- ended Guillo- tine	11.1	10.3	-8

2

* Relative humidity.

** Differential pressures calculated for 1st Quadrant valve chambers are also applicable to corresponding 2nd Quadrant valve chambers.

Calc. No. 3C8-0282-001
Revision: 2
Page: 20
Project No. 4391-00

TABLE 2

SUBCOMPARTMENT VENT PATH DESCRIPTION

MAIN STEAM LINE BREAK IN MAIN STEAM TUNNEL OR VALVE ROOM

ENT ATH O.	FROM VOL. NO.	TO VOL. NO.	DESCRIPTION OF VENT PATH FLOW ¹ <u>CHOKED³ UNCHOKED</u>	AREA ² ft ²	LENGTH ² ft	HYDRAULIC DIAMETER ft	HEAD LOSS, K				TOTAL
							FRICTION K, ft/d	TURNING LOSS, K	EXPAN- SION, K	CONTRAC- TION, K	
1	14	1	Main Steam Tunnel to Turbine Building <u>Choked (13,14)</u>	270.8	28.0	13.9	-	-	-	-	1.0656
2	2	5	2nd Quadrant Upper Valve Chamber to Lower Valve Chamber <u>Unchoked</u>	121.0	16.4	5.7	-	-	-	-	1.5207
3	3	4	2nd Quadrant Upper Valve Chamber to Lower Valve Chamber <u>Unchoked</u>	121.0	16.4	5.7	-	-	-	-	1.5207
4	6	4	2nd Quadrant Lower Valve Chamber to Main Steam Tunnel <u>Unchoked</u>	73.0	17.2	4.5	-	-	-	-	1.5685
5	6	5	2nd Quadrant Lower Valve Chamber to Main Steam Tunnel <u>Choked (5)</u>	73.0	17.2	4.5	-	-	-	-	1.5685
6	5	4	Openings Between 2nd Quadrant Lower Valve Chambers <u>Unchoked</u>	100.0	16.1	7.1	-	-	-	-	1.5071

¹ See Figures 1 and 2.

² Length/Area is the inertial term input directly into RELAP4/MODE5.

³ Number in parentheses indicates the volume number of the break location which caused choke flow in the vent. For break locations not indicated, unchoked flow had occurred for the vent.

TABLE 2 (Cont'd)

SUBCOMPARTMENT VENT PATH DESCRIPTIONMAIN STEAM LINE BREAK IN MAIN STEAM TUNNEL OR VALVE ROOM

VENT PATH NO.	FROM VOL. NODE NO.	TO VOL. NODE NO.	DESCRIPTION OF VENT PATH FLOW ¹ CHOKED ² UNCHOKED	AREA ² ft ²	LENGTH ² ft	HYDRAULIC DIAMETER ft	HEAD LOSS, K				TOTAL
							FRICTION K, ft/d	TURNING LOSS, K	EXPAN- SION, K	CONTRAC- TION, K	
7	6	7	2nd Quadrant Main Steam Tunnel to Main Steam Tunnel Unchoked	199.8	102.0	13.3	-	-	-	-	2.1860
8	7	8	Main Steam Tunnel to 1st Quad- rant Main Steam Tunnel Unchoked	199.8	132.4	13.3	-	-	-	-	2.7530
9	12	9	1st Quadrant Upper Valve Chamber to Lower Valve Chamber Unchoked	121.0	16.4	5.7	-	-	-	-	1.5207
10	9	10	Openings Between 1st Quadrant Upper Valve Chambers Unchoked	100.0	11.2	4.5	-	-	-	-	1.5120
11	11	10	1st Quadrant Upper Valve Chamber to Lower Valve Chamber Unchoked	121.0	16.4	5.7	-	-	-	-	1.5207
12	12	11	Openings Between 1st Quadrant Lower Valve Chambers Unchoked	100.0	16.1	7.1	-	-	-	-	1.5071

¹ See Figures 1 and 2.² Length/Area is the inertial term input directly into RELAP4/MOD5.³ Number in parentheses indicates the volume number of the break location which caused choke flow in the vent. For break locations not indicated, unchoked flow had occurred for the vent.

TABLE 2 (Cont'd)

SUBCOMPARTMENT VENT PATH DESCRIPTION

MAIN STEAM LINE BREAK IN MAIN STEAM TUNNEL OR VALVE ROOM

VENT PATH NO.	FROM VOL. NODE NO.	TO VOL. NODE NO.	DESCRIPTION OF VENT PATH FLOW ¹ CHOKED ³ UNCHOKED	AREA ² ft ²	LENGTH ² ft	HYDRAULIC DIAMETER ft	HEAD LOSS, K				TOTAL
							FRICTION K, ft/d	TURNING LOSS, K	EXPAN- SION, K	CONTRAC- TION, K	
13	8	13	1st Quadrant Main Steam Tunnel Unchoked	373.6	42.0	17.6	-	-	-	-	2.2600
14	13	14	1st Quadrant Main Steam Tunnel Unchoked	270.8	42.0	13.9	-	-	-	-	2.2600
15	8	11	1st Quadrant Lower Valve Chamber to Main Steam Tunnel Unchoked	73.0	17.2	4.5	-	-	-	-	1.5685
16	8	12	1st Quadrant Lower Valve Chamber to Main Steam Tunnel Unchoked	73.0	17.2	4.5	-	-	-	-	1.5685
17	2	3	Openings Between 2nd Quadrant Upper Valve Chambers Unchoked	100.0	11.2	4.5	-	-	-	-	1.5120
18	2	1	HVAC Panels in 2nd Quadrant Upper Valve Chambers Choked (5, 6)	51.3	15.2	5.9	-	-	-	-	2.900

¹ See Figures 1 and 2.

² Length/Area is the inertial term input directly into RELAP4/MOD5.

³ Number in parentheses indicates the volume number of the break location which caused choke flow in the vent. For break locations not indicated, unchoked flow had occurred for the vent.

TABLE 2 (Cont'd)

SUBCOMPARTMENT VENT PATH DESCRIPTIONMAIN STEAM LINE BREAK IN MAIN STEAM TUNNEL OR VALVE ROOM

VENT PATH NO.	FROM VOL. NODE NO.	TO VOL. NODE NO.	DESCRIPTION OF VENT PATH FLOW ¹ CHOKED ³ UNCHOKED	AREA ² ft ²	LENGTH ² ft	HYDRAULIC DIAMETER ft	HEAD LOSS, K				TOTAL
							FRICTION K, ft/d	TURNING LOSS, K	EXPAN- SION, K	CONTRAC- TION, K	
19	3	1	Door and HVAC Panels in 2nd Quadrant Upper Valve Chambers Choked (5, 6)	75.8	25.3	5.4	-	-	-	-	2.900
20	9	1	HVAC Panels in 1st Quadrant Upper Valve Chamber Choked (5) ⁴	51.3	15.2	5.9	-	-	-	-	2.900
21	10	1	Door and HVAC Panels in 1st Quadrant Upper Valve Chamber Choked (5) ⁴	75.8	25.3	5.4	-	-	-	-	2.900
22(a) ⁵	0	5	Main Steam Line Break in Node 5 Fill	1.0	0.0	0.0	-	-	-	-	0.000
22(b) ⁵	0	6	Main Steam Line Break in Node 6 Fill	1.0	0.0	0.0	-	-	-	-	0.000
22(c) ⁵	0	7	Main Steam Line Break in Node 7 Fill	1.0	0.0	0.0	-	-	-	-	0.000
22(d) ⁵	0	8	Main Steam Line Break in Node 8 Fill	1.0	0.0	0.0	-	-	-	-	0.000

¹ See Figures 1 and 2.² Length/Area if the inertial term input directly into RELAP4/MOD5.³ Number in parentheses indicates the volume number of the break location which caused choke flow in the vent. For break locations not indicated, unchoked flow had occurred for the vent.⁴ Choking results for 2nd quadrant valve room are applied to 1st quadrant valve room.⁵ Four cases were considered each having a different break location.

TABLE 3

BLOWDOWN RATES AND ENTHALPY FOR RUPTURED MAIN STEAM LINE*

<u>TIME (SEC)</u>	<u>FLOW (LB/SEC)</u>	<u>ENTHALPY (Btu/LB)</u>
0.0	11,000	1,195.4
2.0	10,434	1,195.1
4.0	9,608	1,196.9
6.0	9,017	1,197.7
8.0	8,613	1,199.4
10.0	9,318	1,199.8
10.1	2,098	1,201.1
20.0	1,993	1,199.2
30.0	1,879	1,208.1
50.0	1,625	1,206.1
75.0	1,064	1,203.0
100.0	814	1,201.5

* See Reference 6.

TABLE 4

SUMMARY OF PEAK PRESSURES AND DESIGN MARGINS
BETWEEN VALVE ROOMS AND MAIN STEAM TUNNEL

<u>WALL LOCATION</u> <u>BETWEEN NODES*</u>	<u>DESIGN</u> <u>PRESSURE (PSID)**</u>	<u>PEAK</u> <u>PRESSURE (PSID)</u>	<u>DESIGN</u> <u>MARGIN (%)***</u>
2-3 and 9-10	6.3	6.49	-2.9
3-4 and 10-11	13.2	12.66	4.3
4-5 and 11-12	17.6	13.36	31.7
2-5 and 9-12	13.2	12.66	4.3
4-6, 5-6, 11-8, and 12-8	19.4	14.88	30.4

* See Figures 1 and 2.

** See Reference 1.

*** Determined using peak pressure as base value.

Calc. No. 3C8-0282-001
Revision: 2
Page: 25
Project No. 4391-00

TABLE 5
SUMMARY OF MAXIMUM TEMPERATURES FOR MAIN
STEAM TUNNEL AND VALVE ROOMS

<u>Node No.</u>	<u>Maximum Temperature (°F)</u>	<u>Break* Location</u>
2, 3, 9, 10	333	Lower Valve Room
4, 5, 11, 12	333	Lower Valve Room
6	322	Lower Valve Room
7	309**	Node 7
8	310**	Node 8
13	318	Node 13
14	315	Node 14

* See Figures 1 and 2.

** Temperature was still rising from this value after one second.




FIGURE 1: MAIN STEAM TUNNEL VIEW PLAN





FIGURE 2: Nodalization Schematic

09/16/82 PLT-FILE-834

NODAL DIFFERENTIAL PRESSURE (PSID)



NODAL DIFFERENTIAL PRESSURE (PSID)




FIGURE 3:
PRESSURE TRANSIENT FOR NODES 2, 3, 4, & 5

07/22/82 PLT-FILE-952






FIGURE 4:
PRESSURE TRANSIENT FOR NODES 6, 7, 8, 13, & 14

09/16/82 PLT-FILE-836

NODAL DIFFERENTIAL PRESSURE (PSID)



NODAL DIFFERENTIAL PRESSURE (PSID)





FIGURE 5:
PRESSURE TRANSIENT FOR NODES 9, 10, 11, & 12

09/17/82 PLT-FILE-012

NODAL DIFFERENTIAL PRESSURES (PSID)



NODAL DIFFERENTIAL PRESSURES (PSID)





FIGURE 6:
PRESSURE TRANSIENT FOR NODES 2, 3, 4, & 5

07/22/82 PLT-FILE-958

NODAL DIFFERENTIAL PRESSURES (PSID)



NODAL DIFFERENTIAL PRESSURES (PSID)





FIGURE 7:
PRESSURE TRANSIENT FOR NODES 6, 7, 8, 13, & 14

09/17/82 PLT-FILE-014

NODAL DIFFERENTIAL PRESSURES (PSID)



NODAL DIFFERENTIAL PRESSURES (PSID)





FIGURE 2:

PRESSURE TRANSIENT FOR NODES 9, 10, 11, & 12

09/17/82 PLT-FILE-015

NODAL DIFFERENTIAL PRESSURES (PSID)



NODAL DIFFERENTIAL PRESSURES (PSID)





FIGURE 9:
PRESSURE TRANSIENT FOR NODES 2, 3, 4, & 5

07/22/82 PLT-FILE-984

NODAL DIFFERENTIAL PRESSURES (PSID)



NODAL DIFFERENTIAL PRESSURES (PSID)





FIGURE 10:
PRESSURE TRANSIENT FOR NODES 6, 7, 8, 13, & 14

09/17/82 PLT-FILE-016

NODAL DIFFERENTIAL PRESSURES (PSID)



NODAL DIFFERENTIAL PRESSURES (PSID)





FIGURE 11:
PRESSURE TRANSIENT FOR NODES 9, 10, 11, & 12

09/17/82 PLT-FILE-017

NODAL DIFFERENTIAL PRESSURES (PSID)



NODAL DIFFERENTIAL PRESSURES (PSID)




FIGURE 12:

PRESSURE TRANSIENT FOR NODES 2, 3, 4, & 5

07/23/82 PLT-FILE-967





FIGURE 13:
PRESSURE TRANSIENT FOR NODES 6, 7, 8, 13, & 14

09/17/82 PLT-FILE-018






FIGURE 14:
PRESSURE TRANSIENT FOR NODES 9, 10, 11, & 12

09/26/84 PLT-FILE-690

NODAL DIFFERENTIAL PRESSURES (PSID)



NODAL DIFFERENTIAL PRESSURES (PSID)





FIGURE 15:

PRESSURE TRANSIENT FOR NODES 2, 3, 4 & 5

09/26/84 PLT-FILE-689

NODAL DIFFERENTIAL PRESSURES (PSID)



NODAL DIFFERENTIAL PRESSURES (PSID)





FIGURE 16:
PRESSURE TRANSIENT FOR NODES 6 7 8 13 & 14

09/26/84 PLT-FILE-691

9000 L DIFFERENTIAL PRESSURES (PSID)



9000 L DIFFERENTIAL PRESSURES (PSID)





FIGURE 17:
PRESSURE TRANSIENT FOR NODES 9, 10, 11, & 12

09/26/84 PLT-FILE-694

NODAL DIFFERENTIAL PRESSURES (PSID)



NODAL DIFFERENTIAL PRESSURES (PSID)





FIGURE 18:
PRESSURE TRANSIENT FOR NODES 2, 3, 4, & 5

09/26/84 PLT-FILE-693

NODAL DIFFERENTIAL PRESSURES (PSID)



NODAL DIFFERENTIAL PRESSURES (PSID)





FIGURE 19:

PRESSURE TRANSIENT FOR NODES 6, 7, 8, 13, & 14

09/26/84 PLT-FILE-695

NODAL DIFFERENTIAL PRESSURES (PSID)



NODAL DIFFERENTIAL PRESSURES (PSID)





FIGURE 20:
PRESSURE TRANSIENT FOR NODES 9, 10, 11, & 12

09/17/82 PLT-FILE-021

TEMPERATURE (DEG-F)



TEMPERATURE (DEG-F)





FIGURE 21 :
TEMPERATURE TRANSIENT FOR NODES 2, 3, 4, & 5

07/22/82 PLT-FILE-955

TEMPERATURE (DEG-F)



TEMPERATURE (DEG-F)





FIGURE 22:
TEMPERATURE TRANSIENT FOR NODES 6, 7, 8, 13, & 14

09/17/82 PLT-FILE-022

TEMPERATURE (DEG-F)



TEMPERATURE (DEG-F)




FIGURE 23:

TEMPERATURE TRANSIENT FOR NODES 9, 10, 11, & 12

09/17/82 PLT-FILE-023





FIGURE 24 :
TEMPERATURE TRANSIENT FOR NODES 2, 3, 4, & 5

07/22/82 PLT-FILE-961





FIGURE 25:
TEMPERATURE TRANSIENT FOR NODES 6, 7, 8, 13, & 14

09/17/82 PLT-FILE-024






FIGURE 26:
TEMPERATURE TRANSIENT FOR NODES 9, 10, 11, & 12²

09/17/82 PLT-FILE-026

TEMPERATURE (DEG-F)



TEMPERATURE (DEG-F)




FIGURE 27:

TEMPERATURE TRANSIENT FOR NODES 2, 3, 4, & 5

07/23/82 PLT-FILE-018






FIGURE 28:

TEMPERATURE TRANSIENT FOR NODES 6, 7, 8, 13, & 14

09/17/82 PLT-FILE-028

TEMPERATURE (DEG-F)



TEMPERATURE (DEG-F)





FIGURE 29:
TEMPERATURE TRANSIENT FOR NODES 9, 10, 11, & 12

09/17/82 PLT-FILE-032

TEMPERATURE (DEG-F)



TEMPERATURE (DEG-F)




FIGURE 30:
TEMPERATURE TRANSIENT FOR NODES 2, 3, 4, & 5

07/23/82 PLT-FILE-970





FIGURE 31:

TEMPERATURE TRANSIENT FOR NODES 6, 7, 8, 13, & 14

09/17/82 PLT-FILE-033





FIGURE 32:

TEMPERATURE TRANSIENT FOR NODES 9, 10, 11, & 12

09/26/84 PLT-FILE-698





FIGURE 33:
TEMPERATURE TRANSIENT FOR NODES 2, 3, 4, & 5

09/26/84 PLT-FILE-696





FIGURE 34:
TEMPERATURE TRANSIENT FOR NODES 6, 7, 8, 13, & 14

09/26/84 PLT-FILE-699





FIGURE 35:
TEMPERATURE TRANSIENT FOR NODES 9, 10, 11, & 12

09/26/84 PLT-FILE-701







FIGURE 36:
TEMPERATURE TRANSIENT FOR NODES 2, 3, 4, & 5

09/26/84 PLT-FILE-700

TEMPERATURE (DEG-F)



TEMPERATURE (DEG-F)




2

FIGURE 37:
TEMPERATURE TRANSIENT FOR NODES 6, 7, 8, 13, & 14

09/26/84 PLT-FILE-702

TEMPERATURE (DEG-F)



TEMPERATURE (DEG-F)




FIGURE 38:
TEMPERATURE TRANSIENT FOR NODES 9, 10, 11, & 12

TABLE OF CONTENTS OF COMPUTER OUTPUT

PART	PROGRAM	DATE	PAGES	CALC.NO.	REV.	RUN-ID
DESCRIPTION		TIME	SUP	SYM-FILE-NAME		
PART 1-0	REL098026570	22 JUL 82	454	3C8-0282-001	0	GJS
MAINSTEAM BREAK IN NODE 5 (LOWER VALVE ROOM)		19:02	45.88	GJS-BYR*SYM2(3).		
		20:38				
PART 2-0	REL098026570	22 JUL 82	457	3C8-0282-001	0	GJS
MAINSTEAM BREAK IN NODE 6 (2ND QUAD. SECT. OF TUNNEL)		21:47	45.96	GJS-BYR*SYM2(6).		
		22:42				
PART 3-0	REL098026570	22 JUL 82	454	3C8-0282-001	0	GJS
MAINSTEAM BREAK IN NODE 7 (2ND & 1ST QUAD. SECT. OF TUNNEL)		22:55	45.67	GJS-BYR*SYM2(9).		
		23:46				
PART 4-0	REL098026570	22 JUL 82	454	3C8-0282-001	0	GJS
MAINSTEAM BREAK IN NODE 8 (1ST QUAD. SECT. OF TUNNEL)		23:59	44.14	GJS-BYR*SYM2(12).		
		00:50				
SECTION 1-1 PPP098099101/L		22 JUL 82	9	3C8-0282-001	0	GJS
FOR STEAM BREAK IN 2ND QUAD. DOGHOUSE (NODE 5)		20:39	4.19	GJS-BYR*SYM2(4).		
		20:46				
SECTION 2-1 PPP098099101/L		22 JUL 82	9	3C8-0282-001	0	GJS
FOR STEAM BREAK IN 2ND QUAD. TUNNEL (NODE 6)		22:43	4.18	GJS-BYR*SYM2(7).		
		22:49				
SECTION 3-1 PPP098099101/L		22 JUL 82	9	3C8-0282-001	0	GJS
FOR STEAM BREAK IN 2ND & 1ST QUAD TUNNEL (NODE 7)		23:47	4.19	GJS-BYR*SYM2(10).		
		23:56				
SECTION 4-1 PPP098099101/L		23 JUL 82	9	3C8-0282-001	0	GJS
FOR STEAM BREAK IN 1ST QUAD. TUNNEL (NODE 8)		00:51	4.19	GJS-BYR*SYM2(13).		
		00:59				
SECTION 5-1 PPP098099111/S		22 JUL 82	8	3C8-0282-001	0	GJS
FOR STEAM BREAK IN 2ND QUAD. DOGHOUSE (NODE 5)		20:46	4.19	GJS-BYR*SYM2(5).		
		20:53				
SECTION 6-1 PPP098099111/S		22 JUL 82	9	3C8-0282-001	0	GJS
FOR STEAM BREAK IN 2ND QUAD. TUNNEL (NODE 6)		22:50	4.18	GJS-BYR*SYM2(8).		
		22:54				

Calc. No. 3C8-0282-001
Revision: 2
Page: 65
Project No. 4391-00

SECTION 7-1 PPP098099111/S
FOR STEAM BREAK IN 2ND & 1ST QUAD TUNNEL (NODE 7)

23 JUL 82 9
13:10 4.18
13:15

3C8-0282-001 0 GJS
GJS-BYR*SYM2(15).

SECTION 8-1 PPP098099111/S
FOR STEAM BREAK IN 1ST QUAD. TUNNEL (NODE 8)

23 JUL 82 8
00:59 4.18
01:03

3C8-0282-001 0 GJS
GJS-BYR*SYM2(14).

SECTION 9-1 PPP098099111/S
FOR MAIN STEAM LINE BREAK

23 JUL 82 198
17:22 30.12
18:13

3C8-0282-001 0 GJS
GJS-BYR*SYM2(17).

***** IT IS NOTED FOR SECTIONS 1-1 THRU 4-1 THAT THE INCORRECT PROGRAM
NUMBER IS INDICATED. THE NUMBER SHOULD BE PPP098099111/S.

***** MICROFICHE FOR REVISION 1 *****

SECTION 1-1 PPP098099101/L
FOR STEAM BREAK IN 2ND QUAD. DOGHOUSE (NODE 5)

16 SEP 82 8
08:43 2.79
08:47

3C8-0282-001 1 GJS
GJS-BYR*SYM2(26).

SECTION 2-1 PPP098099101/S
FOR STEAM BREAK IN 2ND QUAD. TUNNEL (NODE 6)

17 SEP 82 8
14:49 2.79
15:06

3C8-0282-001 1 GJS
GJS-BYR*SYM2(27).

SECTION 3-1 PPP098099101/S
FOR STEAM BREAK IN 2ND & 1ST QUAD TUNNEL (NODE 7)

17 SEP 82 8
15:10 2.79
15:16

3C8-0282-001 1 GJS
GJS-BYR*SYM2(28).

SECTION 4-1 PPP098099101/S
FOR STEAM BREAK IN 1ST QUAD. TUNNEL (NODE 8)

17 SEP 82 8
15:22 2.79
15:32

3C8-0282-001 1 GJS
GJS-BYR*SYM2(29).

SECTION 5-1 PPP098099111/S
FOR STEAM BREAK IN 2ND QUAD. DOGHOUSE (NODE 5)

17 SEP 82 8
15:51 2.80
15:57

3C8-0282-001 1 GJS
GJS-BYR*SYM2(30).

SECTION 6-1 PPP098099111/S
FOR STEAM BREAK IN 2ND QUAD. TUNNEL (NODE 6)

17 SEP 82 8
16:02 2.79
16:08

3C8-0282-001 1 GJS
GJS-BYR*SYM2(31).

SECTION 7-1 PPP098099111/S
FOR STEAM BREAK IN 2ND & 1ST QUAD TUNNEL (NODE 7)

17 SEP 82 8
16:15 2.80
16:20

3C8-0282-001 1 GJS
GJS-BYR*SYM2(32).

SECTION 8-1 PPP098099111/S
FOR STEAM BREAK IN 1ST QUAD. TUNNEL (NODE 8)

17 SEP 82 8
16:23 2.79
16:34

3C8-0282-001 1 GJS
GJS-BYR*SYM2(33).

***** IT IS NOTED FOR SECTIONS 1-1 THRU 4-1 (REV. 1) THAT THE INCORRECT PROGRAM
NUMBER IS INDICATED. THE NUMBER SHOULD BE PPP098099111/S.

1

Calc. No. 3C8-0282-001
Revision: 2
Page: 66
Project No. 4391-00
12

***** MICROFICHE FOR REVISION 2 *****

PART 5-0	REL098026570	26 JUN 84	454	3C8-0282-001	2	GJS
MAINSTEAM BREAK IN NODE 13 (1ST QUAD SECT OF TUNNEL)		16:57	32.92	GJS-BYR*SYM(3).		
		17:50				
PART 6-0	REL098026570	26 JUN 84	454	3C8-0282-001	2	GJS
MAINSTEAM BREAK IN NODE 14 (1ST QUAD SECT OF TUNNEL)		17:51	32.05	GJS-BYR*SYM(4).		
		18:40				
SECTION 10-1PPP09809912I/L		26 SEP 84	9	3C8-0282-001	2	GJS
FOR STEAM BREAK IN 1ST QUAD. TUNNEL (NODE 13)		14:48	1.85	GJS-BYR*SYM2(1).		
		14:51				
SECTION 11-1PPP09809912I/L		26 SEP 84	9	3C8-0282-001	2	GJS
FOR STEAM BREAK IN 1ST QUAD. TUNNEL (NODE 14)		14:53	1.84	GJS-BYR*SYM2(2).		
		14:56				
SECTION 12-1PPP09809912I/L		26 SEP 84	8	3C8-0282-001	2	GJS
FOR STEAM BREAK IN 1ST QUAD. TUNNEL (NODE 13)		14:57	1.84	GJS-BYR*SYM2(3).		
		15:01				
SECTION 13-1PPP09809912I/L		26 SEP 84	11	3C8-0282-001	2	GJS
FOR STEAM BREAK IN 1ST QUAD. TUNNEL (NODE 14)		15:03	1.84	GJS-BYR*SYM2(4).		
		15:11				

2

Calc. No. 3C8-0282-001
Revision: 2
Page: 67
Project No. 4391-00

Calc. No. 3C8-0282-001
Revision: 2
Page: 68
Project No. 4391-00

MICROFICHE*

*Microfiche from Revisions 0 and 1 are to be retained.

REVIEW METHOD SHEET

The NSLD Calc. No. 3C8-0282-001 Revision 2 has been reviewed by me according to the method(s) checked below:

Computer Aided Calculations:

- ☐ A review to determine if the input data as specified for program execution is consistent with the design input, correctly defines the problem for the computer algorithm, and is sufficiently accurate to produce results within any numerical limitation of the program.
- ☒ Review of code input only since the computer program has sufficient history of use at Sargent & Lundy in similar calculations.
- ☐ Comparison of computer program's solution to test problem(s).
- ☐ Comparison of results of the computer calculation with the results of an independent hand calculation.
- ☐ Other. Explain: _____

Hand Prepared Design Calculations:

- ☐ Detailed review of the original calculations.
- ☐ Review by an alternate, simplified, or approximate method of calculation.
- ☐ Review of a representative sample of repetitive calculations.
- ☐ Review of the calculation against a similar calculation previously performed.

Revisions:

- ☐ Editorial changes only.
- ☐ Elimination of unapproved input data without altering calculation results.
- ☒ Other. Explain: Detailed Review of the two additional cases analyzed in this calculation

☐ Other: _____

Reviewer: Vijay Kumar Sehgal Date: 10/18/84



Calcs. For Main Steam Tunnel Pressure
Study For Main Steam Line Break
☒ Safety-Related ☐ Non-Safety-Related

Calc. No. 38-0282-001
Rev. 0 Date 8/11/82
Page A1 of

Client Commonwealth Edison Co.
Project Byron - Unit 1
Proj. No. 4391-00 Equip. No.

Prepared by A. Schweitzer Date 8-6-82
Reviewed by Thomas Kury Date 8-6-82
Approved by John W. Ahrens Date 8-11-82
for R.T.H.

Appendix A

Hand Calculations

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 308-0282-001

Rev. 0

Date

☒ Safety-Related☐ Non-Safety-Related

Page A2

of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

I recalculated volumes, flow areas, vent areas, inertia terms, and loss coefficients in this appendix. Having the previous values used in Reference 1 on hand, actual input used is as follows;

1.) Volumes

Will take 90% of recalculated gross volume for node 6. All other volumes used in reference 1 will be used.

2.) Verts

Even though there is very good agreement, I replaced values where recalculation is smaller.

3.) Inertia Terms

Larger of two values will be used.

4.) Loss Coefficients

Larger of two values will be used.

5.) Flow Areas

I used recalculated values when smaller than previously used.

SARGENT & LUNDYENGINEERS
CHICAGO

Calc. For

Calc. No. 368-0282-001

Rev. 0

Date

X

Safety-Related

Non-Safety-Related

Page A3

of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

Table A-1

Summary of Gross Volumes And Volumes Used
in Analysis

Node(s)	Recalculated Gross Volume (ft ³)	Volume Used In Analysis (ft ³)	Difference (%) *
2, 3, 9, 10	6360	4900	-23
4, 5, 11, 12	6650	6005 (3,695)	-10
6	15,217	14,687	-3.5
7	39,192	34,865	-11
8	42,845	35,016	-18
13	21,956	17,388	-20
14	16,660	13,530	-19

* Used Recalculated Gross Volume as base.

SARGENT & LUNDYENGINEERS
CHICAGO

Calc. For

Calc. No. 368-0282-00

Rev. 0 Date

☒ Safety-Related☐ Non-Safety-Related

Page A4 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00 Equip. No.

Approved by

Date

Table A-2

Summary of Vent Areas And Vent Areas Used in Analysis

Vent No	Area Used In Analysis	Recalculated Net Area	Difference (%)
1	271	298**	- 9.0
2	125	121	+ 3.3
3	125	121	+ 3.3
4	75	73	+ 2.7
5	75	73	+ 2.7
6	100	100	0.0
7	200	202	- 1.0
8	200	202	- 1.0
9	125	121	+ 3.3
10	100	100	0.0
11	125	121	+ 3.3
12	100	100	0.0
13	374	422**	- 11.4
14	271	298**	- 9.1
15	75	73	+ 2.7
16	75	73	+ 2.7
17	100	100	0.0
18	51.3	53	- 3.2
19	75.8	78.5	- 3.4
20	51.3	53	- 3.2
21	75.8	78.5	- 3.4

* Is determined using Recalc. Net Area as base.

** Gross Vent Area minus Area equal to cross-sectional area of 4 MS Lines and 4 FW lines.

SARGENT & LUNDY**ENGINEERS
CHICAGO**

Calcs. For

Calc. No. 308-0282-001Rev. 0 Date☒ Safety-Related☐ Non-Safety-RelatedPage A5 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

Table A-3Summary of Recalculated Inertia Values
and Inertia Values used in the analysis

<u>Vent No.</u>	<u>Inertia (YA) Used in Analysis</u>	<u>Recalculated Inertia</u>
1	.1034	.0897
2	.0320	.1358
3	.0320	.1358
4	.0600	.2350
5	.0600	.2350
6	.0200	.1614
7	.5105	.446
8	.6306	.662
9	.0320	.1358
10	.0200	.1115
11	.0320	.1358
12	.0200	.1614
13	.1124	.099
14	.1551	.098
15	.0600	.2350
16	.0600	.2350
17	.0200	.1115
18	.2970	.2893
19	.3330	.1919
20	.2970	.2893
21	.3330	.1919



Calc. For	
☒ Safety-Related	☐ Non-Safety-Related

Calc. No. 318-0282-001	
Rev. 0	Date
Page A6	of

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No. 4391-00	Approved by	Date
Equip. No.		

Table A-4

Summary of Recalculated Loss Coefficients (K)
and Loss Coefficients Used in the Analysis

Vent No.	K Used in Analysis	Recalculated K
1	1.0271	1.0656
2	1.5150	1.5207
3	1.5150	1.5207
4	1.5040	1.5683
5	1.5040	1.5685
6	1.5043	1.5071
7	1.8315	2.186
8	2.0500	2.753
9	1.5150	1.5207
10	1.5043	1.512
11	1.5150	1.5207
12	1.5043	1.5071
13	1.0366	2.26
14	1.0543	2.26
15	1.5040	1.5685
16	1.5040	1.5685
17	1.5043	1.512
18	1.6930	2.9
19	2.90	2.9
20	1.6930	2.9
21	2.900	2.9

SARGENT & LUNDYENGINEERS
CHICAGO

Calc. For

Calc. No. 358-0282-001

Rev. 0 Date

☒ Safety-Related☐ Non-Safety-Related

Page A7 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

Check for Reynolds Number

Will select Junction 2 (3, 9, 11)

This junction consists of 3 openings.

Max. Mass Flow = 620 lbm/sec (Computer Output 1-0)

Opening #1

(t = .015 seconds)

$$4 \times 5.5 = 22 \text{ ft}^2$$

$$\text{Perimeter} = 19 \text{ ft}$$

$$\therefore D_H = \frac{4 \text{ Area}}{\text{Perimeter}} = 4.63$$

$$\text{Proportioning Mass Flow} = 7 \frac{22}{125} = .176 (620) = 109.1 \frac{\text{lbm}}{\text{sec}}$$

At t = .015 seconds,

$$r = 12.9578 \frac{\text{ft}^3}{\text{lbm}}$$

$$\therefore \rho = .0771736 \frac{\text{lbm}}{\text{ft}^3}$$

$$V = 109.1 \frac{\text{lbm}}{\text{sec}} = 64.2 \text{ ft/sec}$$

$$.0771736 \frac{\text{lbm}}{\text{ft}^3} (22 \text{ ft}^2)$$

$$\text{Rey No.} = \frac{\rho D_H V}{\mu}$$

$$.0771736 (4.63) (64.2 \frac{\text{ft}}{\text{sec}}) \frac{\text{lbm}}{\text{ft}^3}$$

$$(.005 \text{ centipoises}) .000672$$

(u = .005 centipoises,

Marks, Page 4-50

Fig. 47)

$$\text{Rey No.} = 6.8 \times 10^6$$

Turbulent Flow

$$\therefore r = 4.36 \times 10^{-5} = \frac{\text{ft}^2}{\text{sec}}$$

Calc. For

Calc. No. 35-0282-001

Rev. 0 Date

☒ Safety-Related

☐ Non-Safety-Related

Page A8 of

Client

Prepared by J. Schweitzer

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

Volume Computation

1. Nodes 2, 3, 9, 10

Upper Valve Rooms

See Drawing Nos. S-900, S-1056, S-899

3 Sections

S-1051

1. Volume Between ELS 401'0" & 413'4"

Length = 27.3 ft

Width = 13.3 ft

Ht = 12.3 ft

Vol = 4466 ft³

2. Volume Between ELS 413'4" & 416'4"

Length = 20.5 ft

Width = 6.5 ft

Ht = 3.0 ft

Vol = 399.75 ft³

3. Volume Between El. 416'4" & 421'8"

Length = 21'2"

Width = 13.3 ft

Ht = 5.3 ft

Volume = 1492 ft³

Total
Gross Volume = 6357.8 ft³

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 38-1282-001

Rev. 0 Date

☒ Safety-Related☐ Non-Safety-Related

Page A9 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

2. Nodes 4, 5, 11, 12Lower Valve Rooms

See Drawings S-896 ; S-1056

Length = 25 ft (See S-896)

Width = 13.3 ft (See S-896)

Ht = 20 ft (See S-1056)

Gross Volume = 6650 ft³To subtract pipe volume, see Drawing Nos.
M-160, Sht. 3, and M-188, Sht. 1.Main Steam piping Dia = 32 ³/₄

$$\text{Volume}_{\text{thru. room}} = \left(\frac{32.0625}{12} \right)^2 \frac{\pi}{4} (25) = 140 \text{ ft}^3$$

Feedwater piping Dia = 16"

$$\text{Volume}_{\text{thru. room}} = \left(\frac{16}{12} \right)^2 \frac{\pi}{4} 25 = 34.9 \text{ ft}^3$$

The following calculations are estimates;

Approximately 8 → 3 inch lines. Dia = 3.5 in

$$\text{Total Volume (8 pipes)} = \left(\frac{3.5}{12} \right)^2 \frac{\pi}{4} (25) 8 = 13.4 \text{ ft}^3$$

Approximately 8 → 6 inch lines

$$\text{Total Volume (8 pipes)} = \left(\frac{6}{12} \right)^2 \frac{\pi}{4} (25) 8 = 39.2 \text{ ft}^3$$



Calcs. For	
☒ Safety-Related	☐ Non-Safety-Related

Calc. No. 368-0282-001	
Rev. 0	Date
Page A10 of	

Client
Project
Proj. No. 4391-00 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

Total piping Volume = 228 ft³
Therefore,
Volume minus piping = 6422 ft³

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 328-0282-04Rev. 0 Date☒ Safety-Related☐ Non-Safety-RelatedPage A11 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00 Equip. No.

Approved by

Date

3. Note 6Main Steam Tunnel - 2nd QuadrantSee Drawings Nos. 5-896 & 5-1056
Section is shaped as

A)


Width = 18 ft

Length = 28 ft (See 5-896)

Ht = 19 ft

Volume = 9576 ft³

B)

Cos 30°
 $X \approx 28.6'$

Ht = 19' (See 5-1056)

Volume $\approx$ 4891 ft³C.) Volume in Vents

3 Vents

(See No. 5-1056) 1. $(5' 10") \times 6.5' \times 6 = 227.5 \text{ ft}^3$ $\times 2 = 455 \text{ ft}^3$ 3. $7' \times 7' \times 6 = 294 \text{ ft}^3$

Cross

Total Vol. $\approx$ 15,217 ft³750 ft³

SARGENT & LUNDY

CHICAGO

Calc. For

Calc. No. 308-0282-001

Rev. 0

Date



Safety-Related

Non-Safety-Related

Page A12 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

Will Subtract Volume for 2 main stem
lines and 2 FW lines

Approximate Length = 58'

(I simply added the lengths
for A & B of previous page for
conservative estimate)
See No. M-160 Sta. 1

$$MS \Rightarrow \left(\frac{32}{12}\right)^2 \frac{\pi}{4} 58(2) = 647.9 \text{ ft}^3$$

$$FW \Rightarrow \left(\frac{16}{12}\right)^2 \frac{\pi}{4} 58(2) = 162 \text{ ft}^3$$

$$\underline{810 \text{ ft}^3}$$

$$\text{Net Volume} = 14,407 \text{ ft}^3$$

810 ft³ is 5.6% of Gross Volume

I will use 90% of gross in analysis

$$\underline{\text{Volume} = 12966 \text{ ft}^3}$$

SARGENT & LUNDYENGINEERS
CHICAGO

Calc. For

Calc. No. 368-0282-001

Rev. 0 Date

☒ Safety-Related☐ Non-Safety-Related

Page A13 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

4. Node 7

Main Steam Tunnel
Connecting 2nd & 1st Quadrants
See Drawing Nos. S-895 ; S-896 ; S1060

$$\text{Length} = (31' 1\frac{1}{4}" - 22') + 47' 0" + 23' 3" + 28' 4" \\ + 45' 8" + 18' 6" = 171.9 \text{ ft}$$

$$\text{Width} = 12 \text{ ft}$$

$$\text{Ht} = 19 \text{ ft}$$

Gross Volume = 39,192 ft³
Volume to be subtracted
2 Main Steam lines

$$\left(\frac{32}{12}\right)^2 \frac{\pi}{4} (172) 2 = 1921 \text{ ft}^3$$

2 FW lines

$$\left(\frac{14}{12}\right)^2 \frac{\pi}{4} (172) 2 = 480 \text{ ft}^3$$

$$\text{Total} = 2401 \text{ ft}^3$$

$$\text{Net Volume} = 36,791 \text{ ft}^3$$

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00 Equip. No.


Approved by

Date

5. Node 8

1st Quadrant Main Steam Tunnel


See Drawings S-688 ; S-1555 ; S-765
S-1062



A. $W = 23.75 \text{ ft}$
 $Ht = 20.0$
 $Length = 76.0 \text{ ft}$

$Volume = 36,100 \text{ ft}^3$

B.



$X = 28.7 \cos 35^\circ$ *measured from drawing*

$X = 23.5 \text{ ft}$

$Ht = 20 \text{ ft}$ (See S-1062)

$Volume = 6,745 \text{ ft}^3$

Gross Volume = 42,845 ft³



Calc. For	
☒ Safety-Related	☐ Non-Safety-Related

Calc. No. 3081282-001	
Rev. 0	Date
Page A15 of	

Client
Project
Proj. No. 4391-00

Prepared by	Date
Reviewed by	Date
Approved by	Date

4 MS Lines in Note 8

$$\left(\frac{32}{12}\right)^2 \frac{\pi}{4} (76) 4 = 1700 \text{ ft}^3$$

4 FW Lines in Note 8

$$\left(\frac{16}{12}\right)^2 \frac{\pi}{4} (76) 4 = 424 \text{ ft}^3$$

Total $\rightarrow 2125 \text{ ft}^3$

Tip volume represents about 5% of the gross volume in Note 8

SARGENT & LUNDYENGINEERS
CHICAGO

Calc. For

Calc. No. 308-0282-001Rev. 0

Date

☒

Safety-Related

Non-Safety-Related

Page A16 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

6. Node 13

1st Quadrant Main Steam Tunnel (Node 13)
(Section where floor drops while
making 90° turn) (P-Q) & (8-10)

Length - 25.5'
Width - 28.7'
height - 30.0'

Gross Volume = 21,956 ft³



Calc. For	
☒ Safety-Related	☐ Non-Safety-Related

Calc. No. <u>218-0282-001</u>	
Rev. <u>0</u>	Date
Page <u>A17</u>	of

Client
Project
Proj. No. <u>4391-00</u>

Prepared by	Date
Reviewed by	Date
Approved by	Date

7. Node 14

Last Leg of Main Steam Tunnel
(L-P) (8-10)

See drawing No. S-688 & S-762

Length = 52 ft
Width = 26.7 ft
Height = 12.0 ft

Gross Volume = 16,660.8



Calc. For	
☒ Safety-Related	☐ Non-Safety-Related

Calc. No. 308-0282-001	
Rev. 0	Date
Page A1B of	

Client
Project
Proj. No. 4391-00 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

Vent Computation

1. Junctions 2, 3, 9, 11

(Vents between upper & lower Valve Rooms)

See Drawings S-899 & S-900

There are 3 openings.

		Area	Perimeter (ft)	R _H
1.	4 × 5.5 =	22 ft ²	19	4.63
2.	6 × 10.5 =	63 ft ²	33	7.63
3.	3 × 13.333 =	40 ft ²	32.666	4.90
		125 ft ²	84.7	

The only obstruction is a 28" pipe leading from the INS line to the S/RV's. (See M-159 Sht 1 & M-187 Sht 1)

$$\text{Area (28")} = \left(\frac{28}{12} \right)^2 \frac{\pi}{4} = 4.3 \text{ ft}^2$$

$$\text{Net Area} = 120.7$$

$$\text{Hydraulic Radius} = \frac{\text{Area}}{\text{Wetted Perimeter}}$$

$$D = 4R = \frac{4(120.7)}{84.7} = \underline{\underline{5.7}}$$

SARGENT & LUNDYENGINEERS
CHICAGO

Calc. For

Calc. No.

308-2232-001

Rev. 0

Date



Safety-Related

Non-Safety-Related

Page A19

of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00 Equip. No.

Approved by

Date

2. Junctions 4, 5, 15, 16
(Lower Valve Chambers to Main Steam. Tunnels)
See Drawing No. S-1056 & S-1061

4 Openings

	Area (ft ²)	Perimeter (ft)
1. 3.5 x 2	7.0	11.0 2.54
2. 3.0 x 2.75	8.25	11.5 2.87
3. 6.0 x 5.83		
- 2	35.9	23.5 6.11
4. 3.5 x 7		
- 2.5	2.2	19.5 4.63
	73.15	65.5

$$\text{Hydraulic Diameter} = 4 \frac{(73)}{65.5} = 4.5$$

SARGENT & LUNDYENGINEERS
CHICAGO

Calc. For

Calc. No. 368-0282-001Rev. 0 Date☒ Safety-Related☐ Non-Safety-RelatedPage A20 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

3. Junctions 6 and 12 (Between Lower Valve Chambers)

See Drawing NOS. 5-895, 5-896,
5-1056, and 5-1057

2 openings

		Area	Perimeter	R _H
1.	$6 \times 7 =$	42	26	6.46
2.	$8.33 \times 7 =$	58.33	30.67	7.61
		100 ft ²	56.7	

$$\text{Hydraulic Diameter} = \frac{4(100)}{56.7} = \underline{\underline{7.1}}$$

SARGENT & LUNDYENGINEERS
CHICAGO

Calc. For

Calc. No. 368-0282-001Rev. 0

Date



Safety-Related

Non-Safety-Related

Page A21 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00 Equip. No.

Approved by

Date

4. Junctions 7;8 See Drawing Nos. S-896; S-1060
and S-899; E-688
(Between Nodes 6;7 and 7;8)
Perimeter

Width = 11 ft

Height = 19 ft

Area 209 ft²

60 ft

Subtract Area for 2 ms Lines
and 2 FW lines

$$2 \text{ ms} \Rightarrow \left(\frac{22}{12}\right)^2 \frac{\pi}{4} = 11.2 \text{ ft}^2$$

$$2 \text{ FL} \Rightarrow \left(\frac{16}{12}\right)^2 \frac{\pi}{4} = 2.8 \text{ ft}^2$$

$$\text{Net Area} = 195 \text{ ft}^2$$

$$\text{Hydraulic Diameter} = \frac{4(200)}{60} = 13.3$$

Calc. For

Calc. No. 38-0282-001

Rev. 0 Date

☒ Safety-Related

☐ Non-Safety-Related

Page A22 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

5. Junctions 10 and 17
(Vents between Upper Valve Chambers)

See S-899, S-900, S-1056; S-1057

3 openings

		Area (ft ²)	Perimeter ft
1.	2.5 x 12.333	30.83	29.67 4.16
2.	2.75 x 12.333	33.92	28.17 4.82
3.	3.0 x 12.333	37.00	30.666 4.83

Subtract $\frac{(3 \times 1)}{2} = 1.5$

101.75 ft²
- 1.50
100.25 ft²

Hydraulic Diameter = $4 \left(\frac{100.25}{88.5} \right) = \underline{\underline{4.5}}$

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 318-0282-001Rev. 0

Date

Page A23 of

Safety-Related

☐ Non-Safety-Related

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

6.

Junction 13

(Between Nodes 8 and 13)

See Drawings 5-688, 5-762

$$\text{Area} = 22.5 \times 20 = 450 \text{ ft}^2$$

$$\text{Perimeter} = 85 \text{ ft}$$

$$\text{Area } 4 \text{ ms} = \left(\frac{32}{12}\right)^2 \times \frac{1}{4} (4) = 22.3 \text{ ft}^2$$

$$\text{Area } 4 \text{ FW} = \left(\frac{16}{12}\right)^2 \times \frac{1}{4} (4) = \frac{5.6}{28 \text{ ft}^2}$$

$$\text{Net Area} = 422 \text{ ft}^2$$

(373 ft² was used in calculation)

$$\text{Hydraulic Diameter} = 4 \left(\frac{373}{85} \right) = 17.6$$



Calc. For	
☒ Safety-Related	☐ Non-Safety-Related

Calc. No. 308-0282-001	
Rev. 0	Date
Page A24 of	

Client
Project
Proj. No. 4391-00 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

7. Junctions 1 and 14

(Vents between Nodes 13 & 14 and 14 & 1)
Junctions 1 and 14.

$$\text{Area} = 27.17 \times 12 = 326 \text{ ft}^2$$

$$\text{Perimeter} = 78.3 \text{ ft}$$

Area of 4 ms & 4 FW lines equal to 28 ft^2

(271 ft^2 was used in calculation)

$$\text{Hydraulic Diameter} = \frac{4(271)}{78} = 13.9$$

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 318-022-001Rev. 0 Date☒ Safety-Related☐ Non-Safety-RelatedPage A25 of

Client

Project

Proj. No. 4391-00

Equip. No.

Prepared by

Date

Reviewed by

Date

Approved by

Date

8. Junctions 18 and 20
(Upper Valve Chamber not containing Door)
See Drawing Nos. 5-899 5-900
5-1056 5-1057

Area HVAC Openings (Blow open - 1.5 psid)
(See 5-1056)

$$\begin{aligned}\text{Area} &= 13'4" \times 4 = 53.3 \text{ ft}^2 \\ \text{Perimeter} &= 34.7 \text{ ft}\end{aligned}$$

(51.3 ft² was used in calculation)

$$\text{Hydraulic Diameter} = \frac{4(51.3)}{34.7} = \underline{\underline{5.9}}$$

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 368-0782-001Rev. 0 Date☒ Safety-Related☐ Non-Safety-RelatedPage A26 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

9. Junctions 19 & 21
(Upper Valve Chambers containing Door)

See Drawing Nos. S-899, S-900, S-K56, ¹/₅-1057

2 Openings (Blow open - 1.5 psid)

Door = $3.5 \times 7'2\frac{1}{2}"$ (See S-1061) R_h 3.40
HVAC = 53.3 ft^2 (See Previous page)

Total Area = 78.5 ft^2
Perimeter = 56.1

Used 75.83 ft^2 in the Analysis

$$\text{Hydraulic Diameter} = \frac{4(75.83)}{56.1} = \underline{\underline{5.4}}$$

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

Inertial Values

1. Junctions 2, 3, 9, 11 (Vents between upper & lower valve rooms)

This junction consists of 3 parallel vents
(See Drawing Numbers S-1056 & S-1057)

$$\text{Path \#1)} \sum \frac{L}{A} = \frac{L_1 - D_H}{A_1} + \frac{L_v + 2D_H}{A_v} + \frac{L_2 - D_H}{A_2}$$

$$L_1 \text{ (Upper Valve Room)} = 20.6/2 = 10.3 \text{ ft}$$

$$A_1 = 363 \text{ ft}^2$$

$$L_v \text{ (Vent)} = 4 \text{ ft}$$

$$A_v = 22 \text{ ft}^2$$

$$L_2 \text{ (Lower Valve Room)} = 20/2 = 10 \text{ ft}$$

$$A_2 = 332.5 \text{ ft}^2$$

$$D_H = 4.63 \text{ ft}$$

$$\sum \frac{L}{A} = \frac{10.3 - 4.63}{363} + \frac{4 + 2(4.63)}{22} + \frac{10 - 4.63}{332.5}$$

$$\sum \frac{L}{A} = .0156 + .6027 + .0162$$

$$\sum \frac{L}{A} = .6345$$

$$\text{Path \#2)} A_v = 63 \text{ ft}^2$$

$$D_H = 7.63 \text{ ft}$$

$$\sum \frac{L}{A} = \frac{10.3 - 7.63}{363} + \frac{4 + 2(7.63)}{63} + \frac{10 - 7.63}{332.5}$$

$$\sum \frac{L}{A} = .0074 + .3057 + .0071$$

$$\sum \frac{L}{A} = .3202$$

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 308-0282-001Rev. 0 Date☒ Safety-Related☐ Non-Safety-RelatedPage A28 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

Path #3)

$$A_v = 40 \text{ ft}^2$$

$$D_H = 4.90$$

$$\sum \frac{L}{A} = \frac{10.3 - 4.90}{363} + \frac{4 + 2(4.7)}{40} + \frac{11 - 4.9}{332.5}$$

$$\sum \frac{L}{A} = .0149 + .345 + .0153$$

$$\sum \frac{L}{A} = .3752$$

$$\sum \frac{L}{A} = \frac{1}{\left(\frac{1}{.6345} + \frac{1}{.3202} + \frac{1}{.3752} \right)} = \frac{1}{7.36}$$

$$\sum \frac{L}{A} = \underline{\underline{.1358}}$$

Calc. No. 308-0282-001	
Rev. 0	Date
Page A29 of	

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No. 4391-00 Equip. No.	Approved by	Date

2. Junctions 4, 5, 15, 16

(Vents between Lower Valve rooms and main steam Tunnel)

See Drawings S-895 & S-896

Junction consists of 4 parallel paths

$$\text{Path \#1)} \leq \frac{L}{A} = \frac{L_1 - D_H}{A_1} + \frac{L_v + 2D_H}{A_v} + \frac{L_2 - D_H}{A_2}$$

$$L_1 (\text{Valve Room}) = 25/2 = 12.5 \text{ ft}$$

$$A = 266 \text{ ft}^2$$

$$L_v(\text{Path}) = 6 \text{ ft}$$

$$A_v = 7f + 2$$

$$L_2 \text{ (Main Steam)} = 28(\frac{2}{3}) + 28/2 = 23.5 \text{ ft}$$

$$A_2 = 342 \text{ ft}^2$$

$$R_H^2 = 2.54$$

$$\sum \frac{L}{A} = \frac{12.5 - 2.54}{266} + \frac{6 + 2(2.54)}{7} + \frac{23.5 - 2.54}{342}$$

$$\sum \frac{L}{A} = .0374 + 1.5829 + .06129$$

$$\sum \frac{L}{A} = 1.6816$$

Path #2) $A_v = 8.25 \text{ ft}^2$
 $D_v = 2.87$

$$D_H = 2.87$$

$$\Sigma \frac{L}{A} = \frac{12.5 - 2.87}{266} + \frac{6 + 2(2.87)}{8.25} + \frac{23.5 - 2.87}{342}$$

$$\sum \frac{L}{A} = .0362 + 1.423 + .0603$$

$$\Sigma \frac{L}{A} = 1.5195$$



Calcs. For	
☒ Safety-Related	☐ Non-Safety-Related

Calc. No. 368-0282-001	
Rev. 0	Date
Page A30 of	

Client
Project
Proj. No. 4391-00

Prepared by	Date
Reviewed by	Date
Approved by	Date

Path #3) $A_v = 35.9 \text{ ft}^2$
 $D_H = 6.11 \text{ ft}$

$$\sum \frac{L}{A} = \frac{12.5 - 6.11}{266} + \frac{6 + 2(6.11)}{35.9} + \frac{23.5 - 6.11}{342}$$

$$\sum \frac{L}{A} = .02402 + .5075 + .05085$$

$$\sum \frac{L}{A} = .5824$$

Path #4) $A_v = 22 \text{ ft}^2$
 $D_H = 4.63$

$$\sum \frac{L}{A} = \frac{12.5 - 4.63}{266} + \frac{6 + 2(4.63)}{22} + \frac{23.5 - 4.63}{342}$$

$$\sum \frac{L}{A} = .0296 + .6936 + .0552$$

$$\sum \frac{L}{A} = .7784$$

Total $\sum \frac{L}{A} = \frac{1}{\frac{1}{1.6816} + \frac{1}{1.5195} + \frac{1}{.5824} + \frac{1}{.7784}} = \frac{1}{4.25}$

$$\sum \frac{L}{A} = .2350$$

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

3. Junctions 6 & 12

(Between Lower Valve Chambers)

See Drawings S-895 and S-896

Junction consists of 2 parallel paths

$$\sum \frac{L}{A} = \frac{L_1 - D_H}{A_1} + \frac{L_V + 2D_H}{A_V} + \frac{L_2 - D_H}{A_2}$$

Path #1)

$$L_1 (\text{Value Room}) = L_2 = 13.3/2 = 6.7'$$

$$A_1 = A_2 = 500 \text{ ft}^2$$

$$L_V = 2 \text{ ft}$$

$$A_V = 42 \text{ ft}^2$$

$$D_H = 6.46$$

$$\sum \frac{L}{A} = \frac{6.7 - 6.46}{500} + \frac{2 + 2(6.46)}{42} + \frac{6.7 - 6.46}{500}$$

$$\sum \frac{L}{A} = .3562$$

Path #2)

$$A_V = 58.33 \text{ ft}^2$$

$$D_H = 7.61$$

$$\sum \frac{L}{A} = 0 + \frac{2 + 2(7.61)}{58.33} + 0$$

$$\sum \frac{L}{A} = .2952$$

Total

$$\sum \frac{L}{A} = \frac{1}{\frac{1}{.3562} + \frac{1}{.2952}} = \frac{1}{6.195}$$

$$\sum \frac{L}{A} = \underline{\underline{.1614}}$$



Calcs. For	
☒ Safety-Related	☐ Non-Safety-Related

Calc. No. <u>308-0282-001</u>	
Rev. <u>0</u>	Date
Page <u>A32</u> of	

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No. <u>4391-00</u> Equip. No.	Approved by	Date

4. Junction 7

(Between nodes 6 & 7)

See Drawings S-895 & S-896

$$L(\text{Node 6}) = 28 + 28.6\left(\frac{2}{3}\right) / 2 = 23.5'$$

$$L(\text{Node 7}) = 171.9 / 2 = 86 \text{ ft}$$

$$\text{Area (Node 6)} = 342 \text{ ft}^2$$

$$\text{Area (Node 7)} = 228 \text{ ft}^2$$

$$\sum \frac{L}{A} = \frac{23.5}{342} + \frac{86}{228} = \underline{\underline{.446}}$$

5. Junction 8

(Area between nodes 7 & 8)

Going into 2nd 90° Turn in Tunnel

$$L_1(\text{Node 7}) = 171 / 2 = 86 \text{ ft}$$

$$A_1 \quad " = 342 \text{ ft}^2$$

$$L_2(\text{Node 8}) = 76 / 2 = 38 \text{ ft}$$

$$A_2 \quad " = 475 \text{ ft}^2$$

$$\sum \frac{L}{A} = \frac{86}{342} + \frac{38}{475} = .331$$

To account for 90° turn
will double γA

$$\therefore \frac{L}{A} = \underline{\underline{.662}}$$



Calc. For

Calc. No. 368-0282-001

Rev. 0 Date

☒ Safety-Related☐ Non-Safety-Related

Page A33 of

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No. 4391-00 Equip. No.	Approved by	Date

6 Junctions 10 § 17

(Vent areas between Upper Valve rooms)

See Drawings S-899 & S-900

This junction consists of 3 parallel paths

$$L_1 = L_2 \text{ (Upper Valve Room)} = 13.2/2 = 6.7 \text{ ft}$$
$$A_1 = A_2 = 336 \text{ ft}^2$$

$$\text{Path \#1)} \quad \sum \frac{L}{A} = \frac{L_1 - D_H}{A_1} + \frac{L_v + 2D_H}{A_v} + \frac{L_2 - D_H}{A_2}$$

$$L_v = 2 \text{ ft}$$
$$A_v = 30.83 \text{ ft}^2$$
$$D_H = 4.16$$

$$\sum \frac{L}{A} = 2 \left(\frac{6.7 - 4.16}{336} \right) + \frac{2 + 2(4.16)}{30.83}$$
$$\sum \frac{L}{A} = .3347$$

$$\text{Path \#2)} \quad A_v = 33.92 \text{ ft}^2$$
$$D_H = 4.82$$

$$\sum \frac{L}{A} = 2 \left(\frac{6.7 - 4.82}{336} \right) + \frac{2 + 2(4.82)}{33.92}$$
$$\sum \frac{L}{A} = .3432$$

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 308-0282-001

Rev. 0 Date

☒ Safety-Related☐ Non-Safety-Related

Page A34 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No.

4391-00

Equip. No.

Approved by

Date

Path #3) $A_v = 37 \text{ ft}^2$
 $D_H = 4.83$

$$\sum \frac{L}{A} = 2 \left(\frac{6.7 - 4.83}{336} \right) + \frac{2 + 2(4.83)}{37}$$

$$\sum \frac{L}{A} = .3263$$

Total

$$\sum \frac{L}{A} = \frac{1}{.3347} + \frac{1}{.2432} + \frac{1}{.3263} = \frac{1}{8.97}$$

$$\sum \frac{L}{A} = \underline{\underline{.1115}}$$

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 38-0212-001Rev. 0 Date☒ Safety-Related☐ Non-Safety-RelatedPage A35 of

Client

Project

Proj. No. 4391-00

Equip. No.

Prepared by

Date

Reviewed by

Date

Approved by

Date

7. Junction 13

(Between Nodes 8 & 13)

See Drawing No. S-688

$$L_1 (\text{Node 8}) = 76/2 = 38 \text{ ft}, \text{Area} = 475 \text{ ft}^2$$

$$L_2 (\text{Node 13}) = 20.5/2 = 10.25, \text{Area} = 765 \text{ ft}^2$$

$$\sum \frac{L}{A} = \frac{38}{475} + \frac{10.25}{765} = \underline{\underline{.099}}$$

8. Junction 14

(Between Nodes 13 & 14)

See Drawing No. S-688

$$L_1 (\text{Node 13}) = 28/2 = 14, \text{Area} = 861 \text{ ft}^2$$

$$L_2 (\text{Node 14}) = 52/2 = 26, \text{Area} = 320 \text{ ft}^2$$

$$\sum \frac{L}{A} = \frac{14}{861} + \frac{26}{320} = \underline{\underline{.098}}$$

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 318-0282-001Rev. 0 Date☒ Safety-Related☐ Non-Safety-RelatedPage A36 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

9. Junction 1

(Between Node 14 and 1)

- opening from ms tunnel to Turbine building -

Will use

$$\sum \frac{L}{A} = \frac{L_1}{A_1} + \frac{6 D_H}{31 A_1}$$

$$L_1 (\text{Node 14}) = 52/2 = 26 \text{ ft}$$

$$A_1 = 320 \text{ ft}^2$$

$$D_H = 13.9$$

$$\sum \frac{L}{A} = \frac{26}{320} + \frac{6(13.9)}{31(320)}$$

$$\sum \frac{L}{A} = \underline{\underline{.0897}}$$

10. Junctions 18 and 20 valve
(HVAC opening in upper chamber)Will use $\sum \frac{L}{A}$ equation per Junction 1

$$L_1 (\text{Upper Valve room}) = 27.3/2 = 13.7 \text{ ft}$$

$$A_1 = 51.3 \text{ ft}^2$$

$$D_H = 5.9$$

$$\sum \frac{L}{A} = \frac{13.7}{51.3} + \frac{6(5.9)}{31(51.3)} = \underline{\underline{.2893}}$$

SARGENT & LUNDYENGINEERS
CHICAGO

Calc. For

Calc. No. 368-0282-001

Rev. 0

Date

☒ Safety-Related☐ Non-Safety-Related

Page A37 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

11. Junctions 19 & 21

(Between Upper Valve Rooms and
atmosphere - HVAC and door)

This junction consists of 2 parallel paths

Path #1) HVAC - already calculated
for junctions 18 and 20
 $\frac{1}{A} = .2893$

Path #2) Door

$$A_v = 25.2 \text{ ft}^2$$

$$D_H = 3.4 \text{ ft}$$

$$\sum \frac{L}{A} = \frac{13.7}{25.2} + \frac{6(3.4)}{31(25.2)} = .5698$$

Total

$$\sum \frac{L}{A} = \frac{1}{\frac{1}{.2893} + \frac{1}{.5698}} = \frac{1}{5.21}$$

$$\sum \frac{L}{A} = \underline{\underline{.1919}}$$

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00


Equip. No.

Approved by

Date

Loss Coefficients

1. Junctions 2, 3, 9, 11



$L_v = 4 \text{ ft}$
(Floor thickness)

(Vents Between
Upper & Lower
Valve Rooms)

This junction consists of 3 parallel vents.

Reference: I.E. Idel'chik, AEC-TR-6630, 1960

Common to each of 3 vents { Entrance Loss = .5 (See Page 100)
Exit Loss = 1.0 (See Page 128)

To determine conservative friction factor, I will calculate conservative relative roughness by using largest ϵ_n for concrete and smallest D_H of vents.

$$\therefore \text{For concrete } \epsilon = .01 \Rightarrow \frac{\epsilon_{\text{max}}}{D_{H \text{ min}}} = \frac{.01}{4.63} = .0022 \Rightarrow f_{\text{max}} = .024$$

$$K_v = f_{\text{max}} \frac{L_v}{D_{H \text{ min}}} = .024 \frac{(4 \text{ ft})}{4.63} = .0207$$

$\therefore$

$$K = 1 + .5 + .0207$$

Conservatively, it will be assumed this K is applicable to all 3 vents,

$$\therefore \underline{K_T = 1.5207}$$

This is applicable to either flow direction

* Friction factor curves being used can be found in most any fluids book. The book being used in this analysis is, "Fluid Mechanics with Engineering Applications", by Daugherty & Franzini, McGraw-Hill, Inc, 1977 (Seventh Edition). The curves are on Page 214.

SARGENT & LUNDYENGINEERS
CHICAGO

Calc. For

Calc. No. 358-0282-001Rev. 0 Date☒ Safety-Related☐ Non-Safety-RelatedPage A39 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

2. Junctions 4, 5, 15, 16(Vents between Lower Valve Rooms
and Main Steam Tunnel)These junctions consist of 4 parallel ventsCommon
to each of
4 ventsEntrance Loss = .5 (page 100, idel'chik)
Exit Loss = 1.0 (page 128, idel'chik)

$$\frac{E_{\text{entr}}}{D_{\text{HMIN}}} = \frac{.01}{2.54} = .004$$

$$\therefore f_{\text{max}} = .029 \quad K_v = f_{\text{max}} \frac{L_v}{D_{\text{HMIN}}} \quad L_v(\text{vent}) = 6\text{ft}$$

$$K = K_v + K_{\text{EN}} + K_{\text{EX}} = \frac{.029(6.0)}{2.54} + 1.0 + .5$$

Conservatively, it will be assumed this K is applicable to all 4 vents,

$$\therefore \underline{K_T = 1.5685}$$

This applicable for both flow directions.

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 318-0282-001

Rev. 0 Date

☒

Safety-Related

Non-Safety-Related

Page A40 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

3. Junctions 6 and 12 (Between Lower Valve Rooms)

This junction consists of 2 parallel vents

Applicable to both vents { Entrance Loss = .5 (See page 100, idel'chik)
Exit Loss = 1.0 (See page 128, idel'chik)

$$\frac{E_{max}}{D_{Hmin}} = \frac{.01}{6.46} = .00155 \therefore f_{max} = .023$$

$$L_{vent} = 2 \text{ ft} \Rightarrow f_{max} \frac{L_v}{D_{Hmin}} = K_v = .023 \frac{(2)}{6.46} = .0071$$

$$K = 1.5071$$

Conservatively, it will be assumed
this K is applicable to both
vents, therefore,

$$\underline{K_T = 1.5071}$$

This applicable to both flow directions

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 38-0282-001

Rev. 0 Date

☒ Safety-Related☐ Non-Safety-Related

Page A41 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

4.) Junction 7 - (Vent Between Nodes 6 & 7)

Distance Between Nodes (centroids)

$$= \frac{42.3 + 172}{2} = 107.1 \text{ ft}$$

$$\frac{L_{min}}{D_H} = \frac{.01}{13.3} = .00075 \therefore f = .018$$

$$K_V = f \frac{L}{D_H} = \frac{.018 (107.1)}{13.3} = .145$$

For Turning Loss -

See Page 214 of Idel'Chik,
AEC-TR-6630, Handbook of
Hydraulic Resistance, Coefficients
of Local Resistance and
of Friction, 1960.

(Diagram 6-6)

For rough walls $\Rightarrow \xi_T = \xi_1 k_{re} k_a$

$$\xi_1 = f \left(\frac{b_1}{b_0} \right) \Rightarrow b_0 = 18 \text{ ft (node 6)} \quad a_0 = 19.8 \text{ ft}$$

$$b_1 = 12 \text{ ft (Node 7)}$$

$$\frac{b_1}{b_0} = \frac{12}{18} = .67$$

$$\frac{a_0}{b_0} = \frac{19}{18} \approx 1.0$$

$$\xi_1 = 1.59$$

SARGENT & LUNDY**ENGINEERS
CHICAGO**

Calcs. For

Calc. No. 318-0282-001Rev. 0 Date☒ Safety-Related☐ Non-Safety-RelatedPage A42 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

To determine K_{RE} & K_A , see Table 6-11,
Page 215 of *Idel'chik*.

It is assumed Reynolds Number $\geq 4 \times 10^4$

$$\text{Since } \Delta = \frac{\epsilon}{D_H} = .00075$$

$$\therefore K_{RE} = 1.0$$

$$K_A = 1 + 500(.00075) = 1.375$$

$$K_T = 1.59 (1.0) (1.375)$$

$$\underline{\underline{K_T = 2.186}}$$

It is evident from page 214, that
by reversing the flow, K_T would be less.
Both the b_1/b_0 and a_0/b_0 ratios would be
greater than 1 driving down ξ_1 .

For conservatism, the above K will be
applicable for both flow directions

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 348-0282-001Rev. 0 Date☒ Safety-Related☐ Non-Safety-RelatedPage A43 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00 Equip. No.

Approved by

Date

5. Junction 8 (Between nodes 7 & 8)Distance Between Centroids
 L_8 (Node 8) = 76 ft and L_7 (Node 7) = 172 ft

$$L_v = 172 + 76 = 124 \text{ ft}$$

$$\frac{E_{\max}}{b_H} = \frac{.01}{13.3} = .00075^2 \therefore f = .018$$

$$K_v = f \frac{L_v}{D_H} = .018 \frac{(124 \text{ ft})}{13.3}$$

$$K = .168$$

For flow from Node 7 to 8

See Page 214

$$b_0 = 12 \text{ ft}$$

$$a_0 = 19 \text{ ft}$$

$$b_1 = 23.75 \text{ ft}$$

$$a_1 = 20 \text{ ft}$$

$$b_1/b_0 = \frac{23.75}{12} \approx 2.0$$

$$a_0/b_0 = 19/12 = 1.58$$

$$\xi_1 = .805$$

As for Junction 7

$$K_{KE} = 1.0$$

$$\therefore K_0 = 1.375$$

$$K_{\text{TOTAL}} = (.805)(1.0)(1.375) + .168$$

$$K_{\text{TOTAL}} = 1.275$$

7 → 8



Calc. For	
☒ Safety-Related	☐ Non-Safety-Related

Calc. No. 308-0282-01	
Rev. 0	Date
Page A44	of

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No. 4391-00	Approved by	Date
Equip. No.		

For flow from Node 8 to 7

See Page 214, 1st chik

$$b_1/b_0 = \frac{12}{23.75} = .51$$

$$\frac{a_1}{b_0} = \frac{20}{23.75} = .84$$

Interpolation to determine ξ_1

	<u>.5</u>	<u>.6</u>	<u>.8</u>
--	-----------	-----------	-----------

.25		1.76	1.43
.84	1.88	1.71	1.38
1.00		1.70	1.36

$$\xi_1 = 1.88$$

$$K_{KE} = 1.0$$

$$K = 1.375$$

$$K_{TOTAL} = (1.88)(1.0)(1.375) = 1.68$$

$$\underline{\underline{K_7 = 2.753}}$$

For conservatism, the above K will be applicable for both flow directions

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 348-0282-001

Rev. 0 Date

☒ Safety-Related☐ Non-Safety-Related

Page A45 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

6.) Junctions 10 and 17
(Vents between Upper Valve Rooms)

This junction consists of 3 Parallel vents

Applicable to all vents $\left\{ \begin{array}{l} K_{\text{ENTRANCE}} = .5 \\ K_{\text{exit}} = 1.0 \end{array} \right.$ $\frac{f_{\text{max}} \cdot .01}{D_{\text{HMIN}} \cdot 4.16} = .0024 \therefore f_{\text{max}} = .025$

$$L_v = 2 \text{ ft}$$

$$K_v = \frac{f_{\text{max}} L_v}{D_{\text{HMIN}}} = \frac{.025 (2 \text{ ft})}{4.16}$$

$$K = .012$$

$$\underline{K_{\text{TOTAL}} = 1.512}$$

This K value will be applicable to both
flow directions

7.) Junctions 13 and 14
(Between Nodes 8;13 and 13;14)

See Page 229 in idel'chek

$$b_0 = 23.75 \text{ ft} \quad a_0 = 20 \text{ ft}$$

$$\frac{a_0}{b_0} = \frac{20}{23.75} = .84 \quad L'_0 = 14 \text{ ft} \quad (\text{difference between Centerlines of nodes 8 and 14})$$

$$\frac{L'_0}{b_0} = \frac{14}{23.75} = .59 \approx .6 \therefore \xi_1 = 2.9$$

Rough walls

$$\xi = K_0 C_1 \xi_1 + \xi_{fr}$$

See Page 230

$$\xi_{fr} = f \left(1 + \frac{a_0}{b_0} \right)$$

$$\xi_{fr} = .025 (1 + .6)$$

$$\xi_{fr} = .04$$

$$Re \geq 4 \times 10^4 \therefore K_0 = 1.5$$

$$\frac{a_0}{b_0} = .84 \therefore C_1 = 1.03$$

$$K = (1.5)(1.03)(2.9) + .04$$

$$K = 4.52$$

(See Page 230)
Table B

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 318-0282-001

Rev. 0 Date

☒ Safety-Related☐ Non-Safety-Related

Page 446 of

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

The loss coefficient is for both junctions 13 and 14, therefore, $\frac{1}{2}$ of the coefficient will be used for each junction.

$$\therefore K_{T13} = K_{T14} = 2.26$$

For reverse flow, $2\phi/b_0$ would be smaller resulting in a smaller ξ_1 . Also, a_0/b_0 would also be smaller resulting in a smaller C_1 . Therefore, the above K will be applicable to both flow directions

8. Junction 1

(From main steam tunnel to Turbine Building (atmosphere))

$$L_{14} \text{ (Note 14)} = 52 \text{ ft} \quad L_{ATM} = 44 \text{ ft}$$

$$L_v = 44 + 52 = 98 \text{ ft}$$

$$\frac{C_{max}}{D_H} = \frac{.01}{13.9} = .00072 \quad \therefore f = .019$$

$$K = f \frac{L_v}{D_H} = .019 \frac{(98)}{13.9} = .0656$$

$$K_{exit} = 1.0$$

$$\underline{K_T = 1.0656}$$

Entrance to the tunnel results in a lower K , therefore the above K will be applicable to either flow direction



Calc. For		Calc. No. <u>318-0282-001</u>	
		Rev. <u>0</u>	Date
☒ Safety-Related	☐ Non-Safety-Related	Page <u>A47</u> of	

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No. <u>4391-00</u> Equip. No.	Approved by	Date

9.) Junctions 18 and 20

(Upper HVAC openings in Upper Valve chambers of Safety valve room)

Will treat opening as an orifice.

Therefore, see page 135 of 'Idel'chick

K is a function of the ^{ratio of the} projected areas of the nodes. Since atmosphere is represented as a very large node, the ratio goes to zero.

Therefore, from the tables,

$$\underline{K_T = 2.9} \quad (\text{Applicable to both flow directions})$$

10.) Junctions 19 and 21

(Upper HVAC openings and doors in Upper Valve chambers of Safety Valve room)

I will treat door as an orifice
Therefore, as explained for junctions 18, 20,

$$\underline{K_T = 2.9} \quad (\text{Applicable to both flow directions})$$



Calcs. For		Calc. No. <u>318-0282-001</u>
☒ Safety-Related	☐ Non-Safety-Related	Rev. <u>0</u> Date
		Page <u>A48</u> of

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No. <u>4391-00</u> Equip. No.	Approved by	Date

Determination of Node Flow Areas

1. Nodes 2 and 9

Flow will be vertical

Flow area to HVAC opening at top of volume is dictated by dimensions at El. 413'4" and 416'4".

$$F.A. = 20 \text{ ft} \times 6.5 \text{ ft} = \underline{133.25 \text{ ft}^2}$$

2. Nodes 3 and 10

Flow will be both vertical and horizontal

Will use flow area equal to that determined for Nodes 2 and 9 plus twice the area of the door.

$$F.A. = 133.25 + (25.2)2 = \underline{183.7 \text{ ft}^2}$$

3. Node 6

Flow is horizontal

$$F.A. = 18 \times 19 = 342 \text{ ft}^2$$

Projected area of 2 ms lines (33") and 2 Fw lines (16") is equal to 15 ft²

I will subtract 25 ft² to account for piping

$$\therefore F.A. = \underline{317 \text{ ft}^2}$$

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

4.) Node 7

Flow is horizontal

$$FA = 12 \times 19 = 228 \text{ ft}^2$$

minus 25 ft^2 for piping (15 ft^2)

$$F.A. = \underline{203 \text{ ft}^2}$$

5.) Node 8

Flow is horizontal

$$F.A. = 20 \times 23.75 = 475 \text{ ft}^2$$

minus 40 ft^2 for piping

$$F.A. = \underline{435 \text{ ft}^2}$$

6.) Node 13Flow is directed both vertically
and horizontallyWill set flow capacity equal to
Node 8 to which it connects.

$$F.A. = \underline{435 \text{ ft}^2}$$

7.) Node 14

Flow is directed horizontally

$$F.A. = 26.7 \times 12 = 320 \text{ ft}^2$$

minus 40 ft^2 for piping

$$F.A. = \underline{280 \text{ ft}^2}$$

SARGENT & LUNDYENGINEERS
CHICAGO

Calcs. For

Calc. No. 348-0282-001Rev. 0

Date



Safety-Related

Non-Safety-Related

Page A50 of FINAL

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No. 4391-00

Equip. No.

Approved by

Date

8.) Notes 4, 5, 11, 12

Flow will be both vertical and horizontal, therefore, the smaller of the two will be used.

$$20 \times 13.3 = 266 \text{ ft}^2 \times 0.8 = 213 \text{ ft}^2$$

APPENDIX B

Revised Main Steam Tunnel Pressure For Byron/Braidwood Unit 1

Based On Mass And Energy Release From

FTI 32-1258100-00 (Reference B1)

For Replacement Steam Generator (RSG)

Table of Contents

<u>Section</u>	<u>Description</u>	<u>Page(s)</u>
	List of Tables	B 3
	List of Figures	B 4
1.0	Purpose and Scope	B 5
2.0	Design Input	B 5
3.0	Assumptions	B 5
4.0	Approach	B 6
5.0	Calculations	B 7
6.0	Results	B 10
7.0	References	B 12
8.0	Attachments	B 13
	Tables	B 14
	Figures	B 21
	Computer Disk Directory	B 41
	Microfiche of Computer Output	B 42

List of Tables

<u>Table No.</u>	<u>Description</u>	<u>Page(s)</u>
B1	Mass and Energy Release from FTI 32-1258100 -00 (Reference B1)	B 14
B2	Comparison of Node Pressures and Nodal Differential Pressures	B 16
B3	Comparison of Internal Wall Differential Pressures	B 17
B4	Peak Pressure Differentials - Main Steam Line Breaks in Main Steam Tunnel or Valve Rooms	B 18
B5	Summary of Peak Differential Pressures Between Valve Rooms and Main Steam Tunnel	B 19
B6	Comparison of MSLB in MST with 4" AFW Break in Auxilary Feedwater Tunnel	B 20

List of Figures

<u>Figure No.</u>	<u>Description</u>	<u>Page(s)</u>
B1	Main Steam Line Break in Lower 2nd Quadrant Valve Room (Node 5) (Volumes 4 & 5)	B 21
B2	Main Steam Line Break in 2nd Quadrant Tunnel (Node 6)	B 22
B3	Main Steam Line Break in 2nd and 1st Quadrant Tunnel (Node 7)	B 23
B4	Main Steam Line Break in 1st Quadrant of Tunnel (Node 8)	B 24
B5	Main Steam Line Break in 1st Quadrant Tunnel (Node 13)	B 25
B6	Main Steam Line Break in 1st Quadrant Tunnel (Node 14)	B 26
B7	Main Steam Line Break in Lower 2nd Quadrant Valve Room (Node 5) (Volumes 2 & 3)	B 27
B8	Peak Differential Pressures Between Valve Rooms and Main Steam Tunnel (Between Nodes 2 & 3, 9 & 10)	B 28
B9	Peak Differential Pressures Between Valve Rooms and Main Steam Tunnel (Between Nodes 2 & 5, 9 & 12, 3 & 4, 10 & 11)	B 29
B10	Peak Differential Pressures Between Valve Rooms and Main Steam Tunnel (Between Nodes 4 & 5, 11 & 12)	B 30
B11	Peak Differential Pressures Between Valve Rooms and Main Steam Tunnel (Between Nodes 4 & 6, 5 & 6, 11 & 8, 12 & 8)	B 31

1.0 PURPOSE AND SCOPE

The purpose of this appendix is to recalculate the peak differential pressures for the Byron and Braidwood Unit 1 main steam tunnels and valve rooms using the mass and energy releases of Reference B1 for the break locations defined in Section II of the main report. Reference B2 drawings will be reviewed to verify that there are no changes that would significantly affect the node and junction parameters calculated in Appendix A. Except for the use of the Reference B1 mass and energy releases, the RELAP4/MOD5 (Reference B3) computer models will be those used in previous revisions of the calculation.

2.0 DESIGN INPUT

- 2.1 The Reference B1 mass and energy release rates for the postulated main steam line rupture.
- 2.2 The Reference B2 mechanical and structural drawings.

3.0 ASSUMPTIONS

Assumptions and information used in this calculation are as noted in Section IV and V of the main report, except the mass and energy release rates for the postulated steam line rupture were taken from Reference B1.

4.0 APPROACH

The approach to this calculation is the same as that described in Section V.

(Method of Analysis) of the main report except:

- 4.1 The Sargent & Lundy drawings listed in Reference 5 of the main report were updated to include the Reference B2 drawings of this appendix as the basis for the computer model.

The Reference B2 drawings were reviewed to verify that there are no changes that would significantly affect the node and junction geometrical and flow parameters listed in Tables 1 and 2, respectively, of the main report.

- 4.2 The Reference B3 version of RELAP4/MOD5 was used to determine the pressure transients for the six cases, each having a different break location in the main steam tunnel.

- 4.3 The blowdown rates and average enthalpies are based on the mass and energy flows of Reference B1 and are presented in Table B1.

5.0 CALCULATIONS

5.1 Mass Energy Release

The Reference B1 mass and energy releases are presented in that reference as mass flows (lbm/sec) and energy flows (Btu/sec) for the single and triple loop. Per Reference B1, the single loop rates represents the mass and energy flows from the broken steam generator and the triple loop rates represent the mass and energy flows from the intact steam generator into the containment (prior to isolation). Per Reference B1, these rates should be combined for any subcompartment analysis. Therefore, in this calculation the break mass flow rate was set equal to the total of the single and triple loop values and an average enthalpy was used as input to the RELAP4 model as shown in Table B1. The average enthalpy was determined by summing the single and triple loop energy flow rates and dividing by the total mass flow rate.

5.2 Computer Runs

Six RELAP4/MOD5 (Reference B3) computer runs were made corresponding to the break locations described in Section II of the main report and shown schematically in Figures 1 and 2 of the main report. As in the main report Table of Contents of Computer Output (page 65), the computer run part numbers used in this appendix correspond to the same break locations:

5.2 Computer Runs (contd.)

<u>Part No.</u>	<u>Break Location</u>
1	Node 5
2	Node 6
3	Node 7
4	Node 8
5	Node 13
6	Node 14

The same computer model was used for each case, but the break node location was changed to correspond to Figure 2 of the main report.

5.3 Nodal Differential Pressures

For each node in the computer model the maximum nodal pressure was determined for each computer run. These maximum pressures were then compared as shown in Table B2 to determine the overall maximum pressure for each node. The maximum nodal differential pressures with respect to the areas surrounding the main steam tunnel and valve rooms were then obtained by subtracting atmospheric pressure (or the minimum transient node pressure) from the overall maximum pressure for each node (See Table B2).

These overall maximum nodal differential pressures along with the symmetry of the main steam tunnel areas was then used to determine the peak nodal differential pressures for this calculation.

5.4 Differential Pressure Across Internal Walls

For each wall/floor internal to the valve rooms and those separating the valve rooms from the main steam tunnel areas, the maximum differential pressure across these walls was calculated for each break location. These maximum wall differential pressures were then compared as shown in Table B3 to determine the overall maximum differential pressure across each wall.

These overall maximum wall/floor differential pressures along with the symmetry of the main steam tunnel areas was then used to determine the peak nodal differential pressures for this calculation.

6.0 RESULTS

The peak nodal differential pressures which represent the difference between steam tunnel/valve room nodes and the surrounding areas are presented in Table B4 and Figures B1 through B7. From this table and the figures it is seen that the highest peak nodal differential pressure of 17.7 psid occurs in the lower valve chambers.

The peak differential pressures across internal walls/floors are shown in Table B5 and Figures B8 through B11. From this table and the figures it is seen that the highest peak differential pressure of 14.4 psid is for the vertical wall separating the lower valve rooms from the main steam tunnel.

The results presented above for the main steam tunnel conservatively do not consider a path to the auxiliary feedwater (AFW) tunnel. The AFW tunnel lies beneath the main steam tunnel. If one or more hatches covering the four approximately 15 square foot ladder openings in the lower valve rooms are left open, however, flow paths from the main steam tunnel to the AFW tunnel do exist. Based on a review of drawing M-159, the largest high-energy lines in the AFW tunnel are 4-inch AFW system lines. The estimated mass flow from a double-ended guillotine break of these 4-inch lines is on the order of 50 to 60% of that from the MSLB as shown in Table B6. From that same table, it is also seen, however, that the enthalpy of

6.0 RESULTS (contd.)

the water in these 4-inch lines is quite small, so that the resulting total energy release is less than 4% of that from the MSLB. Because of this, nodal pressure differentials for the AFW tunnel would be bounded by those for the main steam tunnel.

In general the nodal differential pressures for Byron and Braidwood Unit1 determined in this Appendix are less than the Revision 2 results. The only exception is the nodal differential pressure for node 14 (the last segment of the MST that opens into the turbine building) which is 0.2 psid higher (less than 2%) than the Revision 2 results.

7.0 REFERENCES

B1. NDIIT No. 960136, "Steam Generator Replacement Project: Transmittal of SLB M&E for Steam Tunnel Pressure Analysis," Dated 9/16/96. (Attached)

B2. Sargent and Lundy Drawings:

<u>Drawing No.</u>	<u>Sheet No.</u>	Byron Braidwood <u>Revision</u>	Byron <u>Revision</u>	Braidwood <u>Revision</u>
M-159	1	M	-	-
M-159	2	D	-	-
M-159	3	J	-	-
M-160	1	L	-	-
M-187	1	L	-	-
M-188	1	L	-	-
S-688	1	-	AE	-
S-688	1	-	-	AE
S-758	1	-	J	-
S-758	1	-	-	K
S-762	1	-	W	-
S-762	1	-	-	W
S-765	1	-	K	-
S-765	1	-	-	K
S-895	1	-	AA	-
S-895	1	-	-	AD
S-896	1	-	U	-
S-896	1	-	-	W
S-899	1	-	W	-
S-899	1	-	-	W
S-900	1	-	W	-
S-900	1	-	-	Y
S-1056	1	-	Y	-
S-1056	1	-	-	AB

B2. Sargent and Lundy Drawings:(contd.)

<u>Drawing No.</u>	<u>Sheet No.</u>	<u>Byron Braidwood Revision</u>	<u>Byron Revision</u>	<u>Braidwood Revision</u>
S-1057	1	-	AK	-
S-1057	1	-	-	AS
S-1060	1	-	U	-
S-1060	1	-	-	Z
S-1061	1	-	Y	-
S-1061	1	-	-	AB
S-1062	1	-	U	-
S-1062	1	-	-	W

B3. User's Manual for RELAP4, "Nuclear Plant Transients," Sargent & Lundy
Program Number 03.7.407-1.0, April 14, 1993.

B4. Piping Line List from Sargrent & Lindy PDIS.

B5. Byron/Braidwood Stations Piping Design Table "907BB" Carbon Steel,
Rev. C, 12-31-84

B6. Crane Technical Paper No. 410, 1976.

B7. User's Manual for FLS, "Flood Level Simulator," Sargent & Lundy Program
Number 03.7.195-1.3, January 13, 1992.

B8. ASME Steam Tables.

8.0 ATTACHMENTS

Pages B_

1. NDIT No. 960136

32

40

Table B1 : Blowdown Rate and Enthalpy**For Ruptured Main Steam Line (Per Reference B1)**

Time (sec)	Flow (lbm/sec)	Enthalpy (Average) (Btu/lbm)
0	14189	1024.9
0.02	14189	1024.9
0.04	13883	1116.4
0.06	12901	1119.3
0.08	12479	1124.6
0.1	12342	1133
0.12	12250	1134
0.14	12093	1128.3
0.16	11827	1119.4
0.18	11434	1111.2
0.2	11022	1107.3
0.22	10642	1105.7
0.24	10315	1105.5
0.26	10041	1105.9
0.28	9810	1106.3
0.3	9608	1106.4
0.32	9424	1106.4
0.34	9255	1106.3
0.36	9097	1106.4
0.38	8954	1106.8
0.4	8827	1107.7
0.42	8728	1110.1
0.44	8633	1109.1
0.46	8558	1112.7
0.48	8522	1116.4
0.5	8512	1119.5
0.52	8523	1122.7
0.54	8553	1125.9
0.56	8598	1128.8
0.58	8652	1131.3
0.6	8709	1133.3
0.62	8765	1134.8
0.64	8813	1135.8
0.66	8852	1136.5
0.68	8879	1136.9
0.7	8894	1137.2
0.72	8898	1137.3
0.74	8892	1137.4
0.76	8878	1137.5
0.78	8875	1138.5

Table B1 (contd.): Blowdown Rate and Enthalpy**For Ruptured Main Steam Line (Per Reference B1)**

<u>Time</u>	<u>Flow</u>	<u>Enthalpy</u>
(sec)	(lbm/sec)	(Average) (Btu/lbm)
0.8	8846	1137.5
0.82	8816	1137.9
0.84	8788	1138.3
0.86	8761	1138.5
0.88	8733	1138.7
0.9	8705	1138.9
0.92	8679	1139.1
0.94	8655	1139.3
0.96	8632	1139.5
0.98	8611	1139.6
1	8591	1139.8
1.02	8573	1139.9
1.04	8557	1140.1
1.06	8542	1140.2
1.08	8529	1140.3
1.1	8518	1140.4
1.12	8508	1140.5
1.14	8499	1140.5
1.16	8492	1140.5
1.18	8486	1140.4
1.2	8481	1140.3
1.22	8477	1140.2
1.24	8473	1140
1.26	8471	1139.7
1.28	8468	1139.4
1.3	8466	1139
1.32	8465	1138.6
1.34	8463	1138.1
1.36	8462	1137.5
1.38	8462	1136.9
1.4	8461	1136.2

Table B2: Comparison of Maximum Calculated Node Pressures and Nodal Differential Pressures															
PART No.		Volume 2	Volume 3	Volume 4	Volume 5	Volume 6	Volume 7	Volume 8	Volume 9	Volume 10	Volume 11	Volume 12	Volume 13	Volume 14	
(Break		Average	Average	Average	Average	Average	Average	Average	Average	Average	Average	Average	Average	Average	
Location)		Pressure	Pressure	Pressure	Pressure	Pressure	Pressure	Pressure	Pressure	Pressure	Pressure	Pressure	Pressure	Pressure	
		(psia)	(psia)	(psia)	(psia)	(psia)	(psia)	(psia)	(psia)	(psia)	(psia)	(psia)	(psia)	(psia)	
PART 1	MIN	14.70	14.70	14.70	14.70	14.70	14.70	14.70	14.69	14.69	14.69	14.69	14.66	14.63	
(Node 5)	MAX	29.89	28.95	29.51	32.30	27.99	25.54	19.11	17.83	17.78	18.11	18.13	18.25	16.19	
PART 2	MIN	14.70	14.70	14.70	14.70	14.70	14.70	14.70	14.69	14.69	14.70	14.70	14.68	14.63	
(Node 6)	MAX	25.89	25.52	26.68	26.86	30.63	27.98	20.16	18.55	18.50	18.99	18.97	19.02	16.48	
PART 3	MIN	14.69	14.69	14.70	14.70	14.70	14.70	14.70	14.69	14.69	14.70	14.70	14.70	14.64	
(Node 7)	MAX	24.14	24.05	25.14	25.17	28.22	29.83	21.12	19.24	19.17	19.67	19.70	19.89	16.84	
PART 4	MIN	14.69	14.69	14.70	14.70	14.70	14.70	14.70	14.70	14.70	14.70	14.70	14.70	14.69	
(Node 8)	MAX	19.34	19.30	19.90	19.88	21.33	22.33	22.97	20.77	20.74	21.51	21.62	23.20	19.47	
PART 5	MIN	14.69	14.69	14.70	14.70	14.70	14.70	14.70	14.70	14.70	14.70	14.70	14.70	14.70	
(Node 13)	MAX	18.12	18.07	18.48	18.49	19.59	20.33	22.73	20.55	20.36	20.97	21.08	25.32	21.91	
PART 6	MIN	14.69	14.69	14.70	14.70	14.70	14.70	14.70	14.69	14.69	14.70	14.70	14.70	14.70	
(Node 14)	MAX	16.78	16.76	17.08	17.06	17.94	18.05	19.46	18.36	18.18	18.67	18.68	21.76	25.88	MIN
	MIN	14.69	14.69	14.70	14.70	14.70	14.70	14.70	14.69	14.69	14.69	14.69	14.66	14.63	14.63
	MAX	29.89	28.95	29.51	32.30	30.63	29.83	22.97	20.77	20.74	21.51	21.62	25.32	25.88	
DELTA P		15.3	14.3	14.9	17.7	16.0	15.2	8.3	6.1	6.1	6.9	7.0	10.7	11.3	

Table B3: Comparison of Calculated Maximum Internal Wall Differential Pressures													
		Junction 17	Junction 10	Junction 3	Junction 11	Junction 6	Junction 12	Junction 2	Junction 9	Junction 4	Junction 5	Junction 15	Junction 16
Between Nodes	2-3	9-10	3-4	10-11	4-5	11-12	2-5	9-12	4-6	5-6	11-8	12-8	
PART 1	1.63	0.02	3.51	0.00	0.00	0.04	12.50	0.00	4.88	14.40	0.01	0.01	
(NODE 5)*	5.48	0.12	2.11	0.83	13.20	0.06	0.00	0.75	0.00	0.00	1.42	1.37	
PART 2	0.03	0.03	3.80	0.00	0.17	0.04	3.82	0.00	0.00	0.00	0.00	0.00	
(NODE 6)*	0.46	0.13	0.00	0.91	0.17	0.07	0.00	0.83	10.41	10.41	1.68	1.63	
PART 3	0.02	0.03	1.71	0.00	0.06	0.04	1.54	0.00	0.00	0.00	0.00	0.00	
(NODE 7)*	0.23	0.15	0.00	1.03	0.10	0.08	0.00	0.92	4.33	4.25	2.01	1.95	
PART 4	0.02	0.03	0.98	0.00	0.03	0.11	0.90	0.00	0.00	0.00	0.00	0.00	
(NODE 8)*	0.12	0.30	0.00	1.87	0.06	0.13	0.00	1.88	2.18	2.13	4.84	4.84	
PART 5	0.02	0.03	0.87	0.00	0.03	0.10	0.80	0.00	0.00	0.00	0.00	0.00	
(NODE 13)*	0.12	0.28	0.00	1.36	0.06	0.12	0.00	1.37	1.65	1.59	4.24	4.24	
PART 6	0.02	0.03	0.72	0.11	0.03	0.09	0.66	0.09	0.00	0.00	0.65	0.71	
(NODE 14)*	0.10	0.21	0.00	0.83	0.05	0.10	0.00	0.83	1.09	1.04	2.57	2.57	
MAX Delta P	5.48	0.30	3.80	1.87	13.20	0.13	12.50	1.88	10.41	14.40	4.84	4.84	
(*)* - Break Node													

**Table B4: Peak Pressure Differentials - Main Steam Line
Breaks in Main Steam Tunnel or Valve Rooms**

Volume No.	Description	Break Location Volume No.	Calc. Peak Press. Diff. (psid)
1	Atmosphere	-	-
2	2nd Quadrant Upper Valve Chamber	5	15.3
3	2nd Quadrant Upper Valve Chamber	5	15.3
4	2nd Quadrant Lower Valve Chamber	5	17.7
5	2nd Quadrant Lower Valve Chamber	5	17.7
6	2nd Quadrant Main Steam Tunnel	6	16.0
7	Main Steam Tunnel	7	15.2
8	1st Quadrant Main Steam Tunnel	8	8.3
9	1st Quadrant Upper Valve Chamber	5**	15.3
10	1st Quadrant Upper Valve Chamber	5**	15.3
11	1st Quadrant Lower Valve Chamber	5**	17.7
12	1st Quadrant Lower Valve Chamber	5**	17.7
13	1st Quadrant Main Steam Tunnel	13	10.7
14	1st Quadrant Main Steam Tunnel	14	11.3

** Differential pressures calculated for 1st Quadrant valve chambers are also applicable to corresponding 2nd Quadrant valve chambers

TABLE B5: SUMMARY OF PEAK PRESSURES BETWEEN VALVE ROOMS AND MAIN STEAM TUNNEL					
WALL LOCATION BETWEEN NODES		DELTA P ACROSS		PEAK PRESSURE (PSID)	
2-3	9-10	VERT'L WALL		5.48	
3-4	10-11	HORZ'L FLOOR		12.50	
4-5	11-12	VERT'L WALL		13.20	
2-5	9-12	HORZ'L FLOOR		12.50	
4-6	5-6	MST VERT'L		14.40	
11-8	12-8	WALL			

TABLE B6: Comparison of MSLB in MST with 4" AFW Break in Auxiliary Feedwater Tunnel

Line Break Location	System	Nominal Diameter (Ref. B2, M-159)	Inside Diameter (Refs. B4, B5 & B6) (in)	Inside Area (Ref. B6) (ft ²)	Operating Temp. (Ref. B4) (°F)	Operating Pressure (Ref. B4) (psia)	Approx. Mass Flux (Ref. B3 & B7) (lbm/ft ² -sec)		Enthalpy (Ref. B8) (Btu/lbm)	Mass Flow (lbm/sec)	Energy Flow (Btu/sec)	% of MST Break Energy Flow (—)
MST (Ref B1)	MS	-	-	-	-	-	-	Maximum	1140.5	14189	1.55E+07	100
								Minimum	1024.9	8461	9.51E+06	100
AF Tunnel	AFW	4	3.624	0.07163	100	2080	34000	Maximum	73.5	4871	3.58E+05	2.31
								Minimum	73.5	4871	3.58E+05	3.76

**FIGURE B1: MAIN STEAM LINE BREAK IN LOWER SECOND QUADRANT VALVE ROOM
(NODE 5)**





FIGURE B2: MAIN STEAM LINE BREAK IN 2ND QUADRANT TUNNEL (NODE 6)


FIGURE B3: MAIN STEAMLINE BREAK IN 2ND & 1ST QUADRANT TUNNEL (NODE 7)


FIGURE B4: MAIN STEAM LINE BREAK IN 1ST QUADRANT OF TUNNEL (NODE 8)


FIGURE B5 : MAINTEAM LINE BREAK IN 1ST QUADRANT TUNNEL (NODE 13)




Figure B6 : Main Steam Line Break in 1st Quadrant of Main Steam Tunnel (Node 14)

FIGURE B7: MAIN STEAM LINE BREAK IN LOWER 2ND QUADRANT VALVE ROOM (NODE 5)

**FIGURE B8: PEAK DIFFERENTIAL PRESSURES BETWEEN VALVE ROOMS AND MAINSTREAM
TUNNEL (BETWEEN NODES 2 & 3, 9 & 10)**



**FIGURE B9: PEAK DIFFERENTIAL PRESSURES BETWEEN VALVE ROOMS AND MAIN
STEAM TUNNEL (BETWEEN NODES 3 & 4, 10 & 11, 2 & 5, 9 & 12)**




FIGURE B10: PEAK DIFFERENTIAL PRESURES BETWEEN VALVE ROOMS AND MAIN STEAM TUNNEL (BETWEEN NODES 4 & 5, 11 & 12)





FIGURE B11: PEAK DIFFERENTIAL PRESSURES BETWEEN VALVE ROOMS AND MAIN STEAM TUNNEL (BETWEEN NODES 4 & 6, 5 & 6, 11 & 8, 12 & 8)



NUCLEAR FUEL SERVICES DEPARTMENT NUCLEAR DESIGN INFORMATION TRANSMITTAL		
☒ SAFETY RELATED ☐ NON-SAFETY RELATED ☐ REGULATORY RELATED	Originating Organization ☒ Nuclear Fuel Services ☐ Other (specify) _____	NDIT No. <u>960136</u> Rev. No. <u>0</u> Page 1 of 1
Station <u>Byron/Braidwood</u> Unit <u>1</u> Cycle <u>9/8</u> Generic _____ To: <u>Bob Peterson (S&L)</u>		
Subject <u>Steam Generator Replacement Project: Transmittal of SLB M&E for Steam Tunnel Pressure Analysis</u>		
Amy Jo Patterson Preparer	<u>Amy Jo Patterson</u> Preparer's Signature	<u>9/16/96</u> Date
Candice Y. Chou Reviewer	<u>Candice Y. Chou</u> Reviewer's Signature	<u>9/16/96</u> Date
Kenneth N. Kovar NFS Supervisor	<u>Kenneth N. Kovar</u> NFS Supervisor's Signature	<u>9/16/96</u> Date
Status of Information: ☒ Verified ☐ Unverified ☐ Engineering Judgement		
Method and Schedule of Verification for Unverified NDITs: _____		
Description of Information: <u>Mass & Energy Release Rates following a postulated MSLB in the Main Steam Tunnel are provided.</u>		
Purpose of Information: <u>For use by S&L in the Main Steam Tunnel Pressure analysis to determining functional integrity of the steam tunnel following a postulated MSLB.</u>		
Source of Information <u>FTI Document 32-1258100-00, "SLB Subcompartment M&E."</u>		
Supplemental Distribution: NFS NDIT File DG Central File S. Berteau (S&L), w/o attachment M. Leutloff (Byron), w/o attachment S. Mullens (Braidwood), w/o attachment D. Rogowski, w/o attachment B. Waninski, w/o attachment J. Mattingly (Braidwood), w/o attachment H. S. Kim, w/o attachment D. Kruger (Byron) w/o attachment M. Spisak (Braidwood) w/o attachment		



DOCUMENT RELEASE NOTICE

(DRN)

RELEASE
DATERECORDS
MGMT. INITIALS

CONTRACT NUMBER 4100508		PLANT BYRON-1/BRAIDWOOD-1		CC OR CHARGE NUMBER 41010		PAGE 1 OF 1		
PART NO. OR TASK NO. (N/A If not applicable)	FTG DOCUMENT NUMBER	DOCUMENT TITLE (30 CHARACTER MAXIMUM)			SAFETY CLASSIF.	PUL STAT (Y/N)	COM ATT? (Y/N)	
14	32-1258100-00	SLB M&E for Subcompartment			S	N	Y	
					Calc. No. 3C8-0282-001			
					Revision : 3			
					Page No. B 33 of			
					Project Nos. 4391-00			
REQUIRED DISTRIBUTION (ORGANIZATION OR TE)		NO. COPIES			INFORMATION COPIES (INDIVIDUAL'S NAME)		NO. COPIES	
		DRN	DOC	COM			DRN	DOC
M.V. Parece		1	1					
W.L. Redd		2	2	2				
M.D. Ripley		1	1					
S.H. Estes (Original)								
RELEASED BY (PREPARED)					PROJECT MANAGEMENT FUNCTION APPROVAL:			
(SIGNATURE) <i>M.D. Ripley</i>					(SIGNATURE) <i>W.L. Redd</i>			8/16/96
(PRINTED NAME) M. D. RIPLEY		8/15/96			(PRINTED NAME) W.L. Redd			DATE
		DATE			REVIEWED BY:			
					(SIGNATURE) <i>M.V. Parece</i>			8/16/96
					(PRINTED NAME) M. V. Parece			DATE



CALCULATION SUMMARY SHEET (CSS)

DOCUMENT IDENTIFIER

32-1258100-00

TITLE

SLB Subcompartment M&E

PREPARED BY:

REVIEWED BY:

NAME M.D. Ripley

NAME M.V. Parece

SIGNATURE

SIGNATURE

TITLE Engineer IIR

DATE 8/15/96

TITLE Supervisory Engr I

DATE 8/16/96

COST CENTER 41010

REF. PAGE(S)

3

TM STATEMENT: REVIEWER INDEPENDENCE

PURPOSE AND SUMMARY OF RESULTS:

Commonwealth Edison is replacing the original steam generators (OSGs) at the Byron-1 and Braidwood-1 nuclear power plants with BWI replacement steam generators (RSGs). Part of this effort involves subcompartment analysis following high energy line breaks.

The purpose of this document is to determine and transmit the steam line break mass and energy release rates to be used by Sargent and Lundy for subcompartment analysis.

Calc. No. 3C8-0282-001

Revision : 3

Page No. B34 of

Project Nos. 4391-00

THE FOLLOWING COMPUTER CODES HAVE BEEN USED IN THIS DOCUMENT:

CODE/VERSION/REV

CODE/VERSION/REV

RELAP5/MOD2/20/0HP

THIS DOCUMENT CONTAINS ASSUMPTIONS
THAT MUST BE VERIFIED PRIOR TO USE
ON SAFETY-RELATED WORK



YES



NO

Purpose

The purpose of this document is to produce mass and energy release rates for the first 2-seconds following a steam line break for design input for Sargent and Lundy subcompartment analyses.

Method

The steam line break was performed in Reference 1 for the evaluation of mass and energy release rates to the containment building. The 102% power, MSIV failure case, double ended rupture case of Reference 1 was reproduced with increased minor edit frequency.

Evaluation

Case "SLBC1_1" from reference 1 was reproduced with a more frequent minor edit request and the end time set to 2.0 seconds:

203 152.0 1.0E-6 0.01 03 2 50 10000

*

* Minor Edits

301 MFLOWJ 856000000 * break A flow

302 MFLOWJ 858000000 * break B flow

303 UFLOWJ 856000000 * break A total enthalpy rate

304 UFLOWJ 858000000 * break B total enthalpy rate

With these changes, the case was renamed "SLBME" and executed using RELAP5/MOD2 Version 20.0HP. This case is a restart case, with the restart file documented in Reference 1 as case "SLBIC2" (HASH = FOQX).

Due to the initial high SG level of the base deck, the liquid quality out the break was plotted with time to assure that the swell from the SG does not cause liquid entrainment and a corresponding non-conservative reduction in mixture enthalpy from the break. From plots of the volume enthalpy of the steam dome and steam piping enthalpy shows the quality not decreasing significantly out the break until approximately 1.4 seconds. To provide a conservatively high energy rate, only values until 1.4 seconds should be used for subcompartment analysis, with the values at 1.4 seconds used for all later times if necessary.

Conclusion

The mass and energy release rates from a double-ended steam break at 102% power were generated for design input for subcompartment analysis. Only values prior to 1.4 seconds should be applied due to a possible non-conservatism due to the high initial water level of the steam generators. The mass and energy release rates are provided in the following table. The single loop rates represent the mass and energy flows from the broken steam generator. The triple loop rates represent the mass and energy flows from the intact steam generator into the containment (prior to steam line isolation). These rates should be combined for any subcompartment analyses.

Reference

1. FTI Document 32-1239267-00, "Byron/Braidwood SLB for Containment".

Microfiche Listing


<u>Title</u>	<u>HASH</u>	<u>Description</u>
SLBME	VNDG	Double-Ended SLB for Subcompartment M&E

**Mass and Energy Release Rates
Double-Ended SLAB at 100% Power**

TIME (SEC)	Single Loop Mass Flow (LB/SEC)	Triple Loop Mass Flow (LB/SEC)	Single Loop Energy Flow (BTU/SEC)	Triple Loop Energy Flow (BTU/SEC)
0.000	0.0	0.0	0.00000E+00	0.00000E+00
0.020	7117.5	7071.4	7.17672E+06	7.36495E+06
0.040	6877.9	7005.5	7.58499E+06	7.91457E+06
0.060	6564.0	6337.2	7.48887E+06	6.95145E+06
0.080	6489.9	5989.2	7.42525E+06	6.60814E+06
0.100	6489.3	5852.8	7.44343E+06	6.54072E+06
0.120	6471.2	5778.7	7.38963E+06	6.50233E+06
0.140	6339.2	5753.5	7.14948E+06	6.49439E+06
0.160	6076.6	5750.7	6.75264E+06	6.48682E+06
0.180	5733.5	5700.4	6.29299E+06	6.41231E+06
0.200	5374.0	5648.1	5.85325E+06	6.35126E+06
0.220	5044.0	5598.3	5.47312E+06	6.29397E+06
0.240	4763.7	5551.1	5.16257E+06	6.24023E+06
0.260	4533.4	5507.8	4.91230E+06	6.19199E+06
0.280	4342.5	5467.5	4.70633E+06	6.14679E+06
0.300	4179.5	5428.7	4.52844E+06	6.10252E+06
0.320	4032.9	5391.4	4.36714E+06	6.06002E+06
0.340	3898.0	5356.5	4.21751E+06	6.02111E+06
0.360	3771.8	5325.4	4.07775E+06	5.98765E+06
0.380	3653.7	5300.2	3.94793E+06	5.96267E+06
0.400	3543.9	5283.5	3.82855E+06	5.94953E+06
0.420	3442.7	5285.4	3.72017E+06	5.96867E+06
0.440	3350.3	5282.6	3.62242E+06	5.95269E+06
0.460	3266.4	5291.1	3.53443E+06	5.98732E+06
0.480	3190.3	5332.1	3.45585E+06	6.05856E+06
0.500	3121.6	5390.6	3.38559E+06	6.14376E+06
0.520	3059.4	5463.8	3.32258E+06	6.24649E+06
0.540	3003.1	5550.1	3.26594E+06	6.36420E+06
0.560	2951.9	5645.9	3.21461E+06	6.49069E+06
0.580	2905.3	5746.6	3.16808E+06	6.61963E+06
0.600	2862.9	5846.5	3.12613E+06	6.74439E+06
0.620	2824.4	5940.4	3.08823E+06	6.85815E+06
0.640	2789.4	6023.8	3.05404E+06	6.95607E+06
0.660	2757.8	6093.8	3.02322E+06	7.03688E+06
0.680	2729.2	6149.5	2.99549E+06	7.09912E+06
0.700	2703.4	6190.5	2.97062E+06	7.14331E+06
0.720	2680.2	6217.5	2.94828E+06	7.17090E+06
0.740	2659.2	6232.6	2.92817E+06	7.18522E+06
0.760	2640.3	6237.4	2.91004E+06	7.18799E+06
0.780	2623.5	6251.8	2.89392E+06	7.21018E+06
0.800	2608.4	6237.9	2.87940E+06	7.18321E+06
0.820	2594.6	6221.6	2.86626E+06	7.16576E+06
0.840	2582.2	6206.2	2.85434E+06	7.14929E+06
0.860	2570.9	6189.6	2.84354E+06	7.13016E+06
0.880	2560.7	6171.8	2.83373E+06	7.10962E+06
0.900	2551.4	6153.8	2.82482E+06	7.08915E+06
0.920	2543.0	6136.2	2.81671E+06	7.06942E+06
0.940	2535.3	6119.4	2.80933E+06	7.05071E+06

0.960	2528.3	6103.6	2.80262E+06	7.03303E+06
0.980	2522.0	6088.7	2.79653E+06	7.01639E+06
1.000	2516.3	6074.7	2.79103E+06	7.00084E+06
1.020	2511.1	6061.8	2.78611E+06	6.98646E+06
1.040	2506.6	6050.0	2.78178E+06	6.97331E+06
1.060	2502.7	6039.2	2.77808E+06	6.96137E+06
1.080	2499.5	6029.4	2.77499E+06	6.95057E+06
1.100	2496.9	6020.6	2.77254E+06	6.94076E+06
1.120	2495.0	6012.5	2.77073E+06	6.93179E+06
1.140	2493.9	6005.1	2.76957E+06	6.92348E+06
1.160	2493.6	5998.3	2.76906E+06	6.91568E+06
1.180	2494.0	5991.8	2.76920E+06	6.90821E+06
1.200	2495.3	5985.5	2.76996E+06	6.90091E+06
1.220	2497.3	5979.4	2.77132E+06	6.89363E+06
1.240	2500.1	5973.2	2.77325E+06	6.88617E+06
1.260	2503.8	5966.9	2.77575E+06	6.87836E+06
1.280	2508.2	5960.1	2.77882E+06	6.87000E+06
1.300	2513.4	5952.9	2.78244E+06	6.86091E+06
1.320	2519.4	5945.1	2.78660E+06	6.85098E+06
1.340	2526.7	5936.6	2.79158E+06	6.84014E+06
1.360	2534.9	5927.4	2.79730E+06	6.82844E+06
1.380	2544.0	5917.6	2.80368E+06	6.81598E+06
1.400	2554.0	5907.3	2.81090E+06	6.80293E+06


COMED SLB INSIDE CONTAINMENT
102% POWER, 4.4ft2, MSIV failure



Calc. No. 3C8-0282-001
Revision : 3
Page No. B 39 of
Project Nos. 4391-00

32-1258100-00

COMED SLB INSIDE CONTAINMENT
102% POWER, 4.4ft2, MSIV failure



Calc. No. 3C8-0282-001
Revision : 3
Page No. B40 of
Project Nos. 4391-00

COMPUTER DISK DIRECTORY

Volume in drive C is PC1240
Volume Serial Number is 192B-43CE
Directory of C:\BB\MSTU1

.	<DIR>	10-21-96	11:00a
..	<DIR>	10-21-96	11:00a
part1	inp	7567 09-18-96	11:30a
part1	out	1535287 09-06-96	9:03a
part2	inp	7567 09-06-96	10:32a
part2	out	1535311 09-06-96	11:22a
part3	inp	7565 09-06-96	1:11p
part3	out	1535309 09-06-96	3:01p
part4	inp	7560 09-06-96	3:15p
part4	out	1535695 09-09-96	11:14a
part5	inp	7568 09-05-96	10:54a
part5	out	1535773 09-05-96	11:35a
part6	inp	7568 09-05-96	2:13p
part6	out	1535773 09-05-96	3:00p
14 file(s)		9258543 bytes	
		4345856 bytes free	

Standard configuration
Mon 10-21-1996 13:22
C:\BB\MSTU1>

MICROFICHE OF COMPUTER OUTPUT