



SEP 13 2017

L-2017-152
10 CFR 50.55a
10 CFR 50.36

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Re: St. Lucie Unit 2
Docket No. 50-389
Refueling Outage SL2-23
Steam Generator Tube Inspection Report

Attached is the St. Lucie Unit 2 Technical Specification 6.9.1.12 steam generator tube inspection report for the spring 2017 refueling outage (SL2-23). This submittal was made within 180 days after the initial entry into hot shutdown following the completion of the steam generator inspection that was performed in accordance with TS 6.8.4.1, Steam Generator (SG) Program.

Please contact Ken Frehafer at (772) 467-7748 should you have any questions regarding this submittal.

Sincerely,

A handwritten signature in black ink that reads 'Michael J. Snyder'.

Michael J. Snyder
Licensing Manager
St. Lucie Plant.

MJS/dlc

Enclosure with 6 appendices (A- F): SL2-23 Steam Generator Tube Inspection Report
(88 Pages)

Enclosure

SL2-23 Steam Generator Tube Inspection Report

Introduction:

The enclosed Steam Generator (SG) Tube Inspection Report for St. Lucie Unit 2 is submitted for the inspection of the RSGs during refueling outage 23 (hereafter referred to as the SL2-23 inspection/outage), as required by Technical Specification section 6.9.1.12. Per the St. Lucie Unit 2 Technical Specification section 6.8.4.1.1.d, the first sequential period is 144 EFPMs. The inspection in SL2-23 was performed in accordance with Technical Specification 6.8.4.1.1, and was the fifth inspection of the RSGs in the first sequential period. References to prior SG Tube Inspection Reports of the RSGs are tabulated in Appendix A along with a list of acronyms and abbreviations used in this report.

At unit shutdown for the SL2-23 inspection, the RSGs had operated for approximately 7.69 EFPY (92.3 EFPM) since replacement in December 2007. This included operation for approximately 1.32 EFPY (15.82 EFPM) during the fuel cycle (cycle 22) leading-up to the SL2-23 inspection. Initial entry into Hot Shutdown following completion of the SL2-23 inspection was made on March 18, 2017.

St. Lucie Unit 2 is a Combustion Engineering 2-loop PWR with Model 86/19TI RSGs manufactured by AREVA. The RSGs were fabricated using thermally-treated Inconel 690 tubing. Each RSG contains 8,999 U-tubes; each tube has a nominal OD of 0.75" and a nominal wall thickness of 0.0429". The tubes have a tri-pitch arrangement and are supported by broached tube support plates (TSPs). The inspection of the RSGs during the SL2-23 outage meets the requirements of the St. Lucie Unit 2 Technical Specifications and the EPRI SGMP: PWR Steam Generator Examination Guidelines, Revision 7.

A. Scope of Inspections Performed on each SG

Primary-side:

- 100% full-length bobbin probe examination of all active tubes.
- Array probe examination at TTS locations of all tubes in hot and cold leg tube expansion transitions of peripheral high-flow regions, and low-row tubes along the tube-free lane. (Peripheral tubes in each RSG span the 2 outermost tubes (of each row) exposed to the annulus, and all tubes in Rows 1-4 along the tube-free lane.) The exam extent was +/- 3.0" from the TTS.
- Array probe examination of all tubes with previously-identified PLP Indications based on +Point™ exams, and adjacent tubes.
- 30% sample of tight-radius U-bends of Rows 1 & 2 using the +Point™ probe. The exam extent was from the uppermost TSP on the hotleg to the uppermost TSP on the cold leg.
- Diagnostic +Point™ examination at special interest locations as required based on the results of the bobbin coil and array coil data.
- Selected wear indications were profiled with line-by-line sizing to provide additional information for condition monitoring and operational assessment purposes.
- Visual inspection of all installed tube plugs in each RSG.
- Visual inspection of channel-head of each RSG per Westinghouse NSAL 12-1 "Steam Generator Channel Head Degradation" January 5, 2012.

Secondary-side:

- Upper bundle flush, sludge lancing and foreign object search and retrieval (FOSAR) in each RSG.
- Visual inspection of select components of the Upper Internals section of both RSGs, including the feedwater ring and supports.

B. Active degradation mechanisms found

Wear at tube support locations was the only active (existing) degradation mechanism identified during the SL2-23 RSG inspection. This degradation mechanism was found on tubes at the following tube support locations:

- Wear at anti-vibration bar (AVB) contact points
- Wear at V-shaped support pad (V-SSP) contact points¹
- Wear at tube support plate (TSP) contact points

No degradation was identified that was due to foreign objects or to corrosion degradation mechanisms. No evidence of tube-to-tube wear was found.

C. Nondestructive examination techniques utilized for each degradation mechanism

Table 1 is a list of the EPRI Examination Technique Specification Sheets (ETSS) used for degradation detection/sizing during the SL2-23 inspection.

Table 1

NDE Technique		Degradation Mechanism			ETSS detection/sizing
		Location/Description	Status	Type	
1	Bobbin	Wear at AVB and TSP Supports (extended for detection of V-shaped Support Pad and V-shaped Support Bar wear)	Existing	Volumetric	96004.1 Rev. 13
2	Bobbin	Wear at AVB and TSP Supports	Existing	Volumetric	96004.3 Rev. 13
3	Bobbin	Foreign Object Wear (PLP)	Potential	Volumetric	27091.2 Rev. 2
4	Bobbin	Tube-to-tube Wear	Potential	Volumetric	13091.1 Rev. 0
5	+Point™				13901.1 Rev 1
6	Array ²	Wear at Broached Support Plates	Existing	Volumetric	11956.3 Rev 2, 11956.4 Rev 2
7	+Point™				96910.1 Rev. 10
8	+Point™	Wear at AVB Supports (extended for detection of V-SSP)	Existing	Volumetric	10908.4, Rev. 1
9	+Point™	Volumetric Freespan	Not Potential	Volumetric	21998.1 Rev. 4
10	+Point™	PLP Wear (morphology dependent) ³	Potential	Volumetric	27901.1 Rev 1, 27902.1 Rev 2, 27903.1 Rev 1, 27904.1 Rev 2, 27905.1 Rev 2, 27906.1 Rev 1, 27907.1 Rev 2

¹ Wear at V-SSPs is also commonly called "appui" wear. Clarification of V-SSP Wear is documented in the St. Lucie Unit 2 Response to RAIs #10 & 11 (NRC ADAMS Accession No. ML15190A336) on the SL2-21 SG Tube Inspection Report.

² Array exam extended for detecting foreign object (FO) wear at the TTS and freespan, and for detecting FOs.

NDE Technique		Degradation Mechanism			ETSS detection/sizing
		Location/Description	Status	Type	
11	+Point™	Wear at V-Shaped Support Structure (V-SSP)	Existing	Volumetric	See footnotes ^{3, 4}
12	Array	Circumferential ODSCC at the TTS and Expansion Transitions ²	Not Potential	Circumferential	20400.1 Rev 5

D. Location, orientation (if linear), and measured sizes (if available) of service induced indications

The actual listing of service-induced indications identified during the SL2-23 inspection is attached in Appendix B thru F of this report, per the index table below (Table 2a). Unless noted otherwise, each Appendix contains Indications for both SG-2A and SG-2B.

Table 2a - Indexed listing of Indications

Description	Appendix	No. of Pages
Bobbin; All TSP Wear	B	4
+Point™; Wear at V-shaped support pads (V-SSP)	C	2
Bobbin; AVB U-bend Apex Wear ⁵ (AV4/5, AV3/6)	D	2
Bobbin; AVB Wear ≥40% TWD	E	2
Bobbin; AVB Wear 20-39%, 1-19% TWD	F	72

Table 2b summarizes the number of tubes and indications associated with wear at AVBs and TSPs. In Appendix D (AVB U-Bend Apex wear), 15 of the 23 tubes in SG-2A and 8 of the 13 tubes in SG-2B also had typical AVB wear elsewhere and are listed in Appendix F.

Table 2b - AVB/TSP Wear Tubes and Indications

Location	SG 2A		SG 2B	
	No. of		No. of	
	Tubes	Indications	Tubes	Indications
AVBs	2622	8883	2051	6050
TSPs	139	178	137	165

E. Number of tubes plugged during the inspection outage for each active degradation mechanism

The number of tubes plugged for each active degradation mechanism is summarized below in Table 3:

³ ETSS 27905.1 Rev. 1 was used in SL2-21 to provide supplemental V-SSB wear sizing information. ETSSs 27901.1 thru 27907.1 (all Rev 1) have been extended for sizing V-SSB wear.

⁴ Site specific qualification for V-SSP wear per AREVA (proprietary) document 51-9193913, "Appui Wear Detection and Sizing Site Qualification".

⁵ Note: AV4/5 and AV3/6 AVB U-bend Apex wear occur on tubes in Rows 69 and 40, respectively. Additional info on AVB U-bend Apex wear is documented in the St. Lucie Unit 2 Response to RAI #10 in NRC ADAMS document, ML15190A336.

Table 3 - Tubes Plugged during SL2-23 inspection outage

Reason for Plugging	SG 2A	SG 2B	Total
AVB Wear \geq 40% - Tech Spec limit	17	0	17
AVB Wear < 40% - preventive plugging ⁶	21	0	21
AVB U-bend Apex Wear (AV4/5, AV3/6) ⁷	0	0	0
PLP indications - preventive plugging	0	0	0
Wear at V-shaped support pad (V-SSP)	0	0	0
TSP Wear	0	0	0
Total	38	0	38

F. Total number and percentage of tubes plugged to date

The total number and percentage of tubes plugged to-date in each SG is summarized below in Table 4:

Table 4 - Cumulative Tube Plugging Summary following the SL2-23 Inspection

SG	Total Plugged	% Plugged
2A	298	3.31%
2B	40	0.44%

G. The results of condition monitoring, including the results of tube pulls and in-situ testing

All SG tubes inspected during the SL2-23 outage satisfied the condition monitoring (CM) requirements for structural and leakage integrity. No evidence of corrosion degradation was found, and no indications were found to exceed structural limits.

1. The largest TSP Wear indication in each SG was 26% TWD. All detected TSP wear indications fell well below the CM limit for burst and leakage. The +Point™ voltages for all indications were less than 3.0 volts, confirming the burst and leakage integrity for the tubes and in situ pressure testing is not required. No tube required plugging or were preventively plugged due to TSP Wear. The list of TSP Wear indications identified in SL2-23 is provided in Appendix B.
2. Four (4) wear indications were identified in SL2-23 which were associated with V-shaped support pad (V-SSP) locations. Each of the 4 indications were previously-identified. As previously, the V-SSP indications were sized with a qualified sizing technique, and the tubes were returned to service based on a plug-on-NDE sizing assessment (See NDE Technique #11 of Table 1). For each indication, the observed wear was shallow in depth and short in length, showed no growth from the previous inspection (SL2-22), and met the CM margin requirements. No wear indications were identified on tubes *adjacent* to V-SSP location (known as v-shaped support bars or V-SSBs). The list of V-SSP indications is provided in Appendix C.
3. During the primary side examinations, no damage was detected from possible loose parts (PLPs) on the secondary-side of the tubes in any SG. In SG-2A, loose part signals (LPS) reported for 2 adjacent peripheral tubes (near the TTS in the CL) using the array probe, were not confirmed when inspected using the +Point™ probe. In addition, no foreign objects were identified in that location when visually examined during FOSAR exams. In SG-2B, PLP

⁶ These additional tubes were selected for preventive plugging based on a chosen criteria. This preventive measure allows for additional margins on wear rates, and to limit the likelihood that CM screening limits would be exceeded during the next scheduled inspection (SL2-24).

⁷ The SG AVB arrangement for St. Lucie 2 is shown in Figure 2 of document with NRC ADAMS Accession No. ML14279A237.

signals reported on 3 adjacent tubes during array probe exams (near the TTS in the CL), were confirmed using the +Point™ probe. The object was visually confirmed to be a small sludge rock during secondary side inspection (SSI), but was not removed since it had not caused (and had no potential to cause) tube wear. No degradation/wear was detected on any tube (or bounding tubes) having a LPS or PLP indication during the SL2-23 inspection. These tubes remain in service.

4. AVB U-bend Apex wear was detected using the bobbin probe on some tubes in Row 69 of both SGs, and 1 tube in Row 40 of SG-2A. Row 69 and Row 40 are located just below the AV4/5 and AV3/6 design depth locations, respectively. Prior to the SL2-23 inspection, U-bend Apex wear had only been identified in Row 69 tubes; the indication in Row 40 is the first occurrence of AVB U-bend Apex wear in this row. The highest recorded indications of AVB U-bend Apex wear (AV4/5) was 33% TWD in SG 2A and 9% TWD in SG 2B. The highest growth of previously-identified AVB U-bend Apex wear indications was 4% TWD since the previous inspection (SL2-22). The AVB U-bend Apex wear (AV3/6) indication in SG-2A measured 6% TWD. No indication of AVB U-bend Apex Wear met the criteria for preventive plugging. AVB U-bend Apex Wear indications are provided in Appendix D.
5. Seventeen (17) tubes in SG 2A were reported as having AVB Wear of 40% TWD or greater. The tubes were plugged based on exceeding the plugging limits in Technical Specifications. The highest AVB wear indication measured 43% TWD. No AVB Wear indications \geq 40% TWD were identified in SG 2B. The list of AVB Wear indications \geq 40% TWD is provided in Appendix E. A number of AVB Wear indications (with $<$ 40% TWD) were identified during the SL2-23 inspection. To provide added margin on wear rates and to limit the likelihood that the CM screening limits would be exceeded during the next scheduled inspection (SL2-24), twenty-one (21) additional tubes (all in SG-2A) were selected for "preventive plugging" based on a developed criteria comprised of indication depths, growth rates and/or number of indications on the tubes. A complete listing of AVB Wear indications (with $<$ 40% TWD) is provided in Appendix F. All detected wear at AVB supports met the required integrity margins for CM, whether sized by bobbin or +Point™, therefore AVB wear indications met the CM requirements for burst and leakage.
6. Although industry operating experience described in Westinghouse NSAL 12-01 is not directly applicable to St. Lucie Unit 2, supplemental visual inspection of the primary-side channel head bowl (in both SGs) was performed in accordance with the recommendations presented in NSAL 12-01. All previously-installed tube plugs (HL and CL) were visually inspected during the SL2-23 inspection outage. All plugs were confirmed to be in their correct locations, and showed no visible signs of leakage based on the visual examination. No degradation of the tube plugs, tubesheets or primary-side channel head bowl areas were noted apart from that incurred during a historical foreign object event in SG-2B⁸. No corrosion-related degradation was identified on any of the SG channel head components.
7. Secondary-side inspection activities comprised of visual inspection of select areas of the Upper Internals section of both SGs, including the feedwater rings and supports, and the loose-part trapping screens in each SG. A sample of the primary moisture separators, instrumentation / water-level taps, chevrons, drains and hatches were also visually examined. No damage or deficiencies were observed in the Upper Internals section of the SGs during the SL2-23 inspection. Top-of-tubesheet sludge lancing performed after upper bundle flush (UBF) in each SG, removed 46 and 60 lbs. of sludge from SG-2A and SG-2B, respectively. In SG-2B, a small piece of aluminum shaving (approx. 1-in x 1/8-in) was identified/removed from the CL TTS location during FOSAR. The bounding tubes showed no signs of wear during array probe inspections.

⁸ This event is described in Section G Item #8 of the SL2-22 SG Tube Inspection Report (NRC ADAMS Accession No. ML16111B235).

In summary, all wear indications detected (AVBs, V-SSP and TSP locations) met CM requirements. Therefore, no tubes required in-situ pressure testing for either tube burst or leakage based on the SL2-23 inspections. All tubes met the structural and leakage integrity requirements of the St. Lucie Unit 2 Technical Specifications. No tube pulls were required.

H. The effective plugging percentage for all plugging in each SG

No tube repair methods (i.e. sleeving) are approved for St. Lucie Unit 2 that would have an effect on the effective plugging percentages. Therefore, the applicable effective plugging percentage is synonymous with the % Plugged in "Item F" above.

APPENDIX A - Additional Information

References to Prior SG Tube Inspection Reports

SG ISI #	EOC	Outage	NRC ADAMS Accession No.
1	EOC-17	SL2-18	ML093230226
2	EOC-18	SL2-19	ML11270A015
3	EOC-19	SL2-20	ML13141A479
4	EOC-20	SL2-21	ML14279A237
5	EOC-21	SL2-22	ML16111B235

Abbreviations and Acronyms

AVB	Anti-Vibration Bar	OD	Outside Diameter
CL	Cold Leg	ODSCC	Outside Diameter Stress Corrosion Cracking
CM	Condition Monitoring	PLP	Possible Loose Part
EOC22	End-of-cycle 22 (SL2-23 inspection)	RSG	Replacement Steam Generator
EFPM	Effective Full Power Months	SG	Steam Generator
EFPY	Effective Full Power Years	SSI	Secondary Side Inspection
EPRI	Electric Power Research Institute	TSP	Tube Support Plate
ETSS	Exam Technique Specification Sheet	TTS	Top of Tubesheet
FO	Foreign Object	TWD	Through Wall Depth
HL	Hot Leg	V-SSB	V-Shaped Support Bar wear (side bar wear)
ISI	In-service Inspection	V-SSP	V-Shaped Support Pad wear (appui wear)
LPS	Loose Part Signal	WAR	Mechanical Wear

Appendix B: TSP Wear

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin TSP Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
1	2	12	04C +0.42	35	118	7	02H -0.35	108	111	7	03C -0.70
		12	04H -0.70	37	6	9	04C +0.00	109	34	10	04H -0.70
1	62	17	04C +0.36	47	162	7	05C +0.56			15	04H +0.51
1	80	13	06C -0.67	48	9	8	04C +0.44	109	40	11	04H -0.67
1	82	11	05C -0.61	53	158	11	05C +0.46	109	42	6	07C -0.84
		10	05C +0.40	54	159	9	05C +0.44	110	39	9	04H +0.49
1	86	12	05C +0.31	55	14	6	04H -0.64	110	43	6	04H -0.67
		9	05C -0.76	57	10	7	04C +0.46	111	36	11	04H -0.65
		13	04C +0.31	57	14	6	04H +0.00			9	07H -0.70
		9	04C -0.67	58	157	9	05C +0.44			8	07H +0.44
1	92	10	04C +0.38	59	160	8	05C +0.49	111	38	10	04H +0.48
		11	02C -0.59	60	157	9	05C -0.64	113	38	7	04H -0.65
1	96	8	02C +0.44	60	159	7	05C +0.56	116	41	9	04H -0.67
1	140	8	06C -0.74	62	85	6	03H -0.64	117	42	7	04H +0.44
		12	04C +0.36	63	156	13	05C -0.64	117	128	5	03C -0.70
		15	04C -0.75	64	157	11	05C +0.54	119	42	9	04H -0.65
		8	05C -0.74	67	156	13	05C +0.65			9	05H -0.69
1	154	11	05C +0.34	68	157	9	05C -0.62	119	44	7	05H -0.72
		14	05C -0.78	69	16	6	05H +0.51	120	45	9	04H +0.50
		6	04C +0.40	70	151	14	05C +0.53	120	111	5	05C +0.37
1	156	8	04C +0.42	72	155	12	05C +0.42	121	124	9	05C -0.75
1	160	15	05C -0.76	73	18	7	04H -0.55	122	45	6	04H -0.64
		13	04C -0.75	74	71	12	07C +0.11			5	04H +0.51
1	162	15	05C -0.78	75	22	8	04H -0.65	122	47	7	05H -0.62
1	168	9	05C +0.38	77	18	8	04H +0.44	124	49	8	04H -0.53
		14	05C -0.74	77	20	12	04H -0.57	127	100	6	05C +0.37
		18	04C +0.40	79	22	4	04H -0.67	129	80	8	05C +0.48
		9	04C -0.71	79	26	5	04H -0.62	129	96	13	05C +0.51
2	1	6	06H -0.83	79	130	7	04C +0.51	129	114	9	06H -0.67
		8	05C +0.40	80	17	13	04H -0.07	130	57	6	04H -0.64
		15	05C -0.67	81	18	9	04H -0.62	131	92	12	05C +0.46
		12	04C +0.40			19	04H +0.48	131	104	6	04C +0.37
2	91	11	04C -0.75			10	05H -0.64	131	108	8	03C +0.39
2	97	8	02C +0.40	86	21	16	04H -0.53	131	110	9	05C -0.70
2	121	10	04C +0.34			7	05H -0.66			8	03C +0.39
3	2	11	04H -0.74	87	26	5	04H -0.62	134	103	13	05H +0.51
3	8	8	04H +0.44	87	28	5	06H -0.67	134	105	10	05H +0.48
		12	04H -0.76	88	25	14	04H -0.65	135	78	8	04C -0.62
3	158	10	05C -0.78			15	04H +0.48	136	77	10	03H +0.39
3	168	5	05C +0.36	89	22	19	04H +0.46	138	83	8	05H +0.00
		9	05C -0.70			7	04H -0.64				
		13	04C +0.40	90	23	10	04H -0.59				
4	5	9	04C +0.40	90	33	7	05H -0.84				
4	73	6	04C +0.34			10	04H -0.71				
4	143	7	04C -0.59	92	25	8	04H +0.50				
4	151	7	04C -0.75	92	27	6	04H +0.67				
5	82	6	03H +0.37	92	29	11	04H +0.55				
5	164	8	05C +0.38	93	26	10	04H -0.65				
		9	05C -0.78	93	34	6	04H -0.67				
5	168	12	05C -0.74	94	31	7	04H +0.53				
6	7	8	04C +0.37	94	37	8	04H -0.65				
6	9	8	04H -0.65	95	36	8	04H -0.67				
6	169	10	04C -0.69	96	27	9	07H -0.67				
7	2	8	04C +0.39	96	29	13	04H -0.56				
7	92	5	04C +0.35	96	31	10	04H -0.65				
		6	01C +0.44	98	143	9	07H -0.67				
10	1	4	04H -0.55	99	28	8	04H -0.65				
10	3	7	04C -0.72			11	04H +0.56				
10	9	8	04H +0.50	99	30	13	04H -0.63				
12	141	10	04C -0.83	100	29	5	06H -0.58				
13	2	7	04H -0.62	100	31	10	05H -0.53				
14	13	6	04H -0.64	102	39	9	04H -0.70				
14	167	6	05C -0.78			8	04H +0.53				
17	2	9	04H +0.48	103	32	15	04H +0.48				
18	91	4	03C -0.67			15	04H -0.65				
30	9	5	05C -0.77	106	43	5	04H -0.62				
30	17	7	03H -0.60	106	45	8	04H -0.67				
31	66	6	02C +0.35	108	39	11	04H -0.65				

Total Tubes : 138
 Total Records: 176

Appendix B: TSP Wear

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin TSP Wear 20-39%

ROW	COL	%TW	LOCATION
2	1	26	04C -0.65
2	7	22	04C -0.67

ROW COL %TW LOCATION

ROW COL %TW LOCATION

Total Tubes : 2
Total Records: 2

Appendix B: TSP Wear

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin TSP Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
1	32	9	04C -0.71	78	19	11	07C -0.81				
1	56	13	05C -0.76	81	152	12	04H +0.47	133	106	7	04C -0.77
1	70	12	05C -0.63			10	05H +0.38	133	108	8	04H +0.45
1	82	19	05C +0.29	86	21	19	04H +0.49	134	65	13	07H +0.41
		11	04C +0.34	86	27	6	04H +0.50			8	05C +0.37
1	84	19	05C +0.27	86	141	6	05C +0.34	134	71	9	06C +0.28
1	110	8	04C -0.71	87	22	7	04H +0.48	134	83	11	03C -0.64
1	116	13	05C -0.78	89	144	9	03C -0.73	134	89	8	04H +0.48
1	148	14	05C -0.76	91	70	9	07C -0.86	134	91	12	07C +0.18
1	154	11	05C +0.31	93	146	6	05H -0.67	135	70	10	06C +0.28
1	166	14	06C +0.30	99	142	13	06C +0.21			12	05C +0.35
1	168	15	04C +0.34			8	05H -0.62	135	74	10	04H +0.51
		9	05H -0.78			9	05C -0.70	136	71	10	05C +0.37
2	7	13	05C +0.29	100	141	8	05H -0.63	136	73	11	05C +0.33
2	21	10	05C -0.21	104	139	10	06C -0.74	136	77	9	04H +0.45
2	63	10	04C +0.33	106	33	5	04H -0.62			9	05C +0.30
		14	04C -0.69	107	60	10	05C +0.25			10	03C -0.69
		7	03C +0.38	107	62	9	05C -0.65	136	91	9	04C -0.59
2	69	10	04C -0.76	108	137	10	04C -0.58	137	82	12	07C +0.22
2	75	9	02C +0.38			7	05C +0.42	137	92	9	04C +0.39
2	89	7	05C -0.76			11	05C -0.75	138	73	13	04H +0.41
2	91	8	05C -0.74	109	56	8	07C -0.65			6	05C +0.39
2	95	6	05C -0.73	112	37	8	04H -0.48	138	79	8	05C +0.30
2	113	5	05C -0.73	113	54	6	05C -0.68			12	03C -0.69
2	115	9	05C +0.29	113	60	7	05C +0.35	138	81	9	03C -0.69
2	159	5	04C +0.40	114	45	8	04C +0.37	139	86	9	06C -0.66
2	169	11	06C +0.36	115	56	5	06C +0.30			7	06C +0.39
		14	05C +0.34	116	131	18	05C -0.73				
3	30	8	05C -0.75	117	50	5	04H -0.64				
3	52	9	05C -0.79	118	41	13	04H -0.62				
3	168	11	03C -0.69			9	06C +0.26				
10	53	8	05H +0.39	120	127	10	04C +0.37				
11	80	10	04C +0.39	121	46	8	06C +0.26				
16	3	8	04H +0.48	121	48	7	05C -0.51				
17	36	8	05C +0.30	121	126	19	04C -0.65				
17	82	5	05C +0.34	122	51	14	06C -0.68				
18	167	5	05H -0.62	122	107	10	04C -0.59				
20	17	13	04H +0.48	123	46	5	04H -0.62				
20	167	9	05H -0.68			8	05C -0.64				
22	45	9	04H -0.62	123	50	10	06C +0.28				
		11	04C -0.76			10	06C -0.79				
22	85	7	01C -0.67	124	51	13	06C -0.81				
22	125	12	03C -0.76			6	04H -0.55				
31	10	8	04C -0.63	124	55	9	05C -0.73				
36	5	8	04C -0.77	124	57	8	05C -0.73				
39	8	10	04C -0.73	124	101	9	04C -0.63				
42	7	11	04C -0.72	124	103	7	04C -0.72				
44	7	12	04C -0.70	125	54	11	06C -0.76				
44	15	8	04C +0.33	126	51	5	04H -0.63				
45	8	8	04C -0.74	126	75	8	03C -0.71				
51	20	6	04H +0.42	126	113	10	04H +0.44				
54	13	9	04C -0.72	127	58	7	06C -0.81				
55	160	7	04H -0.62	127	70	10	03C -0.76				
		6	05H -0.48	128	73	11	04H +0.46				
61	12	7	04C -0.70	129	78	8	03C -0.59				
61	160	11	05C +0.37	129	104	9	04C -0.67				
66	153	11	05C +0.30	130	57	10	07H +0.43				
67	14	12	04C -0.67	130	63	10	04H +0.49				
68	19	7	07C -0.83	130	67	9	05C +0.40				
		9	03C -0.70	130	99	14	04C -0.73				
68	151	5	05H -0.69	130	103	7	04H +0.00				
70	13	9	04C +0.35	131	82	9	03C -0.69				
		11	04C -0.72	131	96	11	04C -0.73				
72	19	6	07C -0.79	131	98	9	06C +0.42				
74	15	9	05C +0.00	131	106	8	04H +0.47				
75	18	10	05C +0.00	133	66	10	07C -0.73				
75	72	8	04H -0.62	133	76	11	05C +0.37				
77	152	6	05C +0.34	133	102	9	04H -0.62				

Total Tubes : 137
 Total Records: 163

Appendix B: TSP Wear

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G B

03/17 - EOC22
Bobbin TSP Wear 20-39%

ROW	COL	%TW	LOCATION
1	82	21	05C -0.78
1	168	26	05C +0.00

ROW	COL	%TW	LOCATION
-----	-----	-----	----------

ROW	COL	%TW	LOCATION
-----	-----	-----	----------

Total Tubes : 2
Total Records: 2

VPAD (V-SSP) Indications

Appendix C: V-shaped support pad (V-SSP) Wear

QUERY: QueryM2[1] .qry

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	UTIL 1	LEG
120	43	0.12	86	P6	WAR		AV7 +23.76	16	COLD
135	102	0.13	95	P7	WAR		AV3 +0.96	17	HOT

Total Tubes : 2
Total Records: 2

Note: the "UTIL 1" entries represent %TWD values.

VPAD (V-SSP) Indications

Appendix C: V-shaped support pad (V-SSP) Wear

QUERY: QueryM2[1] .qry

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	UTIL 1	LEG
110	135	0.24	95	P6	WAR		AV8 -1.60	25	COLD
112	133	0.23	97	P6	WAR		AV8 -1.20	24	COLD

Total Tubes : 2
Total Records: 2

Note: the "UTIL 1" entries represent %TWD values.

03/17 - EOC22
Bobbin AVB Wear in AVB Transition Row Tubes (Crossover Tubes)

QUERY: QueryM2[1] .qry

ROW	COL	%TW	LOCATION
40	145	6	AV3 +1.13
69	74	15	AV4 +1.42
69	98	13	AV4 +0.08
69	100	20	AV4 +0.99
69	102	27	AV4 +1.36
69	104	17	AV4 +0.11
69	106	33	AV4 +0.56
69	108	32	AV4 +0.57
69	110	15	AV4 +1.36
69	112	24	AV4 +1.30
69	114	9	AV4 -0.11
69	116	4	AV4 +1.53
69	118	8	AV4 +1.16
69	120	8	AV4 +1.20
69	122	7	AV4 +1.20
69	124	6	AV4 +1.20
69	126	6	AV4 +0.03
69	128	6	AV4 +0.00
69	130	7	AV4 +1.04
69	132	4	AV4 +1.05
69	136	7	AV4 +0.17
69	138	7	AV4 +0.06
69	144	9	AV4 +0.15

Total Tubes : 23
Total Records: 23

03/17 - EOC22
Bobbin AVB Wear in AVB Transition Row Tubes (Crossover Tubes)

QUERY: QueryM2[1] .qry

ROW	COL	%TW	LOCATION
69	18	7	AV4 +1.49
69	20	6	AV4 +1.30
69	24	6	AV4 +1.35
69	36	5	AV4 +1.19
69	44	6	AV4 +1.65
69	46	5	AV4 +1.42
69	52	5	AV4 +1.50
69	56	6	AV4 +1.37
69	62	9	AV4 +1.49
69	78	9	AV4 +1.49
69	84	5	AV4 +0.88
69	92	6	AV4 +1.52
69	98	8	AV4 +0.65

Total Tubes : 13
Total Records: 13

Appendix E: AVB Wear (>= 40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 40-100%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
79	100	40	AV3	+0.11							
83	90	42	AV6	+0.00							
84	93	40	AV6	+0.09							
84	99	40	AV4	+0.10							
		40	AV5	+0.09							
		42	AV6	+0.09							
85	98	40	AV4	+0.13							
87	104	41	AV3	+0.00							
91	104	40	AV5	+0.00							
93	86	41	AV5	+0.00							
95	92	42	AV6	+0.00							
98	91	41	AV6	+0.00							
99	90	40	AV7	+0.00							
99	92	41	AV7	+0.00							
		42	AV6	+0.00							
100	93	41	AV6	+0.00							
106	81	41	AV6	+0.00							
126	91	40	AV5	+0.00							
127	82	43	AV7	+0.00							
138	91	40	AV6	+0.00							

Total Tubes : 17
Total Records: 20

Appendix E: AVB Wear (>= 40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G B

03/17 - EOC22
Bobbin AVB Wear 40-100%

ROW COL %TW LOCATION

ROW COL %TW LOCATION

ROW COL %TW LOCATION

Total Tubes : 0
Total Records: 0

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
24	167	7	AV7 +0.00								
25	166	11	AV7 +0.20	40	161	6	AV7 -0.23	45	156	5	AV7 +0.18
26	19	6	AV1 -0.09	40	163	6	AV1 +0.16		7		AV6 +0.20
27	4	7	AV7 +0.36	41	6	7	AV7 +0.00	45	158	7	AV8 +0.09
27	164	7	AV7 +0.00	41	8	7	AV2 +0.00		8		AV6 +0.00
29	4	6	AV2 -0.16			7	AV8 +0.00	45	160	8	AV7 +0.11
		6	AV7 +0.00	41	158	7	AV8 +0.13		7		AV2 -0.19
29	6	7	AV8 +0.00			7	AV7 -0.26	45	162	8	AV8 -0.25
29	166	5	AV7 +0.24	41	162	13	AV2 +0.20		6		AV7 +0.00
30	5	6	AV2 +0.00	41	164	8	AV7 -0.20		12		AV6 +0.18
31	164	6	AV7 +0.00			9	AV2 -0.23		5		AV3 +0.00
31	166	10	AV7 +0.00	42	7	10	AV7 +0.28		10		AV2 -0.16
		8	AV2 +0.00	42	9	8	AV2 +0.00		6		AV1 -0.22
		6	AV1 +0.00			6	AV3 -0.27	46	7	8	AV3 -0.20
32	163	6	AV7 -0.33			10	AV7 -0.19		18		AV6 +0.25
33	6	8	AV2 +0.00	42	159	7	AV7 +0.00		10		AV7 +0.23
		11	AV7 +0.00	42	161	7	AV8 +0.00	46	9	6	AV2 -0.16
		7	AV8 +0.00			15	AV6 +0.00		10		AV6 +0.26
33	8	8	AV2 +0.00			6	AV7 +0.11	46	11	8	AV2 -0.12
33	162	5	AV2 +0.00			8	AV7 -0.34		8		AV3 -0.18
33	164	10	AV7 +0.19	42	163	6	AV8 +0.00		8		AV6 +0.24
		12	AV2 -0.23			10	AV7 +0.00		8		AV7 +0.23
34	5	8	AV7 +0.31			13	AV2 +0.25	46	13	6	AV2 +0.00
34	7	7	AV7 +0.00	43	6	6	AV2 +0.00	46	35	6	AV3 +0.26
34	163	6	AV7 +0.00			5	AV3 +0.00	46	141	7	AV6 +0.00
		7	AV2 +0.00			6	AV6 +0.37	46	157	6	AV6 -0.49
34	165	7	AV7 +0.00			10	AV7 +0.00		5		AV1 -0.20
35	6	7	AV7 -0.23			7	AV8 +0.24	46	159	9	AV7 +0.11
35	8	7	AV7 +0.25	43	8	6	AV1 +0.28		8		AV6 +0.13
35	162	6	AV2 -0.23			6	AV6 +0.32	46	161	7	AV7 +0.00
35	164	10	AV7 +0.00			9	AV7 +0.20		17		AV6 +0.16
36	7	8	AV2 -0.21	43	124	5	AV2 +0.00		11		AV2 -0.12
		8	AV7 +0.27	43	154	6	AV6 +0.21	46	163	6	AV8 +0.00
36	161	6	AV7 +0.14			9	AV3 -0.29		12		AV7 +0.00
36	163	5	AV2 -0.25	43	158	5	AV6 +0.16		9		AV6 +0.00
36	165	7	AV7 +0.20	43	160	7	AV1 -0.07		7		AV2 +0.00
37	6	7	AV7 +0.29	43	162	5	AV7 +0.17	47	8	7	AV2 +0.05
37	8	8	AV7 +0.00			10	AV6 +0.22		10		AV3 -0.20
37	158	7	AV7 -0.30	43	164	8	AV7 +0.18		12		AV6 +0.26
37	162	7	AV8 +0.09			7	AV6 +0.32		11		AV7 +0.22
		6	AV2 +0.00			6	AV2 -0.21		7		AV8 +0.04
		8	AV7 +0.15	44	7	6	AV1 +0.00	47	10	7	AV7 +0.21
		6	AV7 -0.38			8	AV2 -0.16	47	12	6	AV8 -0.14
37	164	7	AV7 -0.05			11	AV3 -0.20	47	44	7	AV3 +0.00
38	5	7	AV7 +0.00			12	AV6 +0.30	47	142	6	AV6 +0.00
38	7	7	AV2 -0.14			9	AV7 +0.27	47	154	9	AV6 +0.16
		11	AV7 +0.27	44	9	7	AV2 -0.12		17		AV3 -0.27
38	9	7	AV1 +0.05			7	AV3 -0.18	47	160	7	AV8 -0.25
		7	AV2 -0.14			6	AV6 +0.30		7		AV7 +0.12
		7	AV7 -0.20			10	AV8 -0.16		7		AV6 +0.13
		9	AV8 -0.13	44	11	6	AV2 -0.14		12		AV2 -0.21
38	11	7	AV2 -0.11			7	AV8 -0.11		7		AV1 +0.14
		7	AV7 -0.20	44	141	7	AV6 -0.42	47	162	18	AV6 +0.20
38	161	7	AV7 +0.00	44	153	7	AV6 -0.48		8		AV3 -0.27
		6	AV2 +0.00	44	157	9	AV7 -0.22		9		AV2 -0.21
38	163	8	AV7 +0.00	44	159	7	AV7 -0.25		9		AV8 -0.23
		9	AV2 +0.00	44	161	11	AV6 +0.20	48	7	10	AV3 +0.00
38	165	11	AV7 +0.00	44	163	7	AV8 -0.25		12		AV6 +0.29
		6	AV1 -0.22			9	AV6 +0.22		8		AV7 +0.00
39	6	12	AV2 -0.14			9	AV2 +0.18	48	9	10	AV2 +0.00
		9	AV7 +0.29			6	AV1 +0.00		10		AV3 +0.00
39	8	9	AV7 +0.20	45	8	5	AV2 +0.00		11		AV6 +0.00
39	10	8	AV7 +0.20			7	AV6 +0.00		8		AV7 +0.00
39	162	11	AV7 +0.14			8	AV7 +0.00		7		AV8 +0.00
		6	AV2 -0.21	45	12	6	AV2 -0.12	48	11	7	AV2 +0.00
39	164	10	AV7 +0.00	45	14	5	AV3 +0.00		11		AV7 +0.23
		11	AV2 +0.00	45	120	6	AV3 -0.29	48	13	7	AV2 +0.00
40	7	10	AV2 -0.18	45	130	6	AV6 +0.20		6		AV3 +0.00
		10	AV7 +0.25	45	142	8	AV6 +0.17	48	35	9	AV3 +0.25
40	9	13	AV7 +0.00	45	154	7	AV6 +0.00	48	141	7	AV6 -0.40

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION
48	147	10	AV6 -0.14
48	153	7	AV6 -0.51
48	157	5	AV6 +0.26
48	159	6	AV7 +0.15
		7	AV3 +0.23
48	161	12	AV7 +0.17
		18	AV6 +0.20
		12	AV2 -0.19
		5	AV1 +0.14
48	163	9	AV7 -0.27
		6	AV2 -0.25
49	8	6	AV2 +0.00
		9	AV3 +0.00
		7	AV6 +0.00
		6	AV7 +0.00
49	10	9	AV2 -0.11
		8	AV3 -0.16
		6	AV6 +0.22
		11	AV7 +0.18
49	12	8	AV2 -0.09
		8	AV3 -0.07
		9	AV8 +0.05
49	16	7	AV3 +0.36
		13	AV6 +0.00
49	22	6	AV2 +0.00
49	26	6	AV3 +0.00
49	34	7	AV3 -0.13
49	128	6	AV3 -0.25
49	142	6	AV6 +0.16
49	144	7	AV3 +0.20
49	154	9	AV3 +0.00
49	156	7	AV7 +0.12
49	158	6	AV7 -0.25
		7	AV6 -0.43
		7	AV3 +0.29
49	160	6	AV8 -0.27
		10	AV7 +0.07
		10	AV2 -0.21
49	162	7	AV7 +0.00
		12	AV6 +0.00
		5	AV3 +0.00
		11	AV2 +0.00
50	7	6	AV2 +0.30
		8	AV3 -0.21
		11	AV6 +0.26
		9	AV7 +0.29
50	9	7	AV2 -0.16
		11	AV3 -0.18
		12	AV6 +0.27
		9	AV7 +0.23
		7	AV8 +0.09
50	11	16	AV2 -0.09
		7	AV3 -0.16
		8	AV6 +0.22
		10	AV7 +0.23
50	13	5	AV6 +0.00
		6	AV2 +0.00
		5	AV3 +0.00
50	15	9	AV3 -0.05
		6	AV7 -0.13
		7	AV8 -0.09
50	19	7	AV3 -0.07
50	45	5	AV3 +0.00
50	111	7	AV6 +0.00
50	125	6	AV3 +0.00
50	137	7	AV6 +0.00
50	147	7	AV6 +0.14
50	153	9	AV6 +0.00
		14	AV3 +0.00
50	155	15	AV6 -0.39

ROW	COL	%TW	LOCATION
50	157	8	AV7 -0.27
		6	AV6 +0.00
50	159	8	AV7 +0.11
		8	AV6 +0.16
		7	AV3 +0.00
		9	AV2 -0.14
50	161	11	AV7 +0.14
		14	AV6 +0.14
		9	AV6 -0.45
		8	AV3 +0.23
		9	AV2 -0.16
		6	AV1 -0.20
50	163	13	AV7 +0.00
		10	AV6 +0.00
		6	AV3 +0.00
51	8	11	AV3 -0.20
		11	AV6 +0.27
		6	AV8 +0.00
51	10	8	AV2 -0.14
		8	AV6 +0.24
		7	AV7 +0.23
		8	AV8 +0.18
51	12	7	AV3 +0.14
51	16	5	AV2 -0.11
		10	AV6 -0.22
		8	AV7 +0.00
		7	AV8 +0.00
51	18	10	AV3 +0.19
51	34	6	AV3 +0.00
51	102	8	AV6 +0.00
51	108	6	AV6 +0.15
51	128	6	AV3 +0.00
51	144	10	AV3 +0.19
51	154	4	AV7 +0.10
		10	AV6 +0.16
		15	AV3 -0.25
51	156	10	AV7 +0.00
		11	AV6 +0.00
51	158	7	AV7 +0.15
		6	AV6 -0.28
51	160	10	AV8 -0.24
		10	AV7 +0.15
		8	AV3 +0.06
		17	AV2 -0.23
		7	AV1 -0.02
51	162	10	AV7 -0.02
		14	AV3 -0.27
		7	AV3 +0.25
		17	AV2 -0.18
		12	AV1 -0.20
52	9	10	AV2 -0.14
		16	AV3 -0.21
		12	AV6 +0.22
		9	AV7 +0.25
52	11	7	AV8 +0.05
		15	AV7 +0.12
		12	AV6 +0.12
		8	AV2 -0.27
52	13	10	AV2 -0.11
		8	AV6 +0.24
		6	AV7 -0.18
		8	AV8 -0.11
52	15	9	AV7 +0.00
		8	AV8 +0.00
52	17	7	AV2 -0.11
		7	AV3 -0.11
		9	AV6 +0.13
		7	AV8 +0.05
52	35	10	AV3 +0.34
		5	AV6 -0.27

ROW	COL	%TW	LOCATION
52	111	6	AV3 -0.18
52	121	8	AV3 +0.14
52	141	11	AV6 -0.35
52	145	5	AV2 +0.09
		6	AV1 -0.05
52	147	7	AV6 -0.08
52	149	6	AV6 +0.11
52	151	8	AV7 -0.18
52	153	16	AV6 -0.33
		15	AV3 +0.25
52	155	6	AV6 +0.16
52	157	6	AV6 +0.16
52	159	7	AV7 +0.19
		11	AV2 -0.23
		6	AV1 -0.23
52	161	8	AV7 -0.25
		19	AV6 -0.36
		15	AV6 +0.18
		11	AV2 -0.23
		7	AV1 -0.22
53	8	15	AV2 +0.36
		13	AV3 -0.18
		8	AV6 +0.27
		7	AV8 +0.04
53	10	6	AV1 +0.28
		11	AV2 -0.16
		5	AV3 -0.16
		11	AV6 +0.20
		9	AV7 +0.21
53	12	7	AV2 -0.16
		9	AV3 +0.08
		9	AV8 -0.14
53	20	7	AV3 -0.14
53	34	8	AV3 -0.05
		8	AV6 +0.13
53	44	6	AV3 +0.00
53	54	4	AV3 +0.00
53	102	6	AV6 +0.12
53	110	6	AV3 -0.21
53	124	8	AV3 -0.02
53	128	8	AV3 -0.18
53	130	6	AV6 +0.07
53	136	4	AV6 +0.00
53	142	12	AV6 +0.16
53	144	9	AV7 +0.09
		9	AV3 +0.22
53	148	6	AV7 -0.09
		7	AV6 +0.00
53	154	11	AV6 +0.00
		12	AV3 +0.00
53	156	8	AV8 -0.24
		15	AV7 +0.19
		11	AV6 +0.16
53	158	7	AV8 +0.00
		13	AV7 +0.00
53	160	6	AV8 -0.25
		12	AV7 +0.07
		7	AV3 -0.23
		10	AV2 -0.24
53	162	12	AV7 -0.41
		8	AV3 +0.00
54	9	7	AV2 -0.21
		17	AV6 +0.25
		13	AV7 -0.18
		10	AV8 +0.25
54	11	11	AV7 +0.16
		11	AV6 +0.07
54	13	13	AV6 +0.00
		9	AV7 +0.00
		8	AV8 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
54	15	5	AV2 -0.14	55	142	9	AV6 +0.00	18			AV6 +0.18
		9	AV3 -0.18	55	144	8	AV3 +0.18	8			AV2 +0.18
54	19	6	AV3 -0.16	55	148	6	AV6 -0.19	57	10	6	AV1 -0.18
54	39	6	AV3 +0.08	55	154	7	AV6 +0.16			11	AV2 -0.14
54	101	8	AV6 -0.21			12	AV3 -0.21			7	AV3 -0.18
54	105	6	AV3 +0.00			5	AV1 +0.14			9	AV6 +0.22
54	109	10	AV3 +0.00	55	156	10	AV7 +0.00			8	AV7 +0.21
54	111	6	AV6 +0.00			7	AV6 +0.00	57	12	6	AV3 +0.16
54	119	6	AV6 +0.00			9	AV1 +0.00	57	14	6	AV2 +0.00
54	121	7	AV6 +0.00	55	158	14	AV7 +0.18			8	AV3 +0.00
		6	AV3 +0.00			10	AV6 -0.37			6	AV6 +0.00
54	125	6	AV2 +0.00			7	AV3 +0.37	57	18	7	AV2 +0.07
54	135	10	AV7 +0.00	55	160	10	AV7 -0.05			8	AV3 -0.07
		6	AV6 +0.00			13	AV6 -0.32			6	AV8 -0.11
54	137	6	AV2 +0.00			14	AV2 -0.23	57	20	10	AV3 -0.12
54	139	7	AV6 +0.00			11	AV1 +0.16	57	22	8	AV3 +0.00
54	141	11	AV6 -0.39			5	AV3 -0.23	57	28	7	AV3 -0.18
54	143	5	AV6 +0.00	56	9	11	AV3 -0.21	57	44	6	AV3 -0.11
54	145	6	AV7 +0.09			10	AV7 +0.25	57	100	6	AV3 +0.10
54	147	10	AV6 +0.14			6	AV8 +0.25			8	AV6 +0.23
54	153	8	AV3 +0.00	56	11	9	AV8 +0.09	57	102	9	AV6 +0.17
		6	AV6 +0.11			13	AV7 -0.07	57	104	7	AV6 +0.00
54	155	6	AV6 +0.00			19	AV6 -0.16	57	108	7	AV6 +0.00
		6	AV1 +0.00			11	AV3 +0.00	57	110	6	AV7 -0.10
54	157	12	AV6 +0.07			11	AV2 -0.33	57	112	7	AV6 +0.00
		15	AV3 -0.18			7	AV1 -0.20	57	116	7	AV3 +0.00
		7	AV2 -0.17			8	AV6 +0.18			18	AV6 +0.00
		6	AV1 +0.12	56	13	6	AV3 +0.00	57	120	8	AV6 -0.05
54	159	8	AV8 -0.25			6	AV6 +0.00			9	AV3 -0.28
		14	AV7 +0.13			6	AV8 +0.00	57	124	6	AV6 +0.16
		6	AV3 -0.25	56	15	7	AV3 +0.18	57	126	8	AV7 -0.07
		10	AV2 -0.17			6	AV6 +0.00			8	AV6 +0.14
		9	AV6 +0.14			7	AV7 +0.02	57	128	5	AV6 +0.14
		10	AV6 -0.32			7	AV8 -0.11			7	AV3 -0.19
55	10	13	AV2 -0.14	56	17	8	AV2 +0.09	57	136	6	AV7 +0.00
		10	AV3 +0.08			9	AV3 +0.16			9	AV6 +0.00
		13	AV6 -0.30			13	AV6 +0.02	57	138	9	AV6 -0.05
		9	AV6 +0.25			7	AV7 +0.09			7	AV3 +0.00
		12	AV7 -0.18			10	AV8 +0.05	57	142	6	AV7 -0.09
		8	AV7 +0.25	56	19	7	AV3 -0.05			10	AV6 +0.16
55	12	7	AV1 -0.09	56	25	8	AV3 +0.21	57	144	6	AV3 +0.24
		8	AV2 -0.12	56	33	6	AV6 +0.18	57	148	9	AV6 +0.07
		10	AV3 +0.19	56	35	8	AV3 +0.44	57	154	8	AV6 +0.00
		7	AV6 +0.22	56	43	7	AV3 +0.00			13	AV3 +0.00
		6	AV7 +0.05			6	AV6 +0.00			8	AV1 +0.00
		9	AV8 -0.11	56	111	8	AV6 -0.16	57	156	4	AV8 -0.22
55	14	10	AV3 +0.00	56	113	6	AV2 -0.23			11	AV7 +0.19
		9	AV6 +0.00	56	121	7	AV7 -0.07			7	AV6 +0.14
		11	AV7 +0.00			10	AV6 -0.11			8	AV1 +0.14
		7	AV8 +0.00			6	AV3 +0.08	57	158	8	AV8 -0.14
55	16	8	AV2 -0.14	56	123	7	AV6 +0.14			8	AV7 +0.00
		7	AV3 -0.09			6	AV3 -0.28			13	AV3 +0.00
		15	AV6 +0.00	56	125	6	AV2 -0.05			12	AV2 +0.00
		9	AV7 +0.00	56	127	7	AV6 +0.07	57	160	13	AV7 -0.05
		9	AV8 +0.00	56	137	9	AV7 -0.02			10	AV3 +0.29
55	20	8	AV3 -0.02	56	143	11	AV3 -0.14			9	AV2 -0.19
55	26	6	AV3 +0.00	56	147	9	AV7 -0.28			8	AV1 -0.22
55	34	6	AV6 -0.18			13	AV6 -0.38			8	AV6 +0.12
		6	AV3 -0.11	56	149	9	AV6 -0.34			10	AV6 -0.39
55	38	5	AV3 -0.14			7	AV3 +0.21	58	9	12	AV3 -0.18
55	108	6	AV6 +0.12	56	153	7	AV6 -0.08			9	AV6 +0.27
55	112	7	AV6 +0.12			10	AV3 +0.26			16	AV7 -0.18
55	116	8	AV6 -0.05	56	155	7	AV8 -0.26			9	AV8 +0.27
55	118	7	AV3 +0.00	56	157	7	AV6 +0.16	58	11	8	AV1 -0.16
55	120	7	AV3 +0.00			6	AV1 -0.02			13	AV2 -0.16
55	122	7	AV7 +0.00	56	159	5	AV8 +0.16			15	AV6 +0.00
		6	AV6 +0.00			11	AV7 +0.18			19	AV7 +0.00
55	128	7	AV3 +0.00			14	AV2 -0.23			12	AV8 -0.09
55	130	6	AV6 +0.00			10	AV1 -0.20	58	13	6	AV1 +0.00
55	134	7	AV6 +0.00	56	161	11	AV7 -0.23			6	AV3 -0.14

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		10	AV6 +0.00			14	AV3 +0.10			9	AV2 -0.16
		8	AV7 +0.02			7	AV2 -0.18			9	AV3 +0.28
58	15	6	AV1 +0.23			10	AV1 -0.02			14	AV6 +0.00
		6	AV2 +0.23			7	AV2 +0.02			12	AV7 +0.00
		7	AV7 +0.02			10	AV3 +0.08			11	AV8 +0.23
		6	AV8 -0.09	59	14	11	AV6 +0.00	60	13	8	AV2 +0.00
58	17	11	AV3 -0.07			7	AV7 +0.02			7	AV3 +0.00
		8	AV8 -0.14			8	AV8 -0.07			12	AV6 +0.00
58	19	8	AV6 +0.00			7	AV1 -0.09			7	AV8 +0.00
		8	AV7 +0.00	59	16	16	AV6 +0.02	60	15	6	AV3 +0.23
		7	AV8 +0.00			8	AV3 +0.00			10	AV6 -0.20
58	25	5	AV3 +0.00	59	18	8	AV3 +0.00	60	17	7	AV2 -0.16
58	35	8	AV3 +0.38	59	20	9	AV3 -0.18			6	AV3 -0.16
		8	AV6 -0.15	59	22	5	AV8 +0.20			6	AV8 -0.14
58	43	6	AV6 -0.13	59	24	7	AV2 +0.12			7	AV3 +0.20
58	73	7	AV6 +0.00			7	AV3 +0.20	60	21	8	AV6 -0.18
58	75	6	AV6 +0.00	59	26	7	AV2 -0.07	60	31	10	AV6 +0.00
		6	AV7 +0.00	59	34	6	AV3 -0.05			6	AV7 +0.00
58	101	6	AV6 -0.03			5	AV6 +0.20	60	33	6	AV6 +0.00
58	109	6	AV6 +0.00	59	44	6	AV3 +0.00	60	53	5	AV6 +0.23
58	113	10	AV7 +0.00	59	58	6	AV6 +0.00	60	61	11	AV6 +0.00
		7	AV2 +0.00	59	68	9	AV3 +0.00	60	67	9	AV3 +0.00
58	115	6	AV3 +0.00			9	AV6 +0.00			7	AV6 +0.00
58	117	5	AV2 +0.00			7	AV7 +0.00			6	AV7 +0.00
58	119	6	AV3 +0.00	59	76	5	AV6 +0.00	60	103	5	AV3 -0.05
58	121	7	AV6 +0.00	59	84	10	AV6 +0.00			6	AV2 -0.05
58	125	6	AV6 +0.00			13	AV7 +0.00	60	109	8	AV7 -0.07
		7	AV3 +0.00			8	AV8 +0.00			7	AV6 -0.13
		6	AV2 +0.00	59	100	6	AV6 +0.22			10	AV3 -0.07
58	127	6	AV6 +0.00	59	102	9	AV6 +0.00	60	111	6	AV6 -0.10
58	129	8	AV3 +0.00			7	AV3 +0.00	60	121	10	AV6 -0.08
		8	AV2 +0.00	59	104	7	AV6 +0.02			6	AV3 +0.05
58	133	7	AV6 -0.38			7	AV3 +0.00	60	123	7	AV6 -0.13
58	137	7	AV3 +0.03	59	106	8	AV6 -0.08	60	129	6	AV7 -0.02
58	141	9	AV7 +0.00	59	108	7	AV6 +0.05			8	AV6 -0.30
58	145	9	AV6 -0.05			8	AV3 -0.02	60	135	11	AV7 +0.00
		8	AV3 -0.02	59	110	14	AV6 +0.00			12	AV6 +0.00
		7	AV1 -0.02			16	AV3 +0.00	60	137	12	AV7 -0.05
58	147	10	AV3 -0.02			9	AV2 +0.00			10	AV6 -0.08
		7	AV7 -0.23	59	116	8	AV6 -0.08	60	141	8	AV7 -0.02
		7	AV6 -0.05	59	118	7	AV3 +0.00			14	AV6 -0.28
58	151	9	AV7 -0.12	59	120	8	AV3 +0.00	60	145	6	AV8 -0.23
58	153	8	AV6 +0.00	59	124	6	AV6 +0.00			6	AV7 -0.07
		6	AV3 +0.00	59	128	6	AV6 +0.00	60	147	7	AV6 +0.20
		6	AV1 +0.00	59	132	6	AV7 +0.00	60	149	7	AV6 -0.10
58	155	8	AV8 -0.20	59	140	9	AV2 +0.02	60	151	9	AV3 +0.05
		10	AV6 +0.00	59	142	9	AV6 +0.00	60	153	10	AV8 -0.05
		6	AV2 -0.21			9	AV2 +0.00			11	AV7 -0.09
		6	AV1 -0.20	59	144	8	AV2 -0.09			11	AV3 +0.03
58	157	6	AV6 +0.00	59	148	9	AV6 -0.13	60	155	6	AV7 +0.12
		6	AV3 -0.11			7	AV3 +0.00			7	AV1 -0.23
		7	AV2 +0.00			8	AV2 -0.02	60	157	8	AV8 +0.15
		8	AV1 -0.18			4	AV1 +0.14			13	AV3 -0.18
58	159	7	AV7 +0.11	59	150	11	AV3 +0.03			7	AV1 -0.23
		9	AV6 +0.18			7	AV2 +0.00	60	159	7	AV8 +0.16
		15	AV3 +0.23	59	152	8	AV6 -0.31			11	AV7 +0.18
		8	AV1 -0.20			8	AV3 +0.03			12	AV6 +0.21
58	161	11	AV7 -0.25			7	AV2 +0.11			14	AV3 +0.15
		16	AV6 +0.16			5	AV1 -0.23			8	AV2 -0.23
		10	AV6 -0.42	59	154	7	AV6 +0.14			14	AV1 -0.23
		8	AV3 -0.18			11	AV3 -0.18	61	10	6	AV2 +0.00
59	10	7	AV1 -0.16			6	AV1 -0.23			12	AV3 -0.14
		11	AV2 -0.18	59	156	9	AV8 -0.18			17	AV6 +0.22
		13	AV3 -0.18			11	AV7 +0.16			10	AV8 +0.22
		9	AV6 +0.23			13	AV6 +0.00			6	AV7 +0.00
		7	AV7 +0.25			7	AV1 +0.00	61	12	5	AV6 -0.36
		12	AV8 +0.23	59	160	6	AV8 +0.16			7	AV3 +0.23
59	12	13	AV8 -0.18			9	AV7 -0.28	61	14	8	AV2 +0.00
		16	AV7 -0.27			9	AV3 +0.23			8	AV3 +0.00
		16	AV6 -0.31			13	AV2 +0.16			7	AV6 +0.00
				60	11	7	AV1 -0.14			9	AV7 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
61	16	13	AV8 +0.00	62	11	10	AV3 -0.23	63	14	7	AV6 -0.30
		9	AV6 +0.00			10	AV8 +0.23			9	AV3 +0.00
		9	AV3 -0.05			12	AV7 -0.22			6	AV2 -0.09
61	18	6	AV3 +0.30			11	AV1 -0.11			8	AV1 +0.00
		11	AV6 +0.00			12	AV2 +0.07	62	159	9	AV8 +0.11
		10	AV7 +0.00			14	AV3 +0.36			9	AV3 +0.23
61	20	7	AV3 +0.03			8	AV6 +0.38			11	AV2 +0.21
		11	AV6 -0.03	62	13	5	AV1 +0.00			10	AV1 -0.22
		7	AV7 +0.02			6	AV2 -0.16			7	AV7 -0.02
61	22	12	AV3 +0.00			13	AV3 +0.00	63	12	7	AV6 -0.35
		7	AV6 -0.03			16	AV6 +0.00			12	AV2 -0.02
61	28	6	AV2 +0.00			9	AV7 +0.00			9	AV1 -0.02
61	30	7	AV3 +0.10			7	AV8 +0.00	63	14	6	AV1 +0.00
		7	AV6 +0.11	62	15	16	AV6 +0.00			7	AV2 +0.00
61	32	6	AV3 +0.32			11	AV7 +0.00			8	AV3 +0.00
61	34	6	AV6 +0.02			7	AV8 -0.11			7	AV6 +0.00
		7	AV3 -0.18	62	17	8	AV2 +0.07			7	AV7 +0.00
61	38	9	AV6 +0.00			7	AV3 -0.05			5	AV8 +0.00
		8	AV7 +0.09	62	19	6	AV1 -0.14	63	16	7	AV2 -0.18
61	44	7	AV3 -0.14			7	AV3 +0.15			14	AV3 +0.00
61	48	6	AV3 -0.07	62	23	7	AV1 -0.07			7	AV6 +0.21
61	50	8	AV3 +0.07			8	AV2 +0.12			5	AV7 +0.00
61	60	6	AV3 -0.02	62	25	6	AV1 +0.05			9	AV8 +0.21
		7	AV6 +0.00			7	AV3 +0.00	63	18	8	AV3 +0.17
61	102	16	AV6 +0.00	62	31	7	AV3 +0.05			7	AV7 +0.16
		9	AV3 -0.05	62	35	6	AV3 +0.40			9	AV8 +0.05
61	104	7	AV3 +0.00			8	AV6 -0.15	63	34	13	AV6 +0.05
		7	AV2 +0.00	62	59	9	AV3 +0.20			10	AV3 +0.00
		6	AV7 +0.00			9	AV6 +0.00	63	38	13	AV6 +0.00
		10	AV6 +0.00			12	AV7 +0.00			7	AV7 +0.00
61	106	10	AV6 +0.00	62	61	6	AV6 +0.00			6	AV8 +0.00
61	108	8	AV6 +0.00			4	AV7 +0.00	63	44	6	AV2 +0.07
		10	AV3 +0.00	62	65	8	AV6 +0.00			8	AV3 +0.00
		7	AV2 +0.00	62	73	8	AV3 +0.00	63	46	6	AV6 +0.00
61	110	8	AV6 -0.05			9	AV6 +0.00	63	58	10	AV6 +0.00
		8	AV3 -0.09	62	97	7	AV6 +0.05			7	AV3 +0.00
61	112	6	AV6 +0.00	62	99	6	AV6 +0.27	63	60	6	AV3 +0.00
		13	AV3 +0.00	62	103	8	AV6 +0.00			7	AV6 +0.00
61	114	10	AV6 +0.00			8	AV3 +0.00	63	64	8	AV3 +0.00
		10	AV3 +0.00	62	105	9	AV7 +0.00			13	AV6 +0.00
		8	AV2 +0.00			8	AV3 +0.00	63	74	10	AV6 +0.00
61	116	8	AV7 +0.00	62	107	11	AV3 +0.00	63	76	9	AV3 +0.00
		16	AV3 +0.00	62	109	8	AV6 +0.00			11	AV6 +0.00
		8	AV2 +0.00			13	AV3 +0.00	63	78	15	AV3 +0.00
61	118	8	AV6 -0.05			9	AV2 +0.00			7	AV6 +0.00
61	126	5	AV6 +0.11	62	111	10	AV6 +0.00	63	90	3	AV1 +0.00
		7	AV3 +0.00	62	113	12	AV7 +0.00			4	AV2 +0.00
61	130	7	AV7 -0.11			7	AV6 +0.00	63	98	6	AV3 +0.12
		13	AV6 -0.10			7	AV3 +0.00			5	AV6 +0.23
		7	AV3 -0.02			7	AV2 +0.00	63	100	12	AV6 +0.07
61	134	6	AV7 +0.09	62	115	7	AV7 +0.00	63	102	10	AV6 +0.00
		8	AV6 -0.03			7	AV6 +0.00			7	AV2 +0.00
61	140	7	AV6 +0.09			6	AV3 +0.00	63	104	8	AV7 -0.05
61	142	16	AV6 -0.08	62	117	9	AV3 +0.07			12	AV6 -0.05
61	146	9	AV6 -0.33	62	119	6	AV3 -0.05			6	AV3 +0.23
61	152	6	AV8 +0.00	62	121	12	AV6 +0.00			7	AV2 -0.07
		11	AV6 +0.00	62	129	6	AV6 +0.00	63	106	11	AV6 -0.05
		7	AV3 +0.00	62	131	9	AV6 -0.10			16	AV3 -0.02
61	154	6	AV8 +0.00	62	139	6	AV2 +0.00	63	108	7	AV6 -0.03
		10	AV6 +0.00	62	143	8	AV7 +0.00	63	110	16	AV6 +0.00
61	156	13	AV7 +0.16			7	AV6 +0.00			8	AV3 +0.00
		11	AV3 +0.18	62	151	10	AV3 +0.07	63	112	7	AV7 -0.09
		12	AV2 -0.05			7	AV1 +0.00	63	114	12	AV7 -0.04
		11	AV1 -0.05	62	153	11	AV8 +0.00			10	AV3 -0.05
61	158	12	AV7 +0.00			12	AV7 +0.00	63	116	10	AV6 +0.00
		7	AV6 +0.00			15	AV6 +0.00	63	118	7	AV6 +0.00
		12	AV3 +0.30			16	AV3 +0.00	63	128	7	AV3 +0.00
		8	AV2 +0.00	62	155	5	AV7 +0.00	63	130	8	AV6 +0.00
61	160	12	AV7 -0.26	62	157	14	AV8 +0.11	63	132	12	AV3 +0.24
		9	AV6 -0.08			10	AV7 +0.11			13	AV6 +0.02

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
63	134	14	AV6 +0.00					65	48	12	AV6 +0.00
		9	AV3 +0.00	64	101	12	AV3 +0.20	65	50	8	AV6 +0.00
		11	AV2 +0.00			17	AV6 +0.02			6	AV7 +0.00
63	136	7	AV7 +0.00			14	AV7 +0.04	65	56	5	AV6 +0.00
		9	AV6 +0.00	64	103	6	AV7 -0.05	65	58	7	AV6 -0.10
63	142	8	AV6 +0.00			6	AV6 -0.25	65	62	7	AV3 +0.00
63	144	9	AV8 -0.11			7	AV3 -0.18			6	AV6 +0.00
		7	AV7 +0.07	64	105	6	AV7 -0.02	65	70	5	AV2 +0.00
		16	AV6 -0.08			16	AV6 -0.02			9	AV3 +0.00
		14	AV3 +0.18			6	AV3 -0.02			9	AV6 +0.00
		6	AV2 -0.07	64	111	13	AV6 -0.10			11	AV7 +0.00
63	146	7	AV7 -0.12			10	AV3 -0.02	65	74	10	AV6 +0.00
		12	AV3 -0.07	64	113	8	AV7 -0.07			8	AV7 +0.00
		6	AV2 -0.07			6	AV6 +0.07	65	78	7	AV6 +0.00
63	148	11	AV6 -0.23			10	AV3 -0.05			7	AV3 -0.13
		9	AV3 +0.03			7	AV2 -0.02	65	84	5	AV2 +0.00
		7	AV1 -0.19	64	115	13	AV6 -0.12			9	AV3 +0.00
63	150	14	AV3 +0.10			15	AV3 +0.00			7	AV6 +0.00
		10	AV2 +0.02	64	117	8	AV3 -0.09	65	86	4	AV7 +0.04
		7	AV1 +0.17	64	119	11	AV3 +0.00	65	94	10	AV6 +0.02
63	152	6	AV8 -0.23			6	AV2 +0.00	65	96	11	AV3 +0.19
		6	AV7 +0.16			9	AV6 +0.00	65	98	10	AV3 +0.22
		9	AV6 -0.25	64	121	8	AV6 -0.10			13	AV6 +0.09
		7	AV1 -0.19	64	123	7	AV6 -0.22	65	100	7	AV6 +0.23
63	154	6	AV8 -0.18	64	125	6	AV2 +0.00	65	102	8	AV7 -0.07
		6	AV6 -0.08	64	133	6	AV6 +0.29			16	AV6 -0.02
		10	AV3 -0.18	64	135	9	AV6 +0.00			7	AV3 -0.09
		10	AV2 -0.02	64	137	8	AV7 -0.05	65	104	7	AV7 +0.00
		8	AV1 -0.16			12	AV6 -0.10			6	AV6 +0.00
63	156	11	AV8 -0.29			8	AV3 +0.00			9	AV3 +0.00
		13	AV7 +0.13	64	143	6	AV3 -0.12	65	106	10	AV7 +0.00
		14	AV6 +0.00	64	145	6	AV7 -0.21			10	AV6 +0.00
		10	AV2 +0.23			7	AV3 -0.07			10	AV3 +0.00
		17	AV1 -0.23			10	AV1 +0.12	65	108	10	AV7 +0.00
64	11	8	AV7 +0.12	64	149	10	AV2 +0.00			11	AV3 +0.00
		9	AV6 +0.14	64	153	6	AV8 -0.18	65	110	14	AV7 -0.09
		6	AV3 -0.30			9	AV6 +0.19			8	AV3 +0.05
64	13	5	AV1 +0.00			14	AV3 +0.00	65	112	10	AV7 +0.00
		8	AV2 +0.00	64	155	10	AV7 +0.11			12	AV6 +0.00
		15	AV3 +0.00			9	AV6 +0.16			7	AV3 +0.00
		7	AV8 +0.00			6	AV2 +0.09			8	AV2 +0.00
64	15	7	AV3 +0.35			16	AV1 -0.21	65	114	9	AV6 +0.00
		10	AV6 +0.02	64	157	8	AV8 +0.16			16	AV3 +0.00
64	17	6	AV3 +0.00			9	AV7 +0.18			8	AV2 +0.00
		15	AV6 +0.00			9	AV6 -0.28	65	116	18	AV3 +0.00
		7	AV7 +0.00			8	AV1 -0.20			16	AV6 +0.00
		13	AV8 +0.00	64	159	7	AV7 -0.23			9	AV7 +0.00
64	19	10	AV6 +0.00			6	AV6 +0.16	65	118	10	AV7 -0.09
64	27	9	AV6 +0.00	65	12	7	AV8 +0.11			8	AV6 -0.05
64	29	17	AV6 +0.00			12	AV3 +0.13			5	AV3 -0.16
		9	AV7 +0.02			16	AV2 +0.14			7	AV2 -0.05
64	33	14	AV6 -0.02			9	AV1 -0.22	65	120	9	AV7 -0.07
		7	AV3 -0.25	65	14	6	AV1 +0.23			16	AV6 -0.05
64	39	7	AV6 +0.00			12	AV2 +0.00			10	AV3 +0.07
64	45	7	AV6 +0.00			19	AV3 +0.00	65	126	6	AV6 +0.09
64	55	8	AV3 +0.00			14	AV6 +0.00	65	128	12	AV6 -0.10
		7	AV6 +0.00			7	AV7 +0.00	65	130	6	AV6 +0.18
64	61	7	AV6 +0.00	65	16	9	AV2 -0.07			9	AV3 -0.05
64	63	5	AV2 +0.00			10	AV3 +0.10			6	AV2 -0.25
		9	AV3 +0.00			12	AV7 +0.02	65	134	10	AV7 +0.02
		13	AV6 +0.00			15	AV8 +0.02			16	AV6 -0.02
64	75	6	AV3 +0.00	65	18	15	AV6 +0.00			7	AV2 -0.02
		16	AV6 +0.00			10	AV7 +0.00	65	136	10	AV6 +0.00
		5	AV7 +0.00	65	20	7	AV2 +0.00	65	138	8	AV3 +0.02
		4	AV2 +0.21	65	22	8	AV7 +0.00	65	144	9	AV8 -0.05
64	87	7	AV2 +0.05	65	34	4	AV6 +0.22			14	AV6 -0.07
64	91	4	AV2 -0.07	65	42	11	AV6 +0.00	65	152	14	AV8 +0.00
64	93	9	AV6 +0.05	65	44	6	AV3 +0.00			17	AV7 +0.00
64	97	8	AV6 +0.05			6	AV7 +0.00	65	154	10	AV8 +0.00
64	99	11	AV3 +0.20			5	AV8 +0.00			14	AV7 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		19	AV6 +0.00	66	103	12	AV8 +0.00			9	AV3 -0.07
		15	AV3 +0.00			18	AV3 +0.00	67	38	8	AV2 +0.16
		9	AV1 +0.00							16	AV3 +0.10
65	156	14	AV8 -0.20	66	105	10	AV7 +0.00			12	AV6 +0.07
		6	AV7 +0.18			8	AV2 +0.00			9	AV7 -0.13
		7	AV6 +0.00	66	107	11	AV6 +0.00			9	AV8 +0.12
		6	AV3 +0.15			12	AV3 +0.00	67	40	9	AV6 +0.04
		7	AV2 +0.14	66	109	7	AV8 +0.00			6	AV7 +0.07
		9	AV1 -0.25			8	AV7 +0.00	67	44	10	AV2 +0.09
65	158	7	AV8 +0.16			10	AV6 +0.00			13	AV6 +0.05
		7	AV7 +0.13			8	AV2 +0.00	67	46	7	AV6 +0.02
		19	AV6 -0.28	66	111	9	AV6 +0.00	67	48	7	AV8 +0.07
		10	AV3 +0.20			15	AV3 +0.00	67	50	15	AV3 +0.05
66	13	6	AV1 +0.00			12	AV2 +0.00			9	AV6 +0.11
		7	AV3 +0.00	66	113	18	AV6 +0.00	67	52	9	AV3 +0.12
		7	AV7 +0.00			19	AV3 +0.00			13	AV7 +0.07
66	15	8	AV1 +0.00	66	115	13	AV3 +0.00	67	54	8	AV6 +0.02
		15	AV2 +0.18			7	AV2 +0.00	67	58	7	AV6 +0.02
		9	AV8 +0.00	66	117	13	AV6 +0.00	67	62	7	AV6 +0.05
66	17	8	AV2 +0.23			7	AV3 +0.00	67	66	13	AV6 +0.00
66	19	6	AV3 +0.00			7	AV1 +0.00	67	68	15	AV3 +0.00
		8	AV6 +0.00	66	119	6	AV3 -0.02			8	AV6 +0.00
66	21	9	AV3 +0.12	66	121	9	AV7 +0.00			8	AV7 +0.00
		8	AV6 -0.12			16	AV6 +0.00	67	70	10	AV3 +0.00
66	23	9	AV6 +0.00	66	123	6	AV3 +0.00			9	AV6 +0.00
66	27	8	AV2 +0.00	66	129	12	AV6 +0.00	67	74	13	AV3 +0.00
66	29	9	AV6 +0.05	66	131	8	AV6 -0.07	67	76	17	AV3 +0.00
66	31	6	AV3 +0.00	66	135	8	AV6 +0.00			17	AV6 +0.00
		10	AV6 +0.00	66	137	9	AV8 +0.00	67	88	6	AV2 -0.05
		12	AV7 +0.00			9	AV7 +0.00	67	92	7	AV2 +0.07
		11	AV8 +0.00			10	AV6 +0.00			8	AV3 +0.15
66	33	12	AV6 +0.00	66	141	8	AV6 +0.00	67	94	7	AV1 +0.12
		6	AV3 -0.05			7	AV3 +0.00			9	AV2 +0.16
		7	AV2 -0.05	66	143	6	AV3 +0.00			9	AV3 +0.19
66	35	15	AV6 +0.00	66	145	14	AV8 -0.07	67	96	6	AV2 +0.05
66	43	12	AV6 +0.00			15	AV7 -0.02			14	AV3 +0.10
		6	AV7 +0.00			11	AV6 -0.07			11	AV7 +0.07
66	45	5	AV3 +0.00			7	AV1 -0.05	67	98	6	AV2 +0.07
66	51	7	AV3 +0.00	66	147	12	AV6 -0.07			8	AV3 +0.15
		13	AV6 +0.00			10	AV3 -0.05			7	AV6 +0.09
66	53	5	AV3 -0.07	66	149	9	AV6 +0.12	67	100	8	AV3 +0.15
		6	AV6 +0.25			8	AV3 +0.05			12	AV6 +0.05
66	55	8	AV3 +0.05			10	AV2 -0.02			5	AV7 +0.04
		7	AV6 +0.05	66	153	19	AV8 +0.00	67	102	8	AV2 +0.00
66	59	8	AV3 +0.00			15	AV7 +0.00	67	104	15	AV2 -0.09
		11	AV6 +0.00			13	AV6 +0.00	67	106	9	AV7 -0.07
		10	AV7 +0.00	66	155	7	AV8 -0.23			7	AV6 +0.00
66	61	12	AV3 +0.00			6	AV7 +0.09			8	AV3 -0.02
		18	AV6 +0.00			6	AV6 +0.09			5	AV2 -0.02
66	75	13	AV6 +0.00			7	AV3 +0.00	67	108	8	AV6 +0.00
		6	AV7 +0.00			10	AV1 +0.00			15	AV3 -0.05
66	77	7	AV2 +0.00	66	157	12	AV8 +0.14			9	AV2 -0.02
		6	AV3 +0.00			11	AV7 +0.00	67	110	8	AV7 +0.00
		8	AV6 +0.00			11	AV6 -0.27			9	AV2 +0.00
66	79	5	AV3 +0.00			13	AV3 +0.30	67	112	9	AV7 -0.05
66	83	7	AV2 -0.09			11	AV1 -0.27			9	AV6 +0.02
66	87	6	AV2 -0.05	67	12	8	AV8 +0.13			10	AV3 -0.05
66	93	6	AV6 +0.16			8	AV6 +0.16			13	AV2 -0.05
66	95	6	AV2 +0.12	67	14	7	AV2 +0.00	67	114	8	AV7 -0.07
		8	AV3 +0.17			7	AV3 +0.00			5	AV3 -0.19
		8	AV6 +0.05			9	AV6 +0.00	67	116	7	AV7 -0.05
		10	AV7 +0.02	67	16	7	AV1 +0.21			12	AV6 -0.10
66	97	13	AV3 +0.24			8	AV2 +0.00			9	AV3 -0.05
		10	AV6 +0.02			9	AV6 +0.00			8	AV2 -0.02
66	99	8	AV2 +0.12			12	AV7 +0.00	67	118	8	AV2 +0.00
		15	AV3 +0.17	67	18	6	AV1 +0.21			7	AV3 +0.00
		13	AV7 +0.09			6	AV3 +0.02			7	AV6 +0.00
66	101	6	AV2 +0.07	67	20	12	AV3 +0.17			10	AV7 +0.00
		8	AV3 +0.20			17	AV6 +0.00	67	122	7	AV6 +0.00
		14	AV6 +0.07	67	34	9	AV6 +0.00	67	128	8	AV7 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
67	130	10	AV3 +0.00	68	75	10	AV3 +0.00	68	157	18	AV8 +0.18
		8	AV6 +0.00			19	AV2 +0.00			16	AV3 +0.11
67	132	9	AV2 +0.05			19	AV7 +0.00			10	AV1 -0.25
		9	AV3 +0.12	68	77	5	AV7 -0.10	69	14	8	AV1 +0.00
		15	AV6 -0.05			12	AV8 +0.00			9	AV2 +0.00
67	134	8	AV6 +0.00	68	79	5	AV3 +0.00			9	AV3 +0.51
67	138	6	AV6 +0.00			10	AV6 -0.04			10	AV6 +0.00
67	140	8	AV6 +0.00	68	81	6	AV3 +0.00	69	18	7	AV2 +0.28
		6	AV1 +0.00			8	AV6 +0.00			8	AV6 -0.16
67	142	5	AV8 +0.00	68	87	11	AV6 +0.00			7	AV3 +0.00
		7	AV6 +0.00			7	AV2 +0.16	69	36	6	AV3 +0.00
		10	AV3 +0.00			8	AV3 +0.00	69	56	12	AV3 +0.00
		13	AV2 +0.00			9	AV7 +0.07	69	60	8	AV7 +0.00
67	144	8	AV1 +0.00	68	89	19	AV3 +0.22	69	62	7	AV6 +0.00
67	146	14	AV2 -0.02			11	AV6 +0.05	69	66	12	AV3 +0.00
		13	AV1 -0.02	68	93	7	AV3 +0.25			10	AV6 +0.00
		14	AV6 -0.10	68	95	7	AV6 +0.05	69	68	8	AV2 +0.00
67	148	11	AV7 -0.10	68	97	8	AV3 +0.17			9	AV3 +0.00
		13	AV2 +0.00			10	AV6 +0.07	69	70	7	AV3 +0.00
		8	AV1 -0.05	68	99	15	AV3 +0.17			11	AV6 +0.00
67	150	7	AV3 +0.07			18	AV6 +0.07	69	72	5	AV3 +0.00
67	152	8	AV7 -0.05			8	AV7 +0.04			9	AV6 +0.00
		12	AV6 -0.05	68	101	8	AV2 +0.07			9	AV7 +0.00
		7	AV2 -0.02			10	AV3 +0.14	69	74	9	AV2 +0.00
		8	AV1 +0.14			10	AV7 +0.04			14	AV3 +0.00
67	154	16	AV7 -0.05	68	103	13	AV7 -0.02			15	AV6 +0.00
		15	AV2 -0.05			13	AV3 -0.12			12	AV7 +0.00
		10	AV1 +0.16			6	AV2 -0.12	69	76	5	AV3 +0.00
67	156	13	AV8 -0.25	68	105	7	AV6 +0.00			10	AV6 +0.00
		8	AV6 -0.40			13	AV3 -0.05	69	86	9	AV6 +0.00
		9	AV3 +0.27			6	AV2 -0.02	69	88	16	AV7 +0.05
		12	AV2 +0.21	68	107	7	AV6 -0.02	69	90	6	AV2 -0.05
		10	AV1 -0.20			7	AV3 +0.00			6	AV6 +0.09
67	158	8	AV8 +0.16	68	109	10	AV2 -0.07	69	92	7	AV3 +0.14
		9	AV7 +0.00			6	AV7 -0.02			7	AV6 +0.02
		15	AV6 -0.25	68	109	6	AV6 +0.00	69	94	9	AV6 +0.00
		5	AV2 +0.23			6	AV6 +0.00	69	96	8	AV3 +0.14
		8	AV1 -0.20	68	111	15	AV3 +0.00			7	AV6 +0.05
68	13	7	AV1 +0.00	68	113	11	AV7 -0.09	69	98	9	AV2 +0.14
		8	AV3 +0.00			7	AV6 -0.05			10	AV3 +0.17
		7	AV6 +0.00	68	115	9	AV8 -0.07			9	AV6 +0.07
		5	AV7 +0.00			18	AV3 +0.02			9	AV7 +0.02
68	15	7	AV1 +0.05	68	117	7	AV2 +0.02	69	100	7	AV2 +0.07
68	17	9	AV1 +0.05			14	AV7 -0.11			14	AV3 +0.17
		8	AV2 +0.09			8	AV3 -0.07			19	AV6 +0.07
		8	AV3 +0.20	68	119	9	AV1 -0.02			17	AV7 +0.07
		17	AV6 -0.14			7	AV6 +0.00	69	102	8	AV7 -0.12
68	19	7	AV1 +0.07	68	121	18	AV6 -0.07			11	AV6 -0.02
68	21	7	AV6 -0.12	68	123	9	AV7 -0.07			10	AV3 -0.07
68	35	7	AV3 -0.02			10	AV6 -0.07			9	AV2 -0.07
		6	AV6 -0.14	68	133	7	AV3 +0.00	69	104	19	AV7 +0.00
68	45	6	AV3 +0.00			7	AV2 +0.00			14	AV3 +0.00
		6	AV6 +0.00	68	135	14	AV6 +0.00			18	AV2 +0.00
68	49	6	AV6 +0.00			14	AV3 +0.00	69	106	12	AV7 +0.00
68	55	8	AV3 +0.00	68	139	6	AV3 -0.19			18	AV6 +0.00
		7	AV6 +0.00			9	AV2 +0.00			14	AV3 +0.00
68	59	6	AV6 +0.00	68	143	5	AV1 +0.16			6	AV2 +0.00
		7	AV7 +0.00			6	AV7 -0.12	69	108	8	AV8 +0.00
68	63	10	AV3 +0.00	68	145	8	AV6 -0.07			7	AV2 +0.00
		5	AV6 +0.07			15	AV3 -0.05	69	110	13	AV6 -0.04
		9	AV7 +0.00	68	147	7	AV3 +0.02			7	AV7 -0.05
68	67	14	AV3 +0.00	68	149	9	AV7 -0.09	69	112	7	AV7 +0.00
		18	AV6 +0.00			17	AV6 -0.09			12	AV6 +0.00
		10	AV7 +0.00	68	151	10	AV6 -0.07	69	114	6	AV7 +0.00
68	69	7	AV2 +0.00	68	153	6	AV8 -0.20			8	AV6 +0.00
		8	AV3 +0.00			10	AV7 -0.16			8	AV3 +0.00
		6	AV6 +0.00			11	AV6 -0.02			6	AV2 +0.00
68	71	8	AV2 +0.00			13	AV3 -0.02			10	AV1 +0.00
						9	AV1 +0.19			8	AV8 +0.00
				68	155	10	AV1 -0.05	69	116	12	AV3 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		16	AV6 +0.00	70	91	9	AV2 +0.11			12	AV6 -0.24
69	118	7	AV6 -0.06			12	AV3 +0.11	70	157	5	AV6 +0.09
		6	AV2 -0.07			13	AV6 +0.09			6	AV3 -0.16
69	120	8	AV7 -0.07			11	AV7 +0.05	71	14	9	AV1 +0.00
		7	AV3 -0.09	70	93	7	AV6 +0.07			10	AV2 +0.00
69	122	5	AV6 -0.30	70	95	12	AV2 +0.16			18	AV3 +0.00
		7	AV3 +0.08			13	AV3 +0.15			13	AV6 +0.00
69	124	5	AV6 -0.23			8	AV6 +0.02	71	16	8	AV1 +0.07
		9	AV3 +0.03	70	97	15	AV3 +0.11			8	AV3 +0.10
69	134	11	AV6 -0.13			15	AV6 +0.05			14	AV7 +0.02
		7	AV3 +0.28			11	AV7 +0.05			7	AV8 -0.09
69	140	5	AV8 -0.05	70	99	8	AV1 +0.11	71	18	7	AV4 +0.50
		7	AV7 -0.26			12	AV2 +0.11	71	20	6	AV3 -0.14
		5	AV1 +0.12			17	AV3 +0.13	71	26	7	AV7 -0.11
69	146	6	AV6 -0.09			7	AV5 -0.16	71	34	13	AV3 +0.10
		7	AV2 -0.02			9	AV6 +0.05	71	40	4	AV3 +0.00
		7	AV1 -0.05			13	AV7 +0.02	71	44	6	AV5 +0.00
69	150	8	AV2 +0.02			9	AV8 +0.05	71	50	8	AV3 +0.00
69	152	10	AV8 +0.00	70	101	8	AV1 +0.14	71	62	6	AV2 +0.00
		9	AV7 +0.00			14	AV2 +0.11	71	66	7	AV5 +0.00
		14	AV6 +0.00			18	AV3 +0.09			16	AV6 +0.00
		5	AV3 +0.00	70	103	10	AV8 +0.00	71	70	8	AV5 +0.00
69	154	12	AV8 +0.00			16	AV7 +0.00			13	AV6 +0.00
		15	AV3 +0.00			14	AV6 +0.00			8	AV7 +0.00
		10	AV2 +0.00			9	AV5 +0.00	71	72	7	AV4 +0.00
		13	AV1 +0.00			12	AV3 +0.00			7	AV5 +0.00
70	13	6	AV6 +0.00			12	AV2 +0.00			15	AV6 +0.00
70	15	17	AV7 +0.02	70	105	9	AV8 +0.00			9	AV7 +0.00
		12	AV8 +0.07			13	AV6 +0.00	71	74	5	AV3 +0.02
		10	AV1 +0.02			11	AV2 +0.00			7	AV4 +0.00
		8	AV2 +0.00			6	AV1 +0.00			6	AV5 +0.00
		9	AV6 +0.07	70	107	15	AV6 +0.00			12	AV6 +0.00
70	17	7	AV1 +0.00			6	AV3 +0.00			15	AV7 +0.00
		9	AV2 +0.23			9	AV2 +0.00			6	AV8 +0.05
		7	AV8 +0.07	70	109	15	AV8 +0.00	71	76	8	AV3 +0.00
70	35	7	AV4 -0.14			6	AV5 +0.00			8	AV4 +0.00
		6	AV6 +0.05			18	AV3 +0.00			14	AV5 +0.00
70	45	7	AV5 -0.53			9	AV2 +0.00			11	AV8 +0.00
70	53	7	AV6 +0.00	70	111	11	AV6 +0.00	71	78	12	AV2 +0.00
		9	AV7 +0.00			7	AV2 +0.00			16	AV3 +0.00
70	57	6	AV6 +0.00			7	AV1 +0.00			8	AV5 +0.00
70	59	7	AV6 +0.00	70	113	14	AV7 +0.00			9	AV7 +0.00
70	63	9	AV3 +0.00			19	AV6 +0.00	71	80	7	AV6 +0.00
		12	AV6 +0.00			7	AV3 +0.00	71	84	6	AV3 +0.00
70	65	10	AV2 +0.00			14	AV2 +0.00			9	AV4 +0.00
		13	AV3 +0.00	70	115	6	AV3 +0.00			6	AV7 +0.00
70	67	10	AV6 +0.00			9	AV2 +0.00	71	88	7	AV2 +0.11
70	69	13	AV6 +0.00	70	117	9	AV2 +0.00			12	AV4 +0.53
		8	AV7 +0.00			11	AV3 +0.00			10	AV5 -0.32
70	71	14	AV6 +0.00			6	AV6 +0.00			12	AV6 +0.05
		6	AV7 +0.00			12	AV7 +0.00			12	AV7 +0.07
70	73	13	AV6 +0.00	70	119	6	AV2 +0.00	71	90	7	AV5 -0.08
		7	AV7 +0.00			8	AV6 +0.00			8	AV7 +0.02
70	75	9	AV2 +0.00	70	121	8	AV6 +0.00	71	92	8	AV2 +0.18
		5	AV3 +0.06			8	AV3 +0.00			8	AV3 +0.16
		6	AV5 +0.00			7	AV2 +0.00			9	AV4 +0.28
		7	AV6 +0.00	70	123	13	AV6 +0.00			12	AV6 +0.02
		8	AV7 +0.00			7	AV3 +0.00	71	94	7	AV5 -0.08
		7	AV8 +0.05	70	129	8	AV6 +0.00			4	AV3 +0.00
70	77	9	AV3 +0.00	70	133	8	AV7 -0.05	71	96	16	AV2 +0.16
		7	AV6 +0.00			12	AV6 -0.08			8	AV3 +0.16
70	79	7	AV6 +0.00	70	135	4	AV6 +0.00			12	AV6 +0.05
70	83	6	AV2 -0.09	70	151	8	AV7 -0.07			9	AV7 +0.07
70	85	8	AV3 +0.12			8	AV1 -0.05	71	98	11	AV2 +0.18
		9	AV6 +0.07	70	153	7	AV8 +0.00			14	AV3 +0.16
70	87	8	AV2 +0.05			9	AV7 +0.00			13	AV4 +0.24
		14	AV3 +0.09			8	AV6 +0.00			15	AV6 +0.05
		8	AV4 +0.00			10	AV3 +0.00			11	AV7 +0.02
		6	AV5 +0.00			10	AV1 +0.00	71	100	8	AV2 +0.09
		15	AV7 +0.02	70	155	15	AV7 -0.19			15	AV3 +0.16

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		9	AV4 +0.33	72	41	5	AV2 +0.19			7	AV3 +0.14
		11	AV6 +0.05	72	53	8	AV7 +0.05			10	AV6 +0.07
		13	AV7 +0.04	72	61	6	AV6 +0.00	72	101	7	AV2 +0.09
71	102	8	AV7 +0.00			8	AV7 +0.00			9	AV3 +0.10
		15	AV6 +0.00	72	63	11	AV6 +0.00			12	AV4 +0.11
		10	AV5 +0.00	72	65	8	AV3 +0.00			10	AV7 +0.02
		15	AV2 +0.00	72	67	15	AV4 +0.00	72	103	9	AV8 +0.00
		10	AV1 +0.00			19	AV5 +0.00			13	AV4 -0.04
71	104	12	AV7 -0.10			19	AV6 +0.00			12	AV2 -0.02
		12	AV5 -0.26			18	AV7 +0.00	72	105	6	AV7 -0.07
		6	AV3 -0.05	72	69	6	AV3 +0.00			8	AV6 -0.02
71	106	7	AV7 +0.02			6	AV6 +0.00			16	AV4 -0.06
		7	AV6 +0.07			11	AV7 +0.00			7	AV2 -0.05
		7	AV4 +0.57			6	AV2 +0.00	72	107	10	AV5 -0.07
		7	AV5 -0.56	72	71	6	AV2 +0.00			10	AV4 -0.02
71	108	18	AV4 +0.04			12	AV3 +0.00	72	109	12	AV7 -0.05
		7	AV2 +0.05			12	AV4 +0.00			10	AV4 +0.04
		14	AV7 -0.05			6	AV5 +0.00			17	AV3 -0.05
		15	AV6 -0.04			18	AV6 +0.00			9	AV2 -0.07
		7	AV5 -0.55			18	AV7 +0.00	72	111	8	AV7 -0.05
71	110	7	AV3 +0.00			9	AV8 +0.00			9	AV6 -0.04
71	112	7	AV5 -0.53	72	73	6	AV2 +0.00			8	AV4 +0.07
		10	AV4 -0.02			9	AV3 +0.00			9	AV3 +0.00
		8	AV3 -0.02			13	AV4 +0.00			11	AV2 +0.00
		8	AV2 +0.00			13	AV5 +0.00	72	113	11	AV7 -0.07
71	114	12	AV6 -0.12			16	AV6 +0.00			13	AV6 -0.08
		7	AV5 -0.56			7	AV7 +0.00	72	117	6	AV5 +0.27
		6	AV4 +0.04	72	75	5	AV1 +0.00			9	AV2 +0.00
71	116	18	AV5 -0.39			7	AV2 +0.00	72	119	6	AV6 +0.00
		12	AV4 +0.57			9	AV3 +0.00			8	AV3 +0.02
		18	AV3 +0.02			8	AV4 +0.00			8	AV2 -0.07
		11	AV2 +0.02			12	AV5 +0.00	72	129	7	AV2 -0.18
		10	AV1 +0.05			15	AV8 +0.00	72	139	8	AV5 -0.56
71	118	12	AV7 +0.00	72	77	9	AV2 +0.00	72	141	7	AV7 +0.09
		12	AV6 +0.00			6	AV3 +0.00			5	AV3 +0.02
		6	AV4 +0.00			8	AV4 +0.00	72	145	7	AV8 -0.23
71	120	7	AV6 +0.00			15	AV5 +0.00	72	147	5	AV6 -0.02
71	138	7	AV3 +0.00			15	AV6 +0.00	72	149	10	AV7 -0.07
71	144	7	AV3 +0.08			12	AV7 +0.00			14	AV6 -0.09
71	150	8	AV1 +0.19	72	79	15	AV2 +0.00	72	151	12	AV6 -0.06
71	152	9	AV8 -0.21			15	AV4 +0.00			11	AV3 -0.23
		7	AV7 -0.19			12	AV5 +0.00	72	153	7	AV3 +0.12
		8	AV6 -0.24			18	AV7 +0.00			10	AV1 -0.21
		7	AV1 +0.14	72	81	6	AV5 +0.00	72	155	13	AV7 -0.16
71	154	6	AV8 +0.14	72	83	5	AV3 +0.13			8	AV5 +0.08
		8	AV2 -0.05	72	85	5	AV3 -0.02			5	AV3 +0.10
		8	AV1 +0.16			8	AV4 -0.02			10	AV1 -0.25
71	156	10	AV8 +0.16			5	AV5 -0.14	73	16	7	AV1 +0.05
72	15	8	AV1 +0.00			6	AV6 +0.05			9	AV2 -0.12
		9	AV2 +0.00	72	87	6	AV5 +0.02			12	AV3 +0.07
		7	AV3 +0.26	72	89	14	AV3 +0.08			7	AV8 +0.21
		18	AV4 +0.41			8	AV5 +0.06	73	18	9	AV1 +0.00
		13	AV5 -0.24			17	AV6 +0.07			10	AV2 +0.26
		13	AV6 -0.17	72	91	9	AV2 +0.14			14	AV6 +0.00
		13	AV7 -0.11			18	AV3 +0.17			16	AV7 +0.00
72	17	5	AV1 -0.14			10	AV4 +0.17			13	AV8 +0.00
		9	AV2 +0.16			15	AV5 +0.06	73	44	7	AV4 -0.18
		6	AV4 +0.33			19	AV6 +0.05			9	AV5 +0.26
		7	AV5 +0.24			18	AV7 +0.04			7	AV8 +0.14
72	25	9	AV4 +0.35			13	AV8 +0.07	73	48	6	AV4 +0.33
		12	AV3 +0.00	72	93	12	AV3 +0.13	73	54	6	AV3 +0.04
		10	AV5 +0.00			11	AV5 +0.08			7	AV4 +0.37
		10	AV6 +0.00	72	95	7	AV3 +0.12			6	AV5 -0.06
72	29	6	AV7 +0.00			11	AV4 +0.36			7	AV6 +0.05
72	31	6	AV8 +0.00			8	AV5 +0.08			6	AV7 +0.00
72	33	7	AV3 +0.00			13	AV6 +0.07	73	60	5	AV6 +0.00
72	35	10	AV4 +0.00	72	97	9	AV2 +0.12			6	AV7 +0.00
		6	AV5 +0.00			8	AV3 +0.17	73	62	6	AV3 +0.00
		7	AV6 +0.00			11	AV6 +0.05			7	AV4 +0.00
72	37	4	AV7 +0.00	72	99	11	AV2 +0.14			6	AV5 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
73	66	8	AV6 +0.00	73	108	8	AV7 +0.00	74	57	9	AV6 +0.09
		7	AV4 +0.00			15	AV6 +0.00	74	59	6	AV6 +0.00
		13	AV6 +0.00			8	AV5 +0.00	74	61	9	AV6 +0.00
73	68	10	AV4 +0.00			17	AV4 +0.00	74	61	5	AV7 +0.00
		18	AV5 +0.00			8	AV2 +0.00	74	63	10	AV2 +0.00
73	70	9	AV3 +0.00	73	110	9	AV8 -0.07	74	63	7	AV3 +0.00
		8	AV5 +0.00			19	AV7 -0.05	74	63	9	AV4 +0.00
		7	AV6 +0.00			19	AV6 -0.07	74	63	10	AV5 +0.00
		7	AV7 +0.00			14	AV5 -0.03	74	63	7	AV7 +0.00
73	72	12	AV5 +0.00	73	112	9	AV5 +0.00	74	65	8	AV3 +0.00
		16	AV6 +0.00			16	AV4 +0.00	74	65	12	AV6 +0.00
73	74	6	AV2 +0.00			7	AV2 +0.00	74	65	9	AV7 +0.00
		14	AV3 +0.00			7	AV1 +0.00	74	67	8	AV5 +0.00
		15	AV8 +0.00	73	114	7	AV8 +0.00	74	67	12	AV8 +0.00
73	76	7	AV8 +0.00	73	116	8	AV6 +0.00	74	69	8	AV4 +0.00
		11	AV1 +0.00			11	AV4 +0.00	74	69	6	AV5 +0.00
		8	AV2 +0.00	73	118	7	AV3 +0.13	74	69	8	AV6 +0.00
73	78	5	AV3 +0.13			5	AV2 +0.16	74	69	10	AV7 +0.00
		11	AV5 +0.00	73	120	8	AV3 -0.05	74	69	8	AV6 +0.00
		6	AV6 +0.00	73	134	6	AV7 -0.31	74	71	10	AV7 +0.00
73	80	6	AV3 +0.00			10	AV6 -0.02	74	71	9	AV2 +0.00
		5	AV5 +0.00			7	AV5 +0.11	74	71	8	AV3 +0.00
		8	AV6 +0.00			7	AV3 +0.17	74	71	16	AV5 +0.00
73	82	5	AV3 +0.09	73	138	5	AV7 -0.02	74	73	5	AV1 +0.00
		7	AV4 +0.28	73	140	6	AV8 +0.14	74	73	18	AV2 +0.00
		9	AV5 -0.12			4	AV6 +0.05	74	73	19	AV7 +0.00
		12	AV6 +0.05			6	AV3 +0.00	74	75	7	AV2 +0.00
		11	AV7 +0.05	73	144	8	AV3 +0.02	74	75	18	AV3 +0.00
73	84	9	AV3 +0.13			10	AV1 -0.02	74	75	10	AV4 +0.00
		12	AV4 +0.03	73	152	7	AV7 +0.00	74	75	16	AV5 +0.00
		8	AV5 -0.12			7	AV6 +0.00	74	75	19	AV6 +0.00
		6	AV7 +0.04			7	AV4 +0.00	74	75	15	AV7 +0.00
73	86	15	AV4 +0.00	73	154	7	AV1 +0.00	74	77	6	AV2 +0.00
		9	AV6 +0.02			9	AV8 -0.27	74	77	11	AV4 +0.00
73	88	5	AV2 +0.07			6	AV6 +0.00	74	77	16	AV7 +0.00
		14	AV4 +0.00			11	AV3 +0.00	74	79	10	AV4 +0.00
		18	AV6 +0.05			11	AV1 +0.00	74	79	6	AV5 +0.00
		18	AV7 +0.05	74	15	7	AV7 -0.11	74	79	10	AV6 +0.00
73	90	9	AV2 +0.07	74	17	10	AV1 +0.11	74	81	14	AV2 +0.00
		12	AV5 +0.13			11	AV2 +0.12	74	81	17	AV5 +0.00
		8	AV6 +0.09			8	AV3 +0.11	74	81	18	AV6 +0.00
		11	AV7 +0.02			9	AV4 +0.26	74	81	10	AV7 +0.00
73	92	11	AV2 +0.09			7	AV5 +0.04	74	81	8	AV8 +0.02
		11	AV3 +0.09			9	AV6 -0.18	74	83	7	AV2 +0.07
		19	AV4 +0.23			9	AV7 +0.02	74	83	16	AV3 +0.13
		13	AV5 +0.09			11	AV8 -0.11	74	83	10	AV4 +0.03
		13	AV6 +0.07	74	19	7	AV1 -0.12	74	83	11	AV5 +0.11
73	94	11	AV2 +0.18			8	AV2 +0.09	74	83	9	AV6 +0.07
		12	AV3 +0.15			7	AV5 +0.07	74	83	7	AV7 +0.02
		16	AV4 +0.12			8	AV6 +0.02	74	85	12	AV5 -0.03
		12	AV7 +0.02	74	21	6	AV4 +0.00	74	85	14	AV4 -0.09
73	96	19	AV4 +0.03			8	AV8 +0.02	74	85	7	AV3 -0.07
		15	AV7 +0.02	74	23	7	AV1 -0.09	74	87	19	AV3 +0.17
73	98	9	AV2 +0.12			6	AV2 +0.00	74	87	17	AV4 +0.09
		14	AV4 +0.03			6	AV4 +0.28	74	87	17	AV6 +0.07
		17	AV6 +0.09			7	AV6 +0.05	74	87	14	AV7 +0.02
		12	AV7 +0.07			7	AV5 -0.14	74	87	10	AV2 +0.16
73	102	11	AV3 -0.07	74	25	7	AV6 -0.13	74	89	11	AV2 +0.09
		8	AV2 -0.05			10	AV7 -0.11	74	89	18	AV4 +0.09
73	104	7	AV7 +0.00	74	29	5	AV4 +0.33	74	91	7	AV2 +0.07
		17	AV4 +0.00	74	33	7	AV8 -0.14	74	91	8	AV3 +0.11
		17	AV3 +0.00			7	AV4 +0.31	74	91	8	AV4 -0.02
		12	AV2 +0.00			6	AV7 +0.00	74	91	11	AV5 +0.09
73	106	8	AV8 +0.00	74	35	7	AV3 +0.35	74	91	17	AV6 +0.07
		9	AV7 +0.00			5	AV4 +0.42	74	91	19	AV7 +0.02
		6	AV6 +0.00			6	AV5 +0.07	74	93	14	AV3 +0.18
		10	AV5 +0.00			7	AV6 -0.13	74	93	12	AV4 +0.06
		18	AV4 +0.00	74	55	12	AV4 +0.00	74	93	13	AV6 +0.07
		18	AV2 +0.00			11	AV5 +0.00	74	93	18	AV7 +0.04
		11	AV1 +0.00			9	AV6 +0.00	74	95	7	AV2 +0.09

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		13	AV3 +0.13	75	18	10	AV2 +0.00	13			AV4 +0.17
		14	AV4 +0.26			15	AV4 +0.00	9			AV5 +0.07
		12	AV5 +0.09			12	AV6 +0.00	16			AV6 +0.07
		18	AV6 +0.07	75	20	7	AV1 +0.00	6			AV7 -0.14
74	97	17	AV7 +0.07	75	28	5	AV5 -0.16	75	94	10	AV2 +0.14
		13	AV2 +0.07	75	30	6	AV4 +0.00	19			AV3 +0.11
		10	AV7 +0.07	75	44	6	AV4 +0.00	75	96	6	AV2 +0.09
74	99	9	AV1 +0.07			10	AV5 +0.18	13			AV3 +0.16
		15	AV2 +0.09			6	AV7 +0.00	8			AV7 +0.07
		9	AV3 +0.13			6	AV8 +0.00	75	98	13	AV2 +0.14
		15	AV5 +0.09	75	52	8	AV2 +0.00	6			AV3 +0.11
		12	AV6 +0.05			7	AV5 +0.00	15			AV5 +0.09
		9	AV7 +0.00	75	54	7	AV6 +0.00	8			AV6 +0.07
74	101	7	AV1 +0.07	75	56	18	AV4 +0.00	17			AV7 +0.02
		15	AV2 +0.07			9	AV5 +0.00	75	100	13	AV2 +0.09
		15	AV3 +0.07			8	AV6 +0.00	17			AV3 +0.11
74	103	13	AV8 +0.00	75	60	6	AV7 +0.00	15			AV4 +0.00
		18	AV7 +0.00	75	62	11	AV4 +0.00	9			AV5 -0.03
		9	AV6 +0.00			14	AV5 +0.00	9			AV8 +0.02
		7	AV5 +0.00			11	AV6 +0.00	75	102	15	AV7 +0.00
		6	AV4 +0.00	75	64	9	AV5 +0.00	19			AV3 +0.00
74	105	10	AV2 +0.00	75	66	13	AV4 +0.00	9			AV2 +0.00
		6	AV8 +0.00			19	AV5 +0.00	75	104	18	AV4 +0.14
		12	AV7 +0.00			15	AV6 +0.00	75	106	12	AV3 +0.00
		7	AV5 +0.00			12	AV7 +0.00	75	108	9	AV7 -0.05
		19	AV4 +0.00	75	68	7	AV5 +0.00	7			AV6 -0.09
		8	AV2 +0.00	75	70	10	AV5 +0.00	17			AV5 -0.03
		6	AV1 +0.00			13	AV6 +0.00	7			AV2 -0.05
74	107	7	AV7 +0.00			18	AV7 +0.00	75	110	11	AV6 +0.00
		16	AV6 +0.00			6	AV8 +0.00	7			AV5 +0.00
		12	AV4 +0.00	75	72	11	AV3 +0.00	11			AV4 +0.00
		11	AV3 +0.00			7	AV2 +0.00	7			AV3 +0.00
		12	AV2 +0.00	75	74	6	AV1 +0.00	75	112	14	AV7 -0.02
74	109	16	AV4 +0.00			8	AV3 +0.00	9			AV6 +0.16
		16	AV3 +0.00			14	AV4 +0.00	9			AV4 -0.04
		12	AV2 +0.00			16	AV5 +0.00	9			AV2 -0.02
74	111	17	AV7 +0.00			15	AV6 +0.00	7			AV1 +0.02
		17	AV4 +0.00			12	AV7 +0.00	11			AV8 -0.05
		10	AV3 +0.00	75	76	6	AV2 +0.00	75	114	8	AV5 -0.26
74	113	9	AV7 +0.00			18	AV3 +0.00	75	116	10	AV6 -0.05
		7	AV3 +0.00			10	AV6 +0.00	11			AV4 +0.06
		14	AV2 +0.00	75	78	18	AV3 +0.00	11			AV3 +0.02
74	115	10	AV8 +0.00			13	AV4 +0.00	7			AV2 +0.05
		10	AV4 +0.00			12	AV5 +0.00	75	118	9	AV4 +0.00
74	117	10	AV2 +0.00			14	AV6 +0.00	9			AV5 +0.00
		4	AV4 +0.00			9	AV7 +0.00	6			AV7 +0.00
74	119	10	AV3 +0.00	75	80	12	AV3 +0.00	75	120	12	AV7 +0.00
		9	AV2 +0.00			15	AV4 +0.00	8			AV6 +0.00
74	123	9	AV6 +0.00			16	AV5 +0.00	75	124	8	AV5 +0.00
		8	AV5 +0.00			13	AV6 +0.00	75	140	6	AV6 +0.00
74	125	11	AV7 +0.00	75	82	10	AV5 +0.04	8			AV5 +0.00
74	129	11	AV3 +0.00			8	AV6 +0.07	75	142	8	AV5 +0.00
74	137	6	AV5 +0.00			12	AV7 +0.05	9			AV3 +0.00
		6	AV2 +0.00	75	84	11	AV3 +0.02	75	144	8	AV8 -0.07
74	139	7	AV8 +0.00			12	AV4 +0.00	12			AV7 -0.05
		6	AV5 +0.00			8	AV5 -0.11	8			AV6 -0.05
		6	AV2 +0.00	75	86	9	AV2 +0.11	13			AV5 -0.32
74	141	7	AV7 +0.00			14	AV4 +0.06	75	146	6	AV5 -0.32
		6	AV4 +0.00			15	AV5 +0.07	6			AV4 +0.12
		8	AV3 +0.00			18	AV6 +0.00	9			AV3 -0.07
74	143	9	AV5 +0.00	75	88	14	AV3 +0.18	75	148	9	AV5 -0.26
74	145	18	AV3 -0.07			11	AV4 +0.08	75	150	6	AV6 -0.07
		16	AV1 -0.05	75	90	5	AV2 +0.09	10			AV5 -0.23
74	153	9	AV8 +0.00			6	AV3 +0.09	11			AV3 +0.04
		9	AV5 +0.00			10	AV4 -0.02	7			AV1 +0.19
		12	AV1 +0.00			14	AV5 +0.09	75	152	10	AV8 -0.20
75	16	5	AV2 +0.16			5	AV6 +0.07	10			AV7 -0.07
		11	AV6 +0.00			7	AV7 +0.07	6			AV4 +0.17
		8	AV7 +0.00	75	92	6	AV2 +0.09	10			AV2 -0.02
		7	AV8 +0.20			6	AV3 +0.09	8			AV1 -0.23

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
75	154	12	AV8 +0.18	9			AV3 +0.02				
		9	AV7 -0.05	8			AV5 +0.07	76	119	9	AV6 -0.05
		8	AV6 -0.07	8			AV6 +0.09	76	121	10	AV5 -0.25
		7	AV3 -0.02	11			AV7 +0.04	76	125	7	AV7 -0.09
		5	AV2 +0.00	76	85	6	AV6 -0.25	76	137	6	AV2 -0.23
		11	AV1 -0.20	8			AV5 -0.19	76	139	5	AV5 -0.30
76	17	6	AV1 +0.00	12			AV4 -0.09	76	143	13	AV5 -0.31
		9	AV2 +0.23	5			AV3 -0.14	76	145	7	AV6 -0.07
		8	AV6 -0.14	76	87	8	AV2 +0.07	10			AV5 -0.28
76	19	8	AV4 +0.24	16			AV7 +0.04	76	147	8	AV5 -0.27
		7	AV6 +0.00	76	89	18	AV4 +0.00	7			AV4 +0.19
76	21	6	AV1 +0.00	19			AV6 +0.07	8			AV3 -0.05
		9	AV4 +0.22	8			AV7 +0.02	17			AV2 -0.07
76	27	6	AV1 +0.05	13			AV2 +0.05	9			AV1 -0.14
		7	AV5 +0.00	76	91	6	AV2 +0.05	76	151	11	AV2 +0.07
76	29	6	AV4 +0.24	12			AV3 +0.14	8			AV1 -0.18
		7	AV6 +0.05	14			AV4 +0.03	76	153	14	AV8 -0.16
76	31	7	AV4 +0.24	14			AV5 -0.08	10			AV7 -0.07
76	33	7	AV4 -0.12	16			AV6 +0.07	10			AV5 -0.23
76	35	8	AV4 -0.16	5			AV7 +0.05	17			AV4 -0.05
76	41	7	AV5 +0.00	76	93	9	AV2 +0.12	9			AV3 +0.11
76	45	7	AV4 +0.30	16			AV3 +0.05	6			AV1 -0.25
76	55	6	AV4 +0.00	9			AV4 +0.06	77	16	8	AV1 -0.09
		9	AV5 +0.00	8			AV5 +0.07	6			AV6 -0.09
76	59	15	AV2 +0.00	76	95	14	AV7 +0.07	77	18	7	AV1 +0.21
		13	AV3 +0.00	8			AV2 +0.11	10			AV2 +0.32
76	61	5	AV5 +0.00	19			AV3 +0.20	10			AV5 -0.08
		12	AV6 +0.00	14			AV4 +0.08	18			AV6 -0.02
		12	AV7 +0.00	8			AV5 +0.11	7			AV7 +0.00
76	63	10	AV3 +0.00	76	97	11	AV7 +0.05	77	20	5	AV4 +0.16
		14	AV4 +0.00	6			AV2 +0.09	77	22	7	AV4 +0.00
		13	AV5 +0.00	19			AV3 +0.14	77	26	7	AV1 +0.07
		15	AV6 +0.00	76	99	7	AV1 +0.09	8			AV2 +0.16
		7	AV7 +0.00	18			AV3 +0.18	7			AV3 +0.19
76	65	15	AV2 +0.00	11			AV4 +0.19	8			AV4 +0.11
		9	AV3 +0.00	19			AV7 +0.04	77	30	5	AV4 +0.05
		18	AV5 +0.00	9			AV8 +0.05	77	36	9	AV4 +0.27
		15	AV6 +0.00	76	101	9	AV2 +0.14	5			AV5 -0.16
		13	AV7 +0.00	9			AV3 +0.09	77	44	6	AV5 +0.00
76	67	5	AV3 +0.09	8			AV4 +0.05	77	46	7	AV4 +0.00
		8	AV5 +0.00	12			AV6 +0.07	77	50	6	AV5 +0.00
		10	AV6 +0.00	76	103	6	AV8 -0.10	77	54	6	AV4 +0.00
		8	AV7 +0.00	16			AV6 -0.07	9			AV6 +0.00
76	69	7	AV3 +0.00	7			AV3 +0.05	7			AV7 +0.00
		14	AV4 +0.00	6			AV1 -0.14	77	56	12	AV4 +0.00
		6	AV5 +0.00	76	105	12	AV8 -0.07	5			AV5 +0.00
		11	AV6 +0.00	17			AV7 -0.02	6			AV6 +0.00
		7	AV7 +0.00	10			AV6 +0.02	77	60	6	AV3 +0.00
76	71	15	AV2 +0.00	17			AV2 -0.02	9			AV4 +0.00
		14	AV5 +0.00	76	107	6	AV7 -0.05	15			AV5 +0.00
		13	AV6 +0.00	16			AV5 +0.02	12			AV6 +0.00
		6	AV7 +0.00	11			AV2 -0.05	8			AV7 +0.00
76	73	8	AV3 +0.00	7			AV1 -0.05	77	62	7	AV3 +0.00
		8	AV4 +0.00	76	109	18	AV7 -0.09	7			AV5 +0.00
		9	AV6 +0.00	14			AV4 -0.07	77	64	14	AV3 +0.00
		7	AV7 +0.00	19			AV3 -0.05	12			AV5 +0.00
76	75	16	AV2 +0.00	6			AV2 -0.05	10			AV6 +0.00
		9	AV8 +0.00	76	111	9	AV8 -0.05	9			AV7 +0.00
76	77	7	AV2 +0.00	19			AV3 +0.00	77	70	7	AV2 +0.00
		8	AV3 +0.00	12			AV2 -0.02	13			AV3 +0.00
		10	AV4 +0.00	76	113	7	AV8 -0.09	14			AV4 +0.00
		8	AV5 +0.00	12			AV7 -0.02	10			AV5 +0.00
		15	AV6 +0.00	17			AV6 -0.05	77	72	8	AV2 +0.00
		12	AV7 +0.00	76	115	9	AV7 -0.09	7			AV3 +0.00
76	79	6	AV2 +0.00	15			AV6 -0.05	18			AV4 +0.00
		13	AV4 +0.00	11			AV5 +0.02	10			AV7 +0.00
		7	AV5 +0.00	17			AV4 +0.00	77	74	7	AV3 +0.00
		10	AV6 +0.00	11			AV3 +0.00	13			AV7 +0.00
76	81	14	AV2 +0.00	76	117	10	AV5 +0.02	77	76	5	AV1 +0.00
76	83	6	AV2 +0.05	12			AV4 -0.07	12			AV2 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
77	78	17	AV7 +0.00		13	AV5 +0.00		78	75	12	AV2 +0.00
		16	AV3 +0.00		16	AV4 +0.14				16	AV4 +0.00
		12	AV6 +0.00		9	AV3 +0.00				17	AV8 +0.00
77	80	9	AV2 +0.00	77	120	9	AV6 -0.05	78	77	13	AV2 +0.00
		11	AV8 +0.00	77	122	14	AV6 -0.05			17	AV3 +0.00
77	82	6	AV3 +0.00		6	AV5 +0.18				15	AV7 +0.00
		8	AV4 +0.00	77	124	8	AV6 -0.07	78	79	8	AV3 +0.00
		8	AV5 +0.00		8	AV5 -0.19				17	AV5 +0.00
		6	AV6 +0.00		6	AV4 -0.16				13	AV7 +0.00
		10	AV7 +0.00	77	130	6	AV6 +0.14	78	81	6	AV3 +0.00
77	84	6	AV2 +0.00	77	134	5	AV5 -0.28			7	AV5 +0.00
		7	AV3 +0.00		5	AV4 -0.09		78	83	16	AV4 +0.00
		14	AV4 +0.00		9	AV3 +0.02				19	AV5 +0.00
		11	AV5 +0.00	77	138	14	AV5 -0.25			17	AV6 +0.00
77	86	12	AV4 +0.00	77	140	7	AV8 -0.02			16	AV7 +0.00
		12	AV5 +0.00		7	AV5 -0.38				5	AV1 +0.00
		10	AV6 +0.02		7	AV4 -0.04				7	AV2 +0.00
		10	AV7 +0.04	77	142	7	AV5 -0.19			17	AV3 +0.00
77	88	12	AV2 +0.09	77	144	9	AV5 -0.28	78	85	8	AV3 +0.02
		10	AV3 +0.11	77	146	6	AV5 -0.20			14	AV4 +0.05
		15	AV4 +0.05		14	AV3 -0.02				13	AV5 +0.09
		11	AV5 +0.07		13	AV2 -0.05				8	AV6 +0.07
		15	AV6 +0.05		9	AV1 +0.00		78	87	14	AV3 +0.11
77	90	13	AV2 +0.16	77	148	6	AV1 -0.16			17	AV4 +0.05
		19	AV3 +0.18	77	152	9	AV8 +0.00			13	AV5 +0.09
		18	AV6 +0.02		7	AV7 +0.00				17	AV6 +0.05
		17	AV7 +0.02		10	AV6 +0.00				9	AV7 +0.04
77	92	18	AV2 +0.14		7	AV2 +0.00		78	89	16	AV7 +0.05
77	94	18	AV4 +0.03	77	154	9	AV1 -0.23	78	91	13	AV4 +0.11
		14	AV7 +0.07	78	17	7	AV1 -0.18			9	AV5 -0.11
		12	AV2 +0.16		9	AV2 +0.19				16	AV6 +0.02
		12	AV3 +0.11		7	AV6 -0.12		78	93	5	AV2 +0.14
77	96	12	AV2 +0.16		7	AV8 +0.25				10	AV3 +0.07
		10	AV3 +0.14	78	21	8	AV8 +0.07			11	AV4 +0.03
		8	AV4 +0.08	78	23	6	AV4 +0.11			6	AV5 +0.11
		15	AV5 +0.09	78	31	5	AV5 +0.00	78	95	8	AV1 +0.09
77	98	19	AV6 +0.09	78	35	7	AV5 +0.18			14	AV2 +0.07
		16	AV7 +0.04	78	45	13	AV4 +0.00			17	AV5 +0.07
		10	AV8 +0.05	78	47	7	AV4 +0.00			14	AV6 +0.09
77	100	8	AV1 +0.14	78	49	9	AV4 +0.00			14	AV7 +0.09
		10	AV2 +0.11		7	AV5 +0.00		78	97	9	AV2 +0.14
		16	AV4 +0.08	78	53	8	AV5 +0.00	78	99	19	AV4 +0.03
		16	AV5 +0.07		9	AV6 +0.02		78	101	10	AV2 +0.07
		9	AV8 +0.07	78	55	6	AV6 +0.02			11	AV3 +0.09
77	102	12	AV7 -0.11	78	59	7	AV6 +0.00			11	AV7 +0.05
		8	AV3 -0.12		10	AV7 +0.00		78	107	7	AV8 +0.00
77	104	16	AV4 +0.00	78	61	12	AV6 +0.00			6	AV7 +0.00
		17	AV2 +0.00	78	63	7	AV1 +0.00			10	AV5 +0.00
		8	AV1 +0.00		8	AV2 +0.00				17	AV3 +0.00
77	106	10	AV7 +0.00		13	AV3 +0.00				8	AV2 +0.00
		19	AV3 +0.00		12	AV4 +0.00		78	111	7	AV7 +0.00
		15	AV2 +0.00		7	AV5 +0.00				8	AV3 +0.00
77	108	12	AV7 +0.00		13	AV6 +0.00		78	113	18	AV7 +0.00
		17	AV6 +0.00	78	67	9	AV3 +0.00			16	AV5 +0.00
		18	AV3 +0.00		13	AV5 +0.00				11	AV2 +0.00
		9	AV2 +0.00		17	AV6 +0.00		78	115	8	AV8 +0.00
77	110	7	AV8 -0.07		11	AV7 +0.00				6	AV7 +0.00
		7	AV7 -0.11	78	69	8	AV1 +0.00			14	AV6 +0.00
		8	AV6 -0.05		11	AV2 +0.00				9	AV5 +0.00
		9	AV5 -0.14		7	AV7 +0.00				4	AV4 +0.00
77	112	11	AV8 +0.00		10	AV8 +0.00				14	AV3 +0.00
		14	AV3 +0.00	78	71	10	AV1 +0.00			19	AV5 +0.00
		6	AV2 +0.00		12	AV2 +0.00		78	117	16	AV6 +0.00
77	114	15	AV7 +0.00		10	AV3 +0.00				16	AV7 +0.00
		11	AV6 +0.00		14	AV4 +0.00		78	121	12	AV5 +0.00
		14	AV3 +0.00		9	AV5 +0.00		78	123	8	AV5 +0.00
77	116	18	AV7 +0.00		19	AV6 +0.00				8	AV3 +0.00
		8	AV2 +0.00		14	AV7 +0.00		78	125	9	AV7 +0.00
		5	AV1 +0.00	78	73	9	AV2 +0.00			9	AV6 +0.00
77	118	5	AV7 -0.25		17	AV4 +0.00		78	133	7	AV3 -0.12

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
78	137	8	AV5 +0.00			17	AV4 +0.00			7	AV2 -0.02
78	139	7	AV5 +0.00			19	AV7 +0.00	79	134	8	AV7 +0.00
		6	AV3 +0.00							7	AV6 +0.00
78	143	11	AV5 +0.00	79	82	10	AV3 +0.07			8	AV5 +0.00
		6	AV3 +0.00			19	AV4 +0.03			7	AV4 +0.00
78	145	9	AV5 -0.11			16	AV6 +0.02			12	AV3 +0.00
		10	AV2 -0.02			10	AV7 +0.05	79	138	8	AV5 +0.00
78	147	8	AV4 -0.05	79	84	5	AV3 +0.18			6	AV2 +0.00
78	149	8	AV8 -0.05			6	AV4 +0.03	79	144	8	AV5 -0.22
		10	AV7 -0.07			6	AV5 +0.05	79	146	8	AV8 -0.24
78	151	6	AV3 -0.09			6	AV6 +0.07	79	148	6	AV3 +0.07
		6	AV2 +0.00	79	86	9	AV2 +0.07	79	150	7	AV3 +0.07
		7	AV1 -0.18			19	AV4 +0.03	79	152	7	AV8 +0.14
78	153	11	AV8 +0.00			18	AV5 +0.07	80	19	8	AV1 -0.12
		18	AV7 +0.00			11	AV6 +0.09	80	25	6	AV4 +0.00
		10	AV6 +0.00			13	AV7 +0.04			7	AV6 -0.18
		5	AV5 +0.00	79	88	6	AV4 +0.00	80	27	8	AV1 +0.12
		7	AV3 +0.00			7	AV5 +0.07			8	AV2 +0.14
		6	AV2 +0.00	79	90	12	AV2 +0.09			7	AV4 +0.10
		14	AV1 +0.00			18	AV3 +0.11	80	29	7	AV4 +0.24
79	18	7	AV1 +0.23			11	AV4 +0.05	80	31	5	AV4 +0.26
		6	AV2 +0.23			14	AV5 +0.09	80	33	6	AV4 +0.21
		7	AV3 +0.00			16	AV7 +0.05	80	35	9	AV4 -0.05
		6	AV5 -0.13	79	92	14	AV2 +0.07			6	AV5 +0.20
		7	AV6 -0.16			18	AV7 +0.04	80	43	5	AV3 +0.00
79	20	7	AV1 -0.12	79	94	15	AV2 +0.18	80	45	7	AV4 +0.00
		8	AV4 +0.05			19	AV6 +0.00	80	61	7	AV4 +0.00
		9	AV7 +0.05			12	AV8 +0.05			6	AV5 +0.00
		8	AV8 +0.07	79	96	17	AV2 +0.05			10	AV6 +0.00
79	22	8	AV2 +0.00			9	AV3 +0.07	80	67	7	AV3 +0.00
		9	AV4 +0.00			17	AV5 +0.09			12	AV4 +0.00
		8	AV7 +0.00			8	AV7 +0.07			18	AV5 +0.00
79	24	6	AV4 +0.00			8	AV8 +0.05			17	AV6 +0.00
79	30	7	AV1 +0.05	79	100	8	AV1 +0.07			10	AV7 +0.00
		10	AV2 +0.09			14	AV5 +0.07	80	69	4	AV1 +0.00
		7	AV4 +0.05	79	102	8	AV7 +0.00			17	AV3 +0.00
79	34	6	AV5 +0.09			9	AV2 +0.00			7	AV8 +0.00
79	36	9	AV4 +0.24	79	104	14	AV8 +0.00	80	71	13	AV8 +0.00
79	46	12	AV1 +0.02			12	AV7 +0.00			7	AV1 +0.00
		6	AV4 +0.24			18	AV4 +0.00			11	AV2 +0.00
79	50	6	AV4 +0.26			13	AV1 +0.00			19	AV3 +0.00
79	56	8	AV6 +0.09	79	106	14	AV7 -0.05	80	73	13	AV3 +0.00
79	62	13	AV4 +0.00			8	AV2 +0.02			18	AV4 +0.00
		18	AV5 +0.00	79	108	8	AV2 -0.02			18	AV7 +0.00
		9	AV6 +0.00			7	AV1 +0.02	80	75	7	AV2 +0.00
79	64	9	AV5 +0.00			8	AV8 -0.09			7	AV3 +0.00
79	66	7	AV6 +0.00			17	AV6 -0.05			18	AV4 +0.00
79	68	14	AV3 +0.00			12	AV5 -0.05	80	77	12	AV2 +0.00
		11	AV5 +0.00	79	110	13	AV7 +0.00			7	AV7 +0.00
		16	AV6 +0.00			13	AV6 +0.00	80	79	12	AV4 +0.00
		18	AV7 +0.00			7	AV5 +0.00			10	AV6 +0.00
79	70	7	AV3 +0.00			7	AV4 +0.00	80	81	8	AV8 -0.07
		17	AV5 +0.00			18	AV2 +0.00			15	AV7 +0.00
		19	AV6 +0.00	79	112	10	AV6 -0.07			8	AV6 -0.02
		12	AV7 +0.00			10	AV5 -0.03			7	AV5 +0.00
79	72	14	AV3 +0.00			9	AV4 -0.09			10	AV4 +0.00
		18	AV4 +0.00			9	AV2 -0.05			10	AV3 +0.00
		18	AV7 +0.00	79	114	10	AV7 -0.05	80	83	7	AV2 +0.05
79	74	10	AV2 +0.00			12	AV6 +0.00			15	AV3 +0.11
		17	AV3 +0.00			12	AV3 -0.07			18	AV4 -0.02
		15	AV8 +0.00	79	116	9	AV5 +0.16	80	85	15	AV7 -0.07
79	76	9	AV1 +0.00			8	AV3 -0.02			11	AV5 +0.00
		7	AV2 +0.00			7	AV2 +0.05			12	AV4 -0.07
		11	AV3 +0.00			8	AV1 -0.02			13	AV3 -0.05
		11	AV8 +0.07	79	118	13	AV7 +0.00	80	87	10	AV2 +0.16
79	78	8	AV2 +0.00			16	AV6 +0.00			19	AV5 +0.05
		16	AV3 +0.00			13	AV5 +0.00			18	AV7 +0.04
		17	AV5 +0.00			7	AV2 +0.00	80	89	17	AV7 +0.04
		8	AV8 +0.00	79	130	6	AV6 +0.00	80	91	8	AV2 +0.09
79	80	18	AV3 +0.00	79	132	8	AV7 -0.12			13	AV4 -0.14

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		13	AV5 +0.09			7	AV5 +0.00			15	AV6 +0.07
		7	AV7 +0.07	81	38	7	AV4 +0.00			17	AV7 +0.05
80	93	11	AV3 +0.14	81	40	6	AV4 +0.26	81	96	6	AV2 +0.07
		19	AV6 +0.07	81	44	7	AV2 +0.00			12	AV3 +0.14
		12	AV7 +0.04	81	46	7	AV2 +0.00			18	AV5 +0.09
80	95	6	AV2 +0.12			9	AV4 +0.00			8	AV7 +0.09
		13	AV6 +0.07	81	50	8	AV4 +0.00	81	100	7	AV1 +0.07
		8	AV7 +0.05	81	52	8	AV4 +0.00			14	AV2 +0.12
80	99	17	AV2 +0.09	81	54	8	AV6 +0.00			19	AV7 +0.05
		13	AV3 +0.07	81	56	7	AV4 +0.00	81	102	16	AV7 -0.05
		13	AV4 +0.03	81	64	8	AV3 +0.00			13	AV5 -0.05
80	101	9	AV1 +0.07			6	AV5 +0.00			13	AV3 -0.05
		15	AV7 +0.05			12	AV6 +0.00			6	AV1 -0.05
		10	AV8 +0.05	81	66	9	AV2 +0.00	81	106	7	AV7 +0.00
80	105	9	AV7 +0.00			11	AV3 +0.00			10	AV6 +0.00
		6	AV6 -0.05			10	AV4 +0.00			15	AV5 +0.00
		7	AV4 -0.02			17	AV5 +0.00			19	AV4 +0.00
		9	AV3 -0.02			14	AV6 +0.00			15	AV3 +0.00
		16	AV2 -0.11			9	AV7 +0.00			13	AV2 +0.00
80	107	13	AV7 -0.02	81	68	7	AV3 +0.00			6	AV1 +0.00
		14	AV5 -0.08			7	AV4 +0.00			9	AV7 +0.00
		12	AV4 -0.05	81	70	7	AV1 +0.00	81	108	15	AV6 +0.00
		16	AV3 -0.02			13	AV4 +0.00			14	AV4 +0.00
		8	AV2 -0.07			18	AV5 +0.00			14	AV2 +0.00
80	109	10	AV8 +0.00			18	AV7 +0.00	81	110	13	AV7 -0.09
		10	AV7 -0.02	81	72	7	AV1 +0.00			12	AV6 -0.05
		12	AV2 -0.02	81	74	15	AV2 +0.00			13	AV4 -0.02
		10	AV1 +0.00			10	AV3 +0.00			8	AV3 -0.05
80	111	16	AV6 -0.02			19	AV4 +0.00	81	112	9	AV6 +0.00
		17	AV5 +0.02			13	AV5 +0.00			7	AV4 +0.00
		13	AV3 +0.00			12	AV7 +0.00			9	AV3 +0.00
		7	AV2 +0.02	81	76	6	AV1 +0.00			7	AV2 +0.00
80	113	10	AV6 -0.07			8	AV2 +0.00	81	114	11	AV6 +0.00
		13	AV5 -0.03			16	AV3 +0.00			18	AV5 +0.00
		16	AV4 -0.05			6	AV6 +0.00			15	AV3 +0.00
		12	AV3 -0.05			15	AV7 +0.00			12	AV2 +0.00
		12	AV2 -0.05	81	78	18	AV3 +0.00			7	AV1 +0.00
80	115	7	AV2 +0.00			17	AV7 +0.00	81	116	17	AV6 +0.00
		12	AV3 +0.00	81	80	6	AV3 +0.00			15	AV5 +0.00
		14	AV5 +0.00			8	AV4 +0.00			9	AV4 +0.00
		6	AV8 +0.00			11	AV5 +0.00			10	AV2 +0.00
80	117	10	AV8 -0.07			15	AV6 +0.00	81	118	9	AV5 -0.03
		19	AV7 -0.09			14	AV7 +0.00	81	122	8	AV3 +0.09
		16	AV6 -0.09	81	82	13	AV2 +0.05	81	128	6	AV5 -0.08
		19	AV5 +0.21	81	84	6	AV1 +0.07			6	AV3 -0.12
		9	AV4 -0.27			9	AV3 +0.02	81	130	6	AV5 -0.24
		8	AV3 +0.07			5	AV4 +0.03	81	132	12	AV7 +0.00
80	121	9	AV5 -0.05			7	AV5 +0.07			10	AV5 +0.00
80	125	7	AV3 +0.07			14	AV6 +0.07			7	AV3 +0.00
80	133	6	AV5 -0.22	81	86	7	AV2 +0.14	81	134	9	AV3 +0.02
		6	AV2 +0.05			11	AV3 +0.21			8	AV2 +0.00
80	135	6	AV4 +0.00			7	AV4 +0.13			7	AV4 -0.09
		8	AV2 +0.00			8	AV5 +0.02	81	138	7	AV5 -0.24
80	137	12	AV5 -0.27			16	AV7 +0.02			5	AV3 +0.00
		10	AV3 +0.00	81	88	7	AV2 +0.18	81	140	5	AV8 -0.23
80	145	6	AV6 -0.09			17	AV6 +0.02			5	AV4 +0.08
		8	AV5 -0.05			19	AV7 +0.05	81	146	8	AV4 -0.02
		6	AV1 +0.16	81	90	17	AV5 +0.11			8	AV1 -0.19
80	147	6	AV8 +0.16			10	AV6 +0.11	81	148	7	AV8 +0.16
80	149	7	AV8 +0.14			7	AV7 +0.07			10	AV7 -0.07
		5	AV4 -0.04			7	AV2 +0.07			5	AV5 +0.00
81	18	7	AV1 -0.12			18	AV3 +0.14			5	AV1 -0.18
81	22	9	AV4 +0.00			5	AV4 -0.02	81	150	8	AV1 -0.23
81	26	5	AV5 +0.00	81	92	14	AV2 +0.09	82	19	8	AV1 -0.14
81	32	4	AV7 +0.00			10	AV4 +0.19	82	25	6	AV3 +0.00
81	34	7	AV5 -0.11			18	AV5 +0.05	82	27	7	AV4 +0.00
		5	AV4 -0.05			19	AV6 +0.07			5	AV5 +0.00
		5	AV3 +0.02			8	AV7 +0.07	82	35	6	AV3 +0.28
81	36	4	AV1 +0.00	81	94	8	AV1 +0.05			6	AV4 -0.07
		10	AV4 +0.00			15	AV2 +0.09			10	AV5 +0.25

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		9	AV6 +0.02			8	AV3 -0.07			15	AV7 +0.00
		8	AV7 -0.02	82	117	14	AV7 +0.00	83	86	12	AV3 +0.00
82	41	7	AV3 +0.12			16	AV4 +0.00			9	AV4 +0.00
82	45	9	AV4 +0.36			10	AV3 +0.00	83	88	7	AV2 +0.09
82	53	8	AV6 +0.00	82	123	6	AV7 +0.00			11	AV3 +0.09
82	55	7	AV4 +0.00			5	AV5 +0.00	83	90	9	AV1 +0.14
82	59	5	AV4 +0.00	82	127	5	AV5 +0.00			14	AV8 +0.05
		8	AV6 +0.00			5	AV4 +0.00	83	92	14	AV2 +0.16
		11	AV7 +0.00			7	AV3 +0.00			10	AV8 +0.07
82	67	15	AV1 +0.00			8	AV2 +0.00	83	94	4	AV1 +0.28
82	77	8	AV2 +0.00	82	131	10	AV2 +0.00			13	AV2 +0.16
		14	AV3 +0.00	82	133	8	AV6 +0.00			17	AV3 +0.14
		6	AV4 +0.00			15	AV5 +0.00			17	AV4 +0.13
		19	AV5 +0.00			10	AV4 +0.00			9	AV8 +0.07
		17	AV8 +0.00			10	AV3 +0.00	83	96	12	AV2 +0.14
82	79	18	AV2 +0.00	82	135	7	AV2 +0.00			17	AV7 +0.02
		15	AV7 +0.00	82	137	5	AV5 +0.00	83	98	11	AV2 +0.07
		7	AV8 +0.00			6	AV3 +0.00			19	AV6 +0.09
82	81	7	AV2 +0.00	82	139	7	AV5 +0.00			10	AV7 +0.05
		15	AV3 +0.00			6	AV4 +0.00	83	100	11	AV1 +0.11
		15	AV4 +0.00	82	141	10	AV2 +0.02			14	AV2 +0.14
		19	AV5 +0.00	83	20	6	AV1 -0.11			10	AV3 +0.14
		16	AV6 +0.00			6	AV2 +0.00	83	102	7	AV1 +0.00
82	83	10	AV2 +0.05	83	26	7	AV3 +0.16	83	104	10	AV7 +0.00
		11	AV3 +0.09			7	AV5 +0.02			19	AV3 +0.00
82	85	19	AV7 -0.02	83	36	8	AV4 +0.34			7	AV1 +0.00
		6	AV3 +0.12	83	38	5	AV5 +0.00	83	106	10	AV3 -0.07
		5	AV2 -0.07	83	40	4	AV5 +0.00			10	AV2 -0.02
82	87	11	AV3 +0.09	83	46	7	AV4 +0.00	83	110	18	AV4 +0.00
		12	AV5 +0.07	83	50	11	AV4 +0.00			10	AV3 +0.00
		11	AV6 +0.05	83	60	11	AV6 +0.00			12	AV7 +0.00
82	89	16	AV6 +0.09			10	AV7 +0.00			16	AV6 +0.00
82	91	4	AV2 +0.05	83	62	6	AV2 +0.00	83	112	10	AV6 -0.02
		12	AV7 +0.05			7	AV5 +0.00			15	AV5 -0.03
82	93	6	AV1 +0.07	83	64	11	AV4 +0.00			19	AV4 -0.02
		9	AV2 +0.12			19	AV5 +0.00			17	AV3 -0.05
		12	AV3 +0.05			17	AV7 +0.00			11	AV2 -0.07
82	95	10	AV1 +0.14			10	AV8 +0.00	83	114	8	AV4 +0.00
		19	AV6 +0.02	83	66	7	AV3 +0.00			11	AV2 +0.00
		15	AV8 -0.02			9	AV4 +0.00			7	AV1 +0.00
82	97	6	AV1 +0.09	83	68	13	AV4 +0.00	83	116	10	AV7 -0.07
		18	AV2 +0.09			16	AV5 +0.00			10	AV2 +0.02
		7	AV3 +0.11	83	70	11	AV1 +0.00	83	122	7	AV6 +0.00
82	99	19	AV2 +0.14			8	AV3 +0.07	83	124	6	AV5 +0.00
		15	AV3 +0.14			7	AV5 +0.00			7	AV4 +0.00
82	101	12	AV2 +0.12			15	AV6 +0.00	83	132	16	AV7 -0.05
		7	AV8 +0.05			5	AV7 +0.00			9	AV5 -0.24
82	107	16	AV8 +0.00			4	AV2 +0.28	83	134	6	AV3 +0.16
		9	AV5 +0.00	83	72	16	AV3 +0.00			7	AV4 +0.03
		15	AV3 +0.00			17	AV4 +0.00			7	AV6 +0.00
		9	AV2 +0.00			13	AV8 +0.00	83	138	6	AV6 +0.00
82	109	12	AV8 +0.00			9	AV2 +0.00			5	AV4 +0.00
		13	AV7 +0.00	83	74	7	AV2 +0.00			5	AV2 +0.00
		18	AV6 +0.00			18	AV3 +0.00			5	AV3 +0.00
		15	AV5 +0.00			17	AV4 +0.00	83	140	8	AV8 +0.00
		14	AV3 +0.00			18	AV7 +0.00			16	AV7 +0.00
		12	AV2 +0.00	83	76	7	AV1 +0.00			12	AV6 +0.00
		9	AV1 +0.00			16	AV2 +0.00			6	AV4 +0.00
82	111	8	AV7 +0.00	83	78	7	AV2 +0.00			8	AV3 +0.00
		18	AV6 +0.00	83	80	9	AV3 +0.00	83	142	9	AV7 +0.00
		8	AV5 +0.00			19	AV4 +0.00	83	146	7	AV8 -0.28
		13	AV4 +0.00			13	AV8 +0.00			7	AV3 -0.07
		7	AV2 +0.00	83	82	11	AV3 +0.00	83	148	6	AV8 -0.09
82	113	8	AV8 +0.00			7	AV4 +0.00	83	150	10	AV1 -0.23
		7	AV5 +0.00			7	AV6 +0.00	84	35	7	AV3 +0.00
		9	AV3 +0.00			14	AV7 +0.00			7	AV5 +0.00
		8	AV2 +0.00	83	84	7	AV2 +0.00	84	45	11	AV4 +0.00
82	115	18	AV6 -0.05			19	AV3 +0.00	84	47	7	AV4 +0.00
		14	AV5 -0.03			16	AV4 +0.00	84	61	7	AV6 +0.00
		8	AV4 -0.09			17	AV6 +0.00			15	AV7 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		8	AV8 +0.00			17	AV3 +0.00			15	AV7 +0.04
84	63	13	AV2 +0.00	84	117	7	AV8 -0.07	85	106	11	AV7 +0.00
		7	AV3 +0.00			16	AV7 -0.05			13	AV6 +0.00
		12	AV5 +0.00			19	AV6 -0.05			12	AV5 +0.00
		12	AV6 +0.00			16	AV3 +0.09			7	AV1 +0.00
		8	AV7 +0.00			14	AV2 +0.02	85	108	9	AV7 +0.00
84	65	9	AV5 +0.00			8	AV1 +0.00			16	AV5 +0.00
84	67	15	AV3 +0.00	84	121	7	AV6 -0.05			19	AV2 +0.00
		18	AV6 +0.00			7	AV4 -0.14			7	AV1 +0.00
		8	AV7 +0.00	84	123	6	AV5 +0.02	85	112	8	AV5 +0.00
		8	AV8 +0.14	84	125	8	AV2 -0.07			13	AV4 +0.00
84	69	6	AV1 +0.00	84	131	11	AV2 -0.02			9	AV3 +0.00
		9	AV2 +0.00			6	AV5 -0.29			13	AV2 +0.00
		12	AV3 +0.00	84	133	7	AV3 -0.05			7	AV1 +0.00
		16	AV8 +0.00	84	137	10	AV5 -0.24	85	114	10	AV6 +0.00
84	71	7	AV2 +0.00	84	139	7	AV8 -0.25			9	AV5 -0.05
84	73	12	AV2 +0.00	84	141	5	AV2 -0.02			7	AV4 -0.21
		12	AV8 +0.00			5	AV1 -0.05			11	AV3 -0.09
84	75	5	AV1 +0.00	84	143	5	AV3 -0.19	85	116	11	AV6 +0.00
		18	AV2 +0.00	84	145	8	AV7 -0.07			8	AV5 +0.00
		19	AV5 +0.00			7	AV3 -0.02			9	AV4 +0.03
		12	AV6 +0.00	84	147	7	AV7 -0.28			8	AV3 +0.00
84	79	10	AV2 +0.00	85	36	7	AV4 +0.26			7	AV1 +0.00
		16	AV4 +0.00	85	40	8	AV4 +0.23	85	118	5	AV4 +0.26
		13	AV7 +0.00	85	48	7	AV4 +0.03			15	AV5 +0.05
84	81	9	AV7 +0.00	85	50	6	AV4 +0.28			7	AV6 +0.00
		6	AV3 +0.00	85	56	8	AV4 +0.26			8	AV7 +0.00
		17	AV4 +0.00			8	AV7 +0.02			7	AV8 +0.07
84	83	6	AV1 +0.00			4	AV5 +0.25	85	122	6	AV3 +0.20
		14	AV2 +0.00	85	60	5	AV4 +0.00	85	124	7	AV4 -0.07
		6	AV4 +0.00			8	AV7 +0.00	85	128	6	AV1 -0.05
		19	AV5 +0.00			7	AV6 +0.07	85	130	10	AV6 -0.09
		16	AV7 +0.00	85	66	7	AV3 +0.00	85	132	8	AV3 +0.00
84	87	9	AV2 +0.05	85	68	17	AV2 +0.00	85	134	7	AV4 +0.00
		14	AV7 +0.07			18	AV3 +0.00			8	AV5 +0.00
84	89	5	AV1 +0.09			12	AV4 +0.00			6	AV6 +0.00
		14	AV2 +0.00			16	AV5 +0.00			6	AV8 +0.00
		15	AV7 +0.05	85	70	6	AV2 +0.00	85	138	4	AV3 +0.02
84	91	7	AV2 +0.09			19	AV3 +0.00			7	AV2 -0.02
84	93	6	AV1 +0.09			19	AV7 +0.00	85	142	4	AV8 +0.16
		18	AV2 +0.09	85	78	9	AV2 +0.05	86	23	6	AV1 +0.00
		12	AV8 +0.05			17	AV3 +0.07	86	41	5	AV3 +0.00
84	95	8	AV1 +0.14			6	AV8 +0.17	86	43	5	AV4 +0.00
		19	AV3 +0.09	85	80	4	AV2 +0.00			4	AV5 +0.00
		11	AV7 +0.09			12	AV3 +0.00	86	45	7	AV4 +0.00
84	99	9	AV1 +0.11			18	AV4 +0.00			7	AV5 +0.00
		19	AV3 +0.14			16	AV5 +0.00	86	51	6	AV4 +0.00
84	101	9	AV2 +0.09			17	AV7 +0.00	86	53	7	AV2 +0.00
		16	AV3 +0.09	85	82	17	AV3 +0.14	86	55	7	AV1 +0.00
84	105	18	AV7 -0.02	85	86	10	AV2 +0.02	86	59	4	AV3 +0.05
		13	AV2 -0.02			6	AV8 +0.05			5	AV4 +0.34
		10	AV1 +0.05	85	88	6	AV2 +0.14	86	63	7	AV1 +0.00
84	107	14	AV5 +0.00			6	AV3 +0.14	86	65	8	AV6 +0.00
		8	AV2 -0.07			5	AV6 +0.09			7	AV4 +0.08
84	109	12	AV7 -0.05			11	AV7 +0.05	86	69	10	AV3 +0.00
		13	AV5 -0.05	85	90	11	AV2 +0.09	86	75	10	AV1 +0.00
		15	AV4 -0.07			9	AV4 +0.05			13	AV6 +0.00
		13	AV1 -0.05			18	AV6 +0.12			12	AV7 +0.00
84	111	13	AV6 -0.05	85	92	8	AV2 +0.09	86	77	17	AV3 +0.00
		13	AV5 -0.08			19	AV3 +0.09	86	79	12	AV2 +0.00
		5	AV4 -0.18			15	AV8 +0.07			7	AV4 +0.00
		16	AV3 +0.00	85	94	9	AV1 +0.14			8	AV5 +0.00
		15	AV2 +0.05			12	AV2 +0.18			9	AV6 +0.00
84	113	14	AV6 -0.12			18	AV3 +0.18	86	83	12	AV2 +0.05
		18	AV4 -0.05			19	AV7 +0.00			13	AV3 +0.07
		19	AV3 -0.07			12	AV8 +0.05			15	AV7 +0.02
		12	AV2 +0.02	85	98	6	AV1 +0.14	86	87	8	AV2 +0.18
		9	AV1 -0.07			14	AV2 +0.14			19	AV6 +0.05
84	115	8	AV7 +0.00			13	AV7 +0.04			9	AV7 +0.07
		19	AV4 +0.00	85	100	17	AV6 +0.07	86	89	17	AV2 +0.21

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
86	91	18	AV7 +0.07	87	68	8	AV6 +0.00	87	116	6	AV4 -0.23
		6	AV2 +0.09			9	AV5 +0.00			9	AV2 +0.07
		13	AV3 +0.12			7	AV6 +0.00			8	AV1 -0.05
		13	AV7 +0.07	87	70	8	AV3 +0.00			7	AV7 -0.05
		9	AV8 +0.07			19	AV4 +0.00			8	AV6 -0.07
86	93	14	AV2 +0.16	87	72	7	AV1 +0.00			8	AV5 -0.21
86	97	13	AV2 +0.21			7	AV2 +0.00			7	AV2 +0.00
		15	AV4 +0.15			11	AV3 +0.00	87	118	8	AV2 +0.00
		19	AV7 +0.04			18	AV4 +0.00	87	120	6	AV4 +0.00
86	99	10	AV2 +0.12			19	AV6 +0.00			6	AV3 +0.00
		12	AV3 +0.11			11	AV8 +0.00	87	126	6	AV3 +0.00
		9	AV4 +0.13	87	74	7	AV2 +0.00	87	130	8	AV5 +0.00
		18	AV5 +0.07			18	AV3 +0.00	87	132	8	AV5 -0.08
		9	AV7 +0.11			18	AV4 +0.00	87	148	7	AV8 +0.16
		7	AV8 +0.07			14	AV6 +0.00			7	AV6 -0.05
86	101	13	AV2 +0.09			16	AV7 +0.00			6	AV1 -0.18
86	103	19	AV6 -0.05	87	76	7	AV1 +0.00	88	25	7	AV1 +0.00
		8	AV5 -0.03			8	AV2 +0.00	88	33	5	AV5 -0.10
86	105	19	AV7 +0.00			8	AV3 +0.00	88	35	6	AV4 +0.33
		7	AV6 +0.00			16	AV5 +0.00	88	37	6	AV6 +0.00
		17	AV5 +0.00			7	AV6 +0.00	88	39	5	AV5 +0.00
		15	AV4 +0.00			15	AV7 +0.00	88	45	7	AV5 -0.10
86	107	8	AV7 +0.00			8	AV8 +0.00	88	55	7	AV4 +0.00
		9	AV5 +0.00	87	78	7	AV2 +0.00	88	61	11	AV6 +0.00
		12	AV4 +0.00			11	AV3 +0.00			9	AV7 +0.00
		11	AV2 +0.00			12	AV4 +0.00	88	63	7	AV2 +0.00
		6	AV1 +0.00			9	AV5 +0.00			7	AV6 +0.00
86	109	16	AV4 +0.00			8	AV7 +0.00			12	AV7 +0.00
		18	AV3 +0.00	87	80	12	AV2 +0.00	88	65	11	AV3 +0.00
86	111	7	AV6 +0.00			18	AV3 +0.00	88	67	5	AV2 +0.00
		7	AV4 +0.00			13	AV7 +0.00			7	AV3 +0.00
		10	AV3 +0.00	87	82	8	AV2 +0.09			9	AV5 +0.00
86	113	7	AV8 +0.00	87	84	10	AV2 +0.05			6	AV6 +0.00
		6	AV6 +0.00			18	AV3 +0.07			9	AV7 +0.00
		12	AV4 +0.00			19	AV7 +0.05	88	69	10	AV3 +0.00
		17	AV3 +0.00	87	86	15	AV7 +0.04			5	AV4 +0.03
		7	AV1 +0.00	87	88	8	AV2 +0.21			11	AV5 +0.00
86	115	11	AV5 +0.00			8	AV3 +0.16	88	71	7	AV1 +0.00
		5	AV4 -0.23			9	AV6 +0.00			14	AV2 +0.00
		10	AV3 -0.09			8	AV7 +0.07			15	AV3 +0.00
		6	AV2 -0.05	87	90	6	AV2 +0.12	88	73	11	AV1 +0.00
86	117	8	AV7 +0.00			19	AV3 +0.14			18	AV5 +0.00
		6	AV6 +0.00			19	AV4 +0.03			6	AV7 +0.00
		11	AV5 +0.00			7	AV8 +0.09	88	75	9	AV3 +0.00
		15	AV4 +0.00	87	92	14	AV2 +0.14			9	AV4 +0.00
		9	AV3 +0.00	87	96	6	AV1 +0.09			16	AV5 +0.00
86	121	7	AV4 +0.00			19	AV2 +0.09	88	77	7	AV1 +0.09
86	125	7	AV2 +0.00			18	AV5 +0.09			14	AV2 +0.00
86	129	7	AV5 +0.00			7	AV6 +0.07	88	79	7	AV8 +0.00
86	135	8	AV5 +0.00			6	AV7 +0.07			13	AV7 +0.00
		16	AV2 +0.00	87	100	8	AV1 +0.09			12	AV6 +0.00
86	139	5	AV4 +0.00			11	AV7 +0.05			18	AV5 -0.05
86	147	9	AV7 -0.09	87	104	9	AV7 +0.00			7	AV4 -0.09
		7	AV3 -0.02	87	106	6	AV7 -0.05			6	AV3 -0.09
87	26	6	AV1 +0.18			10	AV5 -0.03			6	AV2 -0.07
87	36	7	AV4 +0.00			7	AV1 -0.05	88	81	5	AV2 +0.00
87	42	6	AV4 +0.05	87	108	6	AV6 -0.05	88	83	14	AV2 +0.07
87	44	7	AV3 +0.00			12	AV5 -0.05			11	AV4 +0.05
87	46	8	AV4 +0.00			18	AV2 +0.00			14	AV5 +0.09
87	52	7	AV4 +0.00			6	AV1 -0.05			8	AV6 +0.09
		8	AV7 +0.00	87	110	14	AV5 -0.05			9	AV8 +0.07
87	54	7	AV3 +0.00			9	AV4 +0.00	88	85	7	AV3 +0.12
		7	AV4 +0.00			13	AV2 -0.02			16	AV4 +0.03
		7	AV5 +0.00			8	AV1 -0.05			16	AV5 +0.07
87	60	6	AV4 +0.00	87	112	8	AV7 -0.07			17	AV6 +0.07
87	64	9	AV3 +0.00			7	AV6 +0.07	88	87	10	AV2 +0.12
		9	AV4 +0.00			6	AV3 -0.05			12	AV5 +0.23
		8	AV5 +0.00			13	AV2 -0.02			11	AV7 +0.07
87	66	9	AV4 +0.00	87	114	17	AV8 -0.05	88	89	10	AV3 +0.16
		18	AV5 +0.00			9	AV5 -0.05			18	AV7 +0.09

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
88	91	12	AV2 +0.09					90	61	7	AV4 +0.00
		16	AV3 +0.11	89	72	14	AV2 +0.00	90	63	10	AV3 +0.00
		14	AV5 +0.05			18	AV3 +0.00			7	AV6 +0.00
		16	AV7 +0.05			19	AV4 +0.00	90	65	9	AV1 +0.00
		4	AV1 +0.00			18	AV6 +0.00			16	AV2 +0.00
		4	AV8 +0.00			16	AV7 +0.00			14	AV3 +0.00
88	93	8	AV3 +0.12	89	74	18	AV3 +0.00	90	67	10	AV6 +0.00
		16	AV4 +0.05			17	AV4 +0.00	90	69	6	AV2 +0.00
		10	AV7 +0.09			6	AV2 -0.35			11	AV3 +0.00
88	95	14	AV2 +0.16	89	78	5	AV2 +0.00	90	71	15	AV3 +0.00
		11	AV7 +0.04			11	AV3 +0.00			12	AV8 +0.00
88	97	8	AV2 +0.09			7	AV6 +0.00	90	73	9	AV2 +0.00
		9	AV3 +0.14			9	AV7 +0.00			11	AV4 +0.00
		19	AV5 +0.07	89	80	5	AV2 +0.00			10	AV8 +0.00
		19	AV6 +0.07			8	AV3 +0.00	90	75	8	AV1 +0.00
88	99	17	AV2 +0.16			8	AV4 +0.00			13	AV2 +0.00
		12	AV5 +0.05			12	AV6 +0.00			15	AV3 +0.00
		12	AV7 +0.04			16	AV7 +0.00			16	AV4 +0.00
88	101	9	AV1 +0.14	89	82	14	AV2 +0.00			19	AV5 +0.00
		15	AV2 +0.12			15	AV3 +0.00			14	AV8 +0.00
		16	AV4 +0.08			13	AV8 +0.00	90	79	11	AV3 +0.00
		17	AV7 +0.02	89	84	12	AV3 +0.00			12	AV4 +0.00
88	105	10	AV1 +0.00			7	AV4 +0.00			14	AV6 +0.00
88	107	8	AV5 -0.05			19	AV5 +0.00	90	83	14	AV6 +0.00
		14	AV4 -0.07	89	90	13	AV7 +0.04			17	AV5 +0.00
		8	AV2 -0.05	89	92	15	AV2 +0.16			13	AV4 -0.11
		9	AV6 -0.02			17	AV4 +0.15	90	85	6	AV2 +0.02
88	109	5	AV7 -0.07			12	AV5 +0.07			11	AV3 +0.07
		10	AV5 -0.08			14	AV7 +0.02			19	AV4 +0.03
		17	AV4 -0.07	89	96	11	AV2 +0.16			6	AV8 +0.02
		11	AV2 -0.07			11	AV4 +0.15	90	87	6	AV2 +0.11
88	111	7	AV5 -0.08			7	AV5 +0.07			18	AV3 +0.14
		6	AV4 -0.21			15	AV6 +0.07			18	AV4 +0.08
88	113	6	AV4 -0.21	89	102	19	AV7 +0.00	90	91	11	AV2 +0.14
		9	AV3 -0.05			13	AV6 +0.00	90	99	10	AV1 +0.11
		11	AV1 -0.02			9	AV5 +0.00			10	AV6 +0.02
88	115	10	AV5 +0.00			12	AV1 +0.00			13	AV7 +0.02
88	117	7	AV6 -0.12	89	106	9	AV7 +0.00	90	103	19	AV2 +0.00
		7	AV5 -0.23			13	AV6 +0.00	90	105	16	AV8 +0.00
		11	AV4 -0.07			6	AV3 +0.00			15	AV3 +0.00
		13	AV3 +0.05	89	108	8	AV8 +0.00	90	107	7	AV4 +0.00
		8	AV2 -0.05			10	AV6 +0.00			8	AV3 +0.00
88	121	8	AV3 -0.07			9	AV5 +0.00			6	AV2 +0.00
88	123	8	AV4 +0.00			9	AV3 +0.00			16	AV7 +0.00
88	129	7	AV2 +0.02			12	AV2 +0.00			9	AV6 +0.00
88	137	7	AV3 +0.00			9	AV1 +0.00			12	AV5 +0.00
88	147	7	AV8 +0.14	89	110	8	AV8 +0.00	90	109	10	AV7 +0.00
		9	AV7 -0.25			14	AV7 +0.00			7	AV6 +0.00
		6	AV3 +0.12			11	AV6 +0.00			8	AV3 +0.00
89	26	7	AV2 +0.16	89	112	10	AV7 +0.00	90	111	8	AV7 +0.00
		6	AV5 +0.00			13	AV2 +0.00			7	AV6 +0.00
		9	AV7 +0.07	89	114	7	AV5 +0.00			8	AV4 +0.00
		7	AV6 +0.00			9	AV4 +0.00	90	113	13	AV6 +0.00
89	40	4	AV5 +0.00	89	116	6	AV5 +0.00			10	AV3 +0.00
89	44	4	AV4 +0.00			7	AV4 +0.00			7	AV1 +0.00
89	46	8	AV2 +0.00			7	AV2 +0.00	90	115	7	AV2 +0.00
		7	AV3 +0.00	89	118	7	AV6 +0.00			7	AV5 +0.00
89	48	7	AV4 +0.00			6	AV5 +0.00			7	AV6 +0.00
89	50	6	AV4 +0.00	89	120	9	AV5 -0.05	90	117	5	AV4 +0.00
		8	AV5 +0.00	89	148	8	AV1 -0.16			7	AV6 +0.00
89	54	7	AV4 +0.00	90	37	7	AV2 +0.05	90	121	7	AV3 +0.00
89	62	6	AV3 +0.00			8	AV6 +0.07	90	125	6	AV3 +0.00
89	68	13	AV4 +0.00	90	41	8	AV4 +0.05	90	129	7	AV2 +0.00
		11	AV5 +0.00			7	AV2 +0.00	90	131	7	AV3 +0.00
		10	AV6 +0.00	90	43	7	AV5 +0.00	90	139	6	AV8 +0.00
		15	AV7 +0.00			7	AV5 +0.00	91	56	6	AV5 +0.00
89	70	7	AV3 +0.00	90	51	7	AV5 +0.00			7	AV7 +0.00
		6	AV4 +0.00	90	53	6	AV3 +0.05			6	AV4 +0.03
		5	AV5 +0.23			6	AV4 +0.03	91	58	7	AV2 +0.00
		5	AV6 -0.16	90	55	5	AV4 -0.02	91	62	8	AV6 +0.00
				90	57	8	AV5 +0.18	91	64	13	AV4 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		18	AV5 +0.00	92	53	6	AV4 +0.00	93	52	5	AV4 +0.00
		10	AV6 +0.00	92	55	6	AV4 +0.13	93	56	7	AV4 +0.15
		8	AV7 +0.00	92	59	6	AV3 +0.00	93	60	6	AV3 +0.00
91	66	16	AV5 +0.00			6	AV4 +0.00	93	62	5	AV3 +0.00
		7	AV6 +0.00	92	61	5	AV4 +0.00			7	AV5 +0.00
91	68	10	AV2 +0.00			6	AV5 +0.00	93	64	13	AV6 +0.00
		15	AV5 +0.00	92	65	9	AV8 +0.00			6	AV7 +0.00
		14	AV6 +0.00	92	67	10	AV4 +0.00	93	68	7	AV3 +0.00
		18	AV7 +0.00			7	AV5 +0.00			12	AV4 +0.00
91	70	7	AV1 +0.00			6	AV6 +0.00			7	AV5 +0.00
		8	AV3 +0.00			6	AV7 +0.00			10	AV6 +0.00
		19	AV5 +0.00	92	69	6	AV3 +0.00			13	AV7 +0.00
		13	AV6 +0.00			7	AV5 +0.00			13	AV8 +0.00
		7	AV7 +0.00			7	AV7 +0.00	93	70	17	AV4 +0.00
91	72	14	AV2 +0.00	92	73	8	AV1 +0.00			15	AV5 +0.00
		13	AV4 +0.00			9	AV2 +0.00			15	AV6 +0.00
91	76	14	AV3 +0.00			16	AV7 +0.00			11	AV7 +0.00
		11	AV2 +0.00	92	75	13	AV3 +0.00	93	72	11	AV1 +0.00
91	78	17	AV2 +0.00	92	79	9	AV8 +0.00			11	AV2 +0.00
91	80	6	AV8 +0.00			7	AV4 +0.00			9	AV3 +0.00
		15	AV3 +0.00			18	AV3 +0.00	93	74	9	AV2 +0.00
91	82	17	AV3 +0.00			7	AV2 +0.00			13	AV3 +0.00
		9	AV2 +0.00	92	83	19	AV2 +0.00	93	76	19	AV8 +0.00
91	84	14	AV3 +0.00	92	85	6	AV8 +0.00			16	AV3 +0.00
		9	AV2 +0.00			12	AV2 +0.00	93	78	18	AV6 +0.00
		6	AV8 +0.00	92	87	16	AV7 +0.00			17	AV4 +0.00
91	88	15	AV8 +0.00			19	AV3 +0.00			18	AV3 +0.00
		11	AV3 +0.00			7	AV2 +0.00	93	80	8	AV8 +0.00
		8	AV2 +0.00	92	89	19	AV5 +0.00			6	AV7 +0.00
		7	AV1 +0.00			15	AV3 +0.00			6	AV6 +0.00
91	90	6	AV2 +0.00	92	91	11	AV8 +0.00			8	AV5 +0.00
		17	AV3 +0.00			6	AV1 +0.00			16	AV4 +0.00
91	92	14	AV5 +0.00	92	99	13	AV8 +0.00			7	AV3 +0.00
		18	AV2 +0.00			16	AV2 +0.00	93	82	18	AV6 +0.00
91	94	7	AV8 +0.00	92	101	15	AV5 +0.00			9	AV3 +0.00
		6	AV1 +0.00			5	AV7 +0.00			12	AV2 +0.00
91	96	9	AV1 +0.05	92	103	10	AV2 +0.00	93	86	19	AV7 +0.00
91	98	18	AV2 +0.00			9	AV7 +0.00			13	AV3 +0.00
91	100	8	AV1 +0.00			11	AV8 +0.00			18	AV2 +0.00
		16	AV2 +0.00	92	105	16	AV3 +0.11	93	88	10	AV8 +0.00
		16	AV4 +0.00			19	AV6 +0.16			19	AV4 +0.00
		5	AV5 +0.00			10	AV7 +0.09			12	AV3 +0.00
91	104	13	AV2 +0.00			8	AV8 +0.14			11	AV2 +0.00
91	106	16	AV2 +0.00	92	107	12	AV4 +0.00			8	AV1 +0.00
		10	AV5 +0.00			6	AV5 +0.00	93	92	19	AV2 +0.00
		16	AV6 +0.00			8	AV7 +0.00	93	98	9	AV5 +0.00
		6	AV7 +0.00	92	109	10	AV4 +0.00			7	AV4 +0.00
91	108	6	AV1 +0.00			13	AV7 +0.00			10	AV3 +0.00
		16	AV2 +0.00			7	AV3 +0.00			11	AV2 +0.00
		11	AV7 +0.00	92	111	8	AV3 +0.07	93	100	9	AV3 +0.00
91	110	10	AV2 +0.00			8	AV4 +0.00			8	AV5 +0.00
		18	AV3 +0.00			7	AV5 +0.00			11	AV6 +0.00
		15	AV6 +0.00			10	AV6 +0.00	93	102	19	AV3 +0.00
91	112	13	AV3 +0.00	92	115	7	AV3 +0.16			12	AV7 +0.00
		6	AV5 +0.00			11	AV5 +0.05			9	AV1 +0.00
		6	AV6 +0.00	92	117	5	AV3 +0.12			17	AV2 +0.00
91	114	7	AV2 +0.00			7	AV4 +0.05	93	104	7	AV8 +0.00
		8	AV5 +0.00			8	AV6 -0.05			12	AV1 +0.00
		8	AV7 +0.00			12	AV7 +0.00			12	AV2 +0.00
91	116	13	AV3 +0.00	92	119	6	AV4 +0.00	93	106	13	AV2 +0.00
		16	AV4 +0.00	92	123	6	AV5 +0.07			19	AV3 +0.00
		13	AV5 +0.00	92	131	7	AV3 +0.11			6	AV5 +0.00
		17	AV6 +0.00	92	135	6	AV5 -0.08			12	AV6 +0.00
91	118	7	AV2 +0.00	92	137	7	AV4 +0.08			19	AV7 +0.00
		6	AV6 +0.00	93	42	6	AV2 +0.00	93	108	7	AV2 +0.00
92	45	7	AV5 +0.00			6	AV5 +0.00			11	AV3 +0.00
92	47	7	AV2 +0.00	93	44	5	AV5 +0.00			6	AV5 +0.00
92	49	6	AV4 +0.00	93	48	7	AV5 +0.00			12	AV6 +0.00
92	51	7	AV2 +0.00	93	50	6	AV2 +0.00	93	110	6	AV3 +0.00
		8	AV5 +0.00			8	AV5 +0.00			9	AV6 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
93	112	9	AV3 +0.00	94	99	18	AV7 +0.00	95	88	15	AV6 +0.00
	10		AV4 +0.00			7	AV3 +0.00			10	AV3 +0.00
	14		AV5 +0.00			19	AV3 +0.00			8	AV2 +0.00
	12		AV6 +0.00			5	AV2 +0.00	95	92	12	AV8 +0.00
	15		AV7 +0.00	94	101	17	AV4 +0.10			17	AV2 +0.00
93	114	13	AV4 +0.16			14	AV6 +0.12	95	94	5	AV8 +0.00
	6		AV5 +0.00			18	AV7 +0.11	95	96	14	AV7 +0.00
	14		AV6 +0.00	94	107	8	AV3 +0.00			17	AV4 +0.00
93	116	5	AV2 +0.14			7	AV4 +0.00			19	AV3 +0.00
	10		AV4 +0.10			6	AV5 +0.00	95	98	15	AV7 +0.00
	10		AV5 +0.00	94	109	9	AV4 +0.00			12	AV4 +0.00
93	118	6	AV2 +0.12	94	111	8	AV3 +0.09			14	AV2 +0.00
	6		AV3 +0.00			10	AV5 +0.02	95	100	8	AV3 +0.07
93	122	6	AV5 +0.12			18	AV6 +0.05			14	AV4 +0.05
93	124	6	AV3 +0.09	94	113	6	AV3 +0.12			10	AV8 +0.16
93	126	7	AV4 +0.13			7	AV6 +0.00	95	104	11	AV2 +0.14
93	128	7	AV2 +0.00	94	115	7	AV3 +0.00			12	AV4 +0.10
	5		AV5 +0.00			7	AV4 +0.00			8	AV6 +0.09
94	53	8	AV2 +0.00			6	AV5 +0.02			12	AV7 +0.05
94	55	8	AV4 +0.00	94	117	7	AV5 +0.00	95	106	7	AV3 +0.14
94	57	5	AV5 +0.00	94	121	5	AV5 -0.13			9	AV4 +0.21
94	59	8	AV4 +0.00			4	AV6 -0.14			10	AV5 +0.09
94	61	8	AV2 +0.00	94	139	7	AV8 -0.16			14	AV6 +0.09
	8		AV3 +0.00			95	48	5	AV5 +0.00	7	AV7 +0.11
	11		AV4 +0.00	95	50	5	AV4 +0.00	95	52	7	AV5 +0.00
	8		AV5 +0.00	95	52	7	AV5 +0.00	95	54	6	AV2 +0.00
	12		AV6 +0.00	95	54	6	AV2 +0.00			7	AV5 +0.05
	13		AV7 +0.00			4	AV3 +0.00			6	AV6 +0.07
94	63	6	AV2 +0.00			4	AV4 +0.00	95	110	9	AV4 +0.10
	9		AV3 +0.00	95	60	6	AV3 +0.00			8	AV6 +0.05
	6		AV4 +0.00	95	62	5	AV2 +0.00	95	112	7	AV2 -0.09
	12		AV6 +0.00			6	AV3 +0.00			6	AV3 +0.09
94	65	8	AV4 +0.00			4	AV5 +0.00			8	AV7 +0.05
	10		AV7 +0.00	95	64	8	AV3 +0.00	95	114	6	AV4 +0.00
94	67	8	AV4 +0.00			9	AV4 +0.00	95	116	8	AV2 +0.02
	15		AV6 +0.00			15	AV5 +0.00			7	AV3 +0.00
	17		AV7 +0.00			14	AV6 +0.00			7	AV4 +0.10
	10		AV8 +0.00			10	AV7 +0.00	95	120	7	AV3 -0.07
94	69	16	AV4 +0.00	95	66	6	AV4 +0.00	95	128	7	AV3 +0.16
	11		AV5 +0.00			8	AV6 +0.00			12	AV4 +0.13
	9		AV6 +0.00			10	AV7 +0.00			8	AV5 +0.02
	6		AV7 +0.00	95	68	9	AV2 +0.00	96	27	7	AV2 +0.05
94	71	5	AV2 +0.00			11	AV3 +0.00			5	AV4 +0.00
	15		AV3 +0.00			10	AV4 +0.00			4	AV6 +0.00
	17		AV5 +0.00			16	AV5 +0.00	96	49	7	AV4 +0.00
	7		AV8 +0.00			10	AV6 +0.00	96	53	5	AV2 +0.00
94	73	14	AV1 +0.00	95	70	6	AV1 +0.00			7	AV5 +0.00
	13		AV2 +0.00			9	AV2 +0.00	96	55	6	AV4 +0.00
	14		AV3 +0.00			5	AV4 +0.00			6	AV5 +0.00
94	77	14	AV8 +0.00			10	AV5 +0.00	96	59	8	AV4 +0.00
	14		AV7 +0.00			10	AV7 +0.00			6	AV7 +0.00
	15		AV5 +0.00			8	AV8 +0.00	96	61	6	AV7 +0.00
	16		AV3 +0.00	95	72	6	AV1 +0.00	96	63	5	AV4 +0.00
	9		AV2 +0.00	95	74	8	AV2 +0.00			6	AV7 +0.00
94	79	10	AV7 +0.00			8	AV3 +0.00	96	65	15	AV3 +0.00
	13		AV5 +0.00			13	AV4 +0.00			6	AV4 +0.00
	6		AV4 +0.00			10	AV5 +0.00			16	AV5 +0.00
	10		AV3 +0.00			18	AV6 +0.00			11	AV6 +0.00
	18		AV2 +0.00			10	AV7 +0.00	96	67	14	AV4 +0.00
94	81	6	AV8 +0.00	95	78	17	AV7 +0.00			14	AV7 +0.00
	6		AV4 +0.00			11	AV6 +0.00	96	69	11	AV3 +0.00
	9		AV3 +0.00			9	AV4 +0.00			11	AV6 +0.00
94	87	19	AV2 +0.00			12	AV3 +0.00	96	71	15	AV3 +0.00
94	91	9	AV8 +0.00			13	AV2 +0.00	96	73	8	AV1 +0.00
94	95	14	AV8 +0.00	95	80	19	AV5 +0.00			7	AV2 +0.00
	9		AV5 +0.00			13	AV3 +0.00			8	AV3 +0.00
	16		AV2 +0.00			6	AV2 +0.00	96	75	16	AV8 +0.00
94	97	9	AV7 +0.00	95	82	13	AV3 +0.00			18	AV4 +0.00
	19		AV6 +0.00			12	AV2 +0.00			10	AV3 +0.00
	14		AV5 +0.00	95	84	15	AV7 +0.00			12	AV2 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
96	77	13	AV7 +0.00			14	AV4 +0.00			16	AV4 +0.00
		12	AV3 +0.00			18	AV3 +0.00			15	AV2 +0.00
		7	AV2 +0.00			17	AV2 +0.00	98	91	7	AV1 +0.00
96	79	17	AV2 +0.00	97	80	8	AV7 +0.00	98	93	19	AV7 +0.00
		8	AV1 +0.00			14	AV3 +0.00			19	AV3 +0.00
96	81	11	AV3 +0.00			6	AV2 +0.00			9	AV2 +0.00
96	91	8	AV2 +0.00	97	82	19	AV7 +0.00	98	95	6	AV8 +0.00
96	95	6	AV7 +0.00			12	AV6 +0.00			7	AV6 +0.00
		15	AV4 +0.00			9	AV5 +0.00	98	97	11	AV6 +0.00
		10	AV3 +0.00			9	AV3 +0.00			7	AV4 +0.00
		16	AV2 +0.00			11	AV2 +0.00			8	AV3 +0.00
96	97	10	AV8 +0.00	97	94	6	AV8 +0.00	98	99	10	AV7 +0.00
		12	AV7 +0.00			12	AV7 +0.00			6	AV6 +0.00
		7	AV6 +0.00			11	AV6 +0.00			13	AV5 +0.00
		12	AV5 +0.00			16	AV5 +0.00			13	AV2 +0.00
		19	AV4 +0.00			7	AV4 +0.00	98	101	11	AV3 +0.00
		14	AV3 +0.00			12	AV3 +0.00			8	AV8 +0.00
		6	AV2 +0.00			7	AV1 +0.00	98	105	19	AV2 +0.07
96	101	17	AV2 +0.00	97	96	7	AV7 +0.00			19	AV5 +0.09
		14	AV4 +0.00			9	AV2 +0.00			6	AV8 +0.09
		18	AV6 +0.00	97	98	6	AV8 +0.00	98	107	11	AV2 +0.00
		15	AV8 +0.00			6	AV7 +0.00			16	AV3 +0.00
96	103	7	AV1 -0.02			6	AV6 -0.26			17	AV4 +0.00
		9	AV5 +0.05	97	102	12	AV1 +0.14			11	AV5 +0.00
		15	AV7 +0.02			11	AV4 +0.13	98	109	6	AV4 +0.00
96	105	5	AV2 +0.00	97	106	9	AV2 +0.00			7	AV7 +0.00
		18	AV3 +0.00			14	AV3 +0.00			7	AV8 +0.00
		6	AV4 +0.00			17	AV4 +0.00	98	111	10	AV6 +0.00
96	107	9	AV3 +0.12	97	108	6	AV2 +0.00	98	113	7	AV2 +0.00
		13	AV4 +0.13			10	AV3 +0.00			7	AV3 +0.00
		12	AV5 +0.00			19	AV4 +0.00			5	AV4 +0.00
		7	AV6 +0.14			17	AV5 +0.00			7	AV5 +0.00
		8	AV7 +0.09			9	AV7 +0.00	98	117	7	AV6 +0.07
96	109	7	AV4 +0.13	97	112	7	AV2 +0.00	98	119	8	AV3 +0.00
96	111	9	AV5 +0.00			7	AV4 +0.00	98	121	6	AV4 +0.00
		12	AV6 +0.00			10	AV5 +0.00			7	AV5 +0.00
		7	AV7 +0.00	97	114	7	AV4 +0.00	98	123	6	AV5 +0.00
96	115	5	AV5 +0.00	97	116	10	AV2 +0.00	98	141	6	AV1 +0.21
96	119	7	AV7 +0.07			12	AV3 +0.00			9	AV6 +0.00
96	121	6	AV5 +0.00			11	AV4 +0.00	98	143	6	AV1 +0.32
96	127	9	AV2 +0.14			9	AV5 +0.00	99	54	5	AV2 +0.00
96	143	5	AV8 +0.23	97	120	8	AV6 +0.00			5	AV3 +0.00
97	46	6	AV2 +0.00	98	53	6	AV2 +0.00	99	56	6	AV4 +0.00
		8	AV5 +0.00			6	AV4 +0.00	99	62	5	AV5 +0.00
97	50	8	AV5 +0.00	98	57	6	AV4 +0.00	99	64	6	AV3 +0.00
97	52	8	AV4 +0.00	98	63	6	AV2 +0.00			8	AV4 +0.00
97	60	5	AV5 +0.00			8	AV3 +0.00			6	AV2 +0.37
97	62	7	AV3 +0.00			6	AV4 +0.00	99	66	5	AV4 +0.00
97	64	9	AV3 +0.00	98	65	8	AV3 +0.00			5	AV6 +0.00
		7	AV4 +0.00	98	67	10	AV5 +0.00	99	68	5	AV2 +0.00
		8	AV5 +0.00			9	AV6 +0.00			7	AV3 +0.00
97	66	13	AV3 +0.00			6	AV7 +0.00			18	AV4 +0.00
		8	AV4 +0.00	98	69	9	AV5 +0.00			13	AV5 +0.00
97	68	14	AV3 +0.00			12	AV7 +0.00			15	AV7 +0.00
		18	AV7 +0.00	98	71	7	AV2 +0.00	99	70	7	AV3 +0.00
97	70	9	AV4 +0.00			19	AV3 +0.00			8	AV4 +0.00
		14	AV5 +0.00			15	AV4 +0.00			8	AV7 +0.00
		9	AV6 +0.00			12	AV5 +0.00	99	72	16	AV4 +0.00
		7	AV7 +0.00			8	AV6 +0.00			12	AV7 +0.00
97	72	7	AV2 +0.00	98	73	5	AV1 +0.00	99	74	5	AV1 +0.00
		16	AV3 +0.00			12	AV2 +0.00			7	AV2 +0.00
		16	AV7 +0.00	98	75	13	AV3 +0.00			8	AV3 +0.00
		7	AV8 +0.00			12	AV2 +0.00			12	AV8 +0.00
97	74	5	AV1 +0.21	98	77	12	AV7 +0.00	99	76	17	AV3 +0.00
		12	AV4 +0.13			12	AV3 +0.00	99	78	14	AV8 +0.00
		8	AV8 +0.07			8	AV2 +0.00			10	AV5 +0.00
97	76	6	AV8 +0.00	98	79	7	AV7 +0.00			18	AV4 +0.00
		16	AV3 +0.00			10	AV2 +0.00	99	80	9	AV6 +0.00
97	78	7	AV6 +0.00	98	81	6	AV1 +0.00			6	AV5 +0.00
		18	AV5 +0.00			18	AV8 +0.00			11	AV3 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
99	82	7	AV2 +0.00	100	93	12	AV2 +0.00		18	AV5 +0.00	
		11	AV7 +0.00	100	95	18	AV5 +0.00		10	AV4 +0.00	
		7	AV6 +0.00			16	AV4 +0.00		15	AV3 +0.00	
		19	AV5 +0.00			6	AV3 -0.05		16	AV2 +0.00	
		15	AV4 +0.00	100	97	7	AV7 +0.00		6	AV1 +0.00	
		6	AV3 +0.00			14	AV5 +0.00	101	96	14	AV7 +0.00
		7	AV2 +0.00			12	AV4 +0.00		8	AV6 +0.00	
		6	AV1 +0.00			14	AV3 +0.00		6	AV5 +0.00	
99	88	16	AV1 +0.00			6	AV2 +0.00		15	AV4 +0.00	
99	90	19	AV8 +0.00	100	99	12	AV8 +0.00	101	98	17	AV8 +0.00
		8	AV1 +0.00			16	AV6 +0.00		7	AV7 +0.00	
99	92	10	AV8 +0.00			6	AV4 +0.00		6	AV6 +0.00	
		19	AV4 +0.00			18	AV3 +0.00		15	AV5 +0.00	
		7	AV1 -0.02			10	AV2 +0.00		14	AV4 +0.00	
99	96	6	AV7 +0.00	100	101	12	AV2 +0.12		13	AV3 +0.00	
		9	AV6 +0.00			15	AV4 +0.10	101	100	7	AV1 +0.00
		18	AV4 +0.00			17	AV6 +0.07		10	AV3 +0.00	
		6	AV2 +0.00			11	AV7 +0.05		8	AV4 +0.00	
99	98	19	AV8 +0.00	100	105	8	AV8 +0.00		10	AV5 +0.00	
		7	AV5 +0.00			16	AV3 +0.00		7	AV7 +0.00	
		15	AV4 +0.00	100	107	14	AV2 +0.00	101	104	16	AV2 +0.00
		14	AV3 +0.00			16	AV3 +0.00		18	AV3 +0.00	
		18	AV2 +0.00			18	AV4 +0.00		18	AV6 +0.00	
99	104	7	AV2 +0.00	100	109	8	AV4 +0.00		14	AV8 +0.00	
		9	AV4 +0.00	100	111	8	AV4 +0.08	101	106	6	AV4 +0.13
99	106	18	AV5 +0.00			12	AV6 +0.05		6	AV5 -0.05	
		16	AV6 +0.00	100	115	7	AV4 +0.00	101	108	9	AV4 +0.10
		10	AV7 +0.00			6	AV5 +0.00		10	AV5 +0.07	
		8	AV8 +0.00	100	121	6	AV1 +0.09	101	110	12	AV3 +0.07
99	108	6	AV3 +0.00			8	AV2 +0.14		13	AV4 +0.10	
		10	AV4 +0.00			9	AV3 +0.09		8	AV5 +0.05	
		7	AV5 +0.00			6	AV4 +0.00	101	128	6	AV5 +0.00
99	110	7	AV4 +0.00			8	AV5 +0.12	102	39	6	AV6 +0.02
		5	AV5 +0.00	100	125	7	AV2 +0.09	102	43	6	AV5 +0.00
		8	AV6 +0.00	100	129	8	AV5 -0.08	102	45	7	AV5 +0.00
99	112	7	AV2 +0.00	101	52	6	AV3 +0.00	102	51	6	AV5 +0.00
		8	AV4 +0.00			5	AV4 +0.00		6	AV6 +0.00	
		7	AV6 +0.00			7	AV5 +0.00	102	55	7	AV4 +0.00
99	114	5	AV3 +0.00	101	58	6	AV4 +0.00	102	59	6	AV2 +0.00
		11	AV4 +0.08	101	60	6	AV5 +0.00		10	AV3 +0.00	
		9	AV8 +0.00	101	70	9	AV2 +0.00		8	AV4 +0.00	
99	116	5	AV3 +0.00			14	AV4 +0.00	102	71	16	AV3 +0.00
		6	AV5 +0.00			12	AV5 +0.00		18	AV7 +0.00	
99	118	7	AV5 +0.00	101	72	7	AV1 +0.00		8	AV2 +0.00	
99	122	6	AV5 +0.00			9	AV2 +0.00	102	73	13	AV2 +0.00
100	63	5	AV2 +0.00			14	AV3 +0.00		16	AV3 +0.00	
100	65	13	AV3 +0.00	101	74	9	AV2 +0.00		13	AV4 +0.00	
100	67	6	AV1 +0.00			5	AV7 +0.00		18	AV6 +0.00	
		13	AV3 +0.00			6	AV8 +0.00	102	75	8	AV8 +0.00
		18	AV5 +0.00	101	76	12	AV2 +0.00		16	AV4 +0.00	
		18	AV6 +0.00	101	78	17	AV7 +0.00		11	AV3 +0.00	
100	69	8	AV3 +0.00			14	AV5 +0.00	102	77	11	AV7 +0.00
		16	AV6 +0.00			6	AV4 +0.00		17	AV3 +0.00	
		8	AV8 +0.00			16	AV3 +0.00		13	AV2 +0.00	
100	71	14	AV3 +0.00			11	AV2 +0.00	102	79	16	AV8 +0.00
		13	AV4 +0.00	101	80	13	AV8 +0.02		18	AV7 +0.00	
		18	AV7 +0.00			17	AV7 +0.00		7	AV6 +0.00	
100	73	8	AV4 +0.00			15	AV3 +0.00		8	AV4 +0.00	
100	75	7	AV8 +0.00	101	82	18	AV4 +0.00	102	91	9	AV2 +0.00
100	77	17	AV5 +0.00			9	AV3 +0.00		6	AV1 +0.00	
		18	AV3 +0.00			9	AV8 +0.00		18	AV6 +0.00	
		19	AV2 +0.00	101	88	11	AV8 +0.00		15	AV3 +0.00	
100	79	15	AV7 +0.00			16	AV7 +0.00	102	95	18	AV7 +0.00
100	81	12	AV8 +0.00			11	AV1 +0.00		14	AV5 +0.00	
		9	AV4 +0.00	101	90	19	AV4 +0.00		9	AV3 +0.00	
		17	AV3 +0.00			6	AV1 +0.00		13	AV2 +0.00	
		12	AV2 +0.00	101	92	12	AV8 +0.00	102	97	5	AV7 +0.00
100	91	9	AV8 +0.00			14	AV7 +0.00		6	AV6 +0.00	
		14	AV3 +0.00			7	AV1 +0.00		11	AV5 +0.00	
		14	AV2 +0.00	101	94	6	AV6 +0.00		12	AV3 +0.00	

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION		
102	99	4	AV8 +0.00	103	104	5	AV3 +0.23		14	AV6 +0.00			
		7	AV7 +0.00	103	106	13	AV3 +0.00		8	AV7 +0.00			
		13	AV3 +0.00			8	AV4 +0.00	105	74	10	AV2 +0.00		
		10	AV2 +0.00	103	108	8	AV4 +0.00		16	AV3 +0.00			
102	105	7	AV3 +0.00			6	AV5 +0.00	105	76	19	AV7 +0.00		
		10	AV4 +0.00	103	112	14	AV2 +0.00		16	AV3 +0.00			
		13	AV6 +0.00			10	AV3 +0.00		8	AV2 +0.00			
		13	AV7 +0.00	103	114	8	AV3 +0.00	105	78	8	AV5 +0.00		
102	107	7	AV3 -0.05			6	AV5 +0.00		15	AV3 +0.00			
		6	AV6 +0.23			11	AV6 +0.00		6	AV2 +0.00			
102	111	7	AV2 +0.00	103	116	6	AV7 +0.00		7	AV7 +0.00			
		6	AV4 +0.00	104	49	9	AV5 +0.00	105	80	10	AV8 +0.00		
		7	AV5 +0.00	104	71	10	AV2 +0.00		17	AV7 +0.00			
		10	AV6 +0.00			7	AV3 +0.00		18	AV6 +0.00			
102	113	7	AV3 +0.00			13	AV4 +0.00		10	AV4 +0.00			
		6	AV4 +0.00			19	AV5 +0.00		8	AV3 +0.00			
102	115	7	AV3 +0.16			6	AV6 +0.00		5	AV2 +0.00			
		8	AV5 +0.00	104	73	9	AV2 +0.00	105	82	13	AV7 +0.00		
102	123	11	AV6 +0.09			18	AV3 +0.00		11	AV2 +0.00			
103	44	7	AV5 +0.00			12	AV5 +0.00	105	94	18	AV2 +0.00		
103	46	13	AV5 +0.00			17	AV7 +0.00		16	AV8 +0.00			
103	48	8	AV5 +0.00	104	75	8	AV8 +0.00	105	96	8	AV6 +0.00		
103	54	7	AV5 +0.00			17	AV2 +0.00		17	AV4 +0.00			
103	56	13	AV2 +0.00	104	77	15	AV7 +0.00		11	AV3 +0.00			
		14	AV3 +0.00			15	AV5 +0.00	105	98	13	AV7 +0.00		
		6	AV4 +0.00			14	AV3 +0.00		17	AV4 +0.00			
		7	AV5 +0.00	104	79	12	AV6 +0.00		17	AV3 +0.00			
103	60	7	AV3 +0.00			14	AV5 +0.00		6	AV2 +0.00			
		9	AV4 +0.00			14	AV3 +0.00	105	100	8	AV3 +0.11		
103	64	6	AV4 +0.00			13	AV2 +0.00		19	AV4 +0.13			
		6	AV7 +0.00	104	81	12	AV4 +0.00		19	AV5 +0.09			
103	66	6	AV6 +0.00			7	AV2 +0.00		13	AV6 +0.07			
103	70	13	AV4 +0.00			12	AV6 +0.00		8	AV7 +0.07			
		13	AV5 +0.00			6	AV5 +0.00		6	AV8 +0.16			
		12	AV6 +0.00	104	91	13	AV1 +0.00	105	104	6	AV3 +0.00		
103	72	7	AV2 +0.00	104	95	8	AV6 +0.00		8	AV4 +0.00			
		13	AV3 +0.00			9	AV5 +0.00		12	AV5 +0.00			
		19	AV6 +0.00			18	AV4 +0.00		16	AV6 +0.00			
103	74	12	AV1 +0.02			7	AV3 +0.00	105	106	8	AV5 +0.00		
103	78	7	AV7 +0.00			10	AV2 +0.00	105	112	8	AV1 +0.00		
		18	AV6 +0.00			7	AV1 +0.00		10	AV2 +0.00			
		19	AV2 +0.00	104	97	7	AV7 +0.00		8	AV3 +0.00			
103	80	15	AV8 +0.00			19	AV5 +0.00		7	AV5 +0.00			
		19	AV7 +0.00			8	AV3 +0.00	105	114	8	AV4 +0.00		
		7	AV5 +0.00	104	99	7	AV3 +0.00		7	AV5 +0.00			
		14	AV4 +0.00			10	AV2 +0.00	106	45	6	AV5 +0.00		
		18	AV3 +0.00			6	AV8 -0.05	106	53	9	AV5 +0.00		
		6	AV2 +0.00			9	AV7 +0.00		7	AV6 +0.00			
103	82	19	AV3 +0.00			9	AV6 +0.00	106	57	6	AV5 +0.00		
		15	AV2 +0.00			11	AV5 +0.00	106	63	5	AV3 +0.00		
		19	AV8 +0.00			16	AV4 +0.00	106	67	6	AV6 +0.00		
103	90	10	AV8 +0.00	104	105	5	AV2 -0.07	106	69	7	AV7 +0.00		
		16	AV3 +0.00			6	AV3 +0.11	106	71	8	AV2 +0.00		
		11	AV2 +0.00			15	AV4 +0.18		6	AV3 +0.00			
103	92	12	AV8 +0.00	104	107	7	AV3 +0.00		15	AV4 +0.00			
		19	AV2 +0.00			7	AV4 +0.00		13	AV6 +0.00			
		7	AV1 +0.00			8	AV7 +0.00	106	73	7	AV1 +0.00		
103	94	16	AV8 +0.00	104	109	6	AV4 +0.00		7	AV2 +0.18			
		8	AV2 +0.00	104	117	8	AV3 +0.12		15	AV3 +0.00			
103	96	9	AV8 +0.00			4	AV5 -0.05		11	AV8 +0.00			
		19	AV6 +0.00	105	52	15	AV2 +0.00	106	75	18	AV8 +0.00		
		17	AV4 +0.00			15	AV3 +0.00		16	AV4 +0.00			
		16	AV3 +0.00			11	AV4 +0.00		8	AV3 +0.00			
		7	AV2 +0.00			7	AV5 +0.00	106	77	18	AV6 +0.00		
103	98	7	AV7 +0.00	105	60	6	AV3 +0.00	106	79	17	AV4 +0.00		
		7	AV6 +0.00			105	62	5	AV7 +0.00		12	AV2 +0.00	
		17	AV5 +0.00			105	66	4	AV3 +0.00		6	AV1 +0.00	
		17	AV4 +0.00			105	70	9	AV5 +0.00	106	81	8	AV8 +0.00
		11	AV3 +0.00			105	72	10	AV2 +0.00		8	AV3 +0.00	
103	100	10	AV2 +0.00			15	AV3 +0.00		6	AV2 +0.00			

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
106	93	6	AV8 +0.00					108	127	6	AV4 +0.13
		11	AV7 +0.00	107	100	7	AV2 +0.00	108	131	7	AV5 +0.02
		8	AV3 +0.00			11	AV3 +0.00	108	135	5	AV8 +0.28
		9	AV2 +0.00			9	AV6 +0.00	109	56	8	AV5 +0.00
106	95	10	AV8 +0.05			7	AV7 +0.00	109	60	7	AV3 +0.00
		18	AV3 +0.00	107	102	14	AV4 +0.00			6	AV5 +0.00
		16	AV2 +0.00			16	AV5 +0.00	109	64	7	AV4 +0.00
		7	AV1 +0.00			18	AV6 +0.00	109	68	6	AV1 +0.00
106	97	10	AV7 +0.00	107	104	14	AV3 +0.00			15	AV4 +0.00
		16	AV4 +0.00			8	AV4 +0.00			16	AV6 +0.00
		10	AV2 +0.00			6	AV5 +0.00			6	AV8 +0.00
		9	AV1 +0.00	107	106	5	AV3 +0.05	109	70	6	AV1 +0.00
106	99	12	AV7 +0.00	107	108	8	AV6 +0.07			6	AV2 +0.00
		17	AV4 +0.00	107	110	6	AV6 +0.16			7	AV3 +0.00
		7	AV3 +0.00	107	112	9	AV2 +0.02			9	AV4 +0.00
		7	AV1 +0.00			7	AV3 +0.09			18	AV6 +0.00
106	101	7	AV3 +0.00			4	AV5 +0.00			13	AV7 +0.00
		15	AV5 +0.00			6	AV7 +0.05	109	74	7	AV2 +0.07
		13	AV6 +0.00	107	120	12	AV2 +0.05			6	AV3 +0.09
		10	AV7 +0.00			9	AV6 +0.09	109	76	9	AV5 +0.00
106	103	6	AV2 +0.00	108	35	8	AV5 +0.00			17	AV3 +0.00
		18	AV3 +0.00			7	AV8 +0.00			9	AV2 +0.00
		7	AV7 +0.00	108	49	8	AV5 +0.00	109	82	8	AV8 +0.00
106	107	5	AV3 +0.00	108	51	5	AV5 +0.00			11	AV1 +0.00
		5	AV5 +0.00	108	53	6	AV4 +0.03	109	88	14	AV8 +0.00
106	111	6	AV4 +0.15	108	69	12	AV2 +0.00			19	AV4 +0.00
106	113	6	AV2 +0.16			13	AV7 +0.00			13	AV3 +0.00
		5	AV3 +0.05	108	71	17	AV2 +0.00			11	AV2 +0.00
		9	AV4 +0.08			17	AV3 +0.00	109	92	11	AV8 +0.00
106	115	7	AV2 +0.00			19	AV4 +0.00			9	AV5 +0.00
106	121	6	AV5 +0.09			7	AV7 +0.00			10	AV2 +0.00
107	34	5	AV1 +0.28	108	73	11	AV1 +0.00	109	94	7	AV7 +0.00
107	44	7	AV5 +0.00			16	AV2 +0.00			5	AV4 +0.00
107	50	8	AV2 +0.00			15	AV3 +0.00			11	AV3 +0.00
		9	AV3 +0.00			17	AV4 +0.00			17	AV2 +0.00
		8	AV4 +0.00			12	AV5 +0.00			5	AV1 +0.00
		5	AV5 +0.00	108	75	19	AV7 +0.00	109	96	8	AV5 +0.00
107	66	5	AV3 +0.00			16	AV4 +0.00			16	AV4 +0.00
		6	AV4 +0.00			7	AV3 +0.00			12	AV3 +0.00
		7	AV6 +0.00	108	77	6	AV8 +0.00	109	98	6	AV7 +0.00
107	68	6	AV3 +0.00	108	79	13	AV6 +0.00			18	AV5 +0.00
		10	AV4 +0.00			16	AV5 +0.00			6	AV4 +0.00
		9	AV5 +0.00			16	AV4 +0.00			16	AV3 +0.00
		15	AV6 +0.00			8	AV3 +0.00			6	AV2 +0.00
107	76	7	AV8 +0.00	108	81	13	AV8 +0.00	109	100	14	AV8 +0.00
		18	AV6 +0.00			19	AV5 +0.00			5	AV3 +0.00
		7	AV5 +0.00			19	AV4 +0.00	109	102	5	AV2 +0.00
		10	AV4 +0.00	108	91	19	AV7 +0.00			19	AV7 +0.00
		7	AV2 +0.00			10	AV1 +0.00	109	104	10	AV4 +0.21
107	78	15	AV7 +0.00	108	93	7	AV1 +0.00			8	AV5 +0.02
		15	AV6 +0.00	108	97	12	AV6 +0.00			11	AV6 +0.05
		8	AV5 +0.00			14	AV5 +0.00			9	AV7 +0.07
		9	AV4 +0.00			18	AV4 +0.00			10	AV3 +0.14
		16	AV3 +0.00			7	AV3 +0.00	109	106	6	AV3 +0.00
		9	AV2 +0.00	108	99	12	AV1 +0.00	109	108	7	AV5 +0.00
107	86	19	AV5 +0.00			8	AV7 +0.00	109	112	5	AV3 +0.00
		14	AV2 +0.00	108	101	7	AV1 +0.00	110	45	7	AV5 +0.00
107	90	16	AV8 +0.00			11	AV4 +0.00	110	47	8	AV5 +0.00
		17	AV3 +0.00			6	AV6 +0.00	110	57	6	AV4 +0.00
		13	AV2 +0.00			9	AV7 +0.00	110	65	7	AV4 +0.00
107	96	6	AV8 +0.00	108	103	5	AV2 +0.00	110	67	6	AV2 +0.00
		18	AV6 +0.00			11	AV5 +0.00			5	AV6 +0.00
		5	AV5 +0.00			10	AV7 +0.00	110	69	7	AV2 +0.00
		16	AV4 +0.00	108	105	10	AV4 +0.00			6	AV3 +0.00
		13	AV2 +0.00			15	AV5 +0.00			7	AV4 +0.00
		9	AV1 +0.00			19	AV6 +0.00			17	AV5 +0.00
107	98	16	AV6 +0.00			7	AV7 +0.00	110	71	7	AV1 +0.00
		18	AV5 +0.00	108	107	7	AV3 +0.05	110	75	11	AV6 +0.00
		12	AV4 +0.00			6	AV4 +0.03	110	77	12	AV8 +0.00
		19	AV3 +0.00	108	109	7	AV3 +0.12			12	AV2 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
110	79	9	AV8 +0.00			7	AV4 +0.10			7	AV6 +0.00
		19	AV4 +0.00			12	AV5 +0.07	112	105	7	AV5 +0.00
		12	AV3 +0.00	111	104	6	AV2 +0.00	112	107	9	AV3 +0.00
		14	AV2 +0.00			11	AV3 +0.00	112	115	7	AV5 +0.00
110	81	16	AV6 +0.00			10	AV4 +0.00	112	121	7	AV5 +0.09
		8	AV3 +0.00			6	AV5 +0.00	112	127	8	AV5 +0.05
110	93	6	AV7 +0.00	111	106	6	AV4 +0.00	113	50	4	AV2 +0.00
		5	AV1 +0.00			6	AV6 +0.00			5	AV4 +0.00
110	95	14	AV5 +0.00			13	AV7 +0.00			5	AV5 +0.00
		19	AV3 +0.00	111	110	5	AV2 +0.00	113	56	6	AV2 +0.00
		9	AV1 +0.00			5	AV3 +0.00			6	AV4 +0.00
110	97	7	AV6 +0.00	111	126	7	AV5 +0.09	113	62	5	AV3 +0.00
110	99	7	AV7 +0.00	112	41	4	AV3 +0.12	113	70	7	AV3 +0.00
		17	AV3 +0.00			4	AV5 +0.00	113	74	12	AV2 +0.00
		7	AV2 +0.00			6	AV6 +0.00			8	AV3 +0.00
110	101	14	AV5 +0.09	112	43	6	AV2 +0.00			8	AV7 +0.00
110	103	7	AV1 +0.05			5	AV5 +0.00	113	76	19	AV6 +0.00
		15	AV2 +0.12	112	45	8	AV5 +0.00			10	AV4 +0.00
		18	AV6 +0.05	112	49	6	AV5 +0.00			10	AV2 +0.00
110	105	9	AV6 +0.07	112	51	5	AV4 +0.00	113	78	12	AV8 +0.00
110	109	6	AV3 +0.00			9	AV5 +0.00			14	AV3 +0.00
		6	AV4 +0.00	112	61	6	AV5 +0.00			13	AV2 +0.00
		7	AV5 +0.00	112	67	7	AV3 +0.00	113	80	7	AV5 +0.00
110	113	9	AV3 +0.00			6	AV5 +0.00			18	AV4 +0.00
110	115	6	AV4 +0.18			6	AV6 +0.00			19	AV3 +0.00
110	119	6	AV3 +0.00	112	69	7	AV3 +0.00			15	AV2 +0.00
110	123	7	AV2 +0.05			8	AV4 +0.00	113	88	19	AV3 +0.00
111	46	7	AV5 +0.00			16	AV5 +0.00			11	AV2 +0.00
111	56	9	AV7 +0.00			18	AV6 +0.00	113	90	12	AV2 +0.00
111	62	6	AV3 +0.00			10	AV7 +0.00	113	92	8	AV7 +0.00
111	66	6	AV3 +0.00	112	71	6	AV3 +0.00			10	AV1 +0.00
111	68	5	AV1 +0.00			6	AV4 +0.00	113	94	7	AV7 +0.00
		5	AV2 +0.00	112	73	6	AV2 -0.02			18	AV6 +0.00
		17	AV3 +0.00			10	AV3 +0.07			18	AV5 +0.00
		8	AV8 +0.00			16	AV5 +0.07			12	AV4 +0.00
111	70	7	AV3 +0.00			13	AV7 +0.09			8	AV3 +0.00
		9	AV4 +0.00			13	AV8 +0.09			6	AV1 +0.00
		16	AV5 +0.00	112	75	12	AV4 +0.00	113	96	10	AV3 +0.00
		7	AV6 +0.00			8	AV3 +0.00			8	AV2 +0.00
111	72	7	AV3 +0.00			6	AV2 +0.00	113	98	14	AV5 +0.00
		9	AV4 +0.00			13	AV7 +0.00			7	AV4 +0.00
		13	AV5 +0.00			12	AV6 +0.00			6	AV3 +0.00
111	74	18	AV4 +0.00	112	77	18	AV4 +0.00	113	100	6	AV1 +0.00
		9	AV7 +0.00			6	AV3 +0.00			14	AV4 +0.00
111	76	19	AV5 +0.00	112	79	11	AV8 +0.00	113	102	8	AV4 +0.00
		15	AV4 +0.00			18	AV2 +0.00			12	AV5 +0.00
		7	AV3 +0.00			6	AV1 +0.00			17	AV6 +0.00
111	78	17	AV8 +0.00	112	81	7	AV7 +0.00			7	AV7 +0.00
		19	AV2 +0.00			18	AV4 +0.00	113	108	9	AV2 +0.09
		8	AV1 +0.00			15	AV3 +0.00			10	AV6 +0.05
111	80	18	AV4 +0.00			7	AV2 +0.00	113	110	7	AV6 +0.09
111	82	19	AV7 +0.00	112	83	9	AV8 +0.00	113	114	6	AV6 +0.07
		15	AV6 +0.00			11	AV2 +0.00	113	120	6	AV2 +0.02
		14	AV3 +0.00	112	87	8	AV1 +0.00			6	AV3 +0.07
		5	AV2 +0.00			12	AV8 +0.00			8	AV4 +0.10
111	86	8	AV8 +0.00	112	93	18	AV5 +0.00	113	122	8	AV4 +0.16
		12	AV7 +0.00	112	95	12	AV4 +0.00	113	124	7	AV4 +0.05
		14	AV1 +0.00			9	AV3 +0.00	114	41	10	AV5 +0.00
111	94	19	AV8 +0.00			7	AV1 +0.00	114	49	8	AV7 +0.00
		15	AV4 +0.00	112	97	15	AV4 +0.00	114	59	12	AV5 +0.00
		11	AV1 +0.00			15	AV2 +0.00	114	67	13	AV6 +0.00
111	98	6	AV7 +0.00			6	AV1 +0.00			13	AV7 +0.00
		6	AV6 +0.00			10	AV5 +0.00	114	69	7	AV7 +0.00
		18	AV5 +0.00	112	99	12	AV7 +0.00	114	71	6	AV3 +0.00
		7	AV4 +0.00			15	AV6 +0.00			7	AV4 +0.00
		7	AV3 +0.00			13	AV5 +0.00			11	AV5 +0.00
		6	AV2 +0.00			14	AV4 +0.00	114	75	13	AV7 +0.00
		6	AV1 +0.00			6	AV1 +0.00			13	AV6 +0.00
111	100	6	AV2 +0.21	112	101	19	AV2 +0.00			10	AV3 +0.00
		7	AV3 +0.07	112	103	12	AV2 +0.00	114	77	7	AV7 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		11	AV6 +0.00			18	AV6 +0.07	116	97	9	AV3 +0.00
		12	AV5 +0.00			10	AV7 +0.09			7	AV2 +0.00
		17	AV4 +0.00	115	80	7	AV3 +0.00	116	99	6	AV6 +0.00
		11	AV2 +0.00			7	AV2 +0.00			6	AV3 +0.00
114	79	19	AV4 +0.00	115	82	9	AV8 +0.00			7	AV2 +0.00
		12	AV3 +0.00			18	AV7 +0.00			5	AV1 +0.00
114	81	9	AV7 +0.00			12	AV2 +0.00	116	129	7	AV4 +0.13
		12	AV6 +0.00	115	92	14	AV7 +0.00			9	AV5 +0.00
		13	AV5 +0.00			18	AV6 +0.00			8	AV6 +0.09
		17	AV4 +0.00			18	AV3 +0.00			8	AV8 +0.09
		17	AV2 +0.00			18	AV2 +0.00	117	44	10	AV5 +0.00
114	87	15	AV7 +0.00	115	94	10	AV6 +0.00			7	AV6 +0.00
		17	AV6 +0.00			6	AV3 +0.00	117	46	8	AV6 +0.00
		18	AV2 +0.00	115	96	7	AV6 +0.00	117	48	5	AV4 +0.00
114	91	18	AV8 +0.00			6	AV5 +0.00			8	AV5 +0.00
		16	AV2 +0.00			12	AV4 +0.00	117	58	9	AV5 +0.00
114	93	5	AV7 +0.00			10	AV3 +0.00	117	62	6	AV7 +0.04
		11	AV6 +0.00			10	AV2 -0.21	117	64	7	AV6 +0.00
		17	AV5 +0.00			7	AV1 +0.00	117	68	13	AV2 +0.00
		11	AV4 +0.00	115	102	13	AV1 +0.00			10	AV3 +0.00
		11	AV3 +0.00			16	AV4 +0.00			13	AV4 +0.00
114	95	13	AV2 +0.00			16	AV5 +0.00			13	AV7 +0.00
		8	AV7 +0.00			7	AV6 +0.00	117	70	16	AV7 +0.00
		7	AV5 +0.00	115	104	6	AV1 +0.09	117	72	7	AV8 +0.00
		12	AV3 +0.00			6	AV3 +0.30	117	76	11	AV7 +0.00
114	97	7	AV2 +0.00			7	AV4 +0.13			10	AV5 +0.00
		12	AV5 +0.00			11	AV6 +0.05	117	80	11	AV8 +0.00
		7	AV4 +0.00			9	AV7 +0.07			6	AV4 +0.00
		11	AV3 +0.00	115	126	7	AV3 +0.14			7	AV3 +0.00
114	101	10	AV6 +0.00			10	AV4 +0.13			11	AV2 +0.00
		13	AV7 +0.00	115	130	8	AV4 +0.13	117	92	14	AV7 +0.00
		7	AV3 +0.00			8	AV7 +0.07			19	AV6 +0.00
114	103	7	AV5 +0.00	116	41	5	AV6 +0.00			18	AV5 +0.00
		14	AV6 +0.00	116	47	5	AV3 +0.00			6	AV1 +0.00
		11	AV7 +0.00			5	AV5 +0.00	117	94	16	AV7 +0.00
114	105	7	AV6 +0.00	116	51	6	AV7 +0.00			18	AV4 +0.00
114	107	8	AV4 +0.08	116	57	9	AV3 +0.00			9	AV3 +0.00
114	111	8	AV3 +0.00			8	AV4 +0.00			6	AV2 +0.00
114	125	7	AV4 +0.23			7	AV5 +0.00	117	96	9	AV6 +0.00
		6	AV2 +0.16	116	59	8	AV5 +0.00	117	98	9	AV5 +0.00
115	40	7	AV2 +0.00	116	61	6	AV2 +0.00			9	AV4 +0.00
		6	AV5 +0.00			7	AV3 +0.00			7	AV3 +0.00
		7	AV6 +0.00			7	AV4 +0.00			7	AV2 +0.00
115	42	8	AV6 +0.00			5	AV5 +0.00	117	120	8	AV3 +0.00
115	48	10	AV5 +0.00			6	AV6 +0.00			7	AV4 +0.00
115	52	9	AV6 +0.00	116	69	5	AV3 +0.00			6	AV6 +0.00
115	58	7	AV2 +0.00	116	73	7	AV6 +0.00			4	AV7 +0.00
		7	AV3 +0.00	116	75	7	AV6 +0.00	117	124	16	AV6 +0.09
115	60	7	AV5 +0.00			12	AV5 +0.00	118	69	5	AV7 +0.00
115	66	6	AV1 +0.00			7	AV4 +0.00	118	73	8	AV5 +0.00
		15	AV3 +0.00			11	AV3 +0.00			14	AV6 +0.00
		10	AV4 +0.00			11	AV2 +0.00	118	77	13	AV7 +0.00
		12	AV5 +0.00	116	77	11	AV7 +0.00			13	AV4 +0.00
		16	AV7 +0.00			15	AV6 +0.00			8	AV3 +0.00
115	68	5	AV1 +0.00			16	AV5 +0.00			13	AV2 +0.00
		13	AV2 +0.00			6	AV4 +0.00			7	AV1 +0.00
		7	AV5 +0.00	116	81	12	AV7 +0.00	118	79	13	AV6 +0.00
		17	AV6 +0.00			11	AV2 +0.00			7	AV5 +0.00
115	70	12	AV2 +0.00	116	91	12	AV7 +0.00	118	81	10	AV7 +0.00
		7	AV3 +0.00			18	AV4 +0.00			12	AV4 +0.00
		7	AV4 +0.00			12	AV3 +0.00			9	AV3 +0.00
		11	AV5 +0.00			10	AV2 +0.00			8	AV2 +0.00
		9	AV6 +0.00	116	93	8	AV1 +0.00	118	91	10	AV8 +0.00
115	72	5	AV1 +0.00			18	AV7 +0.00			6	AV7 +0.00
		8	AV2 +0.00			16	AV6 +0.00			19	AV4 +0.00
		8	AV3 +0.00			8	AV4 +0.00			17	AV2 +0.00
		15	AV7 +0.00			13	AV2 +0.00	118	93	12	AV7 +0.00
		10	AV8 +0.00	116	95	18	AV7 +0.00			13	AV6 +0.00
115	74	12	AV1 +0.11			9	AV4 +0.00			13	AV5 +0.00
		16	AV4 +0.03			18	AV3 +0.00			10	AV3 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
118	109	6	AV6 +0.00	120	97	9	AV7 +0.00				
118	127	10	AV2 +0.12			14	AV6 +0.00	122	87	11	AV8 +0.00
		6	AV3 +0.05			11	AV5 +0.00			16	AV7 +0.00
		8	AV4 +0.18			8	AV4 +0.00			19	AV6 +0.00
		8	AV5 +0.02			8	AV3 +0.00			15	AV4 +0.00
		7	AV7 +0.02			9	AV2 +0.00			6	AV3 +0.00
119	54	5	AV6 +0.00	120	99	10	AV7 +0.00			8	AV2 +0.00
		4	AV7 +0.00			17	AV6 +0.00	122	93	5	AV1 +0.00
119	72	6	AV1 +0.00			7	AV1 +0.00	122	95	7	AV2 +0.00
		9	AV2 +0.00	120	103	9	AV6 +0.00	122	101	16	AV2 +0.09
		10	AV3 +0.00			14	AV2 +0.00			6	AV6 -0.14
		17	AV5 +0.00			5	AV3 +0.00	122	115	7	AV7 +0.07
		8	AV6 +0.00			14	AV4 +0.00	123	54	9	AV4 +0.00
119	74	7	AV1 +0.00	120	105	7	AV4 +0.00			7	AV6 +0.00
		9	AV2 +0.00			5	AV5 +0.09	123	62	5	AV6 +0.00
		6	AV3 +0.00			7	AV6 +0.00	123	72	13	AV3 +0.00
		6	AV4 +0.00	120	111	7	AV4 +0.00			14	AV4 +0.00
		16	AV6 +0.00			7	AV5 +0.00			18	AV7 +0.00
		8	AV7 +0.00	120	123	12	AV3 +0.14	123	74	7	AV3 +0.00
119	76	14	AV7 +0.00			7	AV4 +0.16			6	AV4 +0.00
		19	AV6 +0.00			7	AV5 +0.09			6	AV5 +0.00
		14	AV5 +0.00			14	AV6 +0.07			10	AV6 +0.00
		13	AV4 +0.00	121	76	6	AV6 +0.00			12	AV7 +0.00
119	78	10	AV8 +0.00	121	78	9	AV7 +0.00	123	76	11	AV7 +0.00
		11	AV7 +0.00			19	AV5 +0.00	123	78	7	AV7 +0.00
		9	AV6 +0.00			8	AV4 +0.00			6	AV6 +0.00
		5	AV5 +0.00			7	AV3 +0.00			7	AV3 +0.00
		5	AV4 -0.05			6	AV2 +0.00	123	80	14	AV8 +0.00
		6	AV3 +0.00	121	80	9	AV8 +0.00			16	AV7 +0.00
119	80	16	AV8 +0.00			10	AV6 +0.00			9	AV6 +0.00
		13	AV5 +0.00			7	AV5 +0.00			12	AV5 +0.00
		9	AV4 +0.00			6	AV4 +0.00			7	AV4 +0.00
		8	AV2 +0.00			5	AV2 +0.00			8	AV3 +0.00
119	88	11	AV8 +0.00	121	82	9	AV8 +0.00	123	88	9	AV7 +0.00
		17	AV6 +0.00			14	AV7 +0.00			14	AV6 +0.00
		10	AV5 +0.00			7	AV5 +0.00			19	AV4 +0.00
		6	AV2 +0.00			12	AV4 +0.00			11	AV2 +0.00
		11	AV1 +0.00			11	AV3 +0.00	123	90	14	AV5 +0.00
119	94	6	AV6 +0.00			7	AV2 +0.00			12	AV1 +0.00
		8	AV2 +0.00	121	90	7	AV7 +0.00	123	92	7	AV7 +0.00
119	96	13	AV4 +0.00			14	AV2 +0.00			15	AV5 +0.00
		10	AV3 +0.00			10	AV1 +0.00			11	AV4 +0.00
		13	AV2 +0.00	121	92	8	AV8 +0.00			17	AV3 +0.00
		9	AV1 +0.00			10	AV5 +0.00			14	AV2 +0.00
119	100	10	AV3 +0.00			7	AV1 +0.00			8	AV1 +0.00
		11	AV4 +0.00	121	94	10	AV8 +0.00	123	94	7	AV8 +0.00
		11	AV5 +0.00			7	AV3 +0.00			17	AV5 +0.00
119	106	6	AV4 +0.13	121	96	6	AV2 +0.00			14	AV4 +0.00
		6	AV5 +0.07	121	102	14	AV3 +0.00			10	AV3 +0.00
119	122	6	AV3 +0.11			7	AV4 +0.00			9	AV2 +0.00
		8	AV4 +0.00	121	110	6	AV4 +0.00	123	98	6	AV6 +0.00
		8	AV6 +0.02			7	AV5 +0.00			6	AV2 +0.00
120	73	11	AV6 +0.09	122	65	9	AV2 +0.00	123	104	11	AV3 +0.00
120	75	7	AV7 +0.00			7	AV3 +0.00			9	AV4 +0.00
120	77	6	AV2 +0.00			11	AV4 +0.00			8	AV6 +0.00
120	79	7	AV8 +0.00			6	AV5 +0.00	123	106	6	AV5 +0.00
		9	AV6 +0.00			6	AV4 +0.00			8	AV6 +0.00
		7	AV3 +0.00	122	67	6	AV4 +0.00			8	AV6 +0.00
						8	AV6 +0.00	124	55	12	AV4 +0.00
120	81	15	AV8 +0.00			9	AV7 +0.00			11	AV5 +0.00
		8	AV4 +0.00	122	73	6	AV7 +0.00			7	AV6 +0.00
		8	AV3 +0.00	122	75	11	AV7 +0.00			9	AV7 +0.00
120	91	13	AV7 +0.00			9	AV5 +0.00			6	AV8 +0.00
		11	AV6 +0.00	122	77	7	AV7 +0.00	124	63	10	AV2 +0.00
		18	AV3 +0.00	122	79	18	AV7 +0.00			19	AV3 +0.00
		18	AV2 +0.00			19	AV4 +0.00			6	AV5 +0.00
120	93	19	AV6 +0.00			10	AV2 +0.00	124	69	10	AV1 +0.00
		6	AV5 +0.00	122	81	8	AV4 +0.00			12	AV4 +0.00
		14	AV2 +0.00			8	AV3 +0.00			14	AV5 +0.00
120	95	8	AV7 +0.00			6	AV2 +0.00			9	AV8 +0.00
		6	AV2 +0.02	122	83	17	AV6 +0.00	124	71	12	AV3 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
	9		AV4 +0.00	125	92	7	AV8 +0.00	126	99	5	AV5 -0.08
	10		AV5 +0.00		6		AV7 +0.00	126	101	6	AV4 +0.00
	7		AV6 +0.00		17		AV4 +0.00	126	103	5	AV1 +0.00
	9		AV7 +0.00		10		AV3 +0.00		13		AV2 +0.00
	7		AV2 +0.00		7		AV2 +0.00		11		AV3 +0.00
124	73	7	AV3 +0.00	125	98	8	AV4 +0.00		10		AV4 +0.00
	7		AV5 +0.00		6		AV3 +0.00		13		AV5 +0.00
	16		AV7 +0.00		6		AV2 +0.00	126	105	15	AV3 +0.00
124	75	11	AV7 +0.00	125	102	7	AV3 +0.05		12		AV4 +0.00
	10		AV6 +0.00		11		AV5 +0.14	126	109	7	AV4 +0.10
	7		AV5 +0.00		10		AV6 +0.16	127	52	7	AV4 +0.00
	6		AV4 +0.00		7		AV7 +0.16	127	68	8	AV1 +0.00
124	77	19	AV7 +0.00	125	104	8	AV6 +0.00		5		AV3 +0.00
	16		AV6 +0.00	125	106	7	AV2 +0.12		11		AV4 +0.00
	6		AV5 +0.00		7		AV3 +0.09		6		AV7 +0.00
	6		AV4 +0.00		14		AV4 +0.03	127	70	6	AV3 +0.00
124	79	9	AV8 +0.00		8		AV5 +0.05		8		AV4 +0.00
	18		AV7 +0.00		10		AV6 +0.09		8		AV5 +0.00
124	87	11	AV7 +0.00	125	108	8	AV6 +0.09	127	72	6	AV6 +0.00
	16		AV6 +0.00	125	112	7	AV7 +0.00		6		AV7 +0.00
	7		AV3 +0.00	125	120	6	AV5 +0.00	127	74	7	AV7 +0.04
	12		AV2 +0.00		7		AV6 +0.12	127	76	9	AV7 +0.00
124	91	11	AV7 +0.00	126	55	6	AV4 +0.00		15		AV6 +0.00
	7		AV6 +0.00		6		AV5 +0.00		15		AV5 +0.00
	19		AV3 +0.00		8		AV8 +0.00		10		AV4 +0.00
124	93	8	AV6 +0.00	126	67	5	AV3 +0.00	127	80	15	AV7 +0.00
	16		AV5 +0.00		8		AV4 +0.00		7		AV6 +0.00
	8		AV4 +0.00		10		AV5 +0.00		6		AV5 +0.00
	8		AV3 +0.00		13		AV6 +0.00		7		AV4 +0.00
	6		AV2 +0.00	126	69	15	AV2 +0.00		6		AV3 +0.00
124	95	7	AV7 +0.00		18		AV3 +0.00	127	82	19	AV3 +0.00
	7		AV6 +0.00		10		AV4 +0.00		7		AV2 +0.00
	13		AV4 +0.00		12		AV5 +0.00	127	88	16	AV7 +0.00
	13		AV3 +0.00		13		AV6 +0.00		19		AV4 +0.00
	6		AV2 +0.00		7		AV8 +0.00		19		AV2 +0.00
124	97	6	AV2 -0.18	126	71	6	AV4 +0.00		9		AV1 +0.00
124	99	9	AV6 +0.00		7		AV7 +0.00	127	90	17	AV3 +0.00
	11		AV3 +0.00	126	73	7	AV2 +0.12		17		AV2 +0.00
	11		AV2 +0.00		5		AV7 -0.05		10		AV1 +0.00
124	105	7	AV4 +0.00	126	75	7	AV8 +0.00	127	92	14	AV7 +0.00
124	113	8	AV1 +0.07		11		AV7 +0.00		18		AV6 +0.00
125	50	6	AV6 +0.00		6		AV6 +0.00		8		AV1 +0.00
	7		AV7 +0.00		8		AV5 +0.00	127	94	7	AV7 +0.00
	8		AV8 +0.00		9		AV4 +0.00		8		AV6 +0.00
125	68	7	AV2 +0.00	126	77	9	AV4 +0.00		10		AV5 +0.00
	6		AV3 +0.00		6		AV3 +0.00		9		AV4 +0.00
	5		AV4 +0.00	126	79	13	AV7 +0.00		9		AV3 +0.00
	7		AV7 +0.00		6		AV6 +0.00		6		AV2 +0.00
125	72	7	AV5 +0.00		10		AV5 +0.00		7		AV1 +0.00
	8		AV7 +0.00		6		AV4 +0.00	127	96	5	AV2 -0.23
125	74	5	AV2 +0.00	126	91	19	AV8 +0.00		8		AV1 +0.00
	13		AV4 +0.00		19		AV4 +0.00		11		AV3 +0.00
	15		AV5 +0.00		13		AV2 +0.00	127	100	5	AV2 +0.00
	16		AV6 +0.00		5		AV1 +0.00		12		AV4 +0.00
125	76	6	AV7 +0.00	126	93	6	AV6 +0.12	127	102	7	AV2 +0.00
	8		AV3 +0.00		13		AV5 +0.00		9		AV3 +0.00
125	78	7	AV7 +0.00		7		AV4 +0.00		9		AV4 +0.00
125	80	16	AV8 +0.00		6		AV3 +0.00	127	108	6	AV2 +0.00
	10		AV6 +0.00		11		AV2 +0.00		7		AV3 +0.00
	17		AV5 +0.00	126	95	10	AV3 +0.00		7		AV5 +0.00
	17		AV4 +0.00		12		AV2 +0.00	127	118	6	AV8 -0.07
	17		AV3 +0.00		12		AV8 +0.00	128	53	5	AV8 +0.00
	6		AV2 +0.00		10		AV7 +0.00	128	67	6	AV1 +0.00
125	82	18	AV3 +0.00		9		AV6 +0.00		9		AV7 +0.00
	9		AV2 +0.00		6		AV5 +0.05	128	69	8	AV5 +0.00
125	88	11	AV3 +0.00	126	97	17	AV6 -0.05	128	73	10	AV5 +0.00
	14		AV2 +0.00		9		AV5 +0.00		12		AV7 +0.00
125	90	11	AV8 +0.00		13		AV4 +0.00	128	75	6	AV7 +0.00
	18		AV3 +0.00		16		AV3 +0.00		7		AV6 +0.00
	17		AV2 +0.00		9		AV2 +0.00	128	77	8	AV7 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
128	79	6	AV8 +0.00			6	AV4 +0.00	15			AV2 +0.00
		14	AV7 +0.00			9	AV3 +0.00	7			AV1 +0.00
		8	AV5 +0.00			8	AV2 +0.00	11			AV8 +0.00
128	87	12	AV8 +0.00	129	100	9	AV6 +0.09	18			AV6 +0.00
		16	AV7 +0.00	129	104	6	AV1 +0.00	131	96	6	AV6 +0.00
		18	AV6 +0.00			6	AV4 +0.00	8			AV5 +0.00
128	93	19	AV5 +0.00			8	AV5 +0.00	7			AV4 +0.00
		8	AV4 +0.00			16	AV6 +0.00	6			AV2 +0.00
		13	AV3 +0.00			18	AV7 +0.00	131	98	8	AV7 +0.00
		9	AV2 +0.00	129	106	7	AV4 +0.00	6			AV6 +0.00
128	95	8	AV8 +0.00			10	AV5 +0.00	7			AV4 +0.00
		14	AV5 +0.00	130	69	9	AV5 +0.00	6			AV2 +0.00
		7	AV4 +0.00			5	AV6 +0.00	131	102	6	AV3 +0.05
		6	AV3 -0.02	130	71	7	AV3 +0.00	12			AV7 +0.07
		8	AV2 +0.00			8	AV4 +0.00	132	67	8	AV5 +0.00
128	97	6	AV6 +0.00			6	AV5 +0.00			18	AV6 +0.00
		10	AV4 +0.00			12	AV6 +0.00			10	AV8 +0.00
128	99	11	AV8 +0.00	130	73	6	AV6 +0.00	132	69	9	AV4 +0.00
		18	AV6 -0.07			10	AV7 +0.00	7			AV5 +0.00
		7	AV5 +0.00	130	75	10	AV7 +0.00			14	AV7 +0.00
		13	AV4 +0.00			7	AV5 +0.00	132	71	11	AV7 +0.00
		13	AV3 +0.00			9	AV4 +0.00			11	AV8 +0.00
		16	AV2 +0.00			9	AV3 +0.00	132	73	8	AV6 -0.14
128	101	6	AV3 -0.05	130	79	10	AV8 +0.00	12			AV7 +0.09
		9	AV4 +0.08			8	AV4 +0.00	9			AV8 +0.12
		13	AV5 +0.05			10	AV3 +0.00	132	75	10	AV8 +0.00
		9	AV6 +0.07	130	81	11	AV7 +0.00	12			AV7 +0.00
128	103	8	AV2 +0.07			8	AV3 +0.00	6			AV6 +0.00
128	107	7	AV5 +0.00			11	AV2 +0.00	132	77	6	AV8 +0.00
		12	AV6 +0.00	130	93	13	AV8 +0.02	5			AV7 +0.00
128	109	7	AV4 +0.00			14	AV6 +0.00	10			AV6 +0.00
		7	AV5 +0.00			12	AV5 +0.00	7			AV5 +0.00
128	117	11	AV5 +0.07	130	95	12	AV8 +0.07	6			AV3 +0.00
		18	AV8 +0.12			9	AV5 +0.00	132	79	7	AV8 +0.00
129	66	7	AV3 +0.00			14	AV4 +0.00	15			AV4 +0.00
		8	AV5 +0.00			13	AV3 +0.00	11			AV3 +0.00
129	68	7	AV7 +0.00			8	AV2 +0.00	132	81	11	AV5 +0.00
129	70	7	AV7 +0.00			7	AV1 +0.00	18			AV8 +0.00
129	74	9	AV2 +0.00	130	97	15	AV5 +0.00	16			AV7 +0.00
		13	AV4 +0.00			9	AV4 +0.00	132	85	9	AV6 +0.00
		14	AV5 +0.00			18	AV3 +0.00	132	87	14	AV7 +0.00
		11	AV6 +0.00			19	AV2 +0.00	19			AV6 +0.00
		6	AV7 +0.00			7	AV1 +0.00	13			AV5 +0.00
129	78	7	AV8 +0.00	130	101	7	AV2 +0.00	7			AV4 +0.00
		12	AV7 +0.00			10	AV3 +0.00	7			AV3 +0.00
		6	AV5 +0.00			14	AV4 +0.00	6			AV2 +0.00
		6	AV2 +0.00			9	AV5 +0.00	132	93	12	AV5 +0.00
129	80	17	AV3 +0.00	130	113	8	AV8 -0.07	13			AV4 +0.00
		15	AV2 +0.00	131	68	6	AV2 +0.00	17			AV3 +0.00
		5	AV1 +0.00			6	AV3 +0.00	14			AV2 +0.00
129	82	17	AV8 +0.00	131	70	7	AV5 +0.00	132	95	9	AV7 +0.00
129	86	8	AV8 +0.00			12	AV7 +0.00	5			AV5 +0.00
		18	AV6 +0.00	131	74	9	AV2 +0.00	7			AV2 +0.02
		7	AV5 +0.00			5	AV3 +0.00	132	97	9	AV7 +0.00
129	88	11	AV8 +0.00			12	AV8 +0.00	8			AV6 +0.00
		18	AV6 +0.00	131	76	7	AV6 +0.00	9			AV5 +0.00
		11	AV4 +0.00			11	AV5 +0.00	14			AV4 +0.00
		7	AV3 +0.00			8	AV4 +0.00	13			AV3 +0.00
		6	AV2 +0.00	131	78	7	AV7 +0.00	7			AV2 +0.00
		6	AV1 +0.00			16	AV3 +0.00	132	99	14	AV5 +0.00
129	94	7	AV7 +0.00	131	82	13	AV8 +0.00	8			AV4 +0.00
		7	AV5 +0.00			18	AV6 +0.00	7			AV2 -0.20
		10	AV3 +0.00			13	AV5 +0.00	132	101	7	AV4 +0.00
		11	AV2 +0.00			19	AV4 +0.00	133	68	7	AV1 +0.00
129	96	6	AV5 +0.00	131	88	9	AV8 +0.00	17			AV3 +0.00
		9	AV4 +0.00			9	AV6 +0.00	7			AV4 +0.00
		7	AV2 +0.00			16	AV3 +0.00	8			AV5 +0.00
		7	AV1 +0.00	131	92	18	AV5 +0.00	16			AV7 +0.00
129	98	7	AV7 +0.00			13	AV4 +0.00	16			AV8 +0.00
		17	AV5 +0.00	131	94	7	AV5 +0.00	133	70	7	AV6 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
133	72	12	AV8 +0.00	134	85	11	AV7 +0.07	136	75	7	AV8 +0.00
		12	AV3 +0.00			12	AV6 +0.00			7	AV8 +0.00
		12	AV4 +0.00			9	AV5 +0.00			7	AV8 +0.00
		13	AV5 +0.00			8	AV4 +0.00			8	AV4 +0.00
		15	AV6 +0.00			12	AV3 +0.00			8	AV3 +0.00
		17	AV7 +0.00	134	87	18	AV7 +0.00			7	AV2 +0.00
133	74	6	AV2 -0.02			7	AV4 +0.00			8	AV1 +0.00
		11	AV4 +0.00			14	AV3 +0.00	136	77	7	AV2 +0.00
		8	AV6 -0.14			12	AV2 +0.00			18	AV8 +0.00
		19	AV7 +0.04	134	89	6	AV8 +0.00			13	AV7 +0.00
		12	AV8 +0.09			14	AV7 +0.00			9	AV6 +0.00
133	76	7	AV7 +0.00			13	AV6 +0.00			16	AV5 +0.00
		12	AV5 +0.00			6	AV5 +0.00			19	AV4 +0.00
		16	AV4 +0.00	134	93	6	AV8 +0.00			10	AV3 +0.00
		6	AV3 +0.00			7	AV6 +0.00	136	79	6	AV8 +0.00
		6	AV2 +0.00			16	AV5 +0.00			6	AV7 +0.00
		6	AV1 +0.00			10	AV4 +0.00	136	81	13	AV8 +0.00
133	78	8	AV8 +0.00			7	AV3 +0.00			9	AV7 +0.00
		6	AV7 +0.00			8	AV2 +0.00			13	AV6 +0.00
		7	AV6 +0.00	134	95	7	AV6 +0.00			7	AV5 +0.00
		12	AV5 +0.00			10	AV4 +0.00			6	AV3 +0.00
		7	AV4 +0.00	134	97	6	AV6 +0.00			6	AV2 +0.00
		7	AV3 +0.00			9	AV5 +0.00	136	83	9	AV8 +0.00
133	86	16	AV4 +0.00			11	AV4 +0.00			12	AV2 +0.00
		7	AV1 +0.00			13	AV2 +0.00	136	85	14	AV7 +0.00
133	88	14	AV7 +0.00			13	AV1 +0.00			12	AV6 +0.00
		19	AV6 +0.00	134	103	9	AV4 +0.21			9	AV4 +0.00
		6	AV5 +0.00			10	AV5 +0.09			7	AV3 +0.00
		7	AV4 +0.00			8	AV6 +0.16	136	91	14	AV8 +0.00
		6	AV3 +0.00			7	AV7 +0.22			12	AV6 +0.00
		6	AV2 +0.00	135	70	6	AV2 +0.00			18	AV4 +0.00
133	92	10	AV8 +0.00			19	AV3 +0.00			17	AV2 +0.00
		14	AV6 +0.00			8	AV7 +0.00			7	AV1 +0.00
		10	AV5 +0.00	135	72	7	AV4 +0.00	136	93	6	AV8 +0.05
		6	AV1 +0.00			7	AV5 +0.00			15	AV5 +0.00
133	94	9	AV7 +0.00			7	AV6 +0.00			16	AV2 +0.00
		14	AV6 +0.00			9	AV7 +0.00			11	AV1 +0.00
		11	AV5 +0.00	135	74	5	AV1 +0.00	136	95	8	AV6 +0.00
		17	AV4 +0.00			4	AV2 +0.00			7	AV4 +0.00
		13	AV3 +0.00			7	AV5 +0.00			6	AV2 -0.16
133	96	7	AV5 +0.00			6	AV6 +0.00	137	74	13	AV6 +0.14
		5	AV1 +0.00			6	AV7 +0.38			9	AV7 +0.22
133	102	5	AV7 +0.00			6	AV8 +0.37			14	AV8 +0.14
134	65	7	AV8 +0.00	135	78	7	AV7 +0.00	137	76	7	AV7 +0.00
134	67	8	AV2 +0.00			15	AV6 +0.00	137	78	7	AV7 +0.00
		14	AV4 +0.00			18	AV3 +0.00	137	84	12	AV8 +0.00
		13	AV5 +0.00	135	80	9	AV7 +0.00			19	AV7 +0.00
		7	AV6 +0.00			6	AV2 +0.00	137	86	8	AV8 +0.00
		9	AV7 +0.00	135	90	18	AV6 +0.00			10	AV7 +0.00
134	69	9	AV6 +0.00			17	AV3 +0.00	137	92	15	AV7 +0.00
		9	AV7 +0.00			8	AV1 +0.00			9	AV6 +0.00
		9	AV8 +0.00	135	92	7	AV1 +0.00			6	AV3 +0.00
134	71	8	AV7 +0.00	135	94	9	AV8 +0.00	137	94	9	AV8 +0.00
134	73	15	AV2 +0.00			19	AV7 +0.00			12	AV7 +0.00
		11	AV3 +0.00			8	AV6 +0.00			8	AV6 -0.16
		16	AV4 +0.00			7	AV4 +0.00			6	AV5 +0.00
		17	AV5 +0.00			6	AV3 +0.00	137	96	9	AV6 +0.00
		18	AV7 +0.00			7	AV2 +0.00	138	73	9	AV7 +0.29
134	75	7	AV7 +0.00			8	AV1 +0.00			10	AV6 +0.26
		14	AV6 +0.00	135	96	17	AV8 +0.00	138	75	9	AV8 +0.00
		9	AV5 +0.00			7	AV7 +0.00			8	AV7 +0.00
		6	AV4 +0.00			11	AV6 +0.00			6	AV6 +0.00
134	77	6	AV7 +0.00			6	AV2 +0.00	138	77	12	AV7 +0.00
		7	AV6 +0.00	136	71	8	AV5 +0.00			10	AV5 +0.00
134	79	7	AV3 -0.16			9	AV8 +0.00			7	AV4 +0.00
		10	AV8 +0.00	136	73	7	AV2 +0.00	138	79	7	AV8 +0.00
		7	AV7 +0.00			5	AV3 +0.00			8	AV7 +0.00
134	83	8	AV8 +0.00			12	AV4 +0.00			13	AV6 +0.00
		11	AV4 +0.00			8	AV5 +0.00			19	AV5 +0.00
		7	AV3 +0.00			6	AV6 +0.00			7	AV4 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION
138	83	8	AV8 +0.00
		10	AV5 +0.00
138	85	6	AV8 +0.09
		8	AV7 +0.00
		13	AV6 +0.00
		7	AV4 +0.00
138	87	7	AV7 +0.00
138	89	9	AV8 +0.00
138	91	8	AV1 +0.00
138	93	5	AV8 +0.00
		11	AV7 +0.00

ROW	COL	%TW	LOCATION
		18	AV6 +0.00
		6	AV5 +0.00
139	78	9	AV7 +0.00
		14	AV6 +0.00
		18	AV4 +0.00
		10	AV3 +0.00
		7	AV2 +0.00
139	86	8	AV8 +0.00
		12	AV7 +0.00
		6	AV6 +0.00
139	92	12	AV4 +0.00

ROW	COL	%TW	LOCATION
		7	AV3 +0.00
		12	AV2 -0.23
		5	AV8 +0.09
		12	AV6 +0.00
		7	AV5 +0.00

Total Tubes : 2598
Total Records: 6747

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 20-39%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
44	163	21	AV7 -0.24					74	93	21	AV5 +0.11
51	162	26	AV6 +0.18	70	105	21	AV3 +0.00	74	97	26	AV3 +0.13
53	162	20	AV6 +0.00	70	109	27	AV7 +0.00			20	AV4 -0.02
54	9	21	AV3 -0.18			27	AV6 +0.00			26	AV5 +0.13
55	160	21	AV3 +0.21	71	76	23	AV6 +0.00			21	AV6 +0.07
56	9	20	AV6 +0.22			26	AV7 +0.00	74	101	20	AV4 +0.03
56	161	30	AV6 -0.37	71	98	20	AV5 -0.04			21	AV5 +0.09
57	158	20	AV6 -0.47	71	102	24	AV4 +0.00			25	AV6 +0.09
59	160	24	AV6 -0.34			22	AV3 +0.00	74	103	23	AV3 +0.00
60	153	20	AV6 -0.33	71	104	23	AV6 -0.02	74	109	22	AV8 +0.00
60	157	25	AV7 -0.02	71	108	20	AV3 -0.05			32	AV7 +0.00
		23	AV6 -0.10	72	67	20	AV2 +0.00			31	AV6 +0.00
61	116	23	AV6 +0.00			24	AV3 +0.00			36	AV5 +0.00
61	156	20	AV8 -0.21	72	75	26	AV6 +0.00	74	111	23	AV6 +0.00
		25	AV6 -0.08			22	AV7 +0.00			26	AV5 +0.00
62	11	23	AV6 -0.20	72	79	24	AV6 +0.00	74	145	24	AV2 -0.05
		22	AV7 +0.05			26	AV8 +0.00	75	72	20	AV4 +0.00
62	105	23	AV6 +0.00	72	101	21	AV5 +0.06			28	AV5 +0.00
62	107	23	AV6 +0.00			28	AV6 +0.09			25	AV6 +0.00
63	12	31	AV3 +0.05	72	103	23	AV7 +0.02	75	76	22	AV4 +0.00
63	114	21	AV6 -0.05			27	AV6 +0.00			25	AV5 +0.00
63	146	21	AV6 -0.10			32	AV5 +0.02	75	86	24	AV3 +0.22
64	13	22	AV6 +0.00			25	AV3 -0.02			20	AV7 +0.00
64	155	26	AV3 +0.03	72	105	22	AV3 -0.05	75	88	20	AV5 +0.07
65	12	22	AV6 -0.33	72	107	27	AV6 +0.02	75	94	29	AV4 +0.06
65	108	20	AV6 +0.00	72	109	22	AV6 -0.04			25	AV5 +0.07
65	110	20	AV6 -0.10			26	AV5 -0.07			22	AV6 +0.07
65	152	22	AV6 +0.00	73	18	26	AV4 +0.33	75	96	26	AV4 +0.00
66	13	26	AV6 +0.00	73	74	35	AV4 +0.00			23	AV5 +0.09
66	15	23	AV3 +0.00			24	AV5 +0.00			25	AV6 +0.07
		20	AV6 +0.00			29	AV6 +0.00	75	98	20	AV4 +0.00
66	99	25	AV6 +0.07			28	AV7 +0.00	75	100	22	AV6 +0.09
66	103	31	AV7 +0.00	73	76	23	AV4 +0.00			23	AV7 +0.05
		27	AV6 +0.00			28	AV5 +0.00	75	102	28	AV6 +0.00
66	105	25	AV6 +0.00			21	AV6 +0.00			37	AV5 +0.00
66	153	20	AV3 +0.00			26	AV7 +0.00			33	AV4 +0.00
67	52	20	AV6 +0.07			22	AV3 +0.00	75	104	35	AV6 -0.02
67	74	25	AV6 +0.00	73	88	20	AV3 +0.11			33	AV5 -0.03
		21	AV7 +0.00			21	AV5 +0.11			24	AV3 -0.05
67	102	21	AV6 +0.00	73	94	21	AV5 +0.04			20	AV2 -0.02
		24	AV3 +0.00			20	AV6 +0.02	75	106	20	AV6 -0.02
67	104	27	AV6 +0.00	73	96	20	AV5 +0.11			22	AV5 -0.03
		25	AV3 -0.05			20	AV6 +0.07			22	AV4 -0.07
67	110	20	AV6 +0.00	73	98	24	AV5 +0.11	75	108	26	AV4 -0.07
		20	AV3 +0.00	73	102	21	AV7 -0.07			25	AV3 -0.02
67	146	26	AV3 -0.07			28	AV6 +0.00	75	116	21	AV5 -0.29
67	148	21	AV6 -0.07			36	AV5 +0.00	76	59	20	AV4 +0.00
		24	AV3 +0.02			32	AV4 -0.11			24	AV5 +0.00
67	154	26	AV6 -0.05	73	104	30	AV6 +0.00			24	AV6 +0.00
		28	AV3 -0.02			30	AV5 +0.00	76	71	20	AV3 +0.00
68	75	23	AV3 +0.00	73	106	21	AV3 +0.00			24	AV4 +0.00
		33	AV6 +0.00	73	108	21	AV3 +0.00	76	75	21	AV3 +0.00
68	101	23	AV6 +0.07	73	116	26	AV5 +0.00			23	AV4 +0.00
68	111	20	AV7 -0.05	74	67	24	AV6 +0.00			35	AV5 +0.00
		32	AV6 -0.07			21	AV7 +0.00			35	AV6 +0.00
68	115	30	AV7 +0.00	74	71	22	AV4 +0.00			24	AV7 +0.00
		28	AV6 -0.05			31	AV6 +0.00	76	81	23	AV3 +0.00
68	147	22	AV6 -0.05			33	AV7 +0.00			27	AV4 +0.00
68	155	25	AV3 +0.00			22	AV8 +0.00			28	AV5 +0.00
		24	AV8 -0.18	74	73	24	AV3 +0.00			28	AV6 +0.00
		34	AV7 -0.05			26	AV4 +0.00			21	AV7 +0.00
		26	AV6 -0.28			25	AV5 +0.00	76	87	25	AV3 +0.14
68	157	20	AV7 -0.07			21	AV6 +0.00			22	AV4 +0.06
		29	AV6 -0.09	74	77	20	AV5 +0.00			26	AV5 +0.11
69	88	20	AV3 +0.25			23	AV6 +0.00			23	AV6 +0.09
		26	AV6 +0.05	74	81	21	AV3 +0.00	76	89	22	AV3 +0.07
69	104	27	AV6 +0.00			21	AV4 +0.00			20	AV5 +0.07
69	108	21	AV7 +0.00	74	87	22	AV5 +0.09	76	97	20	AV4 +0.05
		30	AV6 +0.00	74	89	27	AV3 +0.15			33	AV5 +0.11
		23	AV3 +0.00			20	AV5 +0.11			24	AV6 +0.09
69	154	22	AV6 +0.00			28	AV6 +0.05	76	99	21	AV2 +0.14
70	101	31	AV6 +0.07			22	AV7 +0.07			31	AV5 +0.09

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 20-39%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		23	AV6 +0.07			20	AV3 +0.00			33	AV4 +0.00
76	103	23	AV7 -0.07	78	69	23	AV3 +0.00			28	AV3 +0.00
		22	AV5 +0.05			28	AV4 +0.00	79	104	22	AV5 +0.00
		20	AV4 -0.11			24	AV5 +0.00			25	AV3 +0.00
		20	AV2 -0.02			22	AV6 +0.00			22	AV2 +0.00
76	105	29	AV5 +0.05	78	73	23	AV3 +0.00	79	106	25	AV6 -0.05
		33	AV4 -0.09			25	AV5 +0.00			29	AV5 +0.00
		26	AV3 +0.00			26	AV6 +0.00			33	AV4 +0.00
76	107	24	AV6 -0.02			23	AV7 +0.00			20	AV3 -0.07
		25	AV4 -0.09	78	75	21	AV3 +0.00	79	108	21	AV3 +0.00
		20	AV3 -0.02			28	AV5 +0.00			24	AV7 -0.07
76	109	24	AV6 +0.00			28	AV6 +0.00			27	AV4 +0.03
		30	AV5 +0.00			30	AV7 +0.00	79	110	20	AV3 +0.00
76	111	21	AV7 +0.07	78	77	21	AV4 +0.00	80	69	24	AV4 +0.00
		25	AV6 -0.05			28	AV5 +0.00			23	AV5 +0.00
		24	AV5 +0.00			25	AV6 +0.00			22	AV6 +0.00
		22	AV4 +0.00	78	79	20	AV4 +0.00			22	AV7 +0.00
77	18	21	AV4 +0.21			26	AV6 +0.00	80	71	36	AV4 +0.00
77	72	28	AV5 +0.00	78	89	26	AV3 +0.11			36	AV5 +0.00
		25	AV6 +0.00			27	AV4 +0.05			26	AV6 +0.00
77	74	27	AV4 +0.00			31	AV5 +0.09			28	AV7 +0.00
		27	AV5 +0.00			28	AV6 +0.07	80	73	20	AV5 +0.00
		25	AV6 +0.00	78	95	25	AV3 +0.11			23	AV6 +0.00
77	76	20	AV3 +0.00			24	AV4 +0.05	80	75	28	AV5 +0.00
		30	AV4 +0.00	78	97	26	AV3 +0.18			28	AV6 +0.00
		30	AV5 +0.00			22	AV4 +0.11			31	AV7 +0.00
		21	AV6 +0.00			35	AV5 +0.09	80	77	26	AV3 +0.00
77	78	22	AV4 +0.00			32	AV6 +0.05			28	AV4 +0.00
		21	AV5 +0.00			20	AV7 +0.04			22	AV5 +0.00
77	80	27	AV3 +0.00	78	99	21	AV2 +0.12			26	AV6 +0.00
		24	AV4 +0.00			23	AV3 +0.09	80	83	25	AV5 +0.07
		30	AV5 +0.00			36	AV5 +0.09			24	AV6 +0.07
		27	AV6 +0.00			35	AV6 +0.09			23	AV7 +0.04
		29	AV7 +0.00			21	AV7 +0.07	80	85	21	AV6 -0.02
77	88	22	AV7 +0.04	78	101	30	AV4 +0.05	80	87	20	AV3 +0.18
77	90	22	AV4 +0.11			31	AV5 +0.07			27	AV4 +0.08
		26	AV5 +0.07			29	AV6 +0.09			20	AV6 +0.00
77	92	25	AV3 +0.14	78	107	21	AV6 +0.00	80	89	28	AV3 +0.16
		26	AV4 +0.08	78	111	24	AV6 +0.00			30	AV4 +0.16
		29	AV5 +0.05			22	AV5 +0.00			32	AV5 +0.05
		30	AV6 +0.05			20	AV4 +0.00			29	AV6 +0.02
		24	AV7 +0.00	78	113	24	AV6 +0.00	80	91	20	AV6 +0.07
77	94	22	AV5 +0.05	79	72	27	AV5 +0.00	80	93	29	AV4 +0.11
		25	AV6 +0.07			30	AV6 +0.00			30	AV5 +0.09
77	96	21	AV6 +0.02	79	74	21	AV4 +0.00	80	95	23	AV3 +0.11
77	98	22	AV2 +0.21			26	AV5 +0.00			28	AV4 +0.03
		25	AV3 +0.18			33	AV6 +0.00			28	AV5 +0.05
		36	AV4 +0.08			26	AV7 +0.00	80	99	27	AV5 +0.07
		37	AV5 +0.09	79	76	24	AV4 +0.00			28	AV6 +0.07
77	100	25	AV3 +0.16			31	AV5 +0.00			22	AV7 +0.05
		24	AV6 +0.09			26	AV6 +0.00	80	101	20	AV2 +0.09
		23	AV7 +0.04			29	AV7 +0.00			25	AV3 +0.05
77	102	28	AV6 +0.00	79	78	20	AV4 +0.00			34	AV4 +0.03
		30	AV5 +0.00			20	AV6 +0.00			34	AV5 +0.09
		27	AV4 -0.07			24	AV7 +0.00			28	AV6 +0.09
77	104	32	AV6 +0.00	79	80	24	AV5 +0.00	80	105	20	AV5 +0.00
		29	AV5 +0.00			23	AV6 +0.00	80	107	25	AV6 +0.00
		21	AV3 +0.00	79	86	32	AV3 +0.14	80	109	31	AV6 +0.00
77	106	27	AV6 +0.00	79	90	20	AV6 +0.07			38	AV5 +0.02
		29	AV5 +0.00	79	92	30	AV3 +0.09			28	AV4 -0.02
		35	AV4 +0.00			27	AV4 +0.03			24	AV3 -0.02
77	108	24	AV5 +0.00			25	AV5 +0.07	80	111	27	AV4 +0.03
		26	AV4 +0.00			30	AV6 +0.07	80	115	22	AV6 +0.00
77	112	23	AV7 +0.00	79	94	22	AV3 +0.20	81	70	21	AV3 +0.00
		22	AV6 +0.00			23	AV4 +0.11			23	AV6 +0.00
		21	AV5 +0.00			21	AV5 +0.00	81	72	20	AV2 +0.00
		24	AV4 +0.00			26	AV7 +0.00			24	AV3 +0.00
77	114	30	AV5 +0.00	79	96	28	AV6 +0.07			27	AV4 +0.00
		23	AV4 +0.00	79	100	25	AV2 +0.09			35	AV5 +0.00
77	116	21	AV6 +0.00			35	AV4 +0.05			36	AV6 +0.00
		34	AV5 +0.00	79	102	23	AV6 +0.00			27	AV7 +0.00
		24	AV4 +0.00			31	AV5 +0.00	81	74	21	AV6 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 20-39%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
81	76	31	AV4 +0.00	82	101	20	AV3 +0.09			21	AV5 -0.08
		31	AV5 +0.00			34	AV4 +0.08			21	AV4 -0.02
81	78	32	AV4 +0.00			38	AV5 +0.07	83	108	29	AV6 -0.02
		29	AV5 +0.00			34	AV6 +0.07			24	AV5 +0.00
		24	AV6 +0.00			27	AV7 +0.04			22	AV4 +0.00
81	82	23	AV3 +0.07	82	107	23	AV7 +0.00			22	AV3 +0.00
		31	AV4 +0.03			27	AV6 +0.00	83	110	22	AV5 +0.00
		28	AV5 +0.07	82	117	23	AV6 +0.00	84	67	24	AV4 +0.00
		28	AV6 +0.05			25	AV5 +0.00			22	AV5 +0.00
		28	AV7 +0.05	83	64	24	AV6 +0.00	84	69	26	AV4 +0.00
81	88	22	AV5 +0.05	83	68	26	AV6 +0.00			32	AV5 +0.00
81	92	20	AV3 +0.11			21	AV7 +0.00			28	AV6 +0.00
81	94	23	AV3 +0.11	83	72	33	AV5 +0.00			27	AV7 +0.00
		25	AV4 +0.03			28	AV6 +0.00	84	71	24	AV3 +0.00
		27	AV5 +0.09			31	AV7 +0.00			27	AV4 +0.00
81	96	31	AV6 +0.07	83	74	25	AV5 +0.00			23	AV5 +0.00
		21	AV4 +0.08			27	AV6 +0.00	84	73	23	AV3 +0.00
81	100	22	AV3 +0.09	83	76	32	AV3 +0.00			27	AV4 +0.00
		31	AV4 +0.05			28	AV4 +0.00			23	AV5 +0.00
		24	AV5 +0.09			35	AV5 +0.00			30	AV6 +0.00
		26	AV6 +0.09			35	AV6 +0.00			20	AV7 +0.00
81	102	32	AV6 +0.02			22	AV7 +0.00	84	75	28	AV3 +0.00
		31	AV4 -0.05	83	78	20	AV3 +0.00			27	AV4 +0.00
81	108	22	AV3 +0.00			35	AV4 +0.00	84	79	24	AV3 +0.00
81	110	22	AV5 -0.03			28	AV5 +0.00			26	AV5 +0.00
82	67	27	AV2 +0.00			24	AV6 +0.00			29	AV6 +0.00
		28	AV3 +0.00			20	AV7 +0.00	84	81	33	AV5 +0.00
		25	AV4 +0.00	83	80	21	AV5 +0.00			21	AV6 +0.00
		26	AV5 +0.00			29	AV6 +0.00	84	83	22	AV6 +0.00
		29	AV6 +0.00			25	AV7 +0.00	84	85	22	AV3 +0.07
		21	AV7 +0.00	83	84	22	AV5 +0.00			28	AV4 +0.05
82	69	23	AV4 +0.00	83	86	24	AV5 +0.00			29	AV5 +0.05
		26	AV5 +0.00			27	AV6 +0.00			31	AV6 +0.09
		22	AV6 +0.00			24	AV7 +0.00			22	AV7 +0.07
		22	AV7 +0.00	83	88	25	AV4 +0.03	84	87	29	AV3 +0.07
82	77	33	AV6 +0.00			30	AV5 +0.07			32	AV4 +0.05
		30	AV7 +0.00			25	AV6 +0.07			28	AV5 +0.05
82	79	29	AV3 +0.00			26	AV7 +0.05			28	AV6 +0.07
		25	AV4 +0.00	83	90	22	AV2 +0.14	84	89	32	AV3 +0.05
		24	AV5 +0.00			36	AV3 +0.18			32	AV4 +0.03
		27	AV6 +0.00			21	AV4 +0.10			30	AV5 +0.02
82	81	23	AV7 +0.00			34	AV5 +0.04			26	AV6 +0.05
82	83	25	AV4 +0.00			28	AV7 +0.05	84	91	28	AV4 +0.13
		29	AV5 +0.05	83	92	29	AV3 +0.16			29	AV5 +0.00
		25	AV6 +0.07			26	AV4 +0.13			24	AV6 +0.02
		26	AV7 +0.04			30	AV5 +0.07	84	93	22	AV3 +0.07
82	85	34	AV6 +0.00			32	AV6 +0.07			36	AV4 +0.03
		32	AV5 -0.11			29	AV7 +0.04			35	AV5 +0.09
		25	AV4 -0.09	83	94	33	AV5 +0.11			24	AV7 +0.05
82	87	25	AV4 +0.05			34	AV6 +0.11	84	95	25	AV2 +0.12
82	89	28	AV3 +0.09			33	AV7 +0.07			26	AV4 +0.10
		31	AV4 +0.08	83	96	37	AV3 +0.18			26	AV5 +0.09
		25	AV5 +0.09			33	AV4 +0.13			20	AV6 +0.07
82	91	22	AV4 +0.05			29	AV5 +0.07	84	99	31	AV2 +0.09
		21	AV5 +0.05			30	AV6 +0.02			25	AV7 +0.07
		20	AV6 +0.07	83	98	34	AV3 +0.14	84	101	30	AV4 +0.08
82	93	29	AV4 +0.03			37	AV4 +0.08			32	AV5 +0.07
		29	AV5 +0.05			28	AV5 +0.07			34	AV6 +0.09
		36	AV6 +0.09	83	100	20	AV4 +0.16			30	AV7 +0.05
		31	AV7 +0.05			32	AV5 +0.07	84	105	24	AV6 -0.02
82	95	20	AV2 +0.14			31	AV6 +0.09			34	AV5 +0.00
		27	AV3 +0.14	83	102	23	AV7 +0.00			35	AV4 -0.02
		36	AV4 +0.10			37	AV6 +0.00			34	AV3 -0.02
		33	AV5 +0.02			35	AV5 +0.00	84	107	25	AV7 +0.00
		28	AV7 +0.09			33	AV4 +0.00			26	AV6 -0.05
82	97	29	AV5 +0.09			35	AV3 +0.00			20	AV4 -0.02
		24	AV6 +0.07			26	AV2 +0.00			20	AV3 -0.05
82	99	27	AV4 +0.08	83	104	33	AV6 +0.00	84	109	26	AV3 -0.05
		35	AV5 +0.07			35	AV5 +0.00			20	AV2 -0.07
		34	AV6 +0.07			25	AV4 +0.00	84	113	20	AV5 -0.05
		28	AV7 +0.02			23	AV2 +0.00	84	115	22	AV6 +0.00
		21	AV8 +0.02	83	106	25	AV6 -0.09			26	AV5 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 20-39%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
84	117	23	AV5 -0.03	86	91	33	AV4 +0.10	88	71	24	AV4 +0.00
		21	AV4 +0.08			32	AV5 +0.09			24	AV5 +0.00
85	68	20	AV6 +0.00			33	AV6 +0.09			29	AV6 +0.00
		25	AV7 +0.00	86	93	27	AV3 +0.18			26	AV7 +0.00
85	70	26	AV4 +0.00			30	AV4 +0.13	88	73	28	AV2 +0.00
		24	AV5 +0.00			39	AV5 +0.05			20	AV3 +0.00
		24	AV6 +0.00			38	AV6 +0.02			22	AV4 +0.00
85	78	33	AV4 +0.05	86	97	29	AV3 +0.20			26	AV6 +0.00
		24	AV5 +0.07			28	AV5 +0.05			26	AV8 +0.00
		21	AV6 +0.07			25	AV6 +0.02	88	75	25	AV6 +0.00
		20	AV7 +0.04	86	99	24	AV6 +0.11			29	AV7 +0.00
85	80	26	AV6 +0.00	86	101	24	AV3 +0.05			24	AV8 +0.00
85	82	21	AV4 +0.10			26	AV4 +0.05	88	77	31	AV3 +0.00
		21	AV5 +0.05			29	AV5 +0.07			28	AV4 +0.00
		23	AV6 +0.07			31	AV6 +0.11			25	AV5 +0.00
		25	AV7 +0.07			22	AV7 +0.02			34	AV6 +0.00
85	86	28	AV3 +0.09	86	103	22	AV7 -0.07			31	AV7 +0.00
		24	AV4 -0.02			23	AV4 -0.07			36	AV8 +0.00
		31	AV5 +0.02			33	AV3 -0.07	88	81	22	AV3 +0.00
		36	AV6 +0.02			29	AV2 -0.02			21	AV4 +0.00
		33	AV7 +0.04	86	105	21	AV3 +0.00			29	AV5 +0.00
85	88	21	AV4 +0.05	87	70	26	AV7 +0.00			22	AV6 +0.00
		23	AV5 +0.07			26	AV5 +0.00	88	83	21	AV3 +0.05
85	90	21	AV3 +0.11			27	AV6 +0.00	88	87	21	AV3 +0.11
		22	AV5 +0.09	87	72	33	AV5 +0.00			21	AV4 +0.10
85	92	26	AV4 +0.00			30	AV7 +0.00			22	AV6 +0.09
		32	AV5 +0.02	87	74	22	AV5 +0.00	88	89	30	AV4 +0.08
		28	AV6 +0.07	87	80	31	AV4 +0.00			23	AV5 +0.09
		34	AV7 +0.02			26	AV5 +0.00			26	AV6 +0.09
85	94	31	AV4 +0.13			28	AV6 +0.00	88	91	23	AV4 +0.10
		36	AV5 +0.07	87	82	23	AV3 +0.07			29	AV6 +0.05
		22	AV6 +0.05			28	AV4 +0.08	88	93	24	AV5 +0.09
85	98	34	AV3 +0.18			23	AV5 +0.09			33	AV6 +0.07
		29	AV5 +0.05			24	AV6 +0.09	88	95	29	AV3 +0.21
		23	AV6 +0.07			28	AV7 +0.07			36	AV4 +0.15
85	100	29	AV4 +0.08	87	84	26	AV4 +0.05			26	AV5 +0.02
		30	AV5 +0.05			34	AV5 +0.07	88	97	23	AV4 +0.05
		20	AV2 +0.14			32	AV6 +0.07	88	99	24	AV3 +0.18
		31	AV3 +0.09	87	86	21	AV2 +0.09			31	AV4 +0.15
85	106	30	AV4 +0.00			30	AV3 +0.12			25	AV6 +0.07
		33	AV3 +0.00			24	AV4 +0.05	88	101	27	AV3 +0.11
		29	AV2 +0.00			34	AV5 +0.07			22	AV5 +0.07
85	108	22	AV6 +0.00			33	AV6 +0.05			21	AV6 +0.05
		21	AV4 +0.00	87	88	30	AV4 +0.10	88	105	20	AV8 -0.05
		29	AV3 +0.00			29	AV5 +0.05			20	AV7 +0.02
86	69	25	AV4 +0.00	87	90	34	AV5 +0.09			25	AV6 +0.00
		29	AV5 +0.00			33	AV6 +0.09			36	AV5 +0.02
		31	AV6 +0.00			20	AV7 +0.07			38	AV4 +0.05
		21	AV7 +0.00	87	92	22	AV4 +0.05			28	AV3 -0.02
86	71	21	AV4 +0.00			32	AV5 +0.11			21	AV2 +0.02
		29	AV5 +0.00			36	AV6 +0.07	88	107	22	AV3 -0.05
		31	AV6 +0.00			24	AV7 +0.07			22	AV7 -0.02
		25	AV7 +0.00			28	AV3 +0.14	88	109	24	AV3 -0.05
86	75	29	AV2 +0.00	87	96	36	AV3 +0.11	89	72	28	AV5 +0.00
		25	AV3 +0.00			28	AV4 +0.10	89	74	20	AV5 +0.00
		32	AV4 +0.00	87	100	29	AV2 +0.12			27	AV6 +0.00
		27	AV5 +0.00			27	AV3 +0.11			26	AV7 +0.00
86	77	22	AV4 +0.00			30	AV4 +0.08	89	78	24	AV4 +0.00
		27	AV5 +0.00			20	AV5 +0.07			21	AV5 +0.00
		35	AV6 +0.00	87	104	35	AV6 +0.00	89	82	30	AV4 +0.00
		31	AV7 +0.00			39	AV5 +0.00			22	AV5 +0.00
86	79	22	AV3 +0.00			37	AV4 +0.00			23	AV6 +0.00
86	83	23	AV4 +0.03			27	AV2 +0.00			32	AV7 +0.00
		26	AV5 +0.02	87	106	23	AV6 +0.00	89	84	24	AV6 +0.00
		26	AV6 +0.07			21	AV4 -0.02			32	AV7 +0.00
86	87	23	AV3 +0.18			21	AV2 -0.02	89	90	21	AV2 +0.18
		33	AV4 +0.15	87	108	20	AV4 +0.00			31	AV3 +0.20
		27	AV5 +0.09			27	AV3 -0.07			29	AV4 +0.15
86	89	23	AV3 +0.21	87	114	24	AV7 -0.07			35	AV5 +0.07
		31	AV4 +0.15			24	AV6 +0.00			37	AV6 +0.02
		29	AV5 +0.07	88	69	24	AV6 +0.00	89	92	24	AV3 +0.18
		30	AV6 +0.02			22	AV7 +0.00			22	AV6 +0.02

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 20-39%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
89	96	21	AV3 +0.21	91	82	22	AV7 +0.00	33	AV5 +0.00		
89	100	25	AV2 +0.18			20	AV6 +0.00	31	AV4 +0.00		
		26	AV3 +0.16			23	AV5 +0.00	21	AV3 +0.00		
		32	AV4 +0.15			29	AV4 +0.00	92	85	27	AV7 +0.00
		34	AV5 +0.11	91	84	35	AV7 +0.00	21	AV6 +0.00		
		33	AV6 +0.09			34	AV6 +0.00	25	AV5 +0.00		
		27	AV7 +0.04			37	AV5 +0.00	25	AV4 +0.00		
89	102	30	AV4 +0.00			32	AV4 +0.00	28	AV3 +0.00		
		31	AV3 +0.00	91	88	36	AV7 +0.00	92	87	21	AV6 +0.00
		30	AV2 +0.00			20	AV6 +0.00	26	AV5 +0.00		
89	106	20	AV4 +0.00			27	AV5 +0.00	20	AV4 +0.00		
90	69	21	AV4 +0.00			32	AV4 +0.00	92	89	26	AV6 +0.00
		30	AV5 +0.00	91	90	27	AV7 +0.00	24	AV4 +0.00		
		36	AV6 +0.00			36	AV6 +0.00	92	91	20	AV7 +0.00
		23	AV7 +0.00			34	AV5 +0.00	33	AV6 +0.00		
90	71	32	AV4 +0.00			27	AV4 +0.00	32	AV5 +0.00		
		35	AV5 +0.00	91	92	26	AV7 +0.00	28	AV4 +0.00		
		39	AV6 +0.00			29	AV6 +0.00	36	AV3 +0.00		
		28	AV7 +0.00			26	AV4 +0.00	24	AV2 +0.00		
90	73	26	AV3 +0.00			30	AV3 +0.00	92	99	25	AV7 +0.00
		21	AV5 +0.00	91	94	34	AV7 +0.00	25	AV6 +0.00		
		37	AV6 +0.00			26	AV6 +0.00	21	AV5 +0.00		
		25	AV7 +0.00			35	AV5 +0.00	25	AV4 +0.00		
90	75	24	AV6 +0.00			37	AV4 +0.00	24	AV3 +0.00		
		20	AV7 +0.00			24	AV3 +0.00	92	101	25	AV3 +0.00
90	79	24	AV5 +0.00			24	AV2 +0.00	92	103	33	AV3 +0.00
90	85	32	AV5 +0.09	91	96	26	AV7 +0.00	33	AV4 +0.00		
		26	AV6 +0.09			23	AV6 +0.00	23	AV5 +0.00		
		27	AV7 +0.07			31	AV5 +0.00	22	AV6 +0.00		
90	87	29	AV5 +0.07			26	AV4 +0.00	92	105	26	AV4 +0.15
		26	AV6 +0.09			33	AV3 +0.00	31	AV5 +0.12		
90	91	29	AV4 +0.15			20	AV2 +0.00	93	72	26	AV4 +0.00
		32	AV5 +0.00	91	98	23	AV6 +0.00	36	AV5 +0.00		
		35	AV6 +0.00			32	AV5 +0.00	34	AV6 +0.00		
		20	AV7 +0.04			31	AV4 +0.00	30	AV7 +0.00		
		24	AV3 +0.18			33	AV3 +0.00	25	AV8 +0.00		
90	97	26	AV2 +0.07	91	100	24	AV3 +0.00	93	74	26	AV4 +0.00
		26	AV3 +0.11			22	AV6 +0.00	33	AV5 +0.00		
		29	AV4 +0.08			21	AV7 +0.00	38	AV6 +0.00		
		30	AV5 +0.07	91	104	26	AV3 +0.00	33	AV7 +0.00		
		24	AV6 +0.05			32	AV4 +0.00	93	76	32	AV7 +0.00
		23	AV7 +0.05			36	AV6 +0.00	37	AV6 +0.00		
90	99	24	AV2 +0.14			27	AV7 +0.00	37	AV5 +0.00		
		23	AV3 +0.14	91	106	23	AV3 +0.00	23	AV4 +0.00		
		29	AV4 +0.13			32	AV4 +0.00	93	78	23	AV7 +0.00
		25	AV5 +0.07	91	108	21	AV3 +0.00	25	AV5 +0.00		
90	103	23	AV7 -0.07			20	AV4 +0.00	21	AV2 +0.00		
		20	AV6 -0.07			27	AV5 +0.00	93	82	26	AV7 +0.00
		26	AV5 +0.00			24	AV6 +0.00	22	AV5 +0.00		
		30	AV4 -0.09	91	110	25	AV4 +0.00	24	AV4 +0.00		
		33	AV3 -0.05			31	AV5 +0.00	93	86	32	AV6 +0.00
90	105	29	AV7 +0.00	91	112	25	AV2 +0.00	35	AV4 +0.00		
		26	AV6 +0.00	92	69	21	AV6 +0.00	93	88	31	AV7 +0.00
		26	AV5 +0.00	92	73	32	AV3 +0.00	22	AV6 +0.00		
		22	AV4 +0.00			21	AV4 +0.00	23	AV5 +0.00		
91	72	23	AV3 +0.00			27	AV5 +0.00	93	92	20	AV7 +0.00
		30	AV5 +0.00			34	AV6 +0.07	36	AV6 +0.00		
		24	AV6 +0.00	92	75	25	AV8 +0.00	32	AV5 +0.00		
		22	AV7 +0.00			35	AV7 +0.00	37	AV4 +0.00		
91	76	27	AV7 +0.00			30	AV6 +0.00	28	AV3 +0.00		
		32	AV6 +0.00			28	AV5 +0.00	93	102	33	AV4 +0.00
		34	AV5 +0.00			20	AV4 +0.00	29	AV5 +0.00		
		30	AV4 +0.00	92	79	32	AV7 +0.00	28	AV6 +0.00		
91	78	22	AV7 +0.00			32	AV6 +0.00	93	104	27	AV3 +0.00
		32	AV6 +0.00			27	AV5 +0.00	22	AV4 +0.00		
		38	AV5 +0.00	92	81	21	AV7 +0.00	30	AV5 +0.00		
		37	AV4 +0.00			34	AV6 +0.00	35	AV6 +0.00		
		20	AV3 +0.00			37	AV5 +0.00	27	AV7 +0.00		
91	80	20	AV7 +0.00			35	AV4 +0.00	93	106	27	AV4 +0.00
		28	AV6 +0.00			36	AV3 +0.00	93	110	27	AV4 +0.00
		23	AV5 +0.00			21	AV2 +0.00	29	AV5 +0.00		
		24	AV4 +0.00	92	83	33	AV6 +0.00	94	71	21	AV4 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 20-39%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		20	AV6 +0.00	95	92	34	AV7 +0.00			24	AV4 +0.00
		33	AV7 +0.00			32	AV5 +0.00	97	80	28	AV6 +0.00
94	73	33	AV4 +0.00			38	AV4 +0.00			29	AV5 +0.00
		37	AV5 +0.00			30	AV3 +0.00			35	AV4 +0.00
		39	AV6 +0.00	95	94	24	AV7 +0.00	97	82	28	AV4 +0.00
		23	AV7 +0.00			37	AV6 +0.00	97	96	20	AV6 +0.00
		25	AV8 +0.00			37	AV5 +0.00			29	AV5 +0.00
94	77	27	AV6 +0.00			28	AV4 +0.00			30	AV4 +0.00
		24	AV4 +0.00			29	AV3 +0.00			29	AV3 +0.00
94	79	20	AV6 +0.00	95	96	27	AV6 +0.00	97	98	25	AV5 +0.00
94	81	27	AV7 +0.00			29	AV5 +0.00			29	AV4 +0.00
		29	AV6 +0.00	95	98	20	AV6 +0.00			29	AV3 +0.00
		24	AV5 +0.00			24	AV5 +0.00			30	AV2 +0.00
94	87	22	AV7 +0.00			22	AV3 +0.00	97	102	25	AV2 +0.14
		36	AV6 +0.00	95	100	26	AV5 +0.07			24	AV3 +0.09
		36	AV5 +0.00			27	AV6 +0.12			28	AV5 +0.07
		29	AV4 +0.00			24	AV7 +0.02			31	AV6 +0.09
		27	AV3 +0.00	95	104	21	AV3 +0.16			31	AV7 +0.02
94	91	29	AV7 +0.00			21	AV5 +0.09	98	73	21	AV3 +0.00
		29	AV6 +0.00	96	67	21	AV5 +0.00			23	AV4 +0.00
		29	AV5 +0.00			21	AV6 +0.00			31	AV5 +0.00
		30	AV4 +0.00	96	71	22	AV4 +0.00			29	AV6 +0.00
		37	AV3 +0.00			26	AV5 +0.00			29	AV7 +0.00
		22	AV2 +0.00			24	AV6 +0.00	98	75	22	AV8 +0.00
94	95	31	AV7 +0.00			28	AV7 +0.00			37	AV7 +0.00
		33	AV6 +0.00	96	73	24	AV4 +0.00			23	AV6 +0.00
		26	AV4 +0.00			30	AV5 +0.00			22	AV5 +0.00
		25	AV3 +0.00			28	AV6 +0.00			20	AV4 +0.00
94	97	21	AV4 +0.00			33	AV7 +0.00	98	77	32	AV6 +0.00
94	99	37	AV6 +0.00			23	AV8 +0.00			32	AV5 +0.00
		33	AV5 +0.00	96	75	28	AV7 +0.00			30	AV4 +0.00
		33	AV4 +0.00			26	AV6 +0.00	98	79	22	AV6 +0.00
94	101	22	AV2 +0.16			27	AV5 +0.00			27	AV5 +0.00
		21	AV3 +0.14	96	77	36	AV6 +0.00			20	AV4 +0.00
		21	AV5 +0.14			30	AV5 +0.00			31	AV3 +0.00
94	103	21	AV2 +0.00			32	AV4 +0.00	98	81	26	AV7 +0.00
		37	AV3 +0.00	96	79	22	AV7 +0.00			27	AV6 +0.00
		36	AV4 +0.00			34	AV6 +0.00			22	AV5 +0.00
		25	AV5 +0.00			30	AV5 +0.00			25	AV3 +0.00
		27	AV6 +0.00			29	AV4 +0.00	98	91	33	AV7 +0.00
94	105	37	AV5 +0.00			33	AV3 +0.00			33	AV5 +0.00
		28	AV6 +0.00	96	81	20	AV5 +0.00			21	AV4 +0.00
		26	AV7 +0.00	96	91	32	AV6 +0.00			26	AV3 +0.00
		29	AV3 +0.00			33	AV5 +0.00			22	AV2 +0.00
		31	AV4 +0.00			30	AV4 +0.00	98	93	25	AV6 +0.00
95	72	23	AV2 +0.00			23	AV3 +0.00			21	AV5 +0.00
		27	AV3 +0.00			22	AV7 +0.00			33	AV4 +0.00
		34	AV4 +0.00	96	95	26	AV6 +0.00	98	95	26	AV5 +0.00
		38	AV5 +0.00			22	AV5 +0.00			35	AV4 +0.00
		32	AV6 +0.00	96	101	25	AV3 +0.00			23	AV3 +0.00
95	78	23	AV5 +0.00			22	AV7 +0.00			29	AV2 +0.00
95	80	23	AV6 +0.00	96	103	21	AV2 +0.09	98	99	26	AV4 +0.00
		29	AV4 +0.00			32	AV3 +0.07			30	AV3 +0.00
95	82	26	AV7 +0.00			20	AV4 +0.10	98	101	23	AV4 +0.00
		20	AV6 +0.00			24	AV6 +0.00			29	AV5 +0.00
		29	AV5 +0.00	96	105	26	AV5 +0.00			31	AV6 +0.00
		33	AV4 +0.00			26	AV6 +0.00	98	105	26	AV3 +0.07
95	84	34	AV5 +0.00			21	AV7 +0.00			31	AV4 +0.10
		34	AV4 +0.00	97	66	21	AV2 +0.00			26	AV6 +0.05
		23	AV3 +0.00	97	68	30	AV4 +0.00			20	AV7 +0.07
		24	AV2 +0.00			20	AV5 +0.00	98	107	20	AV6 +0.00
95	88	28	AV7 +0.00			24	AV6 +0.00	99	68	23	AV6 +0.00
		28	AV6 +0.00	97	72	23	AV4 +0.00	99	72	25	AV5 +0.00
		35	AV5 +0.00			32	AV5 +0.00			27	AV6 +0.00
		32	AV4 +0.00			32	AV6 +0.00	99	74	22	AV4 +0.00
95	90	25	AV8 +0.00	97	74	25	AV3 +0.07			27	AV5 +0.00
		36	AV7 +0.00			23	AV5 +0.09			36	AV6 +0.00
		31	AV6 +0.00			33	AV6 +0.02			20	AV7 +0.00
		31	AV5 +0.00			29	AV7 +0.09	99	76	25	AV6 +0.00
		30	AV4 +0.00	97	76	25	AV7 +0.00			33	AV5 +0.00
		27	AV3 +0.00			36	AV6 +0.00			29	AV4 +0.00
		20	AV2 +0.00			33	AV5 +0.00	99	78	32	AV7 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 20-39%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		20	AV6 +0.00			33	AV8 +0.00			31	AV6 +0.00
		23	AV3 +0.00	101	74	20	AV3 +0.00			29	AV5 +0.00
		22	AV2 +0.00			22	AV4 +0.00			28	AV4 +0.00
99	80	24	AV4 +0.00			28	AV5 +0.00	103	90	31	AV7 +0.00
99	88	21	AV8 +0.00			25	AV6 +0.00			21	AV6 +0.00
		31	AV7 +0.00	101	76	30	AV7 +0.00			36	AV5 +0.00
		26	AV6 +0.00			35	AV6 +0.00			27	AV4 +0.00
		34	AV5 +0.00			24	AV5 +0.00	103	92	33	AV7 +0.00
		35	AV4 +0.00			22	AV4 +0.00			36	AV6 +0.00
		30	AV3 +0.00			20	AV3 +0.00			27	AV5 +0.00
		32	AV2 +0.00	101	78	20	AV6 +0.00			26	AV4 +0.00
99	90	28	AV6 +0.00	101	80	26	AV6 +0.00			32	AV3 +0.00
		24	AV5 +0.00			24	AV5 +0.00	103	94	27	AV7 +0.00
		30	AV4 +0.00			36	AV4 +0.00			30	AV6 +0.00
		30	AV3 +0.00	101	82	25	AV7 +0.00			34	AV5 +0.00
		23	AV2 +0.00			35	AV6 +0.00			22	AV4 +0.00
99	92	35	AV5 +0.00			20	AV5 +0.00			25	AV3 +0.00
		29	AV3 +0.00	101	88	32	AV6 +0.00	103	96	29	AV7 +0.00
		21	AV2 +0.00			31	AV5 +0.00			24	AV5 +0.00
99	96	24	AV5 +0.00			22	AV4 +0.00	103	100	20	AV3 +0.00
		24	AV3 +0.00			36	AV3 +0.00			23	AV4 +0.00
99	98	21	AV7 +0.00			29	AV2 +0.00			26	AV5 +0.00
99	104	22	AV5 +0.00	101	90	25	AV8 +0.00			27	AV6 +0.00
		20	AV7 +0.00			36	AV7 +0.00	103	104	22	AV4 +0.10
100	69	26	AV7 +0.00			26	AV6 +0.00	103	106	22	AV5 +0.00
100	71	21	AV5 +0.00			30	AV5 +0.00	104	73	20	AV4 +0.00
		22	AV6 +0.00			27	AV3 +0.00			20	AV6 +0.00
100	73	21	AV3 +0.00			24	AV2 +0.00	104	75	28	AV7 +0.00
		27	AV5 +0.00	101	92	33	AV6 +0.00			27	AV6 +0.00
		28	AV6 +0.00			36	AV5 +0.00			33	AV5 +0.00
		33	AV7 +0.00			38	AV4 +0.00			30	AV4 +0.00
		23	AV8 +0.00			35	AV3 +0.00			30	AV3 +0.00
100	75	28	AV7 +0.00			20	AV2 +0.00	104	77	26	AV6 +0.00
		25	AV6 +0.00	101	94	23	AV8 +0.00			29	AV4 +0.00
		26	AV5 +0.00			21	AV7 +0.00	104	79	20	AV4 +0.00
		29	AV4 +0.00	101	96	25	AV3 +0.00	104	91	20	AV7 +0.00
		31	AV3 +0.00			20	AV2 +0.00			25	AV6 +0.00
		30	AV2 +0.00	101	100	20	AV6 +0.00			22	AV5 +0.00
100	77	21	AV8 +0.00	101	104	38	AV4 +0.00			21	AV4 +0.00
		29	AV7 +0.00			35	AV5 +0.00			24	AV3 +0.00
		31	AV6 +0.00	102	71	21	AV4 +0.00			28	AV2 +0.00
		24	AV4 +0.00			26	AV5 +0.00	104	97	20	AV6 +0.00
100	79	31	AV5 +0.00			29	AV6 +0.00			28	AV4 +0.00
		25	AV4 +0.00	102	73	22	AV5 +0.00	104	105	21	AV5 +0.07
		32	AV3 +0.00	102	75	36	AV7 +0.00			22	AV6 +0.07
		31	AV2 +0.00			30	AV6 +0.00			25	AV7 +0.07
		30	AV6 +0.00			23	AV5 +0.00	105	72	27	AV4 +0.00
100	81	28	AV7 +0.00	102	77	31	AV6 +0.00			28	AV5 +0.00
		32	AV6 +0.00			32	AV5 +0.00	105	74	26	AV4 +0.00
		32	AV5 +0.00			27	AV4 +0.00			30	AV5 +0.00
100	91	21	AV7 +0.00	102	79	28	AV5 +0.00			25	AV6 +0.00
		30	AV6 +0.00	102	91	30	AV5 +0.00	105	76	26	AV6 +0.00
		31	AV5 +0.00			31	AV4 +0.00			28	AV5 +0.00
		24	AV4 +0.00	102	95	32	AV6 +0.00			30	AV4 +0.00
100	93	20	AV5 +0.00			20	AV4 +0.00	105	78	20	AV6 +0.00
		37	AV4 +0.00	102	97	23	AV4 +0.00	105	80	22	AV5 +0.00
		25	AV3 +0.00	102	99	21	AV5 +0.00	105	82	22	AV6 +0.00
100	95	25	AV6 +0.00			26	AV4 +0.00			30	AV5 +0.00
		20	AV2 +0.00	103	72	32	AV4 +0.00			29	AV4 +0.00
100	99	22	AV7 +0.00			30	AV5 +0.00			20	AV3 +0.00
100	101	22	AV3 +0.14	103	74	25	AV2 +0.11	105	94	26	AV7 +0.00
		27	AV5 +0.07			34	AV3 +0.14			24	AV6 +0.00
100	105	29	AV4 +0.00			31	AV4 +0.13			37	AV5 +0.00
		28	AV5 +0.00			31	AV5 +0.09			33	AV4 +0.00
		21	AV6 +0.00			30	AV6 +0.00			33	AV3 +0.00
		22	AV7 +0.00			30	AV7 +0.09	105	96	22	AV5 +0.00
100	107	27	AV6 +0.00			30	AV8 +0.02	105	98	20	AV6 +0.00
		20	AV7 +0.00	103	78	32	AV5 +0.00			21	AV5 +0.00
101	72	21	AV4 +0.00			26	AV4 +0.00	106	71	23	AV5 +0.00
		29	AV5 +0.00			24	AV3 +0.00	106	73	25	AV4 +0.00
		33	AV6 +0.00	103	80	25	AV6 +0.00			27	AV5 +0.00
		30	AV7 +0.00	103	82	32	AV7 +0.00			29	AV6 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 20-39%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		28	AV7 +0.00			22	AV5 +0.00			25	AV2 +0.00
106	75	31	AV7 +0.00			30	AV4 +0.00	110	99	20	AV4 +0.00
		22	AV6 +0.00			31	AV3 +0.00	110	101	23	AV4 +0.13
		24	AV5 +0.00			28	AV2 +0.00	110	103	23	AV3 +0.07
106	77	22	AV5 +0.00	108	101	26	AV2 +0.00			22	AV4 +0.10
		26	AV4 +0.00			22	AV3 +0.00			26	AV5 +0.07
106	79	28	AV7 +0.00	108	103	24	AV3 +0.00	111	68	33	AV4 +0.00
		36	AV6 +0.00			24	AV4 +0.00			28	AV5 +0.00
		32	AV5 +0.00	109	68	33	AV2 +0.00			25	AV6 +0.00
		21	AV3 +0.00			25	AV3 +0.00	111	72	27	AV6 +0.00
106	81	27	AV7 +0.00			22	AV5 +0.00	111	74	22	AV5 +0.00
		29	AV5 +0.00	109	74	24	AV4 +0.13			24	AV6 +0.00
		24	AV4 +0.00			30	AV5 +0.09	111	76	21	AV6 +0.00
106	93	28	AV6 +0.00			37	AV6 +0.07	111	78	31	AV7 +0.00
		28	AV5 +0.00			27	AV7 +0.07			36	AV6 +0.00
		27	AV4 +0.00	109	76	22	AV7 +0.00			36	AV5 +0.00
106	95	31	AV6 +0.00			27	AV6 +0.00			26	AV4 +0.00
		33	AV5 +0.00			29	AV4 +0.00			34	AV3 +0.00
		31	AV4 +0.00	109	82	25	AV7 +0.00	111	80	25	AV7 +0.00
106	97	24	AV3 +0.00			34	AV6 +0.00			21	AV6 +0.00
106	99	21	AV6 +0.00			31	AV5 +0.00			29	AV5 +0.00
		20	AV5 +0.00			21	AV4 +0.00	111	82	33	AV5 +0.00
106	101	25	AV4 +0.00			28	AV3 +0.00			28	AV4 +0.00
106	103	21	AV5 +0.00			22	AV2 +0.00	111	86	26	AV6 +0.00
		23	AV6 +0.00	109	88	33	AV7 +0.00			29	AV5 +0.00
107	68	20	AV7 +0.00			33	AV6 +0.00			33	AV4 +0.00
107	70	20	AV3 +0.00			26	AV5 +0.00			27	AV3 +0.00
		24	AV4 +0.00	109	92	23	AV7 +0.00			28	AV2 +0.00
		20	AV5 +0.00			26	AV6 +0.00	111	94	31	AV7 +0.00
107	86	20	AV7 +0.00			21	AV4 +0.00			36	AV6 +0.00
		26	AV6 +0.00			27	AV3 +0.00			20	AV5 +0.00
		24	AV4 +0.00	109	94	20	AV6 +0.00			35	AV3 +0.00
		22	AV3 +0.00	109	98	21	AV6 +0.00			24	AV2 +0.00
107	90	34	AV7 +0.00	109	100	32	AV7 +0.00	112	73	20	AV4 +0.10
		29	AV6 +0.00			21	AV4 +0.00	112	75	21	AV5 +0.00
		35	AV5 +0.00			27	AV5 +0.00	112	77	24	AV6 +0.00
		23	AV4 +0.00			33	AV6 +0.00			20	AV5 +0.00
107	94	21	AV7 +0.00	109	102	29	AV3 +0.00	112	79	22	AV7 +0.00
		31	AV6 +0.00			26	AV4 +0.00			31	AV6 +0.00
		34	AV5 +0.00			37	AV5 +0.00			27	AV5 +0.00
		30	AV4 +0.00			22	AV6 +0.00			23	AV4 +0.00
107	96	21	AV3 +0.00	110	69	28	AV6 +0.00			21	AV3 +0.00
		26	AV7 +0.00			24	AV7 +0.00	112	81	22	AV6 +0.00
		20	AV3 +0.00	110	71	26	AV2 +0.00			26	AV5 +0.00
107	100	21	AV4 +0.00			32	AV3 +0.00	112	83	25	AV7 +0.00
		25	AV5 +0.00			29	AV4 +0.00			26	AV6 +0.00
107	102	24	AV3 +0.00			32	AV5 +0.00			24	AV5 +0.00
108	71	33	AV5 +0.00			20	AV6 +0.00			34	AV4 +0.00
		23	AV6 +0.00	110	73	23	AV2 +0.00			21	AV3 +0.00
108	75	21	AV6 +0.00			21	AV3 +0.00	112	87	33	AV7 +0.00
		37	AV5 +0.00			24	AV4 +0.00			35	AV6 +0.00
108	77	25	AV7 +0.00			22	AV5 +0.00			32	AV5 +0.00
		33	AV6 +0.00	110	75	27	AV5 +0.00			27	AV4 +0.00
		23	AV5 +0.00			23	AV4 +0.00			29	AV3 +0.00
		24	AV4 +0.00			22	AV3 +0.00			24	AV2 +0.00
		23	AV3 +0.00	110	77	26	AV6 +0.00	112	93	20	AV7 +0.00
108	81	23	AV7 +0.00			29	AV5 +0.00			20	AV6 +0.00
		20	AV6 +0.00			35	AV4 +0.00			24	AV4 +0.00
		28	AV3 +0.00			27	AV3 +0.00			26	AV3 +0.00
		20	AV2 +0.00	110	79	24	AV7 +0.00			21	AV2 +0.00
108	91	29	AV6 +0.00			31	AV6 +0.00	112	95	21	AV7 +0.00
		32	AV5 +0.00			24	AV5 +0.00			33	AV6 +0.00
		34	AV4 +0.00	110	81	25	AV5 +0.00			21	AV5 +0.00
		31	AV3 +0.00			20	AV4 +0.00			21	AV2 +0.00
		25	AV2 +0.00	110	93	25	AV6 +0.00	112	97	27	AV3 +0.00
108	93	20	AV7 +0.00			20	AV5 +0.00	112	99	29	AV3 +0.00
		25	AV6 +0.00			28	AV4 +0.00			27	AV2 +0.00
		25	AV5 +0.00			31	AV3 +0.00	112	101	25	AV3 +0.00
		21	AV4 +0.00			22	AV2 +0.00			39	AV4 +0.00
		28	AV3 +0.00	110	95	33	AV7 +0.00	112	103	22	AV3 +0.00
		20	AV2 +0.00			37	AV6 +0.00			22	AV4 +0.00
108	99	23	AV6 +0.00			26	AV4 +0.00			29	AV5 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G A

03/17 - EOC22
Bobbin AVB Wear 20-39%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
113	72	30	AV4 +0.00	117	68	27	AV5 +0.00	123	88	33	AV5 +0.00
		26	AV5 +0.00			21	AV6 +0.00			27	AV3 +0.00
		31	AV6 +0.00	117	70	23	AV6 +0.00	123	90	20	AV8 +0.00
		20	AV2 +0.00	117	76	20	AV6 +0.00			24	AV7 +0.00
		32	AV3 +0.00	117	80	20	AV7 +0.00			22	AV6 +0.00
113	74	32	AV4 +0.00			26	AV6 +0.00			25	AV4 +0.00
		25	AV5 +0.00			32	AV5 +0.00			33	AV3 +0.00
		27	AV6 +0.00	117	92	23	AV4 +0.00			21	AV2 +0.00
113	76	21	AV3 +0.00			25	AV3 +0.00	123	92	20	AV6 +0.00
113	78	29	AV7 +0.00			23	AV2 +0.00	123	94	21	AV7 +0.00
		28	AV6 +0.00	117	94	29	AV6 +0.00			24	AV6 +0.00
		31	AV5 +0.00			33	AV5 +0.00	124	63	27	AV4 +0.00
		25	AV4 +0.00	118	77	24	AV6 +0.00	124	69	24	AV2 +0.00
113	80	25	AV7 +0.00			27	AV5 +0.00			25	AV3 +0.00
		25	AV6 +0.00	118	81	31	AV6 +0.00			25	AV6 +0.00
113	88	27	AV7 +0.00			34	AV5 +0.00			23	AV7 +0.00
		29	AV6 +0.00	118	91	20	AV6 +0.00	124	73	25	AV4 +0.00
		24	AV5 +0.00			25	AV5 +0.00			20	AV6 +0.00
		30	AV4 +0.00			23	AV3 +0.00	124	79	36	AV3 +0.00
113	90	29	AV7 +0.00	119	72	27	AV4 +0.00			26	AV2 +0.00
		28	AV6 +0.00	119	80	22	AV7 +0.00			20	AV6 +0.00
		33	AV5 +0.00			26	AV6 +0.00			24	AV5 +0.00
		27	AV4 +0.00	119	88	20	AV7 +0.00			36	AV4 +0.00
		23	AV3 +0.00			28	AV4 +0.00	124	87	20	AV5 +0.00
113	92	34	AV6 +0.00			22	AV3 +0.00	124	91	27	AV5 +0.00
		29	AV5 +0.00	119	96	24	AV5 +0.00			34	AV4 +0.00
		38	AV4 +0.00	120	79	22	AV7 +0.00			20	AV2 +0.00
		38	AV3 +0.00	120	81	23	AV7 +0.00	124	99	23	AV5 +0.00
		27	AV2 +0.00			32	AV6 +0.00			20	AV4 +0.00
114	75	22	AV5 +0.00			27	AV5 +0.00	125	72	22	AV6 +0.00
114	77	27	AV3 +0.00	120	91	26	AV5 +0.00	125	76	21	AV6 +0.00
114	79	24	AV7 +0.00			20	AV4 +0.00			31	AV5 +0.00
		27	AV6 +0.00	120	93	24	AV8 +0.00			20	AV4 +0.00
		25	AV5 +0.00			26	AV7 +0.00	125	80	25	AV7 +0.00
114	81	26	AV3 +0.00			24	AV4 +0.00	125	82	24	AV7 +0.00
114	87	26	AV5 +0.00			25	AV3 +0.00			35	AV6 +0.00
		31	AV4 +0.00	120	99	22	AV5 +0.00			33	AV5 +0.00
		30	AV3 +0.00			24	AV4 +0.00			36	AV4 +0.00
114	91	26	AV7 +0.00			23	AV3 +0.00	125	88	34	AV7 +0.00
		32	AV6 +0.00			25	AV2 -0.05			34	AV6 +0.00
		33	AV5 +0.00	120	103	25	AV5 +0.00			33	AV5 +0.00
		20	AV4 +0.00	121	78	30	AV6 +0.00			27	AV4 +0.00
		22	AV3 +0.00	121	82	33	AV6 +0.00	125	90	23	AV7 +0.00
114	101	23	AV4 +0.00	121	90	22	AV5 +0.00			35	AV6 +0.00
		26	AV5 +0.00			23	AV4 +0.00			33	AV5 +0.00
115	66	26	AV2 +0.00			22	AV3 +0.00			36	AV4 +0.00
		25	AV6 +0.00			29	AV6 +0.00	125	92	22	AV6 +0.00
115	68	32	AV3 +0.00	121	92	30	AV7 +0.00			21	AV5 -0.13
		38	AV4 +0.00			26	AV6 +0.00	126	69	21	AV7 -0.02
115	72	27	AV6 +0.00			22	AV4 +0.00	126	77	22	AV6 +0.00
115	74	30	AV2 +0.09			27	AV3 +0.00			29	AV5 +0.00
		33	AV3 +0.07			22	AV2 +0.00	126	91	34	AV7 +0.00
115	80	24	AV7 +0.00	121	94	22	AV7 +0.00			29	AV6 +0.00
		32	AV6 +0.00			29	AV6 +0.00			24	AV3 +0.00
		29	AV5 +0.00			20	AV5 +0.00	127	82	33	AV8 +0.00
115	82	23	AV6 +0.00	122	79	23	AV6 +0.00			30	AV6 +0.00
		32	AV5 +0.00			25	AV5 +0.00			25	AV5 +0.00
		27	AV4 +0.00			23	AV3 +0.00			35	AV4 +0.00
		27	AV3 +0.00	122	81	20	AV8 +0.00	127	88	26	AV3 +0.00
115	92	24	AV5 +0.00			25	AV7 +0.00			34	AV6 +0.00
		28	AV4 +0.00			28	AV6 +0.00			21	AV5 +0.00
115	102	27	AV2 +0.00			22	AV5 +0.00	127	90	22	AV8 +0.00
		30	AV3 +0.00	122	83	29	AV7 +0.00			32	AV7 +0.00
116	81	32	AV6 +0.00			33	AV5 +0.00			32	AV6 +0.00
		33	AV5 +0.00			27	AV4 +0.00			32	AV5 +0.00
		25	AV4 +0.00			33	AV3 +0.00			25	AV4 +0.00
		21	AV3 +0.00			23	AV2 +0.00	127	92	22	AV3 +0.00
116	91	21	AV6 +0.00	122	87	24	AV5 +0.00			23	AV2 +0.00
		25	AV5 +0.00	122	101	22	AV3 +0.05	127	96	24	AV5 +0.00
116	93	26	AV5 +0.00			31	AV4 +0.03			20	AV4 +0.00
		22	AV3 +0.00	123	72	27	AV5 +0.00	128	67	24	AV2 +0.00
116	95	25	AV6 +0.00			32	AV6 +0.00			30	AV3 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G A

03/17 - EOC22
 Bobbin AVB Wear 20-39%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		22	AV4 +0.00	131	82	24	AV7 +0.00			21	AV4 +0.00
		24	AV5 +0.00	131	88	23	AV7 +0.00	135	90	23	AV8 +0.00
128	73	21	AV6 +0.00			21	AV5 +0.00			26	AV7 +0.00
128	87	26	AV5 +0.00			26	AV4 +0.00			27	AV5 +0.00
		21	AV4 +0.00	131	92	20	AV7 +0.00			36	AV4 +0.00
		20	AV3 +0.00			20	AV3 +0.00			36	AV2 +0.00
		20	AV2 +0.00			32	AV2 +0.00	135	92	34	AV7 +0.00
128	93	22	AV8 +0.00	131	94	28	AV7 +0.00			27	AV6 +0.00
		36	AV7 +0.00			28	AV4 +0.00			32	AV5 +0.00
		27	AV6 +0.00			20	AV3 +0.00			21	AV4 +0.00
128	95	21	AV7 +0.00	132	67	21	AV3 +0.00			26	AV3 +0.00
		31	AV6 +0.00			39	AV4 +0.00			24	AV2 +0.00
128	99	30	AV7 +0.00			21	AV7 +0.00			21	AV7 +0.00
128	117	20	AV6 +0.07	132	69	20	AV3 +0.00	136	75	24	AV6 +0.00
		27	AV7 +0.11			26	AV6 +0.00			21	AV5 +0.00
129	66	25	AV6 +0.00	132	79	26	AV7 +0.00	136	83	27	AV7 +0.00
129	78	20	AV6 +0.00			28	AV6 +0.00			24	AV6 +0.00
129	80	20	AV8 +0.00			22	AV5 +0.00			33	AV5 +0.00
		33	AV7 +0.00	132	81	23	AV6 +0.00			37	AV4 +0.00
		33	AV6 +0.00	132	93	22	AV8 +0.00			34	AV3 +0.00
		30	AV5 +0.00			33	AV7 +0.00	136	85	20	AV2 +0.00
		33	AV4 +0.00			26	AV6 +0.00	136	91	33	AV7 +0.00
129	82	21	AV2 +0.00	133	68	21	AV2 +0.00			29	AV5 +0.00
		33	AV7 +0.00			24	AV6 +0.00			21	AV3 +0.00
		27	AV6 +0.00	133	70	21	AV7 +0.00	136	93	29	AV7 +0.00
		38	AV5 +0.00	133	86	27	AV7 +0.00			33	AV6 +0.00
		35	AV4 +0.00			26	AV6 +0.00			23	AV4 +0.00
		27	AV3 +0.00			33	AV5 +0.00			24	AV3 +0.00
129	86	25	AV7 +0.00			27	AV3 +0.00	137	80	26	AV7 +0.00
129	88	37	AV7 +0.00			26	AV2 +0.00			33	AV6 +0.00
		24	AV5 +0.00	133	92	22	AV7 +0.00			37	AV5 +0.00
130	79	23	AV7 +0.00			30	AV4 +0.00			37	AV4 +0.00
		29	AV6 +0.00			28	AV3 +0.00			22	AV3 +0.00
		24	AV5 +0.00			24	AV2 +0.00	137	84	25	AV6 +0.00
130	81	38	AV6 +0.00	133	96	37	AV4 +0.00			36	AV5 +0.00
		32	AV5 +0.00			26	AV3 +0.00			29	AV4 +0.00
		20	AV4 +0.00			23	AV2 +0.00	137	92	23	AV2 +0.00
130	93	20	AV4 +0.00	134	73	21	AV6 +0.00	138	91	21	AV8 +0.00
		34	AV3 +0.00	134	79	23	AV6 +0.00			34	AV7 +0.00
		32	AV2 +0.00			22	AV5 +0.00			22	AV5 +0.00
130	95	21	AV7 +0.00			30	AV4 +0.00			29	AV4 +0.00
		31	AV6 +0.00	134	83	30	AV7 +0.00			25	AV3 +0.00
130	97	20	AV6 +0.00			20	AV6 +0.00			31	AV2 +0.00
131	70	26	AV4 +0.00			31	AV5 +0.00	139	78	25	AV5 +0.00
131	74	30	AV4 +0.00	134	87	28	AV6 +0.00	139	92	28	AV7 +0.00
		23	AV5 +0.00			31	AV5 +0.00				
		21	AV6 +0.00	134	97	20	AV3 +0.00				
		20	AV7 +0.00	135	70	25	AV4 +0.00				
131	78	27	AV6 +0.00	135	74	22	AV3 +0.00				
		22	AV5 +0.00			21	AV4 +0.00				
		24	AV4 +0.00	135	78	29	AV5 +0.00				

Total Tubes : 738
 Total Records: 2091

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
33	164	6	AV7 +0.00	47	16	6	AV3 +0.00		8		AV6 +0.00
34	165	9	AV2 -0.22	47	24	7	AV3 +0.00	51	158	7	AV3 +0.00
		8	AV7 +0.29	47	156	6	AV6 +0.27		6		AV6 +0.00
35	6	9	AV7 -0.21	47	158	6	AV6 +0.23	51	160	7	AV2 +0.00
36	159	6	AV2 +0.42	47	160	5	AV1 +0.21		7		AV7 +0.00
36	163	7	AV7 +0.31			6	AV2 -0.12	51	162	9	AV2 +0.00
36	165	7	AV2 -0.30			7	AV3 -0.13		11		AV3 +0.00
37	6	9	AV7 +0.00			6	AV7 +0.27		10		AV7 +0.00
37	164	7	AV2 -0.14	47	162	7	AV2 -0.09		6		AV1 +0.00
		5	AV7 +0.31			8	AV3 -0.17	52	9	9	AV2 +0.00
38	163	7	AV2 +0.00			12	AV6 +0.27		10		AV7 +0.00
		7	AV7 +0.00	48	7	13	AV3 +0.00		7		AV8 +0.00
38	165	6	AV7 +0.00			9	AV7 +0.00	52	11	9	AV3 -0.17
39	6	7	AV2 -0.05			7	AV8 +0.00		7		AV6 +0.30
		8	AV7 +0.02	48	9	9	AV2 -0.09		7		AV7 +0.28
39	8	6	AV8 +0.00			6	AV3 -0.19		5		AV1 +0.00
		7	AV7 +0.00			6	AV6 +0.25	52	13	8	AV2 +0.00
39	162	6	AV2 +0.00			6	AV7 +0.28		7		AV3 +0.00
39	164	11	AV2 +0.00	48	11	6	AV3 -0.16		5		AV7 +0.00
		9	AV7 +0.31	48	161	5	AV2 -0.12	52	17	6	AV3 +0.00
		6	AV8 +0.00			12	AV6 +0.27	52	19	6	AV3 +0.00
40	163	7	AV2 -0.11			7	AV7 +0.27	52	23	11	AV3 -0.05
		11	AV7 +0.27	48	163	15	AV2 -0.21	52	39	6	AV3 +0.00
41	6	6	AV2 +0.00	49	8	7	AV2 -0.09	52	151	6	AV6 +0.00
41	164	8	AV7 -0.15			8	AV6 +0.25	52	159	5	AV8 +0.27
42	7	7	AV7 +0.00			8	AV7 +0.18		6		AV1 +0.00
42	9	5	AV2 +0.02	49	10	13	AV3 +0.00		6		AV6 +0.00
42	163	7	AV7 -0.21	49	12	5	AV2 +0.00	52	161	14	AV6 +0.00
43	6	5	AV2 +0.00			10	AV3 +0.00		7		AV7 +0.00
		8	AV3 +0.00	49	14	5	AV2 +0.00	53	8	6	AV1 -0.09
43	162	6	AV6 +0.28			6	AV3 +0.00		6		AV2 -0.09
43	164	7	AV6 +0.00	49	24	7	AV3 +0.47		9		AV3 -0.17
		7	AV7 +0.00	49	158	8	AV6 +0.27		9		AV7 +0.28
44	7	10	AV3 +0.00			8	AV7 +0.27		6		AV8 +0.29
		7	AV7 +0.00	49	160	8	AV2 -0.14	53	10	8	AV2 +0.00
44	9	7	AV2 -0.11			9	AV7 +0.20		10		AV3 +0.33
44	11	6	AV1 +0.00	49	162	7	AV2 -0.14	53	14	6	AV2 +0.00
		7	AV8 +0.00			8	AV3 -0.15		8		AV3 +0.13
44	163	12	AV2 +0.00			7	AV7 +0.27		7		AV8 +0.07
		11	AV3 +0.00	50	7	9	AV2 +0.17	53	16	11	AV3 +0.00
		11	AV6 +0.00			10	AV3 -0.19		9		AV6 +0.00
		8	AV8 +0.00			10	AV7 +0.25		10		AV7 +0.00
45	8	8	AV6 +0.00			8	AV7 -0.23	53	24	12	AV3 +0.00
		7	AV7 +0.00	50	9	6	AV2 -0.14	53	158	6	AV2 -0.07
45	12	7	AV3 -0.16			10	AV7 +0.23		9		AV3 -0.09
45	160	6	AV3 +0.00	50	11	7	AV1 +0.00		5		AV6 -0.30
45	162	6	AV1 +0.00			7	AV3 +0.00		10		AV7 +0.27
		7	AV2 +0.00			7	AV7 +0.00	53	160	11	AV2 -0.12
		9	AV3 +0.00	50	13	6	AV3 +0.00		7		AV3 -0.13
		7	AV6 +0.00	50	15	6	AV3 +0.23		7		AV7 +0.22
		7	AV7 +0.00	50	157	8	AV6 -0.32		7		AV8 +0.25
		7	AV8 +0.00			7	AV7 +0.04	53	162	14	AV3 +0.00
46	7	12	AV3 -0.16	50	159	8	AV3 +0.44		7		AV6 +0.00
		10	AV7 +0.25			8	AV6 -0.23		8		AV7 +0.00
46	9	6	AV3 +0.00	50	161	6	AV2 -0.12	54	9	7	AV1 -0.04
		7	AV6 +0.00			14	AV6 +0.25		14		AV2 -0.16
		6	AV7 +0.00			8	AV7 +0.25		12		AV3 -0.14
46	11	6	AV3 -0.16	50	163	7	AV2 +0.00		8		AV8 +0.23
46	17	7	AV3 +0.00			8	AV3 +0.00		10		AV6 -0.28
46	161	9	AV2 +0.00			7	AV7 +0.00		9		AV6 +0.23
		9	AV6 +0.00	51	8	10	AV2 +0.00	54	11	6	AV2 -0.09
46	163	8	AV2 -0.21			10	AV3 +0.00		7		AV3 +0.11
		7	AV3 -0.15			8	AV6 +0.30		7		AV7 +0.18
		11	AV6 +0.30			11	AV7 +0.00		6		AV8 +0.13
		7	AV8 +0.25			7	AV8 +0.00	54	13	6	AV1 -0.11
47	8	8	AV2 -0.12	51	10	7	AV3 +0.20		9		AV3 +0.37
		6	AV6 +0.32			7	AV8 -0.09		7		AV7 +0.20
47	10	12	AV3 +0.42	51	14	9	AV2 +0.00	54	15	7	AV7 +0.00
47	12	6	AV3 -0.16			6	AV3 +0.00	54	29	6	AV3 +0.00
		6	AV7 +0.20	51	16	7	AV3 +0.00	54	153	8	AV6 -0.24
47	14	4	AV2 +0.16	51	24	9	AV3 +0.08	54	155	9	AV6 -0.27
		6	AV3 +0.47	51	156	7	AV3 +0.00	54	157	6	AV7 +0.22

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G B

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
54	159	6	AV3 +0.35								
		8	AV6 -0.05	57	12	5	AV1 +0.00	59	156	8	AV2 -0.07
		8	AV7 +0.22			7	AV3 +0.00			6	AV3 -0.04
54	161	7	AV1 -0.13			6	AV7 +0.00			9	AV6 +0.23
		7	AV2 -0.09	57	14	8	AV3 +0.00			7	AV7 +0.22
		11	AV3 -0.13	57	16	6	AV3 +0.00	59	158	8	AV1 -0.09
		19	AV6 +0.28	57	20	6	AV3 +0.00			11	AV2 -0.02
55	10	9	AV1 +0.00			6	AV8 +0.00			11	AV3 -0.09
		7	AV7 +0.00	57	24	13	AV3 +0.00			8	AV6 +0.23
55	12	7	AV1 +0.00	57	130	7	AV6 -0.29			13	AV7 +0.25
		6	AV2 +0.00	57	144	7	AV6 +0.00	59	160	10	AV1 -0.11
		11	AV3 +0.00	57	152	7	AV6 +0.00			14	AV7 +0.23
		7	AV6 +0.00			6	AV8 +0.00			12	AV8 +0.25
		10	AV7 +0.00	57	154	7	AV3 +0.00	60	11	7	AV1 -0.11
		9	AV8 +0.00			7	AV6 +0.00			6	AV2 -0.07
55	14	13	AV3 +0.00			8	AV7 +0.00			14	AV3 +0.41
55	16	9	AV3 +0.00	57	156	7	AV2 +0.00			9	AV6 -0.18
		8	AV6 +0.00			8	AV6 +0.00			10	AV7 +0.23
		12	AV7 +0.00	57	158	6	AV1 +0.00			6	AV8 +0.22
		7	AV8 +0.00			8	AV2 +0.00	60	13	6	AV1 +0.09
55	22	7	AV6 +0.00			11	AV3 +0.00			8	AV2 +0.00
55	24	8	AV3 +0.47			10	AV6 +0.00			9	AV3 +0.00
55	146	7	AV6 +0.18			11	AV7 +0.00			9	AV7 +0.25
55	154	5	AV7 +0.18	57	160	12	AV2 +0.00			10	AV8 +0.22
55	156	5	AV6 -0.30			9	AV7 +0.00	60	15	6	AV2 +0.00
		9	AV7 +0.27			9	AV8 +0.00			10	AV3 +0.00
55	158	6	AV3 -0.09	58	9	8	AV3 -0.17	60	17	7	AV3 +0.00
		8	AV6 +0.25			14	AV6 -0.27			8	AV6 -0.21
		7	AV7 +0.25			15	AV7 +0.26			8	AV8 +0.00
55	160	5	AV1 -0.07			6	AV8 +0.11	60	21	6	AV1 +0.11
		12	AV2 -0.07	58	11	5	AV2 -0.05	60	23	5	AV2 -0.07
		7	AV3 -0.13			9	AV3 -0.10			8	AV3 +0.00
		15	AV7 +0.20			9	AV7 +0.30	60	25	6	AV3 +0.00
		9	AV8 +0.25	58	13	6	AV3 +0.00			6	AV7 +0.00
56	9	7	AV2 +0.00			9	AV7 +0.00			6	AV8 +0.00
		18	AV3 +0.00	58	15	5	AV3 +0.00	60	31	4	AV3 -0.19
		16	AV7 +0.00			6	AV7 +0.00	60	51	6	AV3 +0.00
		6	AV8 +0.00	58	17	5	AV3 +0.00	60	143	6	AV6 +0.00
56	11	7	AV2 +0.00	58	19	6	AV8 +0.00	60	145	7	AV6 +0.00
		9	AV3 +0.00	58	23	8	AV3 +0.05	60	149	15	AV6 +0.00
		6	AV6 +0.00	58	51	7	AV3 -0.14	60	153	15	AV6 -0.18
		7	AV7 +0.00	58	65	5	AV3 -0.07	60	157	5	AV1 -0.13
		6	AV8 +0.00	58	143	9	AV6 +0.21			7	AV2 -0.07
56	13	6	AV2 +0.00	58	155	6	AV8 +0.00			6	AV3 +0.33
		7	AV3 +0.00	58	157	6	AV6 +0.00			6	AV6 +0.23
		8	AV7 +0.00			12	AV7 +0.00			11	AV7 +0.25
56	15	9	AV7 +0.00			7	AV8 +0.00			7	AV8 +0.28
56	17	7	AV3 +0.00	58	159	6	AV1 +0.00	60	159	13	AV6 -0.08
		14	AV6 +0.00			6	AV2 +0.00			6	AV7 +0.22
		12	AV7 +0.00			6	AV3 +0.00			7	AV8 +0.30
		6	AV8 +0.00			10	AV6 +0.00			7	AV1 +0.33
56	23	6	AV3 +0.00			7	AV7 +0.00			17	AV2 +0.37
56	25	6	AV3 +0.00			6	AV8 +0.00			14	AV3 +0.08
56	51	7	AV3 +0.00	58	161	7	AV3 +0.00	61	10	10	AV2 -0.12
56	139	6	AV6 +0.16			18	AV6 +0.00			12	AV3 -0.12
56	153	6	AV6 +0.00	59	10	15	AV7 +0.00			14	AV7 +0.28
56	155	7	AV6 +0.00			9	AV8 +0.00	61	12	7	AV1 +0.00
		6	AV7 +0.00			9	AV1 +0.00			12	AV3 +0.00
56	157	6	AV2 +0.13			9	AV2 +0.00			6	AV6 +0.00
		7	AV6 -0.24			7	AV3 +0.00			9	AV7 +0.00
		11	AV7 +0.22			16	AV6 +0.00	61	14	6	AV2 +0.00
56	159	7	AV3 +0.41	59	12	6	AV2 -0.12			16	AV3 +0.00
		10	AV6 +0.02			8	AV3 -0.12			8	AV6 +0.00
		6	AV7 +0.25			6	AV6 +0.16			9	AV7 +0.00
		8	AV8 +0.25			12	AV7 +0.18	61	16	6	AV1 +0.00
56	161	12	AV3 -0.13	59	14	6	AV2 -0.02			7	AV2 +0.00
		18	AV6 +0.25			13	AV3 -0.09			11	AV3 +0.00
		12	AV6 -0.27			6	AV6 +0.09			8	AV6 +0.00
57	10	8	AV1 -0.07			6	AV7 +0.27			6	AV8 +0.00
		7	AV2 -0.14	59	16	6	AV7 +0.00	61	18	7	AV2 +0.00
		11	AV6 -0.24	59	152	7	AV8 -0.09	61	24	7	AV3 +0.43
		12	AV7 +0.30	59	154	7	AV6 +0.25	61	26	6	AV1 +0.12

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
			4 AV3 +0.00	63	150	9	AV6 -0.03	65	62	7	AV6 +0.00
61	54	6	AV3 +0.00	63	152	11	AV6 +0.00	65	64	9	AV3 +0.00
61	142	7	AV6 +0.00			7	AV7 +0.00	65	68	7	AV3 +0.00
61	146	9	AV6 +0.00	63	154	12	AV6 +0.00			7	AV6 +0.00
		8	AV7 +0.02			8	AV7 +0.00	65	86	5	AV3 +0.00
		7	AV8 +0.05	63	156	7	AV1 +0.00	65	104	8	AV6 +0.00
61	154	10	AV6 +0.00			12	AV3 +0.00	65	110	5	AV6 +0.02
		10	AV7 +0.02			8	AV6 +0.00	65	130	10	AV7 -0.05
61	156	6	AV3 +0.48			11	AV7 +0.00			13	AV6 -0.05
		7	AV6 -0.23	63	158	19	AV6 +0.00			11	AV3 +0.03
		11	AV7 +0.25			16	AV7 +0.00	65	132	6	AV6 -0.23
61	158	7	AV2 -0.09			7	AV8 +0.00	65	144	5	AV3 +0.00
		14	AV3 +0.44			11	AV3 +0.00	65	148	14	AV3 +0.00
		13	AV6 -0.21	64	11	13	AV3 -0.14			14	AV6 +0.00
		7	AV7 +0.27			6	AV6 -0.23	65	152	7	AV6 +0.00
61	160	11	AV3 +0.00			7	AV7 +0.28	65	154	9	AV6 +0.00
		10	AV7 +0.00	64	13	7	AV2 -0.12	65	156	6	AV2 -0.02
62	11	10	AV1 +0.00			5	AV3 +0.00			10	AV3 +0.42
		7	AV2 +0.00			8	AV6 +0.00			7	AV7 -0.16
		13	AV3 +0.00			14	AV7 +0.00	65	158	18	AV6 +0.02
		15	AV6 +0.00			10	AV8 +0.00			10	AV8 +0.23
		13	AV7 +0.00	64	15	9	AV2 +0.00	66	13	7	AV1 +0.07
62	13	6	AV1 +0.00			8	AV3 +0.00			15	AV2 +0.17
		10	AV2 +0.00			11	AV6 +0.00			11	AV7 +0.23
		14	AV3 +0.00			7	AV7 +0.00	66	15	8	AV8 +0.22
		9	AV7 +0.00	64	17	6	AV3 +0.00	66	15	6	AV1 +0.00
62	15	6	AV3 +0.13	64	19	5	AV8 +0.00			8	AV2 +0.00
62	17	8	AV3 +0.00	64	21	6	AV3 +0.00			11	AV3 +0.00
		11	AV6 +0.00	64	23	11	AV3 +0.05			9	AV6 +0.00
		7	AV7 +0.00			8	AV8 +0.11			7	AV7 +0.00
		5	AV8 +0.00	64	27	7	AV3 +0.00	66	17	5	AV2 +0.00
62	19	9	AV6 +0.00	64	31	6	AV3 +0.00			9	AV3 +0.13
		8	AV7 +0.00	64	33	7	AV6 +0.00	66	19	13	AV6 +0.00
62	21	9	AV6 +0.00	64	59	5	AV3 +0.00			9	AV7 +0.00
		10	AV7 +0.00	64	67	6	AV3 +0.37			8	AV8 +0.00
62	23	8	AV3 +0.00	64	101	6	AV6 +0.19	66	23	11	AV3 +0.00
62	29	5	AV3 +0.00	64	107	6	AV3 +0.00	66	29	6	AV6 +0.00
62	31	4	AV3 +0.00	64	137	5	AV8 -0.05	66	31	4	AV2 +0.00
62	39	7	AV7 +0.00	64	151	11	AV6 +0.00			6	AV3 +0.00
62	43	5	AV3 +0.00	64	153	12	AV6 +0.02			6	AV6 +0.00
62	131	7	AV6 +0.02			9	AV7 +0.24	66	41	7	AV6 +0.00
62	139	8	AV6 +0.14	64	157	16	AV2 +0.00	66	49	7	AV6 +0.00
62	149	7	AV2 +0.00			8	AV3 +0.00	66	51	10	AV6 +0.00
62	155	6	AV8 +0.00			8	AV6 +0.00	66	57	7	AV6 +0.00
62	157	7	AV1 -0.11			10	AV7 +0.00	66	63	8	AV6 +0.00
		7	AV2 -0.07	64	159	8	AV7 +0.00	66	65	5	AV3 +0.00
		7	AV6 +0.21			8	AV3 +0.00	66	75	5	AV3 +0.00
		10	AV7 +0.25			8	AV6 +0.00	66	89	6	AV3 +0.00
		11	AV8 +0.02			9	AV2 +0.00			7	AV2 +0.00
62	159	6	AV2 +0.31	65	12	8	AV1 +0.00	66	93	6	AV3 +0.00
		9	AV3 +0.43			5	AV2 +0.00	66	95	7	AV2 +0.00
		8	AV6 -0.20			9	AV3 +0.00	66	99	8	AV2 +0.00
		6	AV7 +0.25			6	AV6 +0.00			8	AV3 +0.00
63	12	6	AV3 -0.07			8	AV8 +0.00			11	AV6 +0.00
		13	AV6 +0.00	65	14	14	AV3 +0.12	66	103	7	AV6 +0.02
		7	AV7 +0.00	65	16	6	AV1 +0.00	66	109	6	AV6 -0.03
63	14	7	AV2 +0.00			11	AV3 +0.00			5	AV3 -0.12
		12	AV3 +0.00			17	AV6 +0.00	66	143	9	AV3 +0.00
		7	AV3 +0.41							13	AV6 +0.00
		12	AV6 +0.00	65	18	7	AV3 +0.00			8	AV7 +0.00
63	16	5	AV1 +0.00	65	20	5	AV2 +0.00	66	149	8	AV6 +0.02
		7	AV3 +0.00	65	22	5	AV3 +0.00	66	153	15	AV6 +0.00
		11	AV6 +0.00	65	24	13	AV3 +0.00			11	AV7 +0.05
		6	AV7 +0.00			14	AV6 +0.00			11	AV8 +0.05
		6	AV8 +0.00	65	32	6	AV3 +0.00	66	155	8	AV1 +0.12
63	18	6	AV2 +0.07	65	34	8	AV2 +0.00			7	AV2 +0.09
63	22	11	AV3 +0.22			9	AV3 +0.00			6	AV7 -0.14
		9	AV6 +0.09			16	AV6 +0.00	66	157	8	AV1 -0.13
63	26	6	AV6 +0.00	65	38	6	AV3 +0.00			6	AV2 -0.07
63	32	5	AV3 -0.05			6	AV6 +0.00			5	AV6 +0.07
63	68	7	AV2 +0.00	65	52	7	AV3 +0.00			14	AV7 -0.16
63	110	6	AV6 +0.00			9	AV6 +0.00	67	12	6	AV1 +0.00
						7	AV7 +0.00				

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		16	AV3 +0.00			12	AV6 -0.05			19	AV6 +0.00
		7	AV6 +0.00	68	109	8	AV7 -0.10			10	AV7 +0.00
		7	AV7 +0.00			15	AV6 -0.02			8	AV8 +0.00
		7	AV8 +0.00			12	AV3 +0.00	70	13	5	AV3 +0.28
67	14	7	AV1 +0.00	68	113	9	AV6 -0.02	70	15	5	AV1 +0.00
		6	AV2 +0.00	68	119	6	AV3 +0.00			6	AV2 +0.00
		8	AV3 +0.00	68	137	5	AV6 +0.16			15	AV3 +0.00
		7	AV7 +0.00	68	143	5	AV3 +0.00			13	AV7 +0.00
		11	AV8 +0.00			8	AV6 +0.16			7	AV8 +0.00
67	16	10	AV3 +0.00			6	AV8 +0.26	70	17	6	AV1 +0.00
		15	AV6 +0.00	68	147	7	AV2 +0.04			6	AV2 +0.00
		7	AV8 +0.00			12	AV3 +0.23			14	AV3 +0.00
67	18	6	AV7 +0.00	68	149	9	AV3 +0.16			6	AV6 +0.00
67	22	7	AV3 +0.00			7	AV7 +0.00			5	AV7 +0.00
67	34	7	AV2 +0.19	68	151	6	AV7 +0.07	70	21	7	AV3 +0.00
67	36	7	AV3 +0.00	68	153	7	AV2 +0.00			7	AV6 +0.00
67	58	8	AV6 +0.00			6	AV8 +0.00	70	33	6	AV3 +0.00
67	68	12	AV6 +0.00	68	155	6	AV1 +0.00	70	41	7	AV3 +0.00
		7	AV7 +0.00			15	AV2 +0.00	70	47	7	AV3 +0.26
67	70	8	AV3 +0.00			7	AV3 +0.00	70	65	9	AV6 +0.00
67	96	7	AV3 +0.00	68	157	10	AV1 -0.11	70	67	7	AV3 +0.00
67	98	6	AV3 +0.00			12	AV2 -0.07			10	AV6 +0.00
67	102	7	AV3 +0.02			11	AV3 +0.33			10	AV7 +0.00
67	108	6	AV3 -0.02			19	AV6 +0.00	70	69	7	AV2 +0.00
		8	AV2 +0.07			14	AV7 -0.12			6	AV3 +0.00
67	112	7	AV3 +0.00			10	AV8 +0.02	70	77	7	AV6 +0.00
67	114	7	AV2 +0.00			17	AV7 +0.25	70	81	6	AV2 +0.00
67	120	8	AV6 -0.03	69	14	7	AV2 +0.00	70	83	12	AV3 +0.00
		5	AV3 +0.00			11	AV7 +0.00	70	89	6	AV2 -0.25
67	148	6	AV6 +0.14			5	AV8 +0.00	70	99	10	AV3 +0.00
67	150	7	AV3 +0.22	69	16	8	AV3 +0.00	70	101	4	AV6 -0.02
67	152	7	AV1 +0.09			8	AV6 +0.00	70	107	5	AV7 -0.10
		10	AV3 +0.15	69	18	8	AV6 +0.00			5	AV6 +0.17
		11	AV6 +0.05			5	AV7 +0.00	70	129	5	AV3 -0.23
		10	AV7 +0.04			6	AV8 +0.00	70	153	7	AV7 +0.20
67	154	10	AV3 +0.15	69	20	6	AV1 +0.00			7	AV8 -0.18
		9	AV6 +0.02			8	AV2 +0.00	70	155	11	AV6 -0.06
		9	AV7 +0.05	69	24	7	AV2 +0.05			5	AV3 +0.27
67	156	8	AV1 -0.09			7	AV3 +0.21	70	157	8	AV3 +0.00
		7	AV2 -0.02	69	28	5	AV3 +0.00			7	AV7 +0.00
		15	AV3 +0.35			4	AV7 +0.00	71	16	7	AV2 +0.00
		7	AV6 -0.20	69	34	5	AV2 +0.00			8	AV3 +0.00
		9	AV7 -0.16			6	AV3 +0.00			10	AV6 +0.00
		11	AV8 +0.23	69	36	5	AV3 +0.17			6	AV8 +0.00
67	158	6	AV2 +0.00			9	AV6 +0.00	71	18	12	AV3 +0.00
		11	AV3 +0.00	69	38	7	AV3 +0.00			10	AV4 +0.00
		7	AV6 +0.00	69	46	6	AV3 +0.00			6	AV8 +0.00
		15	AV7 +0.00	69	52	10	AV7 +0.00	71	20	6	AV2 +0.00
		10	AV8 +0.00			9	AV6 +0.00			5	AV3 +0.00
68	13	9	AV1 +0.00	69	62	11	AV3 +0.00	71	24	6	AV3 +0.00
		9	AV2 +0.00			15	AV6 +0.00	71	28	7	AV1 +0.00
		15	AV3 +0.00			7	AV7 +0.00			8	AV6 +0.00
		19	AV6 +0.00	69	68	9	AV6 +0.00	71	62	13	AV6 +0.00
		7	AV7 +0.00	69	74	7	AV3 +0.00			9	AV7 +0.00
		10	AV8 +0.00	69	76	6	AV7 +0.00	71	76	9	AV7 +0.00
68	15	5	AV2 +0.12	69	80	6	AV2 +0.00	71	78	10	AV3 +0.00
		6	AV3 +0.31	69	82	5	AV2 +0.00	71	80	9	AV2 +0.00
		8	AV6 +0.00	69	84	6	AV2 +0.00			10	AV3 +0.00
		12	AV7 +0.00	69	100	4	AV3 +0.00			7	AV6 +0.00
		7	AV8 +0.00	69	102	5	AV6 -0.09	71	88	7	AV2 -0.21
68	17	8	AV3 +0.00	69	104	15	AV6 -0.04	71	92	6	AV2 +0.00
		6	AV7 +0.00			6	AV3 -0.07	71	96	8	AV3 +0.00
68	23	10	AV3 +0.00	69	110	4	AV6 +0.12	71	100	7	AV3 -0.02
68	27	10	AV6 +0.00	69	136	5	AV6 +0.02	71	104	8	AV6 -0.02
68	39	7	AV6 +0.00	69	138	5	AV6 -0.23	71	106	12	AV7 -0.02
68	41	8	AV6 +0.00	69	148	11	AV3 +0.20			13	AV6 -0.02
68	51	6	AV3 +0.00	69	152	8	AV1 +0.00	71	126	5	AV3 +0.12
68	65	10	AV3 +0.00			8	AV3 +0.00	71	128	5	AV3 +0.06
68	67	6	AV3 +0.00	69	154	6	AV3 +0.00	71	130	5	AV7 -0.21
68	93	7	AV2 +0.00			9	AV7 +0.00			5	AV3 -0.07
68	97	7	AV6 +0.00	69	156	8	AV1 +0.00	71	132	7	AV6 -0.20
68	101	6	AV7 -0.07			16	AV3 +0.00	71	150	6	AV1 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G B

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
71	152	7	AV4 +0.54		8		AV7 +0.00		9		AV7 +0.00
71	154	6	AV3 +0.27	73	80	5	AV2 +0.00	74	91	6	AV7 +0.00
		9	AV7 +0.18	73	82	8	AV3 +0.00	74	93	5	AV6 +0.00
		8	AV8 +0.05	73	84	7	AV2 +0.00		6		AV7 +0.00
71	156	8	AV3 +0.25		11		AV3 +0.00	74	95	9	AV2 +0.00
		6	AV6 -0.08		6		AV4 +0.00		6		AV3 +0.00
		7	AV7 -0.19		8		AV5 +0.00		7		AV4 +0.00
		7	AV8 +0.25	73	86	6	AV2 +0.00	74	97	9	AV3 +0.00
72	15	6	AV1 -0.02	73	88	6	AV2 +0.00		10		AV4 +0.00
		7	AV2 +0.31	73	94	6	AV3 +0.00		6		AV7 +0.00
		7	AV3 +0.00	73	96	6	AV5 +0.00		9		AV8 +0.00
		6	AV4 +0.00		8		AV6 +0.00		6		AV2 +0.00
		11	AV6 +0.00	73	98	11	AV4 +0.00	74	99	7	AV5 +0.00
		7	AV7 +0.00		7		AV5 +0.00		8		AV6 +0.00
		10	AV8 +0.00		7		AV6 +0.00		8		AV7 +0.00
72	17	5	AV1 +0.00	73	102	7	AV6 -0.02	74	101	6	AV6 -0.07
		8	AV3 +0.00	73	104	5	AV6 +0.17		7		AV5 -0.03
		7	AV6 +0.00	73	110	6	AV5 +0.00		9		AV4 -0.07
		5	AV8 +0.18	73	116	5	AV7 -0.02		6		AV3 -0.07
72	21	6	AV3 +0.00		8		AV6 +0.02		6		AV2 -0.05
		8	AV7 +0.00	73	144	6	AV3 -0.02	74	103	7	AV5 +0.00
72	23	5	AV1 +0.00	73	150	7	AV6 +0.00		6		AV4 +0.12
		6	AV3 +0.00	73	152	7	AV7 -0.12	74	105	8	AV7 -0.10
72	27	4	AV1 +0.00	73	154	7	AV3 +0.17		4		AV6 -0.09
		4	AV2 +0.00		5		AV6 -0.04	74	107	8	AV7 -0.05
		9	AV3 +0.11		8		AV8 +0.28		6		AV5 -0.03
72	65	11	AV6 +0.00	74	15	6	AV1 +0.09	74	137	9	AV3 +0.02
		11	AV7 +0.00		10		AV2 +0.00		10		AV2 +0.04
72	67	7	AV6 +0.00		6		AV3 +0.19	74	151	7	AV6 +0.02
72	69	9	AV2 +0.00		18		AV4 +0.00	74	153	9	AV4 +0.00
		7	AV3 +0.00		5		AV5 +0.00		6		AV5 +0.00
		9	AV4 +0.00		7		AV6 +0.00	75	16	5	AV1 +0.00
		6	AV6 +0.00		8		AV7 +0.00		8		AV3 +0.05
72	75	7	AV3 +0.00		10		AV8 +0.00		5		AV7 +0.00
		6	AV4 +0.00	74	17	8	AV3 +0.00		8		AV8 +0.02
		6	AV5 +0.00	74	19	9	AV6 +0.00	75	18	8	AV2 +0.12
		7	AV6 +0.00	74	21	5	AV3 +0.09		7		AV3 +0.19
72	77	9	AV6 +0.00		5		AV5 +0.00		6		AV4 +0.12
72	79	8	AV3 +0.00	74	25	7	AV3 +0.00		5		AV5 -0.03
72	85	6	AV2 +0.00	74	27	6	AV5 +0.00		5		AV8 +0.00
72	91	7	AV7 +0.00	74	51	8	AV6 +0.00	75	20	7	AV5 +0.00
72	99	6	AV2 +0.00		8		AV7 +0.00		6		AV8 +0.00
		8	AV3 +0.00	74	53	7	AV4 +0.00	75	26	5	AV1 +0.00
72	101	7	AV3 -0.05		7		AV5 +0.00		8		AV2 +0.00
		9	AV2 -0.02	74	65	6	AV1 +0.00		9		AV8 +0.00
72	103	7	AV6 +0.00		5		AV2 +0.00	75	36	10	AV4 +0.00
		5	AV3 -0.09		12		AV4 +0.00	75	54	6	AV4 +0.31
72	147	6	AV1 +0.00		11		AV5 +0.00	75	60	7	AV7 +0.05
72	151	11	AV6 +0.00		18		AV6 +0.00	75	62	8	AV4 +0.20
72	153	7	AV6 +0.00		14		AV7 +0.00	75	66	5	AV1 +0.00
		9	AV8 -0.16	74	67	7	AV2 +0.00		8		AV2 +0.00
72	155	7	AV8 +0.23		8		AV6 +0.00		12		AV3 +0.00
73	14	8	AV2 +0.00		6		AV7 +0.00		9		AV4 +0.00
73	16	11	AV6 +0.00	74	69	10	AV4 +0.00		9		AV5 +0.00
73	18	7	AV4 +0.00	74	71	8	AV5 +0.00	75	74	7	AV3 +0.00
73	20	6	AV4 +0.00		7		AV6 +0.00		7		AV4 +0.00
		6	AV8 +0.00	74	75	7	AV2 +0.00		9		AV5 +0.00
73	22	9	AV3 +0.00		8		AV3 +0.00		7		AV6 +0.00
73	26	6	AV1 +0.14		8		AV4 +0.00	75	76	6	AV4 +0.00
73	36	5	AV5 +0.00		9		AV5 +0.00		8		AV5 +0.00
73	48	8	AV3 +0.31		12		AV6 +0.00		7		AV6 +0.00
73	54	7	AV4 +0.00		7		AV7 +0.00		7		AV7 +0.00
73	56	7	AV2 +0.14	74	77	6	AV5 +0.00	75	78	8	AV3 +0.00
		9	AV6 +0.09	74	79	7	AV5 +0.00		6		AV4 +0.26
		11	AV7 +0.09		9		AV6 +0.00	75	80	7	AV2 +0.00
73	60	5	AV4 +0.19	74	83	6	AV2 +0.00	75	82	7	AV3 +0.00
73	62	6	AV6 +0.00		7		AV4 +0.00		6		AV5 +0.00
73	70	8	AV5 +0.00		6		AV5 +0.00	75	84	6	AV2 +0.00
73	76	18	AV3 +0.00	74	85	6	AV2 +0.00	75	86	5	AV7 +0.00
		12	AV4 +0.00		16		AV3 +0.00		7		AV6 +0.00
		18	AV5 +0.00		10		AV4 +0.00		10		AV5 +0.00
		13	AV6 +0.00		7		AV6 +0.00		7		AV4 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G B

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
			7 AV3 +0.00				10 AV6 +0.00				16 AV5 +0.00
75	88	7	AV6 +0.00	76	75	7	AV1 +0.00				12 AV6 +0.00
		7	AV5 +0.00			14	AV2 +0.00				8 AV7 +0.00
		6	AV4 +0.00			14	AV3 +0.00	77	64	7	AV5 +0.00
		6	AV2 +0.00			16	AV4 +0.00				6 AV6 +0.00
75	90	6	AV4 +0.00			19	AV6 +0.00				8 AV7 +0.00
75	94	7	AV4 +0.00			10	AV7 +0.00	77	68	6	AV7 +0.00
		8	AV6 +0.00			7	AV8 +0.00	77	70	7	AV3 +0.00
75	98	12	AV4 +0.00	76	77	8	AV4 +0.19				7 AV5 +0.00
		6	AV5 +0.00			14	AV5 +0.00	77	72	5	AV6 +0.00
		9	AV6 +0.00			11	AV6 +0.00	77	76	8	AV3 +0.00
75	100	6	AV7 +0.00			7	AV7 +0.00				13 AV4 +0.00
		6	AV6 +0.00	76	79	10	AV6 +0.00				17 AV5 +0.00
		11	AV5 -0.03			6	AV7 +0.00				13 AV6 +0.00
		6	AV4 +0.12	76	81	7	AV3 +0.00	77	78	8	AV5 +0.00
75	104	8	AV7 -0.07			8	AV5 +0.00	77	80	6	AV2 +0.00
		12	AV6 -0.02	76	85	9	AV3 +0.00				8 AV3 +0.00
		10	AV5 +0.02	76	87	5	AV6 +0.00				7 AV4 +0.00
		8	AV4 -0.05			11	AV5 +0.00				6 AV5 +0.00
75	106	6	AV8 +0.00			6	AV4 +0.00				6 AV6 +0.00
		9	AV7 -0.05			5	AV3 +0.00	77	82	8	AV3 +0.00
		8	AV6 -0.05	76	89	7	AV2 -0.18				7 AV4 +0.00
		8	AV3 -0.02	76	91	8	AV7 -0.05				15 AV5 +0.00
75	108	8	AV6 -0.02			8	AV6 -0.02				8 AV6 +0.00
		6	AV4 +0.17			8	AV5 +0.00	77	86	6	AV5 +0.00
75	126	6	AV5 +0.21			10	AV4 +0.00				6 AV4 +0.00
75	138	5	AV4 +0.17			8	AV3 +0.00	77	90	7	AV6 +0.00
75	150	6	AV3 +0.13			6	AV3 +0.00	77	92	6	AV7 -0.21
75	152	12	AV4 +0.00	76	93	6	AV4 +0.00				6 AV6 +0.12
		6	AV5 +0.00			7	AV5 +0.00				8 AV5 +0.00
		6	AV7 +0.00	76	95	4	AV1 +0.00				6 AV3 +0.00
		6	AV8 +0.00			7	AV2 +0.00				6 AV2 +0.00
75	154	6	AV1 +0.00			5	AV4 +0.27	77	94	5	AV2 +0.00
		9	AV5 +0.00	76	97	5	AV5 +0.00				7 AV3 +0.00
		9	AV7 +0.00			7	AV7 +0.00				6 AV4 +0.00
76	17	9	AV3 +0.00	76	99	7	AV3 +0.00				5 AV5 +0.00
		7	AV6 +0.00			9	AV4 +0.00				10 AV6 +0.00
		10	AV8 +0.00			17	AV5 +0.00	77	96	6	AV2 +0.00
76	19	6	AV7 +0.00			18	AV6 +0.00				6 AV3 +0.00
		8	AV8 +0.00			17	AV7 +0.00				7 AV5 +0.00
76	21	6	AV1 +0.00			12	AV8 +0.00				5 AV6 +0.00
		7	AV2 +0.00			6	AV2 +0.00				11 AV7 +0.00
		12	AV5 +0.00	76	101	6	AV5 -0.03	77	98	7	AV4 +0.00
76	23	8	AV3 +0.09	76	103	6	AV4 +0.14	77	100	4	AV3 -0.21
76	33	7	AV4 +0.00			8	AV3 -0.05				7 AV2 -0.02
76	35	6	AV5 +0.00			6	AV2 -0.07				4 AV1 +0.14
76	49	8	AV3 +0.18	76	135	5	AV4 +0.17	77	104	8	AV5 -0.23
76	61	10	AV4 +0.00	76	139	6	AV4 +0.00				4 AV4 -0.42
		8	AV5 -0.11	76	151	8	AV6 +0.00	77	106	7	AV6 -0.07
		13	AV6 +0.00			6	AV7 +0.00				6 AV5 +0.00
76	63	8	AV2 +0.00	76	153	6	AV3 +0.27	77	110	9	AV5 -0.06
		16	AV4 +0.00			8	AV4 +0.23	77	140	6	AV5 +0.00
		13	AV5 +0.00			7	AV5 -0.20	77	142	5	AV2 +0.07
		19	AV7 +0.00			5	AV7 -0.05				7 AV4 +0.00
76	65	7	AV1 +0.00	77	16	10	AV8 +0.00	77	146	5	AV3 +0.00
		14	AV5 -0.17	77	20	6	AV1 +0.00	77	150	7	AV6 +0.00
		17	AV6 +0.00			12	AV2 +0.00	77	152	6	AV3 -0.07
		14	AV7 +0.00			6	AV3 +0.00				6 AV4 +0.27
		8	AV8 +0.00			12	AV5 +0.00	78	17	7	AV3 +0.00
76	67	19	AV5 +0.00			17	AV6 +0.00				6 AV8 +0.00
		14	AV6 +0.00			9	AV7 +0.00	78	19	8	AV4 +0.00
		7	AV7 +0.00			11	AV8 +0.00	78	23	5	AV1 +0.00
		8	AV4 +0.22	77	22	6	AV2 +0.15				5 AV2 +0.00
76	69	8	AV1 +0.00	77	24	15	AV3 +0.00				6 AV3 +0.00
		13	AV2 +0.00			9	AV4 +0.00	78	25	7	AV5 +0.00
		14	AV3 +0.00			12	AV5 +0.00	78	27	6	AV5 +0.00
		16	AV5 +0.00			13	AV6 +0.00	78	31	5	AV4 +0.00
		9	AV6 +0.00			7	AV7 +0.00	78	43	6	AV3 +0.00
76	71	7	AV6 +0.00	77	46	6	AV4 +0.00	78	49	7	AV3 +0.00
76	73	9	AV3 +0.00	77	48	9	AV6 +0.00	78	63	8	AV4 +0.00
		10	AV4 +0.00	77	52	6	AV3 +0.00	78	65	6	AV4 +0.00
		9	AV5 +0.00	77	62	8	AV3 +0.00				14 AV6 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		11	AV7 +0.00			6	AV4 +0.00			19	AV5 +0.00
78	67	6	AV2 +0.00	79	52	7	AV6 +0.07			13	AV4 +0.00
78	69	8	AV3 +0.00			7	AV7 +0.02			5	AV8 +0.00
		7	AV4 +0.00	79	54	8	AV2 +0.00	79	128	4	AV4 +0.00
		7	AV5 +0.00	79	60	6	AV3 +0.09	79	132	12	AV7 -0.05
78	75	11	AV2 +0.00			7	AV6 +0.00			8	AV6 -0.10
		12	AV3 +0.00	79	62	9	AV3 +0.00			4	AV5 +0.00
		11	AV4 +0.00			8	AV4 +0.00	79	136	6	AV4 -0.16
		15	AV5 +0.00			12	AV5 +0.00	79	150	6	AV1 -0.05
		7	AV6 +0.00	79	64	6	AV5 +0.00			7	AV8 +0.25
78	77	8	AV4 +0.00	79	66	8	AV2 +0.00	79	152	4	AV1 -0.11
		10	AV5 +0.00			15	AV3 +0.00			7	AV2 +0.09
78	81	7	AV2 +0.00			17	AV5 +0.00			5	AV4 +0.22
		7	AV3 +0.00			14	AV6 +0.00			8	AV7 +0.00
78	83	9	AV3 +0.00	79	70	8	AV3 +0.00	80	19	6	AV1 +0.00
		10	AV4 +0.00			8	AV4 +0.00			7	AV3 +0.00
		9	AV5 +0.00			13	AV5 +0.00			7	AV6 +0.00
		9	AV6 +0.00			9	AV6 +0.00			6	AV7 +0.00
		6	AV7 +0.00	79	72	6	AV3 +0.00			9	AV8 +0.00
78	85	13	AV3 +0.00			9	AV5 +0.00	80	21	8	AV1 +0.00
		9	AV4 +0.00	79	76	6	AV2 +0.00			12	AV2 +0.00
		7	AV5 +0.00			6	AV3 +0.00			8	AV4 +0.00
		7	AV7 +0.00			6	AV4 +0.00	80	23	6	AV4 +0.00
78	89	5	AV7 +0.00			6	AV5 +0.00			6	AV6 +0.00
		7	AV6 +0.00			7	AV6 +0.00	80	25	8	AV4 +0.00
		6	AV3 +0.00	79	78	5	AV5 +0.00	80	27	7	AV1 +0.00
		6	AV2 +0.00	79	80	7	AV4 +0.00	80	29	6	AV4 +0.00
78	93	7	AV3 +0.00			8	AV5 +0.00	80	35	8	AV4 +0.00
		7	AV7 +0.00	79	82	7	AV3 +0.00			7	AV7 +0.00
78	95	10	AV4 +0.00			8	AV4 +0.00	80	37	8	AV5 +0.00
		9	AV5 +0.00			15	AV5 +0.00	80	51	9	AV7 +0.00
78	97	9	AV2 +0.00			10	AV6 +0.00	80	59	7	AV7 +0.00
		8	AV3 +0.00			8	AV7 +0.00			11	AV4 -0.14
		6	AV4 +0.00	79	84	12	AV3 +0.00			9	AV1 +0.11
		11	AV5 +0.00			7	AV4 +0.00	80	63	9	AV6 +0.00
		6	AV8 +0.00	79	86	8	AV7 +0.00	80	65	14	AV2 +0.00
78	99	8	AV2 +0.00			9	AV6 +0.00			8	AV3 +0.00
		8	AV3 +0.00			7	AV5 +0.00			12	AV4 +0.00
		9	AV7 +0.00			8	AV4 -0.12			15	AV5 +0.00
78	101	11	AV6 -0.02			9	AV3 +0.00			16	AV6 +0.00
		9	AV5 +0.12	79	88	7	AV5 +0.00			7	AV7 +0.00
		11	AV2 -0.05			8	AV3 +0.00	80	67	5	AV2 +0.00
		7	AV1 +0.44			6	AV2 +0.00	80	69	7	AV5 -0.03
		4	AV3 +0.15	79	92	6	AV7 +0.00			5	AV4 +0.00
		4	AV4 -0.28	79	94	5	AV6 +0.00			8	AV2 +0.00
78	103	6	AV5 -0.03			7	AV4 +0.00	80	71	6	AV3 +0.00
		4	AV6 +0.12			6	AV3 +0.00			10	AV4 +0.00
78	105	7	AV5 +0.14			7	AV2 +0.00			13	AV5 +0.00
		14	AV4 +0.14	79	96	10	AV7 +0.00			13	AV6 +0.00
78	107	5	AV7 -0.02			11	AV6 +0.00	80	73	8	AV4 +0.00
		4	AV6 +0.12			19	AV5 +0.00			7	AV7 +0.00
		5	AV5 -0.06			5	AV4 +0.00	80	75	7	AV3 +0.00
78	109	5	AV6 +0.00			8	AV3 +0.00			10	AV4 +0.00
		11	AV5 -0.06			12	AV2 +0.00			16	AV5 +0.00
78	131	4	AV3 +0.00			7	AV1 +0.00			15	AV6 +0.00
78	149	8	AV5 +0.02	79	98	11	AV5 +0.00	80	77	10	AV3 +0.00
78	151	10	AV6 +0.00			12	AV4 +0.00			18	AV4 +0.00
78	153	6	AV1 -0.07	79	100	10	AV5 +0.00			19	AV5 +0.00
		6	AV6 +0.05			8	AV4 +0.00			19	AV6 +0.00
79	18	6	AV2 +0.00			6	AV3 +0.00			10	AV7 +0.00
		9	AV6 +0.00	79	104	6	AV7 +0.00	80	79	7	AV3 +0.00
		5	AV7 +0.00			6	AV6 +0.00	80	81	5	AV2 +0.00
		5	AV8 +0.00			15	AV5 +0.00			6	AV3 +0.00
79	20	10	AV1 +0.00			16	AV4 +0.00			7	AV5 +0.00
		14	AV5 +0.00			9	AV3 +0.00	80	83	8	AV3 +0.00
79	22	7	AV3 +0.00	79	106	6	AV4 +0.00			13	AV4 +0.00
		8	AV4 +0.00			9	AV3 +0.00			6	AV5 +0.00
79	24	7	AV2 +0.22			9	AV2 +0.00	80	85	9	AV3 +0.00
		7	AV3 +0.36	79	108	9	AV6 +0.00			9	AV4 +0.00
79	26	5	AV1 +0.00			7	AV5 +0.00			5	AV6 +0.00
79	28	6	AV1 +0.00	79	110	17	AV7 +0.00			7	AV7 +0.00
79	32	6	AV1 +0.00			18	AV6 +0.00	80	87	9	AV6 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		14	AV5 +0.00			19	AV4 +0.00			7	AV3 +0.14
		8	AV4 +0.00	81	68	8	AV1 +0.00			6	AV4 +0.13
		8	AV3 +0.00			6	AV2 +0.00	82	25	7	AV1 +0.25
		9	AV2 +0.00			11	AV5 +0.00			9	AV4 +0.08
80	89	6	AV3 +0.00			7	AV6 +0.00	82	27	6	AV4 +0.11
		6	AV2 +0.00	81	70	6	AV4 +0.00	82	29	6	AV4 +0.00
80	91	6	AV4 +0.00			14	AV5 +0.00	82	31	6	AV5 +0.00
		7	AV3 +0.00			16	AV6 +0.00	82	33	9	AV4 +0.00
80	93	6	AV7 +0.00			8	AV7 +0.00	82	41	8	AV3 +0.00
		7	AV6 +0.00	81	72	5	AV2 +0.00	82	43	6	AV4 +0.11
		7	AV3 +0.00			7	AV4 +0.00	82	59	9	AV3 +0.00
80	95	7	AV5 +0.00			11	AV5 +0.00			6	AV7 +0.00
		4	AV4 +0.00			6	AV7 +0.00	82	61	10	AV5 +0.00
		6	AV2 +0.00	81	74	9	AV2 +0.00			8	AV6 +0.00
80	97	6	AV6 +0.00			9	AV3 +0.00	82	65	10	AV5 +0.00
		5	AV5 +0.00			10	AV4 +0.00			14	AV6 +0.00
		4	AV4 +0.00			7	AV5 +0.00			10	AV7 +0.00
		5	AV3 +0.00	81	76	10	AV4 +0.00	82	67	8	AV5 +0.00
		5	AV2 +0.00			9	AV5 +0.00			7	AV6 +0.00
80	99	6	AV6 +0.00			6	AV6 +0.00	82	69	6	AV4 -0.12
		9	AV5 +0.00			10	AV7 +0.00	82	71	10	AV2 +0.00
		8	AV4 +0.00	81	78	10	AV4 +0.00			9	AV6 +0.00
		4	AV2 +0.00			12	AV5 +0.00	82	73	8	AV2 +0.00
80	101	8	AV6 +0.00			12	AV6 +0.00			8	AV6 +0.00
		10	AV5 +0.00			13	AV7 +0.00			7	AV7 +0.00
		6	AV4 +0.00	81	80	7	AV2 +0.00	82	75	8	AV3 +0.00
80	103	4	AV6 +0.00			7	AV3 +0.00			15	AV4 +0.00
80	105	5	AV6 +0.00			17	AV4 +0.00			12	AV7 +0.00
		4	AV5 +0.00			15	AV5 +0.00	82	77	10	AV4 +0.00
		9	AV4 +0.00			10	AV6 +0.00			10	AV5 +0.00
80	109	5	AV6 +0.00			6	AV7 +0.00			17	AV6 +0.00
		6	AV4 +0.00	81	82	13	AV3 +0.00			9	AV7 +0.00
80	115	6	AV5 +0.00			9	AV4 +0.00	82	79	6	AV3 +0.00
80	125	5	AV5 -0.22			12	AV5 +0.00	82	81	6	AV1 +0.00
80	135	6	AV5 -0.19			11	AV6 +0.00			9	AV3 +0.00
		6	AV3 -0.11	81	84	8	AV3 +0.00			9	AV5 +0.00
80	137	4	AV5 -0.08			8	AV4 +0.00	82	83	10	AV3 +0.00
80	139	5	AV3 +0.00			6	AV5 +0.00			11	AV5 +0.00
80	141	5	AV3 +0.00			4	AV6 +0.00			15	AV6 +0.00
80	143	6	AV2 +0.00	81	86	7	AV6 +0.00	82	85	14	AV3 +0.00
80	145	6	AV4 +0.13			14	AV5 +0.00			12	AV4 +0.00
80	151	8	AV1 -0.09			17	AV4 +0.00			8	AV5 +0.00
		5	AV2 +0.09			8	AV3 +0.00			9	AV6 +0.00
		8	AV6 +0.02	81	88	5	AV5 +0.07			8	AV7 +0.00
81	18	6	AV6 -0.14			8	AV3 +0.00	82	87	13	AV6 +0.00
81	22	8	AV3 +0.17			6	AV2 +0.00			11	AV5 +0.00
		7	AV5 +0.05	81	90	6	AV6 +0.00			8	AV4 +0.00
		8	AV6 +0.07	81	92	6	AV6 +0.00			12	AV3 -0.21
81	26	5	AV2 +0.17			9	AV5 +0.00	82	89	7	AV4 +0.00
		6	AV5 +0.20			10	AV4 +0.00			6	AV2 -0.18
81	28	8	AV1 +0.14			8	AV2 +0.00	82	91	6	AV3 -0.23
		5	AV4 +0.00	81	94	6	AV4 +0.00	82	93	6	AV7 +0.00
		5	AV5 +0.00	81	96	14	AV7 +0.00			6	AV4 +0.00
81	30	5	AV4 +0.00			9	AV6 +0.00			6	AV3 +0.00
81	36	5	AV4 +0.00			5	AV4 +0.00			5	AV2 -0.18
81	38	7	AV2 +0.19	81	98	6	AV5 +0.00	82	95	8	AV6 +0.00
		6	AV4 +0.26			7	AV4 +0.00			5	AV5 +0.00
81	44	9	AV6 +0.00			7	AV2 +0.00			6	AV4 +0.00
81	52	7	AV6 +0.00			9	AV1 +0.00			10	AV3 +0.00
		8	AV5 +0.00	81	100	6	AV5 +0.00			8	AV2 +0.00
		7	AV4 +0.00			5	AV2 +0.00			4	AV1 +0.00
		6	AV3 +0.00	81	106	11	AV4 +0.00	82	97	8	AV7 +0.00
81	54	9	AV4 +0.19			11	AV3 +0.00			8	AV6 +0.00
		17	AV5 +0.07			7	AV2 +0.00			15	AV5 +0.00
		16	AV6 +0.09	81	108	6	AV6 +0.00			13	AV4 +0.00
81	56	6	AV5 +0.00	81	150	6	AV1 -0.09			12	AV3 +0.00
		7	AV3 +0.00	82	19	4	AV3 +0.10			10	AV2 +0.00
81	64	7	AV3 +0.00	82	21	7	AV1 +0.00	82	99	14	AV7 +0.00
		10	AV5 +0.00			9	AV3 +0.00			11	AV4 +0.00
		10	AV7 +0.00			8	AV4 +0.00			9	AV3 +0.00
81	66	17	AV7 +0.00			6	AV5 +0.00			8	AV2 +0.00
		12	AV3 +0.00	82	23	9	AV1 +0.16	82	103	10	AV7 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		6	AV4 +0.00			7	AV5 +0.07	84	65	7	AV5 +0.00
82	105	14	AV7 +0.00			5	AV4 +0.00			13	AV6 +0.00
		15	AV6 +0.00			12	AV3 +0.00			11	AV7 +0.00
		12	AV5 +0.00			8	AV2 +0.00	84	67	6	AV1 +0.00
		8	AV4 +0.00	83	90	5	AV6 +0.00			7	AV2 +0.00
82	107	6	AV6 +0.00			7	AV5 +0.00			10	AV4 +0.00
		7	AV5 +0.00			7	AV4 +0.00			6	AV7 +0.00
82	109	8	AV4 +0.00			6	AV3 +0.00	84	71	6	AV2 +0.00
		5	AV3 +0.00			5	AV2 +0.00			9	AV4 +0.00
82	145	6	AV3 +0.00	83	92	7	AV7 +0.00	84	73	4	AV1 +0.00
		7	AV4 +0.05			9	AV6 +0.00			14	AV2 +0.00
82	147	8	AV2 +0.18			9	AV5 +0.00			17	AV3 +0.00
82	149	5	AV2 -0.02			7	AV4 -0.21			14	AV5 +0.00
83	20	7	AV3 +0.07	83	94	5	AV8 +0.00			13	AV6 +0.00
83	22	6	AV2 +0.17			10	AV7 +0.00	84	75	6	AV3 +0.00
83	24	5	AV2 +0.00			7	AV6 +0.00			13	AV4 +0.00
83	26	8	AV4 +0.00			8	AV5 +0.00			18	AV5 +0.00
83	28	7	AV5 +0.00			11	AV4 +0.00			17	AV6 +0.00
83	32	9	AV1 +0.00	83	96	10	AV8 +0.00			9	AV7 +0.00
		10	AV2 +0.00			16	AV7 +0.00	84	77	12	AV3 +0.00
83	36	6	AV3 +0.00			7	AV6 +0.00			16	AV4 +0.00
		11	AV5 +0.00			9	AV5 +0.00			16	AV5 +0.00
83	38	5	AV5 +0.00			5	AV4 -0.23			18	AV7 +0.00
83	46	7	AV4 +0.00			6	AV3 +0.00	84	79	6	AV5 +0.00
83	52	6	AV6 +0.00			5	AV2 +0.00			7	AV6 +0.00
83	54	8	AV6 +0.00	83	98	7	AV7 +0.00	84	81	9	AV3 +0.00
		8	AV5 +0.00			15	AV6 +0.00			7	AV4 +0.00
83	56	8	AV6 +0.00			12	AV4 +0.00			15	AV5 +0.00
		8	AV7 +0.00			7	AV3 +0.00	84	83	6	AV2 +0.00
83	58	6	AV2 +0.00			7	AV2 +0.00			15	AV3 +0.00
		9	AV4 +0.00	83	100	10	AV6 +0.00			11	AV4 +0.00
83	60	6	AV4 +0.00			14	AV5 +0.00			12	AV5 +0.00
83	62	11	AV5 +0.00			9	AV4 +0.00			8	AV6 +0.00
		9	AV6 +0.00			12	AV3 +0.00	84	85	6	AV2 +0.00
		12	AV7 +0.00	83	102	11	AV7 +0.00			12	AV3 +0.00
83	64	11	AV3 +0.00			7	AV6 +0.00			12	AV4 +0.00
		16	AV5 +0.00			7	AV5 +0.00			12	AV5 +0.00
		13	AV6 +0.00	83	104	9	AV6 +0.00			7	AV7 +0.00
		13	AV7 +0.00			8	AV5 +0.00	84	87	8	AV7 +0.00
83	66	10	AV2 +0.00	83	106	11	AV7 +0.00			17	AV6 +0.00
		7	AV3 +0.00			12	AV6 +0.00			12	AV5 +0.00
		14	AV4 +0.00			15	AV5 +0.00			11	AV4 +0.00
		16	AV6 +0.00	83	110	10	AV8 +0.00			7	AV3 +0.00
83	70	7	AV4 +0.00			10	AV8 +0.00	84	89	7	AV7 +0.00
		12	AV5 +0.00			8	AV6 +0.00			16	AV6 +0.00
		16	AV6 +0.00			9	AV5 +0.00			7	AV4 +0.00
83	72	6	AV3 +0.00	83	128	4	AV4 -0.23			7	AV3 +0.00
83	74	6	AV3 +0.00	83	130	3	AV2 +0.27	84	91	7	AV6 +0.00
		8	AV4 +0.00	83	132	4	AV3 +0.00			7	AV7 -0.07
		10	AV5 +0.00	83	136	6	AV3 -0.16	84	93	7	AV7 +0.00
83	76	6	AV4 +0.00	83	140	6	AV5 +0.00			10	AV6 +0.00
		13	AV5 +0.00	83	146	5	AV2 -0.05			10	AV5 +0.00
		18	AV6 +0.00	84	21	9	AV3 +0.00			8	AV2 +0.00
		16	AV7 +0.00			7	AV6 +0.00			7	AV3 +0.00
83	78	13	AV3 +0.00	84	23	9	AV1 +0.00			6	AV1 +0.00
		14	AV4 +0.00			7	AV3 +0.07	84	95	7	AV7 +0.00
		19	AV7 +0.00			6	AV4 +0.00			6	AV6 +0.00
83	80	11	AV3 +0.00			5	AV7 +0.00			8	AV5 +0.00
		14	AV4 +0.00	84	25	6	AV1 +0.09			7	AV4 +0.00
		18	AV5 +0.00			6	AV4 +0.00			14	AV3 +0.00
		18	AV6 +0.00	84	27	6	AV1 +0.00			14	AV2 +0.00
		8	AV7 +0.00			6	AV4 +0.00			9	AV1 +0.00
83	84	14	AV5 +0.00	84	29	5	AV4 +0.00	84	97	5	AV8 +0.00
		13	AV7 +0.00			4	AV8 +0.00			10	AV7 +0.00
		13	AV3 +0.00	84	31	5	AV2 +0.10			6	AV6 +0.00
		8	AV4 +0.00	84	33	5	AV4 +0.00			8	AV4 +0.00
83	86	5	AV7 +0.00	84	57	8	AV5 +0.00			7	AV3 +0.00
		6	AV6 +0.00			8	AV4 +0.00			9	AV2 +0.00
		5	AV5 +0.00			9	AV3 +0.00	84	99	12	AV7 +0.00
		12	AV4 +0.00	84	63	8	AV3 +0.00			15	AV6 +0.00
		6	AV3 -0.16			8	AV4 +0.00			16	AV5 +0.00
83	88	5	AV6 -0.05			13	AV6 +0.00			12	AV4 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
			11 AV3 +0.00	85	84	6	AV6 +0.00	86	67	7	AV2 +0.00
			5 AV2 +0.00	85	86	8	AV6 +0.00			15	AV3 +0.00
84	101	10	AV6 +0.00			8	AV5 +0.00			7	AV4 +0.00
		11	AV5 +0.00			7	AV4 +0.00	86	71	9	AV3 +0.00
		12	AV4 +0.00			5	AV3 +0.00	86	73	8	AV1 +0.00
		7	AV2 +0.00	85	88	7	AV3 +0.00			12	AV4 +0.00
84	103	16	AV6 +0.00	85	90	5	AV5 +0.00			12	AV6 +0.00
		18	AV5 +0.00			5	AV3 +0.00			7	AV7 +0.00
		6	AV4 +0.00	85	92	9	AV7 +0.00			6	AV8 +0.00
		7	AV2 +0.00			8	AV6 +0.00	86	75	14	AV4 +0.00
84	105	10	AV7 +0.00			6	AV5 +0.00			13	AV7 +0.00
		13	AV6 +0.00			10	AV4 +0.00	86	77	5	AV3 +0.00
		17	AV5 +0.00			9	AV3 +0.00			5	AV5 +0.00
		12	AV4 +0.00			12	AV2 +0.00			12	AV6 +0.00
84	107	7	AV4 +0.00	85	94	5	AV7 +0.00			6	AV7 +0.00
		12	AV5 +0.00			6	AV6 +0.00	86	79	8	AV3 +0.00
84	127	5	AV4 +0.00			6	AV5 +0.00			6	AV6 +0.00
84	141	8	AV5 +0.00			6	AV4 +0.00			6	AV7 +0.00
84	149	8	AV2 +0.11			5	AV2 +0.00	86	81	8	AV2 +0.00
		7	AV3 +0.14	85	96	7	AV6 +0.00			5	AV4 +0.00
85	22	9	AV7 +0.00			7	AV5 +0.00			15	AV5 +0.00
		5	AV8 +0.00			7	AV4 +0.00	86	83	7	AV3 +0.00
		8	AV2 +0.00			6	AV3 +0.00			10	AV4 +0.00
		7	AV6 +0.00			8	AV2 +0.00			11	AV5 +0.00
85	24	6	AV1 +0.12			6	AV1 +0.00			8	AV6 +0.00
		6	AV4 +0.13	85	98	11	AV7 +0.00			14	AV7 +0.00
85	26	7	AV1 -0.14			18	AV6 +0.00	86	85	14	AV2 +0.00
		7	AV4 +0.18			17	AV5 +0.00			18	AV3 +0.00
		5	AV5 +0.27			13	AV4 +0.00			14	AV5 +0.11
85	28	7	AV4 +0.00			6	AV3 +0.00			7	AV7 +0.00
		9	AV5 +0.00			7	AV2 +0.00	86	87	7	AV8 +0.00
85	30	5	AV1 +0.00	85	100	10	AV6 +0.00			15	AV7 +0.00
		7	AV2 +0.00			18	AV4 +0.00			17	AV6 +0.00
		6	AV5 +0.00			7	AV3 +0.00			14	AV5 +0.00
85	32	5	AV4 +0.00	85	102	7	AV4 +0.00			13	AV4 +0.00
85	36	5	AV4 +0.00			6	AV3 +0.00			13	AV3 +0.00
		7	AV5 +0.00	85	104	6	AV6 +0.00	86	89	10	AV7 +0.00
85	44	11	AV5 +0.11			12	AV5 +0.00			18	AV6 +0.00
		9	AV6 +0.07			16	AV4 +0.00			14	AV5 +0.00
85	56	8	AV2 +0.16			16	AV3 +0.00			15	AV4 +0.00
85	60	8	AV7 +0.09	85	106	9	AV4 +0.00			8	AV3 +0.00
85	62	8	AV5 +0.00			8	AV3 +0.00			6	AV2 +0.00
85	64	10	AV5 +0.00			8	AV2 +0.00	86	91	4	AV8 +0.00
		7	AV6 +0.00	85	108	8	AV3 +0.00			8	AV7 +0.00
85	66	7	AV4 +0.00	85	110	7	AV5 +0.00	86	93	5	AV8 +0.00
		10	AV5 +0.00			7	AV4 +0.00			9	AV7 +0.00
		8	AV6 +0.00	85	134	4	AV5 +0.00			14	AV6 +0.00
		7	AV7 +0.00	86	23	11	AV1 +0.00			6	AV4 +0.00
85	70	7	AV3 +0.00			9	AV2 +0.00			6	AV3 +0.00
		6	AV4 +0.00			9	AV5 +0.00			9	AV2 +0.00
		11	AV5 +0.00			8	AV7 +0.00	86	95	13	AV7 +0.00
		8	AV6 +0.00			7	AV6 +0.00			14	AV6 +0.00
85	72	10	AV7 +0.00	86	25	6	AV1 +0.00			15	AV5 +0.00
		6	AV4 +0.00			6	AV2 +0.00			9	AV4 +0.00
85	74	5	AV2 +0.00			8	AV4 +0.00			11	AV3 +0.00
		13	AV3 +0.00	86	27	8	AV4 +0.00	86	97	9	AV7 +0.00
		6	AV4 +0.00			7	AV6 +0.00			15	AV6 +0.00
		7	AV5 +0.00	86	43	6	AV6 +0.00			19	AV4 +0.00
		6	AV6 +0.00	86	53	7	AV7 +0.00			12	AV2 +0.00
85	76	14	AV3 +0.00	86	57	12	AV6 +0.00			6	AV1 +0.00
		10	AV4 +0.00			16	AV7 +0.00	86	99	7	AV7 +0.00
		16	AV5 +0.00			9	AV8 +0.00			16	AV6 +0.00
		16	AV6 +0.00	86	59	7	AV6 +0.00			17	AV5 +0.00
		14	AV7 +0.00	86	61	9	AV3 +0.00			12	AV4 +0.00
85	78	8	AV3 +0.00	86	63	6	AV4 +0.00			14	AV3 +0.00
		8	AV4 +0.00			6	AV5 +0.00			9	AV2 +0.00
		14	AV5 +0.00	86	65	7	AV2 +0.12			7	AV1 +0.00
		14	AV6 +0.00			6	AV3 +0.00	86	101	5	AV5 +0.00
		14	AV7 +0.00			4	AV4 +0.00			8	AV4 +0.00
85	80	6	AV5 +0.00			7	AV5 +0.00			7	AV3 +0.00
		7	AV7 +0.00			6	AV6 +0.00	86	103	11	AV6 +0.00
85	82	9	AV6 +0.00			7	AV7 +0.00			15	AV5 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		8	AV4 +0.00							16	AV6 +0.00
86	105	7	AV6 +0.00	87	96	5	AV7 +0.00			15	AV7 +0.00
		6	AV4 +0.00			12	AV6 +0.00			8	AV8 +0.00
86	107	6	AV4 +0.00			18	AV5 +0.00	88	89	10	AV3 +0.00
86	109	7	AV7 +0.00			12	AV4 +0.00			8	AV4 +0.00
		7	AV2 +0.00			14	AV3 +0.00	88	91	6	AV2 +0.00
86	133	7	AV4 +0.00			13	AV2 +0.00	88	93	7	AV2 +0.00
87	24	5	AV7 +0.00	87	98	17	AV8 +0.00			6	AV3 +0.00
87	34	6	AV2 +0.10			17	AV7 +0.00			6	AV4 +0.00
87	36	4	AV4 +0.00			14	AV5 +0.00			9	AV6 +0.00
87	48	7	AV5 +0.00			9	AV4 +0.00			10	AV7 +0.00
87	54	11	AV2 +0.14			11	AV2 +0.00	88	95	12	AV3 +0.00
87	58	6	AV6 +0.00	87	100	6	AV7 +0.14			16	AV4 +0.00
87	64	10	AV4 +0.00			8	AV6 +0.00			13	AV8 +0.00
		12	AV5 +0.00			6	AV5 +0.00			6	AV2 -0.16
87	66	7	AV5 +0.00			7	AV4 +0.00	88	97	13	AV2 +0.00
		9	AV6 +0.00	87	102	15	AV3 +0.00			18	AV4 +0.00
		13	AV7 +0.00			11	AV2 +0.00			11	AV7 +0.00
87	68	10	AV2 +0.00	87	104	6	AV3 +0.00	88	99	8	AV1 +0.00
87	70	6	AV1 +0.00	87	106	10	AV7 +0.00			9	AV2 +0.00
		11	AV2 +0.00	87	110	10	AV7 +0.00			16	AV3 +0.00
		16	AV3 +0.00			7	AV6 +0.00			16	AV7 +0.00
		17	AV4 +0.00			14	AV5 +0.00	88	101	6	AV3 +0.00
87	72	15	AV2 +0.00			8	AV4 +0.00	88	103	6	AV2 +0.00
		7	AV3 +0.00	87	120	5	AV5 +0.00			16	AV4 +0.00
		12	AV4 +0.00	87	122	6	AV4 -0.16			12	AV7 +0.00
		8	AV5 +0.00	87	128	4	AV3 +0.16	88	105	13	AV2 +0.00
		7	AV7 +0.00	87	130	5	AV4 -0.02			9	AV3 +0.00
87	74	9	AV4 +0.00	87	132	5	AV5 +0.00			10	AV6 +0.00
		13	AV5 +0.00	88	23	6	AV1 +0.11	88	107	8	AV3 +0.00
		8	AV6 +0.00			7	AV4 +0.13			7	AV4 +0.00
87	76	10	AV3 +0.00	88	27	6	AV1 +0.09			10	AV5 +0.00
		12	AV6 +0.00			7	AV4 +0.00			8	AV6 +0.00
87	78	11	AV3 +0.00	88	29	9	AV1 +0.00			6	AV7 +0.00
		12	AV4 +0.00	88	37	7	AV5 +0.00	88	113	6	AV5 +0.00
		11	AV5 +0.00	88	39	8	AV4 +0.00	88	125	4	AV5 -0.21
		12	AV6 +0.00	88	41	6	AV4 +0.00			4	AV4 +0.19
87	80	9	AV3 +0.00	88	49	6	AV5 +0.21	88	131	7	AV3 +0.05
		14	AV4 +0.00	88	59	7	AV3 +0.16			4	AV5 -0.16
		18	AV5 +0.00			7	AV4 +0.31	88	133	5	AV4 -0.09
		8	AV7 +0.00			12	AV6 +0.02			5	AV2 +0.00
87	82	6	AV2 +0.00			9	AV7 +0.09	89	26	6	AV1 +0.00
		8	AV3 +0.00	88	63	7	AV5 +0.00	89	36	6	AV4 +0.00
		14	AV4 +0.00	88	65	9	AV2 +0.00	89	38	4	AV4 +0.00
		17	AV5 +0.00			10	AV5 +0.00	89	46	7	AV3 +0.00
		19	AV6 +0.00	88	69	7	AV5 +0.00	89	48	8	AV5 +0.00
		16	AV7 +0.00	88	71	12	AV3 +0.00	89	52	6	AV2 +0.00
87	84	9	AV6 +0.00			16	AV5 +0.00	89	58	8	AV2 +0.00
		13	AV2 +0.00			16	AV7 +0.00			7	AV3 +0.00
		18	AV3 +0.00	88	73	8	AV3 +0.00	89	60	8	AV3 +0.00
87	86	6	AV7 +0.00			19	AV4 +0.00			7	AV7 +0.00
		8	AV6 +0.00			13	AV5 +0.00	89	62	12	AV3 +0.00
		13	AV5 +0.00			13	AV6 +0.00			7	AV4 +0.00
		8	AV4 +0.00	88	75	8	AV2 +0.00			9	AV2 +0.00
		11	AV3 +0.00			6	AV3 +0.00	89	64	8	AV5 +0.00
87	88	8	AV4 +0.00			7	AV5 +0.00	89	66	7	AV5 +0.00
		10	AV3 +0.00	88	77	10	AV7 +0.00			8	AV7 +0.00
		6	AV2 +0.00	88	79	8	AV4 +0.00			12	AV4 +0.00
		12	AV5 +0.00	88	81	7	AV2 +0.00	89	68	9	AV3 +0.00
87	90	9	AV7 +0.00			7	AV4 +0.00			8	AV4 +0.00
		13	AV6 +0.00			11	AV6 +0.00			12	AV5 +0.00
		17	AV5 +0.00			12	AV7 +0.00	89	70	8	AV5 +0.00
		14	AV4 +0.00	88	83	8	AV3 +0.00			12	AV6 +0.00
		9	AV3 +0.00			7	AV5 +0.00			11	AV7 +0.00
87	92	14	AV5 +0.00	88	85	16	AV2 +0.00	89	72	4	AV1 +0.00
		12	AV4 +0.00			17	AV3 +0.00			6	AV2 +0.00
		8	AV3 +0.00			18	AV4 +0.00			11	AV3 +0.00
87	94	7	AV6 -0.02			10	AV6 +0.00			5	AV4 +0.00
		9	AV5 +0.00			18	AV7 +0.00			16	AV5 +0.00
		7	AV4 +0.00	88	87	9	AV3 +0.00			12	AV6 +0.00
		7	AV3 +0.00			8	AV4 +0.00			10	AV7 +0.00
		7	AV2 +0.00			7	AV5 +0.00	89	74	8	AV2 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		12	AV3 +0.00	89	128	4	AV4 +0.00		7		AV3 +0.00
		13	AV4 +0.00			7	AV3 +0.00		7		AV2 +0.00
		9	AV5 +0.00	90	29	6	AV1 +0.00	90	93	12	AV7 +0.00
		13	AV6 +0.00	90	31	6	AV1 +0.00	9			AV6 +0.00
		17	AV7 +0.00	90	33	5	AV3 +0.10	10			AV5 +0.00
89	76	7	AV3 +0.00	90	37	6	AV5 +0.00	8			AV4 +0.00
		8	AV4 +0.00	90	39	4	AV5 +0.00	7			AV3 +0.00
		10	AV5 +0.00	90	43	6	AV3 +0.00	9			AV2 +0.00
		7	AV6 +0.00	90	51	7	AV3 +0.00	90	95	8	AV7 +0.00
		6	AV7 +0.00	90	53	7	AV8 +0.00	13			AV6 +0.00
89	78	10	AV5 +0.00			9	AV7 +0.00	13			AV5 +0.00
		7	AV7 +0.00			7	AV6 +0.00	7			AV4 +0.00
89	80	8	AV2 +0.00			10	AV5 +0.00	7			AV3 +0.00
		13	AV3 +0.00			6	AV3 +0.00	7			AV2 +0.00
		8	AV4 +0.00	90	59	7	AV3 +0.00	90	97	12	AV5 +0.00
		12	AV5 +0.00	90	61	8	AV3 +0.00	11			AV4 +0.00
		9	AV6 +0.00			11	AV5 +0.00	14			AV3 +0.00
89	82	7	AV2 +0.00	90	63	14	AV5 +0.00	13			AV2 +0.00
		16	AV4 +0.00			7	AV6 +0.00	6			AV1 +0.00
		14	AV7 +0.00			6	AV7 +0.00	90	99	10	AV7 +0.00
89	84	6	AV1 +0.00	90	65	12	AV2 +0.00	18			AV6 +0.00
		13	AV2 +0.00			13	AV3 +0.00	17			AV5 +0.00
		11	AV3 +0.00			9	AV5 +0.00	5			AV4 +0.00
		7	AV7 +0.00			15	AV6 +0.00	9			AV3 +0.00
89	86	9	AV7 +0.00			8	AV7 +0.00	7			AV2 +0.00
		12	AV6 +0.00	90	67	7	AV2 +0.00	90	101	8	AV3 +0.00
		18	AV5 +0.00			6	AV3 +0.00	9			AV4 +0.00
		15	AV4 +0.00			6	AV4 +0.00	90	103	18	AV6 +0.00
		15	AV3 +0.00			7	AV5 +0.00	5			AV5 +0.00
		9	AV2 +0.00			10	AV6 +0.00	17			AV4 +0.00
89	88	14	AV7 +0.00			8	AV7 +0.00	9			AV2 +0.00
		9	AV8 +0.00	90	69	5	AV3 +0.00	6			AV1 +0.00
		12	AV6 +0.00			7	AV4 +0.00	7			AV8 +0.00
		9	AV5 +0.00			7	AV5 +0.00	12			AV7 +0.00
		4	AV4 +0.00			9	AV6 +0.00	90	105	7	AV5 +0.00
		10	AV3 +0.00	90	71	5	AV2 +0.00	90	107	13	AV5 +0.00
		7	AV2 +0.00			9	AV7 +0.00	90	127	5	AV5 -0.21
89	90	6	AV7 +0.00	90	73	7	AV3 +0.00	91	24	6	AV1 +0.00
		14	AV6 +0.00			14	AV4 +0.00	91	36	7	AV4 +0.00
		19	AV5 +0.00			16	AV5 +0.00	91	38	6	AV3 +0.10
		19	AV4 +0.00			14	AV6 +0.00	6			AV5 -0.03
		13	AV3 +0.00	90	75	6	AV2 +0.00	91	44	8	AV3 +0.05
		8	AV2 +0.00			7	AV3 +0.00	91	46	7	AV4 +0.00
89	92	10	AV7 +0.00			6	AV4 +0.00	6			AV5 +0.00
		15	AV5 +0.00	90	77	12	AV4 +0.00	91	50	5	AV5 +0.14
		6	AV3 +0.00	90	79	7	AV3 +0.00	8			AV6 +0.12
		6	AV2 +0.00			12	AV4 +0.00	91	54	7	AV4 +0.00
89	94	10	AV7 +0.00			6	AV5 +0.00	91	58	6	AV4 +0.00
		9	AV6 +0.00			12	AV6 +0.00	91	60	12	AV2 +0.09
		7	AV4 +0.00			9	AV7 +0.00	9			AV4 +0.05
		11	AV3 +0.00	90	81	15	AV2 +0.00	91	64	9	AV5 +0.00
		7	AV2 +0.00			7	AV3 +0.00	91	66	7	AV1 +0.00
89	96	7	AV4 +0.00			14	AV4 +0.00	8			AV2 +0.09
		8	AV3 +0.00	90	83	7	AV2 +0.00	12			AV7 +0.00
		10	AV2 +0.00			11	AV3 +0.00	91	68	7	AV3 +0.00
		6	AV1 +0.00			14	AV6 +0.00	91	70	7	AV4 +0.10
		7	AV7 +0.00	90	85	15	AV2 +0.00	12			AV5 +0.00
		7	AV5 +0.00			13	AV3 +0.00	91	72	6	AV2 +0.14
89	98	7	AV7 +0.00			19	AV4 +0.00	10			AV4 +0.00
		6	AV6 +0.00			12	AV8 +0.00	9			AV5 +0.00
		8	AV5 +0.00	90	87	11	AV7 +0.00	7			AV6 +0.00
		15	AV4 +0.00			8	AV6 +0.00	91	74	9	AV3 +0.14
		8	AV3 +0.00			10	AV5 +0.00	12			AV4 +0.05
		9	AV1 +0.00			16	AV4 +0.00	11			AV5 +0.05
89	100	7	AV8 +0.00			9	AV3 +0.00	16			AV6 +0.10
		12	AV7 +0.00	90	89	10	AV7 +0.00	17			AV7 +0.12
		9	AV6 +0.00			17	AV6 +0.00	91	76	10	AV8 -0.02
		9	AV4 +0.00			15	AV5 +0.00	6			AV2 -0.05
		7	AV3 +0.00			8	AV4 +0.00	6			AV1 -0.05
89	104	7	AV4 +0.00			10	AV3 +0.00	91	78	17	AV7 +0.00
		11	AV3 +0.00			8	AV2 +0.00	11			AV5 +0.00
89	116	6	AV5 +0.00	90	91	8	AV4 +0.00	14			AV3 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		6	AV2 +0.00	92	57	6	AV3 +0.02		17	AV3 -0.07	
91	80	13	AV7 +0.00	92	61	8	AV3 +0.02		18	AV2 +0.02	
		18	AV5 +0.00	92	63	7	AV5 +0.05		14	AV1 -0.05	
		10	AV4 +0.00	92	65	7	AV4 +0.13	92	101	6	AV1 +0.00
91	82	8	AV4 +0.00			11	AV6 +0.05		10	AV2 +0.00	
		7	AV2 +0.00			13	AV7 +0.09		8	AV5 +0.00	
91	84	6	AV7 -0.05	92	67	6	AV4 +0.16	92	103	5	AV2 +0.00
		10	AV6 +0.00	92	69	9	AV3 +0.12		8	AV3 +0.00	
		16	AV4 +0.00			6	AV4 +0.05		17	AV5 +0.00	
		11	AV3 +0.00			13	AV6 +0.05	92	107	10	AV3 +0.09
		6	AV2 +0.00			9	AV7 +0.12		9	AV4 +0.03	
91	86	10	AV7 -0.02	92	71	6	AV2 +0.05		6	AV7 +0.02	
		12	AV6 +0.00			7	AV3 +0.02	92	109	7	AV5 +0.09
		17	AV5 +0.00			6	AV6 +0.09	92	117	8	AV4 +0.00
		16	AV4 +0.00			6	AV8 +0.16	92	121	6	AV3 +0.00
		13	AV2 +0.00	92	73	7	AV4 +0.05		7	AV5 +0.00	
91	88	7	AV8 +0.00			7	AV7 +0.12	92	123	6	AV5 +0.07
		8	AV7 +0.00	92	75	7	AV3 +0.00		6	AV2 +0.00	
		8	AV6 +0.00			10	AV4 +0.00	93	24	7	AV1 -0.11
		16	AV5 +0.00			10	AV6 +0.00	93	26	8	AV1 +0.00
		14	AV4 +0.00			15	AV7 +0.00	93	30	6	AV1 +0.23
		10	AV3 +0.00			8	AV8 +0.00	93	40	7	AV3 +0.00
		6	AV2 +0.00	92	77	6	AV3 +0.00		7	AV4 +0.13	
91	90	15	AV7 +0.00			8	AV2 +0.00	93	44	7	AV4 +0.13
		7	AV6 +0.00			5	AV8 +0.00	93	46	7	AV4 +0.08
		8	AV5 +0.00	92	79	12	AV7 +0.00	93	54	6	AV6 +0.07
		15	AV4 +0.00	92	81	8	AV8 +0.00	93	60	6	AV4 +0.00
		8	AV3 +0.00			7	AV4 +0.00	93	64	10	AV5 +0.07
91	92	7	AV3 +0.00			11	AV3 +0.00		13	AV6 +0.05	
		7	AV2 +0.00	92	83	10	AV6 +0.00		9	AV7 +0.07	
		17	AV8 +0.00			19	AV4 -0.07		8	AV4 +0.05	
		18	AV7 +0.00			16	AV3 +0.00	93	66	7	AV6 +0.09
		14	AV4 +0.00			7	AV2 +0.00		7	AV5 +0.05	
91	94	9	AV7 +0.00	92	85	17	AV4 +0.00	93	68	7	AV2 +0.00
		9	AV6 +0.00			10	AV3 +0.00		7	AV3 +0.00	
		7	AV5 +0.00			11	AV2 +0.00	93	70	6	AV4 +0.00
		6	AV4 +0.00			6	AV1 +0.00		7	AV5 +0.00	
		9	AV3 +0.00	92	87	9	AV8 +0.00	93	72	7	AV3 +0.00
		8	AV2 +0.00			13	AV7 +0.00		9	AV4 +0.00	
91	96	15	AV7 +0.00			12	AV6 +0.00		16	AV6 +0.00	
		8	AV3 +0.00			12	AV4 +0.00		6	AV7 +0.00	
		6	AV2 +0.00			14	AV3 +0.00	93	74	6	AV2 +0.00
		7	AV1 +0.00			8	AV1 +0.00		10	AV3 +0.00	
91	98	19	AV7 +0.00	92	89	6	AV6 +0.00		12	AV4 +0.00	
		17	AV5 +0.00			10	AV4 +0.00		14	AV5 +0.00	
		12	AV4 +0.00			8	AV3 +0.00	93	76	12	AV6 +0.00
		12	AV3 +0.00			6	AV2 +0.00	93	78	17	AV5 +0.00
		9	AV2 +0.00	92	91	7	AV7 -0.05		14	AV6 +0.00	
		11	AV1 +0.00			9	AV6 -0.12		7	AV7 +0.00	
91	100	18	AV4 +0.13			5	AV4 +0.08	93	80	9	AV3 +0.00
		14	AV5 +0.12			8	AV3 -0.07		6	AV4 +0.00	
		7	AV6 +0.12	92	93	12	AV7 +0.00		12	AV5 +0.00	
91	102	6	AV5 +0.07			13	AV6 +0.00		18	AV6 +0.00	
		8	AV7 +0.02			18	AV5 +0.00		7	AV7 +0.00	
		7	AV8 +0.07			14	AV4 +0.00	93	82	19	AV6 -0.02
91	104	10	AV3 +0.10			7	AV3 +0.00		9	AV4 +0.00	
		7	AV6 +0.10			7	AV2 +0.00		7	AV3 +0.00	
91	106	7	AV4 +0.11	92	95	7	AV7 +0.00		7	AV2 +0.00	
91	110	8	AV3 +0.07			17	AV6 +0.00	93	84	8	AV8 +0.02
		8	AV4 +0.13			18	AV5 +0.00		16	AV7 +0.00	
91	120	6	AV5 +0.14			13	AV3 +0.00		13	AV3 +0.00	
91	124	5	AV4 -0.09			9	AV2 +0.00		10	AV2 +0.00	
91	128	5	AV4 -0.07	92	97	6	AV2 +0.00	93	86	17	AV3 +0.00
92	25	6	AV1 +0.00			8	AV8 +0.00		8	AV2 -0.09	
92	27	6	AV1 -0.02			12	AV7 +0.00	93	88	9	AV7 -0.09
92	37	5	AV5 +0.07			18	AV6 +0.00		18	AV6 -0.05	
92	39	7	AV5 +0.00			12	AV5 +0.00		16	AV5 +0.00	
92	43	5	AV4 +0.03			7	AV4 +0.00		5	AV4 -0.12	
		6	AV5 +0.02			7	AV3 +0.00		13	AV3 +0.00	
92	45	6	AV5 +0.07	92	99	14	AV8 -0.02		11	AV2 +0.00	
92	49	6	AV4 +0.11			18	AV7 -0.02	93	90	6	AV7 +0.15
92	53	7	AV5 +0.09			11	AV4 +0.00		12	AV5 -0.03	

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		6	AV3 -0.09			8	AV2 +0.00	95	64	5	AV4 +0.00
		7	AV2 +0.00			7	AV3 +0.00			11	AV6 +0.00
		6	AV4 -0.12			6	AV4 +0.00			13	AV7 +0.00
93	92	11	AV8 -0.02	94	81	15	AV3 -0.07	95	66	6	AV1 +0.00
		8	AV6 +0.00			18	AV5 +0.00			7	AV2 +0.00
		17	AV5 +0.00	94	83	10	AV2 +0.00			9	AV3 +0.00
		6	AV4 -0.21			6	AV1 +0.00	95	68	7	AV3 +0.07
		6	AV3 +0.00			9	AV8 -0.08			5	AV5 +0.02
		11	AV2 -0.05			13	AV7 -0.09	95	70	12	AV4 +0.05
93	94	18	AV7 +0.00	94	85	12	AV7 -0.02			5	AV5 +0.09
		5	AV4 +0.00			13	AV6 -0.07			8	AV6 +0.12
		16	AV3 +0.00			18	AV5 -0.08			6	AV7 +0.07
		9	AV2 +0.00			8	AV1 +0.05	95	72	6	AV1 +0.09
		6	AV1 +0.00	94	87	12	AV7 +0.00			16	AV3 +0.09
93	96	7	AV4 +0.00			13	AV6 +0.00			14	AV4 +0.13
		7	AV3 -0.05			8	AV2 +0.00			16	AV5 +0.09
93	98	5	AV8 -0.10	94	89	5	AV7 +0.15			9	AV6 +0.07
		13	AV3 +0.00			7	AV6 -0.02	95	74	7	AV3 +0.16
		6	AV2 -0.07			9	AV5 +0.00			8	AV6 +0.00
		4	AV1 +0.11			13	AV4 +0.00			8	AV7 +0.00
93	100	7	AV2 +0.00			14	AV3 +0.00	95	76	12	AV7 +0.00
		10	AV3 +0.00			11	AV2 +0.00			12	AV6 +0.00
		9	AV5 +0.00			5	AV1 +0.05			16	AV5 +0.00
		13	AV7 +0.00	94	91	12	AV7 +0.00	95	78	10	AV7 +0.00
93	102	8	AV4 +0.00	94	93	5	AV7 +0.00			16	AV6 +0.00
		10	AV5 +0.07			14	AV6 +0.00			19	AV5 +0.00
93	104	17	AV3 +0.00			13	AV5 +0.00			11	AV4 +0.00
		13	AV4 +0.00			16	AV4 +0.00			18	AV3 +0.00
		10	AV5 +0.00			7	AV3 +0.00	95	80	8	AV3 +0.00
		6	AV6 +0.00			6	AV2 +0.00	95	82	6	AV7 +0.00
93	106	6	AV4 +0.00			5	AV1 +0.00			17	AV5 +0.00
93	112	8	AV4 +0.10	94	95	13	AV5 +0.00			7	AV3 +0.00
93	116	6	AV2 +0.00			5	AV1 +0.00			7	AV2 +0.00
93	128	6	AV4 +0.00	94	97	4	AV8 -0.20	95	84	10	AV8 +0.00
		8	AV5 +0.00			9	AV6 +0.00			18	AV7 +0.00
93	134	6	AV8 +0.00			6	AV5 +0.00			11	AV6 +0.00
94	25	6	AV1 -0.11			4	AV4 +0.00			14	AV2 +0.00
94	39	7	AV5 +0.00			6	AV3 +0.00			7	AV1 +0.00
94	45	8	AV4 +0.00			11	AV2 +0.00	95	86	8	AV8 +0.00
94	47	7	AV2 +0.00	94	99	7	AV8 +0.00			17	AV6 +0.00
94	49	7	AV4 +0.00			6	AV7 +0.00			17	AV2 +0.02
94	53	6	AV6 +0.00			16	AV6 +0.00	95	88	8	AV8 +0.00
94	55	6	AV4 +0.00			16	AV5 +0.00			18	AV6 +0.00
		6	AV5 +0.00			17	AV4 +0.00			13	AV5 +0.00
94	59	6	AV3 +0.00			15	AV3 +0.00			12	AV3 +0.00
		5	AV7 +0.00			6	AV2 +0.00			12	AV2 +0.00
94	65	6	AV2 +0.14			6	AV1 +0.00	95	90	9	AV7 +0.00
		7	AV6 +0.00	94	101	6	AV3 +0.12			14	AV6 +0.00
94	67	19	AV4 +0.00			9	AV4 +0.16			18	AV5 +0.00
		14	AV5 +0.00	94	103	10	AV3 +0.12			13	AV4 +0.00
		13	AV6 +0.00			11	AV6 +0.00			6	AV3 -0.18
		12	AV7 +0.00	94	105	10	AV2 +0.09			6	AV2 +0.00
94	69	17	AV3 +0.00			10	AV3 +0.10	95	92	8	AV7 +0.00
		6	AV1 +0.14	94	115	6	AV3 +0.00			7	AV6 +0.00
		7	AV6 +0.09	94	119	6	AV3 +0.00			7	AV4 +0.00
94	71	7	AV1 +0.14			8	AV4 +0.00			6	AV3 +0.00
		8	AV2 +0.09			7	AV5 +0.00			7	AV2 +0.00
		9	AV5 +0.00	94	123	7	AV4 +0.00	95	94	17	AV7 +0.00
		11	AV6 +0.00	94	125	12	AV2 +0.09			12	AV6 +0.00
94	73	11	AV1 +0.00	95	28	6	AV1 +0.05			17	AV5 +0.00
		7	AV2 +0.00	95	46	7	AV4 +0.11			12	AV4 +0.00
		9	AV4 +0.00	95	48	6	AV5 -0.03			13	AV3 +0.00
94	75	7	AV3 +0.00	95	50	7	AV4 +0.00			17	AV2 +0.00
		7	AV4 +0.00			6	AV5 +0.00			10	AV1 +0.00
94	77	8	AV2 +0.00	95	54	8	AV3 +0.00	95	96	14	AV7 +0.00
		9	AV4 +0.00	95	58	7	AV3 +0.05			15	AV3 +0.00
		18	AV5 +0.00			7	AV4 +0.05			6	AV2 +0.00
		13	AV7 +0.00	95	60	7	AV4 +0.00	95	98	10	AV7 +0.00
94	79	12	AV5 +0.00	95	62	6	AV4 +0.00			6	AV6 +0.00
		17	AV6 +0.00			7	AV5 +0.00			6	AV5 +0.00
		11	AV7 +0.00			8	AV6 +0.00			7	AV4 +0.00
		6	AV1 +0.00			7	AV7 +0.00			18	AV3 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		8	AV2 +0.00			6	AV1 +0.00			8	AV5 +0.09
95	100	11	AV1 +0.09	96	89	7	AV8 +0.00			11	AV6 +0.00
		15	AV2 +0.07			12	AV7 +0.00			7	AV7 +0.07
		18	AV3 +0.09			18	AV5 +0.00	97	76	17	AV7 +0.00
		18	AV4 +0.03			7	AV4 +0.00	97	78	12	AV3 +0.00
		16	AV5 +0.05			7	AV3 +0.00			6	AV4 +0.00
		9	AV6 +0.07	96	91	6	AV7 -0.12			15	AV5 +0.00
		8	AV7 +0.05			15	AV6 -0.09			9	AV6 +0.00
95	102	10	AV3 +0.12			5	AV5 -0.08			11	AV7 +0.00
		10	AV4 +0.00			8	AV4 -0.07	97	80	9	AV3 +0.00
95	104	13	AV8 +0.00			7	AV3 -0.19			7	AV5 +0.00
		15	AV6 +0.00			7	AV2 +0.07			6	AV7 +0.00
		13	AV5 +0.00	96	93	6	AV8 +0.00	97	82	8	AV7 +0.00
		6	AV4 +0.00			7	AV4 +0.00			14	AV6 +0.00
		8	AV3 +0.00			13	AV3 +0.00			14	AV5 +0.00
95	106	9	AV5 +0.00			11	AV2 +0.00			9	AV4 +0.00
95	110	8	AV3 +0.00	96	95	8	AV8 +0.00			9	AV3 +0.00
		7	AV2 +0.00			9	AV7 +0.00			7	AV2 +0.00
95	112	6	AV4 +0.00			10	AV6 +0.00	97	84	13	AV7 -0.07
95	118	6	AV5 +0.21			10	AV5 +0.00			18	AV4 +0.00
95	120	6	AV5 +0.00			5	AV4 +0.00			13	AV3 +0.00
		5	AV4 +0.00			8	AV3 +0.00			14	AV2 +0.00
96	39	8	AV4 +0.08			8	AV2 +0.00	97	86	13	AV2 +0.00
96	41	8	AV5 +0.00	96	97	8	AV8 +0.00			9	AV8 -0.05
96	43	7	AV4 +0.00			14	AV4 +0.00			18	AV6 -0.05
96	47	7	AV3 +0.00			15	AV3 +0.00	97	88	9	AV7 -0.05
96	49	7	AV6 +0.00			10	AV2 +0.00			15	AV6 +0.00
96	53	8	AV3 +0.00	96	99	4	AV5 +0.12			14	AV5 +0.00
96	57	8	AV4 +0.16			10	AV4 -0.07			11	AV4 +0.00
96	59	12	AV4 +0.16			7	AV3 +0.05			7	AV3 +0.00
96	61	9	AV1 +0.00	96	101	7	AV3 +0.09			6	AV2 +0.00
96	65	6	AV5 +0.00			9	AV4 +0.03	97	90	14	AV7 +0.00
		7	AV6 +0.00			6	AV5 -0.03			16	AV6 -0.05
96	67	8	AV4 +0.08	96	103	12	AV4 +0.10			8	AV5 +0.02
96	69	6	AV4 +0.00			10	AV5 +0.02			7	AV4 +0.00
		7	AV5 +0.00	96	105	13	AV2 +0.00			15	AV3 +0.00
96	71	7	AV2 +0.00			8	AV4 +0.00			7	AV2 +0.00
		15	AV3 +0.00	96	107	13	AV7 +0.00			4	AV1 +0.00
		16	AV6 +0.07			11	AV6 +0.00	97	92	9	AV8 +0.00
		13	AV8 +0.00			7	AV3 +0.00			12	AV7 +0.00
96	73	14	AV4 +0.05	96	109	9	AV5 +0.00			14	AV6 -0.09
		9	AV5 +0.05			6	AV7 +0.00			16	AV2 +0.00
96	75	7	AV3 +0.00	96	115	6	AV4 +0.00	97	94	10	AV7 +0.00
		6	AV4 +0.00	96	117	7	AV3 +0.00			15	AV6 +0.00
		7	AV5 +0.00	97	34	7	AV3 +0.00			6	AV5 -0.05
		8	AV6 +0.00	97	36	8	AV5 +0.00			7	AV4 +0.00
		6	AV7 +0.00	97	42	5	AV5 -0.11			11	AV3 +0.02
96	77	10	AV8 +0.00			5	AV6 +0.07			8	AV2 -0.02
		12	AV6 +0.00	97	46	7	AV5 +0.00			6	AV1 -0.05
		12	AV4 +0.00	97	48	8	AV5 +0.00	97	96	12	AV3 +0.00
		19	AV2 +0.00	97	50	7	AV4 +0.03			8	AV2 +0.00
96	79	17	AV7 +0.00	97	54	10	AV3 +0.09			6	AV1 +0.00
		10	AV3 +0.00	97	56	5	AV3 +0.00			13	AV7 +0.00
96	81	11	AV8 +0.00			6	AV6 +0.00			16	AV5 +0.00
		14	AV7 +0.00	97	58	5	AV3 +0.00			7	AV4 +0.00
		7	AV6 +0.00			7	AV4 +0.00	97	98	15	AV7 +0.00
		9	AV5 +0.00			12	AV5 +0.00			17	AV6 +0.00
		8	AV4 +0.00			6	AV6 +0.00			16	AV4 +0.00
		10	AV3 +0.00	97	62	7	AV4 +0.00			12	AV3 +0.00
		8	AV2 +0.00	97	64	8	AV8 +0.11			6	AV2 +0.00
96	83	11	AV8 +0.00	97	66	19	AV5 +0.02	97	100	8	AV4 -0.05
		13	AV7 +0.00			16	AV8 +0.09			16	AV5 +0.07
		10	AV6 +0.00	97	68	6	AV3 +0.00			15	AV6 +0.07
		18	AV5 +0.00			6	AV4 +0.00	97	102	6	AV4 +0.13
		18	AV3 +0.00			10	AV5 +0.00			5	AV1 +0.00
		12	AV2 +0.00	97	70	11	AV2 +0.00			9	AV5 +0.05
		10	AV1 +0.00			11	AV3 +0.00	97	104	15	AV3 +0.14
96	87	15	AV7 +0.00			7	AV4 +0.00			18	AV5 +0.09
		17	AV5 +0.00	97	72	8	AV5 +0.00			12	AV6 +0.07
		19	AV4 +0.00			7	AV2 +0.14			11	AV7 +0.00
		18	AV3 +0.00			8	AV3 +0.19	97	106	9	AV3 +0.05
		13	AV2 +0.00			7	AV4 +0.13			10	AV6 +0.07

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		6	AV7 +0.02		6	AV3 +0.00		99	74	11	AV4 +0.00
97	114	5	AV4 -0.02		6	AV2 +0.00				15	AV5 +0.00
97	118	5	AV4 -0.02		4	AV1 +0.00				14	AV6 +0.00
		6	AV5 +0.09	98	95	15	AV8 +0.00			10	AV7 +0.00
98	27	7	AV1 -0.09		17	AV7 +0.00		99	76	8	AV7 +0.00
98	29	7	AV1 +0.00		6	AV5 +0.00				19	AV6 +0.00
		7	AV2 +0.00		4	AV3 +0.00				10	AV5 +0.00
		7	AV8 +0.00		7	AV2 +0.00				9	AV4 +0.00
98	43	5	AV4 +0.08		4	AV1 +0.00				14	AV3 +0.00
98	49	5	AV5 +0.16	98	97	7	AV8 +0.00	99	78	12	AV7 +0.00
98	51	7	AV4 +0.00		9	AV6 +0.00				10	AV6 +0.00
98	53	7	AV3 +0.00		16	AV5 +0.00				11	AV5 +0.00
		8	AV6 +0.05		12	AV3 +0.00				8	AV4 +0.00
98	57	5	AV2 +0.00		17	AV2 +0.00				9	AV3 +0.00
		8	AV4 +0.08	98	99	6	AV8 +0.00	99	80	11	AV7 +0.00
98	59	6	AV5 +0.14		10	AV4 +0.00				8	AV6 +0.00
98	61	7	AV4 +0.13		7	AV3 +0.00				16	AV4 +0.00
98	63	6	AV4 +0.13		7	AV2 +0.00				19	AV3 +0.00
98	65	10	AV6 +0.09	98	101	6	AV2 +0.00			6	AV2 +0.00
		7	AV7 +0.12		6	AV3 +0.00		99	82	8	AV7 +0.00
98	67	9	AV1 +0.00		7	AV6 +0.00				9	AV6 +0.00
		17	AV3 +0.00		6	AV7 +0.00				7	AV2 +0.00
		7	AV4 +0.00	98	103	13	AV2 +0.00	99	84	7	AV8 +0.00
98	69	8	AV2 +0.00		19	AV4 +0.00				10	AV7 +0.00
		7	AV3 +0.16		18	AV5 +0.00				17	AV3 +0.00
		7	AV4 +0.16	98	105	7	AV6 +0.00			18	AV2 +0.00
		7	AV7 +0.07		10	AV3 +0.00				8	AV1 +0.00
98	71	7	AV3 +0.02	98	107	6	AV5 +0.07	99	86	10	AV8 +0.00
		5	AV4 +0.08		16	AV6 +0.07				12	AV5 +0.00
		7	AV6 +0.09		13	AV7 +0.07				8	AV1 +0.00
98	73	6	AV5 +0.12	98	109	9	AV3 +0.00	99	88	9	AV7 +0.00
98	75	4	AV2 +0.00		7	AV4 +0.16				16	AV6 +0.00
		9	AV3 +0.00	98	111	7	AV5 +0.14			16	AV5 +0.00
		6	AV4 +0.00	98	121	7	AV3 +0.00			10	AV4 +0.00
		9	AV6 +0.00		6	AV4 +0.00				9	AV3 +0.00
		16	AV7 +0.00	98	129	6	AV2 +0.07			8	AV2 +0.00
		12	AV8 +0.00		6	AV3 +0.00		99	90	7	AV8 +0.00
98	77	6	AV3 +0.00	98	141	6	AV3 +0.12			10	AV6 +0.00
		8	AV4 +0.00	99	30	6	AV1 -0.02			7	AV5 +0.00
		14	AV5 +0.00	99	32	7	AV1 +0.21			8	AV4 +0.00
		6	AV6 +0.00	99	38	7	AV2 +0.19			10	AV7 +0.00
		7	AV7 +0.00	99	42	6	AV3 +0.00			7	AV3 +0.00
98	79	6	AV4 +0.00	99	44	6	AV4 +0.08	99	92	18	AV7 +0.00
		5	AV5 +0.00	99	46	8	AV5 +0.00			7	AV1 +0.00
		13	AV6 +0.00		7	AV6 +0.00		99	94	8	AV7 +0.00
98	81	13	AV3 +0.00	99	48	7	AV3 +0.02			7	AV6 +0.00
		18	AV4 +0.00	99	50	8	AV2 +0.00			12	AV4 +0.00
		10	AV5 +0.00		8	AV4 +0.00				13	AV3 +0.00
		5	AV6 +0.00	99	52	7	AV4 +0.08			12	AV2 +0.00
98	83	6	AV7 +0.00	99	54	8	AV6 +0.00			8	AV1 +0.00
		5	AV6 -0.02		7	AV3 +0.00		99	96	5	AV7 +0.00
		18	AV5 -0.03	99	56	16	AV3 +0.07			19	AV6 +0.00
		18	AV4 -0.02		8	AV4 +0.16				13	AV3 +0.00
		16	AV3 +0.00	99	58	9	AV3 +0.07			6	AV1 +0.00
		9	AV2 +0.00	99	60	8	AV4 +0.00	99	98	10	AV4 +0.00
98	85	7	AV8 +0.00	99	62	7	AV4 +0.08			6	AV2 +0.00
		16	AV6 -0.05	99	64	9	AV5 +0.12			6	AV1 -0.19
		13	AV5 -0.03		15	AV6 +0.12		99	100	9	AV5 +0.00
		8	AV1 -0.02		6	AV4 +0.13		99	102	9	AV1 +0.09
98	87	12	AV8 +0.00		10	AV8 +0.02				8	AV2 +0.09
		19	AV5 -0.10	99	66	9	AV2 +0.07			7	AV3 +0.07
		14	AV4 -0.02		10	AV3 +0.07				15	AV4 +0.00
		8	AV3 -0.12		7	AV7 +0.07				14	AV5 +0.00
98	89	9	AV6 -0.02	99	68	10	AV2 +0.00	99	104	9	AV2 +0.18
		13	AV5 -0.03		11	AV3 +0.09				8	AV3 +0.16
		12	AV4 +0.00		9	AV4 +0.13				7	AV5 +0.05
		7	AV3 -0.16	99	70	8	AV4 +0.00	99	108	10	AV4 +0.00
98	91	12	AV5 +0.00		7	AV5 +0.00				7	AV5 +0.00
		12	AV3 +0.00	99	72	8	AV3 +0.07			14	AV3 +0.00
98	93	5	AV6 +0.00		9	AV5 +0.00		99	110	13	AV4 +0.00
		12	AV5 +0.00		10	AV6 +0.02		99	116	6	AV4 +0.08
		16	AV4 +0.00		7	AV7 +0.00		99	120	6	AV5 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
99	124	5	AV1 +0.07	100	99	6	AV6 -0.21	101	94	7	AV7 +0.00
		6	AV3 +0.00			17	AV4 +0.00			8	AV6 +0.00
		5	AV4 +0.10			10	AV3 +0.02			12	AV4 -0.05
99	128	6	AV6 +0.00			8	AV2 -0.02			8	AV3 +0.00
99	132	8	AV5 +0.00	100	101	9	AV5 +0.00			7	AV2 +0.00
100	31	6	AV2 +0.00			8	AV6 +0.07	101	96	7	AV7 +0.00
		7	AV5 +0.00			7	AV7 +0.07			6	AV5 +0.00
100	45	6	AV5 +0.00			8	AV3 +0.09			7	AV4 +0.00
100	47	8	AV4 +0.00	100	103	14	AV2 +0.11			13	AV3 +0.00
100	49	7	AV5 +0.00			19	AV3 +0.12			12	AV2 +0.00
100	55	6	AV3 -0.09			16	AV4 +0.13	101	98	7	AV8 +0.00
100	57	4	AV2 +0.00			15	AV5 +0.07			9	AV6 +0.00
		6	AV4 +0.00			12	AV6 +0.12			13	AV5 +0.00
		5	AV5 +0.00	100	105	7	AV6 +0.02			19	AV4 +0.00
100	59	6	AV5 +0.00	100	135	7	AV4 -0.02			18	AV2 +0.00
100	63	5	AV4 +0.00	101	30	11	AV1 +0.00			10	AV1 +0.00
		12	AV7 +0.00			8	AV2 +0.00	101	100	7	AV2 +0.09
100	65	14	AV3 +0.00	101	46	6	AV5 +0.00			11	AV4 +0.00
		7	AV4 +0.00			9	AV6 +0.00	101	104	7	AV6 +0.00
		10	AV6 +0.00	101	48	6	AV4 +0.11			8	AV3 +0.00
		10	AV7 +0.00			5	AV5 +0.09	101	106	7	AV2 +0.00
100	67	7	AV3 +0.00	101	50	6	AV4 +0.00	101	110	7	AV5 +0.00
100	71	8	AV2 +0.00	101	52	8	AV4 +0.00	101	112	10	AV3 +0.00
		11	AV3 +0.00	101	54	5	AV3 +0.00			6	AV2 +0.00
		6	AV4 +0.00			7	AV4 +0.00	101	118	6	AV4 +0.00
		7	AV5 +0.00	101	56	6	AV4 +0.05	101	140	6	AV2 +0.13
		7	AV6 +0.00	101	58	6	AV5 +0.07			6	AV6 +0.00
		14	AV7 +0.00	101	60	8	AV4 +0.00			8	AV7 +0.00
		8	AV8 +0.00	101	62	5	AV4 +0.00	102	31	7	AV2 +0.26
100	73	6	AV1 +0.00	101	64	5	AV3 +0.00			7	AV3 +0.09
100	75	6	AV3 +0.00			6	AV4 +0.00			9	AV6 +0.00
100	77	13	AV4 +0.00			6	AV5 +0.00	102	47	9	AV4 +0.00
100	79	15	AV7 +0.00			15	AV6 +0.00			12	AV6 +0.00
		15	AV6 +0.00			16	AV7 +0.00	102	51	8	AV4 +0.00
		9	AV5 +0.00			7	AV8 +0.00	102	65	8	AV2 +0.00
100	81	9	AV6 +0.00	101	66	16	AV4 +0.00			9	AV4 +0.13
		14	AV4 +0.00			18	AV5 +0.00	102	71	9	AV6 +0.00
		14	AV3 +0.00			14	AV6 +0.00	102	73	11	AV5 +0.00
		9	AV2 +0.00	101	70	8	AV5 +0.12	102	75	4	AV1 +0.09
100	85	9	AV5 +0.00			6	AV6 +0.16			5	AV2 +0.00
		19	AV3 +0.00	101	72	7	AV3 +0.12			9	AV3 +0.00
		13	AV2 +0.00			7	AV5 +0.14			18	AV7 +0.00
		6	AV1 +0.00	101	74	7	AV1 +0.07			12	AV8 +0.00
100	87	16	AV7 +0.00			7	AV2 +0.00	102	77	9	AV4 +0.00
		18	AV4 +0.00			10	AV6 +0.09			12	AV5 +0.00
		8	AV3 +0.00	101	76	11	AV3 +0.00			8	AV6 +0.00
100	89	6	AV7 +0.00	101	78	6	AV5 +0.00			11	AV7 +0.00
		10	AV6 +0.00	101	80	6	AV2 +0.00	102	79	6	AV3 +0.00
		14	AV5 +0.00			8	AV4 +0.00			10	AV4 +0.00
		15	AV4 +0.00			6	AV5 +0.00			6	AV6 +0.00
		9	AV3 +0.00	101	86	18	AV6 -0.09	102	81	6	AV2 +0.00
100	91	13	AV7 -0.02			8	AV3 -0.02			16	AV7 +0.00
		14	AV6 -0.07			12	AV2 +0.00	102	83	6	AV8 +0.12
		18	AV5 +0.00	101	88	5	AV4 -0.21			9	AV3 -0.02
		11	AV4 +0.00			7	AV3 -0.07			6	AV2 -0.07
		5	AV2 +0.00			5	AV2 -0.18	102	85	6	AV8 -0.12
100	93	7	AV6 +0.00			7	AV7 +0.00			13	AV5 +0.00
		14	AV4 +0.00			11	AV6 -0.02			18	AV4 +0.00
		5	AV3 +0.00			8	AV5 -0.10			18	AV2 +0.00
		8	AV2 +0.00	101	90	15	AV8 -0.02			14	AV1 +0.00
100	95	14	AV7 +0.00			18	AV7 +0.00	102	87	4	AV8 +0.14
		6	AV6 +0.00			13	AV6 -0.05			16	AV4 -0.09
		9	AV5 +0.00			13	AV5 -0.05			10	AV3 -0.07
		8	AV4 +0.00			6	AV4 -0.05			11	AV2 -0.05
		7	AV3 +0.00			7	AV3 -0.09			7	AV1 -0.09
		9	AV2 +0.00			7	AV2 -0.09	102	89	16	AV7 -0.02
100	97	7	AV7 +0.00	101	92	8	AV7 -0.28			19	AV4 -0.07
		5	AV5 +0.00			8	AV6 +0.00			8	AV1 +0.00
		5	AV4 -0.07			19	AV5 -0.03	102	91	10	AV4 -0.09
		11	AV3 +0.00			6	AV4 -0.21			15	AV3 +0.00
		12	AV2 +0.00			9	AV3 -0.05			12	AV2 +0.00
		4	AV6 +0.00			8	AV2 -0.02	102	93	6	AV7 +0.02

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		8	AV5 +0.00			9	AV3 +0.00			8	AV8 -0.02
		12	AV4 +0.00			8	AV2 +0.00			11	AV6 -0.09
		8	AV2 +0.00			7	AV8 +0.00	104	93	8	AV3 +0.00
		5	AV1 +0.00	103	92	14	AV8 +0.00	104	95	8	AV7 +0.00
102	95	6	AV8 +0.00			12	AV7 +0.00			6	AV6 +0.00
		6	AV7 +0.00			13	AV6 +0.00			10	AV5 +0.00
		14	AV6 +0.00			17	AV3 +0.00			6	AV4 +0.00
		6	AV5 +0.00			11	AV2 +0.00			9	AV3 +0.00
		7	AV4 +0.00			7	AV1 +0.00			15	AV2 +0.00
		5	AV3 +0.00	103	94	6	AV7 +0.00			7	AV1 +0.00
		7	AV2 +0.00			8	AV5 +0.00	104	97	8	AV6 +0.00
102	97	13	AV8 +0.00			18	AV4 +0.00			16	AV5 +0.00
		13	AV7 -0.02			15	AV3 +0.00			15	AV3 +0.00
		18	AV6 -0.05			6	AV2 +0.00			9	AV2 +0.00
		18	AV5 +0.02	103	96	6	AV6 +0.00	104	99	6	AV7 -0.19
		16	AV3 -0.02			5	AV5 +0.00			6	AV6 -0.05
		14	AV2 +0.02			16	AV4 +0.00			4	AV5 +0.00
		11	AV1 +0.02			12	AV3 +0.00			4	AV4 -0.02
102	99	8	AV4 +0.00			8	AV7 +0.00			16	AV3 +0.02
102	109	7	AV5 +0.00	103	98	10	AV7 +0.00			8	AV2 -0.05
		11	AV3 +0.00			11	AV5 +0.00			5	AV1 -0.05
		12	AV2 +0.00			8	AV4 +0.00	104	105	8	AV4 +0.00
102	113	6	AV5 +0.07			6	AV2 +0.00	104	107	8	AV4 +0.11
102	115	6	AV4 +0.00			9	AV5 +0.02	104	109	6	AV4 +0.16
102	119	6	AV5 +0.00	103	100	9	AV6 +0.00	104	121	6	AV4 +0.00
		6	AV4 +0.00			9	AV7 +0.02	104	133	6	AV7 +0.00
103	44	8	AV5 +0.00	103	104	7	AV4 +0.11	105	38	6	AV6 +0.00
103	52	7	AV3 +0.00	103	110	7	AV5 +0.09	105	54	11	AV5 +0.09
103	54	6	AV3 +0.00	103	120	7	AV4 +0.11			7	AV3 +0.12
103	56	6	AV4 +0.00	103	124	6	AV5 +0.07			7	AV4 +0.13
		6	AV5 +0.00	103	126	6	AV4 +0.00	105	58	8	AV3 +0.12
		6	AV6 +0.00	104	45	5	AV6 +0.02			6	AV4 +0.13
103	58	7	AV6 +0.00	104	49	6	AV3 +0.00	105	64	6	AV5 +0.07
103	60	7	AV4 +0.00	104	59	7	AV4 +0.11	105	70	9	AV6 +0.00
103	64	8	AV4 +0.10	104	61	6	AV3 -0.12	105	72	6	AV1 +0.00
103	66	6	AV2 +0.00	104	63	6	AV4 +0.08			15	AV2 +0.09
		10	AV4 +0.13			9	AV5 +0.07			12	AV5 +0.12
		6	AV6 +0.00			6	AV6 +0.05			8	AV6 +0.07
103	70	6	AV5 +0.00	104	71	6	AV2 -0.02	105	74	8	AV3 +0.00
103	72	6	AV3 +0.00			6	AV3 +0.07			7	AV4 +0.00
		8	AV4 +0.00			6	AV7 +0.14			11	AV6 +0.00
		6	AV5 +0.00	104	73	8	AV2 +0.05			8	AV7 +0.00
		8	AV6 +0.00			7	AV3 +0.02	105	76	6	AV4 +0.00
103	74	9	AV3 +0.07			9	AV4 +0.08	105	78	10	AV2 +0.00
		8	AV4 +0.08	104	77	13	AV7 +0.00			6	AV3 +0.00
		11	AV5 +0.09			10	AV6 +0.00			6	AV4 +0.00
		12	AV6 +0.12			7	AV5 +0.00			12	AV5 +0.00
		11	AV7 +0.14			11	AV4 +0.00	105	80	5	AV2 -0.04
103	76	12	AV6 +0.00			9	AV3 +0.00			5	AV5 +0.00
		7	AV5 +0.00	104	79	6	AV3 +0.00			8	AV6 +0.00
		7	AV4 +0.00			6	AV2 +0.00	105	82	7	AV7 +0.00
		6	AV3 +0.00	104	81	12	AV7 +0.00			11	AV6 +0.00
103	78	8	AV5 +0.00			14	AV6 +0.00			9	AV5 +0.00
103	80	5	AV5 +0.00			15	AV5 +0.00			10	AV4 +0.00
		5	AV1 +0.00			8	AV4 +0.00			16	AV3 +0.00
103	82	8	AV5 +0.00			18	AV3 +0.00	105	86	13	AV8 -0.02
103	84	7	AV8 +0.00	104	83	16	AV8 +0.00			10	AV3 -0.09
		17	AV2 +0.00			8	AV7 +0.00			15	AV2 -0.05
		7	AV1 +0.00			8	AV3 +0.00	105	88	7	AV5 +0.00
103	86	13	AV7 -0.12	104	87	7	AV7 +0.00			7	AV4 -0.02
		18	AV6 +0.00			11	AV6 +0.00			13	AV3 -0.07
		9	AV3 -0.02			17	AV4 +0.00			11	AV2 +0.00
		16	AV2 -0.07			8	AV3 +0.00			8	AV1 +0.00
103	88	16	AV8 +0.00			7	AV2 +0.00	105	90	6	AV4 -0.21
		15	AV7 +0.00			6	AV1 +0.00			6	AV3 -0.14
		16	AV6 +0.00	104	89	11	AV7 +0.00			5	AV2 -0.18
		10	AV5 +0.00			7	AV6 +0.00			7	AV8 -0.07
		6	AV4 +0.00			9	AV5 +0.00			18	AV7 -0.08
		10	AV3 +0.00			9	AV4 +0.00			7	AV6 +0.00
103	90	18	AV7 +0.00			8	AV3 +0.00			14	AV5 +0.00
		11	AV6 +0.00	104	91	13	AV2 +0.00	105	92	6	AV7 -0.31
		8	AV5 +0.00			6	AV1 +0.12			8	AV6 -0.02

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION				
			5 AV4 -0.19				11 AV2 -0.07				17 AV6 +0.00				
			10 AV3 +0.00				9 AV1 -0.14				9 AV5 +0.00				
			6 AV2 +0.16	106	89	12	AV7 -0.12				10 AV3 +0.00				
			6 AV1 +0.09				8 AV6 -0.02				7 AV1 +0.00				
105	94	5	AV7 +0.00				8 AV5 +0.16	107	80	13	AV7 +0.00				
			8 AV6 +0.00				6 AV4 -0.26				10 AV6 +0.00				
			6 AV5 +0.00				6 AV3 -0.18				8 AV4 +0.00				
			9 AV4 +0.00				6 AV2 -0.25	107	82	8	AV7 +0.00				
			7 AV3 +0.00	106	91	9	AV7 +0.00				9 AV6 +0.00				
			6 AV2 +0.00				9 AV6 +0.00				19 AV5 +0.00				
105	96	7	AV6 +0.00				14 AV4 -0.09				16 AV3 +0.00				
			7 AV4 +0.00				7 AV3 +0.00				8 AV2 +0.00				
			12 AV3 +0.00	106	93	9	AV6 -0.02	107	84	18	AV7 +0.00				
			12 AV2 +0.00				13 AV5 -0.05				17 AV3 +0.00				
			8 AV1 +0.00				13 AV4 -0.02				8 AV2 +0.00				
105	98	6	AV7 +0.00				9 AV3 +0.02	107	88	7	AV7 +0.00				
			10 AV5 +0.00				12 AV2 -0.05				9 AV6 +0.00				
			10 AV4 +0.00				6 AV1 -0.09				16 AV5 +0.00				
			13 AV3 +0.00	106	95	8	AV7 +0.00				16 AV4 +0.00				
			7 AV2 +0.00				7 AV6 +0.00				12 AV3 +0.00				
			4 AV1 +0.00				14 AV5 +0.00				7 AV2 +0.00				
105	100	8	AV4 +0.00				16 AV4 +0.00				7 AV1 +0.00				
			7 AV7 +0.00				9 AV3 +0.00	107	90	6	AV7 +0.00				
105	112	12	AV3 +0.00				9 AV2 +0.00				7 AV6 +0.00				
			6 AV5 +0.00	106	97	6	AV7 -0.12				8 AV5 +0.00				
106	33	11	AV6 +0.00				4 AV6 +0.05				7 AV4 +0.00				
			6 AV7 +0.09				13 AV5 -0.05				8 AV3 +0.00				
106	41	9	AV6 +0.00				16 AV4 +0.03				9 AV2 +0.00				
106	43	8	AV5 +0.00				19 AV2 -0.02	107	92	15	AV7 +0.00				
106	53	6	AV1 +0.00				11 AV1 +0.00				7 AV6 +0.00				
			11 AV2 +0.00	106	99	7	AV4 +0.00				19 AV2 +0.00				
			8 AV3 +0.00				7 AV3 +0.00				8 AV1 +0.00				
			8 AV4 +0.00				6 AV2 +0.00	107	94	17	AV6 +0.00				
			8 AV5 +0.00	106	101	8	AV5 +0.07				6 AV5 +0.00				
106	55	7	AV4 +0.00	106	103	6	AV4 +0.10				12 AV4 +0.00				
			6 AV5 +0.00				6 AV5 -0.05				7 AV3 +0.00				
106	57	7	AV4 +0.00				6 AV6 +0.14				14 AV2 +0.00				
106	59	8	AV5 +0.00	106	111	7	AV5 +0.00				7 AV1 +0.00				
106	61	6	AV3 +0.00	106	119	6	AV4 +0.00	107	96	16	AV4 +0.00				
			5 AV4 +0.00				7 AV7 +0.00				19 AV3 +0.00				
			6 AV5 +0.00	106	129	6	AV3 +0.00	107	98	4	AV7 +0.00				
106	63	5	AV3 +0.00	107	34	7	AV1 +0.00				8 AV6 +0.00				
			7 AV5 +0.00				7 AV2 +0.00				11 AV4 +0.00				
106	65	7	AV6 +0.00				7 AV6 +0.00				8 AV3 +0.00				
106	67	6	AV3 +0.09				7 AV7 +0.00				12 AV2 +0.00				
			6 AV4 +0.03				10 AV8 +0.00				6 AV1 +0.00				
106	71	11	AV4 +0.00	107	46	7	AV3 +0.02	107	100	7	AV2 +0.07				
			7 AV3 +0.00				12 AV6 +0.12				18 AV3 +0.07				
106	73	6	AV3 -0.16	107	50	8	AV7 +0.00				12 AV4 +0.05				
			7 AV4 +0.00	107	56	6	AV3 +0.00				8 AV5 +0.00				
			7 AV5 +0.00	107	60	7	AV4 +0.00				6 AV6 +0.00				
			7 AV6 +0.00				7 AV5 +0.00				10 AV7 +0.11				
106	77	5	AV3 +0.00	107	62	5	AV3 +0.00	107	104	6	AV4 +0.00				
			6 AV5 +0.00	107	64	5	AV2 +0.00				107	108	6	AV5 +0.07	
106	81	8	AV3 +0.00				6 AV5 +0.00				107	112	6	AV5 +0.00	
			15 AV4 +0.00				6 AV6 +0.00				107	128	6	AV5 +0.00	
			12 AV5 +0.00				7 AV5 +0.05								5 AV4 +0.00
			13 AV6 +0.00	107	66	7	AV5 +0.05				108	35	7	AV2 +0.26	
			15 AV7 +0.00	107	68	7	AV2 +0.12				108	45	8	AV3 +0.00	
106	83	16	AV5 -0.03				9 AV3 +0.12				108	49	8	AV5 +0.00	
			19 AV3 +0.00				7 AV4 +0.18								17 AV6 +0.00
			8 AV2 +0.00	107	70	6	AV4 +0.03				108	61	6	AV3 +0.00	
			8 AV1 +0.00				9 AV5 +0.05								6 AV5 +0.00
106	85	17	AV5 -0.05				10 AV6 +0.00	108	65	8	AV3 +0.00				
			5 AV4 -0.02	107	72	6	AV2 +0.14				8	AV4 +0.13			
			19 AV2 -0.02				7 AV7 +0.12				7	AV5 +0.05			
			12 AV1 -0.09	107	74	11	AV3 +0.14				8	AV6 +0.02			
106	87	6	AV8 -0.02	107	76	6	AV5 +0.00	108	67	7	AV3 +0.00				
			6 AV7 -0.12				18 AV4 +0.00				7	AV6 +0.00			
			17 AV6 +0.10				15 AV3 +0.00				6	AV7 +0.09			
			9 AV5 -0.08				7 AV2 +0.00	108	71	6	AV4 +0.00				
			7 AV4 -0.02	107	78	16	AV7 +0.00				10	AV5 +0.02			

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G B

03/17 - EOC22
Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		11	AV6 +0.02			12	AV4 +0.18			6	AV5 +0.10
108	73	7	AV2 +0.00			7	AV5 +0.09	109	112	7	AV2 +0.16
		8	AV5 +0.00			9	AV6 +0.09	109	114	9	AV3 +0.07
		8	AV6 +0.05	109	68	6	AV2 +0.09			6	AV5 +0.21
108	75	6	AV4 +0.00			9	AV4 +0.00			7	AV6 +0.14
		10	AV3 +0.00			16	AV6 +0.00			6	AV7 +0.09
108	77	7	AV6 +0.00			7	AV5 +0.02	109	136	6	AV7 +0.00
		9	AV5 +0.00			8	AV7 +0.00	110	51	6	AV5 +0.21
		8	AV3 +0.00	109	70	8	AV4 +0.13	110	53	5	AV3 +0.00
		8	AV2 +0.00			7	AV3 +0.00			6	AV4 +0.00
108	79	6	AV4 +0.00			8	AV7 +0.07			9	AV5 +0.07
		7	AV6 +0.00	109	72	6	AV3 +0.00	110	59	6	AV3 +0.00
		6	AV5 +0.00			12	AV4 +0.00			6	AV4 +0.13
108	81	5	AV7 +0.00	109	74	7	AV3 +0.09			8	AV5 +0.12
		6	AV2 +0.00			6	AV7 +0.14	110	67	6	AV3 +0.00
108	83	13	AV8 +0.00	109	76	10	AV4 -0.07	110	69	8	AV4 +0.13
		16	AV7 +0.00			6	AV6 +0.00			9	AV5 +0.00
		19	AV3 +0.00			5	AV7 +0.00	110	71	7	AV3 +0.05
		11	AV2 +0.00	109	78	7	AV5 +0.00			9	AV4 +0.08
		9	AV1 +0.00	109	80	5	AV2 -0.09			7	AV6 +0.05
108	87	7	AV7 +0.00			7	AV3 +0.00	110	73	6	AV3 +0.09
		17	AV6 +0.00	109	82	7	AV7 +0.07			6	AV4 +0.16
		18	AV5 +0.00			16	AV5 +0.00	110	75	8	AV5 +0.00
		12	AV4 +0.00			12	AV4 +0.16	110	77	10	AV5 +0.00
108	89	9	AV7 +0.00			8	AV3 -0.23			6	AV6 +0.00
		15	AV6 +0.00	109	84	11	AV8 +0.00			7	AV2 -0.18
		15	AV5 +0.00			12	AV6 +0.00			11	AV3 +0.00
		7	AV4 +0.00			17	AV3 +0.00			10	AV4 +0.00
		6	AV3 +0.00			11	AV2 +0.00	110	79	6	AV2 -0.25
		6	AV2 +0.00			13	AV1 +0.00			5	AV3 -0.26
108	91	6	AV7 +0.12	109	86	9	AV8 +0.00			6	AV4 -0.21
		16	AV3 -0.05			14	AV3 +0.00	110	81	7	AV4 +0.00
		15	AV2 +0.02			12	AV2 +0.00	110	83	15	AV6 +0.00
108	93	15	AV4 +0.00	109	88	5	AV6 +0.00			6	AV3 +0.00
		15	AV3 +0.00			10	AV4 -0.12	110	85	13	AV6 -0.02
		13	AV2 +0.00			9	AV3 -0.05			14	AV2 -0.02
		8	AV1 +0.00			7	AV2 -0.05	110	87	19	AV3 -0.02
108	95	14	AV5 +0.00			5	AV1 -0.07			5	AV2 -0.23
		19	AV2 +0.00	109	90	6	AV8 +0.00			12	AV8 +0.00
		7	AV1 +0.00			9	AV6 +0.00			17	AV7 -0.07
108	97	6	AV8 +0.00			5	AV5 +0.12			8	AV5 -0.05
		7	AV7 +0.00			6	AV4 -0.02			14	AV4 -0.02
		11	AV6 +0.00			10	AV3 -0.21	110	89	11	AV7 -0.07
		11	AV5 +0.00	109	92	7	AV7 -0.22			18	AV5 +0.00
		10	AV4 +0.00			5	AV6 +0.12			6	AV4 -0.26
108	99	6	AV8 -0.02			6	AV5 +0.14			5	AV2 +0.00
		7	AV7 +0.00			13	AV4 +0.00	110	91	6	AV8 -0.12
		18	AV6 +0.00			10	AV3 +0.00			12	AV7 +0.02
		18	AV4 -0.07			7	AV2 +0.00			9	AV6 +0.10
		16	AV3 +0.00	109	94	7	AV6 +0.00			14	AV5 -0.03
108	101	10	AV3 +0.00			14	AV5 +0.00			6	AV4 -0.05
		13	AV5 +0.00			11	AV4 -0.02			6	AV3 -0.18
		7	AV6 +0.00			8	AV3 +0.00			5	AV2 -0.05
108	105	9	AV5 +0.00			12	AV2 +0.00	110	93	10	AV7 +0.00
108	107	7	AV5 +0.00			6	AV1 +0.00			5	AV6 +0.00
108	115	6	AV3 +0.00	109	96	12	AV4 +0.00			6	AV5 -0.05
		6	AV4 +0.00			6	AV3 +0.00			12	AV4 +0.00
108	117	7	AV4 +0.00			5	AV2 +0.00			4	AV3 -0.16
		7	AV5 +0.00	109	98	7	AV6 +0.12			10	AV2 -0.05
108	123	6	AV8 +0.09			8	AV5 +0.00	110	95	4	AV6 -0.02
108	125	6	AV3 +0.00			6	AV1 +0.00			8	AV5 +0.00
		11	AV4 +0.00	109	100	5	AV1 +0.16			11	AV3 +0.00
		9	AV5 +0.00			13	AV2 +0.11			10	AV2 +0.00
108	137	6	AV5 +0.07			15	AV3 +0.16	110	97	5	AV7 +0.05
109	48	7	AV5 +0.00			13	AV4 +0.10			7	AV5 -0.08
		6	AV6 +0.00			10	AV5 +0.12			6	AV4 -0.19
109	62	7	AV4 +0.03			8	AV7 +0.09			16	AV3 -0.02
		7	AV5 +0.05	109	102	7	AV2 +0.14			5	AV2 -0.09
109	64	6	AV5 +0.02			6	AV3 +0.05	110	99	14	AV5 +0.00
		8	AV6 +0.05			6	AV4 +0.00			11	AV4 +0.00
109	66	12	AV2 +0.12	109	104	6	AV5 +0.12			9	AV3 +0.00
		7	AV3 +0.02	109	106	6	AV2 -0.07			6	AV2 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
110	101	8	AV1 +0.12	16	AV6 +0.00	113	42	10	AV3 +0.12		
	11		AV2 +0.14	17	AV7 +0.00		7		AV4 +0.23		
	14		AV3 +0.02	8	AV8 +0.00		7		AV6 +0.05		
	10		AV4 +0.08	111	128	9	AV4 +0.00	113	48	7	AV4 +0.08
	16		AV6 +0.05	6	AV5 +0.00		8		AV5 -0.03		
	10		AV7 +0.00	112	63	6	AV5 +0.00		7		AV6 -0.07
110	103	7	AV6 +0.00	7	AV6 +0.00	113	56	8	AV5 +0.00		
	6		AV2 +0.00	11	AV7 +0.00	113	66	7	AV4 +0.00		
	10		AV3 +0.00	6	AV8 +0.00		5		AV6 +0.00		
	9		AV4 +0.00	112	69	13	AV1 +0.09	113	68	14	AV2 +0.12
110	107	7	AV4 +0.00	15	AV2 +0.07		16		AV5 +0.14		
110	127	6	AV4 -0.07	11	AV3 +0.05		8		AV6 +0.09		
	6		AV7 +0.09	10	AV4 +0.03	113	72	6	AV5 +0.07		
110	129	9	AV5 +0.00	112	71	7	AV2 +0.00	113	74	9	AV6 +0.00
111	50	8	AV6 +0.00	9	AV3 +0.00	113	80	6	AV3 -0.21		
111	72	7	AV4 +0.00	8	AV4 +0.00		5		AV6 +0.00		
	7		AV6 +0.00	7	AV6 +0.00	113	82	6	AV3 +0.00		
111	74	9	AV3 +0.00	112	73	14	AV1 +0.00	113	88	14	AV6 -0.05
	6		AV6 +0.00	10	AV2 +0.00		14		AV4 -0.09		
111	76	8	AV4 +0.00	17	AV3 +0.00		7		AV3 -0.02		
	9		AV2 +0.00	13	AV4 +0.00		7		AV2 -0.18		
111	78	5	AV5 +0.00	8	AV6 +0.00	113	90	7	AV8 +0.00		
	14		AV4 +0.00	10	AV7 +0.00		15		AV7 -0.07		
	7		AV3 +0.00	7	AV8 +0.00		14		AV6 -0.09		
111	80	5	AV7 +0.00	112	81	6	AV4 +0.00	14	AV5 -0.08		
111	82	8	AV5 +0.00	112	87	7	AV7 +0.00	5	AV4 -0.19		
	7		AV3 +0.00	9	AV6 +0.00		7		AV3 -0.21		
111	84	16	AV7 +0.00	15	AV5 +0.00	113	92	6	AV7 +0.14		
	17		AV6 +0.00	9	AV3 +0.00		5		AV6 +0.14		
	6		AV2 +0.00	112	89	9	AV2 +0.00	6	AV5 +0.00		
111	86	18	AV8 +0.00	8	AV7 +0.00		5		AV4 -0.21		
	9		AV5 -0.13	11	AV6 +0.00		6		AV3 -0.23		
	10		AV3 -0.07	7	AV5 +0.00		4		AV2 +0.11		
	10		AV2 -0.11	8	AV4 +0.00	113	94	4	AV7 +0.00		
111	88	9	AV6 +0.00	7	AV3 +0.00		4		AV6 +0.00		
	9		AV5 +0.00	112	91	8	AV7 -0.16	12	AV5 +0.00		
	13		AV4 +0.00	9	AV5 +0.00		9		AV4 +0.00		
	11		AV3 +0.00	18	AV4 -0.09		13		AV3 +0.00		
	6		AV2 +0.00	11	AV3 +0.02		5		AV2 +0.00		
111	90	9	AV6 +0.00	7	AV2 -0.09	113	96	6	AV7 +0.00		
	14		AV5 +0.00	7	AV1 +0.00		9		AV6 +0.00		
	10		AV3 +0.00	112	93	6	AV5 +0.00	8	AV5 +0.00		
111	92	7	AV7 +0.00	7	AV4 +0.00		12		AV4 +0.00		
	5		AV6 +0.00	10	AV2 +0.00		13		AV3 +0.00		
	6		AV5 +0.00	6	AV1 +0.00		9		AV2 +0.00		
	5		AV4 +0.00	112	95	6	AV7 +0.00	113	98	8	AV3 -0.18
	12		AV2 +0.00	6	AV6 +0.00		6		AV2 -0.11		
	9		AV3 +0.00	6	AV5 +0.00		5		AV5 +0.09		
	7		AV1 +0.00	6	AV4 +0.00		4		AV4 -0.12		
111	94	4	AV7 +0.00	16	AV3 +0.00	113	100	8	AV2 +0.00		
	8		AV6 +0.00	9	AV2 +0.00		8		AV6 +0.00		
	9		AV4 +0.00	112	97	7	AV6 +0.00	113	102	5	AV4 -0.14
	14		AV3 +0.00	11	AV5 +0.00		11		AV2 +0.00		
	9		AV2 +0.00	13	AV4 +0.00	114	41	11	AV3 +0.00		
111	96	7	AV7 +0.00	11	AV3 +0.00		9		AV4 +0.00		
	17		AV4 +0.00	4	AV2 +0.00		13		AV6 +0.00		
	12		AV3 +0.00	112	99	7	AV6 -0.12	114	43	10	AV2 +0.09
	11		AV2 +0.00	7	AV5 -0.05		9		AV5 +0.12		
	11		AV1 +0.00	13	AV4 +0.00		9		AV6 +0.00		
111	98	13	AV8 +0.00	16	AV3 -0.05		7		AV7 +0.00		
	15		AV7 +0.00	6	AV2 -0.11	114	57	6	AV4 +0.18		
	12		AV6 +0.00	112	101	8	AV2 +0.11		9		AV5 +0.12
	11		AV5 +0.00	14	AV3 +0.07		114	65	8	AV5 +0.00	
	18		AV4 +0.00	15	AV4 +0.16		114	73	7	AV2 +0.14	
	12		AV3 +0.00	8	AV7 +0.14		7		AV4 +0.03		
	11		AV2 +0.00	112	103	7	AV3 +0.00	114	75	8	AV1 +0.00
	4		AV1 +0.00	6	AV5 +0.00		9		AV2 +0.00		
111	100	7	AV2 +0.00	10	AV6 +0.00		9		AV3 +0.00		
	6		AV3 +0.00	15	AV7 +0.04		6		AV4 +0.00		
111	102	17	AV3 +0.00	112	119	8	AV4 +0.00	114	77	6	AV3 +0.00
	18		AV2 +0.00	5	AV6 +0.00		6		AV4 +0.00		
	17		AV4 +0.00	112	121	7	AV4 +0.10		6		AV6 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
114	79	7	AV6 +0.00	9	9	AV3 +0.07	7	7	AV2 +0.00		
114	81	6	AV4 +0.00	9	9	AV4 +0.13	116	91	7	AV7 +0.00	
		6	AV6 +0.00	115	82	5	AV3 +0.00	9	9	AV6 +0.00	
		5	AV7 +0.00	115	84	9	AV8 +0.00	10	10	AV5 +0.00	
114	83	12	AV7 -0.07	18	18	AV6 +0.00	7	7	AV4 +0.00		
		16	AV4 +0.00	19	19	AV5 +0.00	8	8	AV3 -0.09		
		9	AV3 +0.00	18	18	AV3 +0.00	116	93	10	AV5 +0.00	
		6	AV2 +0.00	15	15	AV2 +0.00	11	11	AV4 +0.00		
114	87	15	AV7 +0.00	115	88	8	AV8 +0.00	5	5	AV3 -0.25	
		19	AV6 -0.05	16	16	AV7 +0.00	116	95	15	AV5 +0.00	
		16	AV2 +0.00	13	13	AV6 +0.00	11	11	AV4 +0.00		
		10	AV1 +0.00	8	8	AV3 +0.00	4	4	AV3 +0.00		
114	89	6	AV8 +0.12	7	7	AV2 +0.00	7	7	AV2 +0.00		
		18	AV7 -0.05	115	90	10	AV7 +0.00	116	97	4	AV5 +0.00
		14	AV5 +0.00	18	18	AV6 +0.00	8	8	AV2 +0.00		
		8	AV4 -0.21	17	17	AV5 +0.00	4	4	AV1 -0.02		
		11	AV3 +0.00	9	9	AV3 -0.28	116	99	4	AV3 +0.02	
		14	AV2 +0.00	6	6	AV2 +0.00	117	78	7	AV2 +0.00	
		8	AV1 -0.02	115	92	7	AV7 +0.00	7	7	AV3 +0.00	
114	91	9	AV7 +0.10	6	6	AV6 +0.00	117	82	7	AV5 +0.00	
		12	AV6 +0.02	7	7	AV5 +0.00	117	84	17	AV7 +0.00	
		7	AV5 -0.05	9	9	AV2 +0.00	8	8	AV4 +0.00		
		16	AV4 -0.07	115	94	8	AV7 +0.00	7	7	AV3 +0.00	
		13	AV3 +0.00	11	11	AV6 +0.00	16	16	AV2 +0.00		
		6	AV2 -0.11	11	11	AV3 +0.00	117	86	13	AV8 +0.00	
114	93	6	AV4 +0.00	115	96	11	AV7 +0.00	18	18	AV6 +0.00	
		7	AV3 -0.05	17	17	AV6 +0.00	16	16	AV4 +0.00		
		6	AV2 +0.00	14	14	AV2 +0.00	6	6	AV3 +0.00		
114	95	13	AV5 +0.00	115	100	7	AV2 +0.02	7	7	AV2 +0.00	
		10	AV4 +0.00	8	8	AV5 -0.03	117	88	9	AV6 -0.02	
		12	AV3 +0.00	115	102	11	AV2 +0.05	7	7	AV5 +0.00	
		6	AV2 +0.00	11	11	AV3 +0.05	5	5	AV4 -0.21		
114	97	5	AV5 +0.02	14	14	AV4 +0.08	8	8	AV3 -0.11		
		8	AV3 -0.09	11	11	AV5 +0.05	8	8	AV2 -0.02		
114	99	6	AV7 +0.16	115	104	7	AV5 +0.05	117	90	6	AV8 -0.05
		8	AV6 +0.00	115	112	6	AV3 +0.12	10	10	AV7 -0.05	
		16	AV5 +0.00	115	116	7	AV3 +0.00	12	12	AV6 -0.02	
		16	AV4 +0.00	115	122	6	AV3 +0.00	7	7	AV4 -0.07	
		12	AV2 +0.00	115	130	6	AV5 +0.00	117	92	6	AV7 +0.14
114	101	6	AV1 +0.00	10	10	AV6 +0.00	5	5	AV6 +0.12		
		15	AV2 +0.00	116	55	8	AV4 +0.10	7	7	AV5 +0.00	
		14	AV3 +0.00	7	7	AV5 +0.12	7	7	AV3 -0.25		
		13	AV4 +0.00	116	57	7	AV3 +0.09	9	9	AV2 +0.00	
		6	AV5 +0.00	12	12	AV5 +0.07	117	94	6	AV2 -0.05	
114	103	6	AV2 +0.12	116	59	7	AV5 +0.07	117	98	7	AV7 +0.00
		8	AV5 +0.05	116	61	8	AV5 +0.09	5	5	AV6 +0.00	
114	123	6	AV5 +0.00	116	63	6	AV3 +0.09	7	7	AV5 +0.00	
115	40	8	AV3 +0.00	6	6	AV5 +0.09	7	7	AV3 +0.00		
		8	AV4 +0.00	116	69	8	AV2 +0.05	7	7	AV2 +0.00	
		9	AV8 +0.00	9	9	AV3 +0.00	5	5	AV1 +0.00		
115	56	7	AV4 +0.00	9	9	AV4 +0.00	117	100	10	AV2 +0.00	
		6	AV5 +0.00	9	9	AV5 +0.00	8	8	AV3 +0.00		
		5	AV6 +0.00	116	71	9	AV4 +0.10	7	7	AV5 +0.00	
		6	AV7 +0.00	116	73	6	AV4 +0.10	118	83	12	AV7 -0.02
115	58	6	AV2 +0.00	116	77	6	AV6 +0.00	18	18	AV6 -0.05	
		5	AV3 +0.00	116	79	6	AV4 +0.00	14	14	AV4 -0.07	
		5	AV4 +0.00	6	6	AV3 +0.00	7	7	AV3 +0.00		
		6	AV5 +0.00	6	6	AV2 +0.00	6	6	AV2 +0.00		
115	60	9	AV3 +0.09	116	81	6	AV6 +0.00	118	87	6	AV8 +0.07
		7	AV5 +0.23	8	8	AV4 +0.00	5	5	AV7 +0.00		
115	66	8	AV4 +0.13	116	83	10	AV6 +0.00	13	13	AV6 +0.00	
		7	AV5 +0.05	11	11	AV5 +0.00	16	16	AV3 -0.02		
		11	AV6 +0.11	15	15	AV3 +0.00	15	15	AV2 -0.02		
		12	AV7 +0.12	12	12	AV2 +0.00	118	89	7	AV6 +0.00	
		10	AV8 +0.16	116	87	15	AV8 +0.00	15	15	AV5 -0.08	
115	70	7	AV4 +0.00	18	18	AV5 +0.00	15	15	AV4 -0.05		
		6	AV5 +0.00	17	17	AV4 +0.00	7	7	AV3 -0.14		
		15	AV6 +0.00	11	11	AV3 +0.00	6	6	AV2 -0.21		
115	72	7	AV1 +0.00	11	11	AV2 +0.00	118	91	5	AV8 -0.09	
		7	AV2 +0.00	5	5	AV1 +0.00	13	13	AV7 -0.02		
115	74	7	AV1 +0.09	116	89	9	AV6 +0.00	14	14	AV6 -0.09	
		10	AV2 +0.09	11	11	AV4 +0.00	13	13	AV5 -0.08		

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		6	AV4 +0.00			6	AV6 +0.00			11	AV2 +0.02
		6	AV3 -0.21			7	AV5 +0.00	122	89	7	AV6 +0.00
		6	AV2 -0.07			8	AV4 +0.00			11	AV5 +0.02
118	93	11	AV7 +0.00			5	AV3 +0.00			16	AV4 -0.07
		12	AV6 -0.02			7	AV2 +0.00			7	AV3 +0.12
		7	AV4 -0.12	120	91	15	AV7 +0.00			6	AV2 -0.02
		5	AV3 -0.11			18	AV5 +0.00	122	91	5	AV8 -0.05
		11	AV2 +0.00			12	AV2 +0.00			6	AV7 -0.14
		7	AV1 -0.05			9	AV8 +0.00			6	AV6 -0.07
118	95	10	AV2 +0.00	120	93	6	AV3 +0.00			16	AV5 -0.05
		6	AV1 +0.00			7	AV2 +0.00			6	AV3 -0.09
		6	AV5 +0.00	120	97	8	AV3 +0.00			8	AV2 -0.07
		12	AV4 +0.00			6	AV2 -0.02			6	AV1 -0.05
		7	AV3 +0.00	120	105	6	AV5 +0.00	122	93	8	AV7 +0.10
118	97	16	AV5 -0.05	120	117	6	AV4 +0.00			9	AV5 -0.05
		4	AV3 -0.11	120	119	7	AV7 +0.00			10	AV2 +0.02
		4	AV2 -0.05	120	123	8	AV2 +0.00	122	95	5	AV5 +0.00
118	99	8	AV8 +0.00			6	AV4 +0.00			6	AV4 +0.00
		17	AV7 +0.00	121	58	6	AV4 +0.00			10	AV3 +0.00
		10	AV6 +0.00			7	AV5 +0.00			9	AV2 +0.00
		9	AV4 +0.00			7	AV6 +0.00	122	97	4	AV6 +0.14
		7	AV3 +0.00	121	68	7	AV4 +0.00			5	AV5 +0.07
		5	AV2 +0.00	121	74	7	AV2 +0.16			5	AV2 -0.16
118	101	6	AV7 +0.05			6	AV3 +0.09	122	99	10	AV7 +0.00
118	103	7	AV5 +0.05			8	AV4 +0.10			6	AV5 +0.00
		7	AV7 +0.07	121	82	9	AV5 +0.00			7	AV4 +0.00
118	127	7	AV7 +0.00			7	AV6 +0.00			7	AV2 +0.00
119	78	6	AV7 +0.00	121	84	13	AV7 +0.00	122	101	5	AV3 +0.00
		5	AV6 +0.00			13	AV5 +0.00			7	AV4 +0.00
		5	AV4 +0.00			18	AV4 +0.00			6	AV5 +0.14
119	82	7	AV8 +0.00			6	AV3 +0.00	122	103	9	AV2 +0.00
		11	AV7 +0.00	121	88	5	AV8 +0.07			17	AV3 +0.00
		18	AV4 +0.00			19	AV7 -0.07			13	AV4 +0.00
		8	AV3 +0.00			19	AV6 -0.02			6	AV6 +0.00
119	84	9	AV6 +0.00			15	AV5 +0.00	122	109	6	AV8 +0.12
		14	AV4 +0.00			9	AV4 -0.05			8	AV6 +0.16
		13	AV3 +0.00			9	AV3 -0.07			7	AV4 +0.21
		9	AV1 +0.00			7	AV2 +0.00			6	AV7 +0.05
119	88	9	AV7 +0.00			5	AV1 +0.00	123	70	10	AV4 +0.00
		15	AV6 +0.00	121	90	9	AV8 +0.00			10	AV5 +0.00
		19	AV5 +0.00			13	AV7 +0.00			8	AV7 +0.00
		6	AV4 +0.00			12	AV6 -0.07	123	72	6	AV2 +0.00
		9	AV3 +0.00			15	AV5 -0.08			6	AV3 +0.00
119	90	12	AV2 +0.00			13	AV3 -0.02			6	AV5 +0.00
		12	AV7 +0.00	121	92	11	AV7 +0.17	123	74	6	AV3 +0.00
		13	AV6 +0.00			5	AV2 -0.18			9	AV6 +0.00
		12	AV5 +0.00			5	AV6 +0.10			7	AV7 +0.00
		7	AV3 -0.23			7	AV3 -0.21	123	78	6	AV3 +0.00
		6	AV1 +0.00			6	AV2 +0.05	123	82	9	AV6 +0.00
119	92	9	AV7 +0.00			6	AV1 +0.02			4	AV4 +0.00
		6	AV6 +0.00	121	94	8	AV4 -0.05			6	AV2 +0.00
		10	AV5 +0.00			9	AV3 -0.07	123	84	7	AV8 +0.00
		5	AV3 +0.00			5	AV2 -0.09			7	AV5 +0.00
119	94	7	AV2 +0.00	121	98	5	AV7 +0.00			7	AV3 +0.00
		6	AV1 +0.00	121	100	6	AV2 +0.11	123	86	11	AV6 +0.00
119	96	6	AV1 +0.00			9	AV4 +0.08			13	AV4 +0.00
119	124	7	AV5 +0.07			14	AV6 +0.09			16	AV3 +0.00
120	61	6	AV7 +0.11	121	102	6	AV1 +0.07			8	AV2 +0.00
120	81	5	AV4 +0.00			7	AV3 +0.02	123	88	9	AV8 +0.00
120	83	5	AV6 +0.00			7	AV4 +0.00			14	AV7 +0.00
		13	AV5 +0.00			8	AV5 +0.02			8	AV6 +0.00
		13	AV4 +0.00			9	AV7 +0.02			6	AV5 +0.00
		11	AV3 +0.00	122	73	6	AV4 +0.08			7	AV3 +0.00
120	85	12	AV8 -0.09	122	79	10	AV6 +0.00			8	AV2 +0.00
		6	AV6 -0.02			6	AV7 +0.00	123	90	10	AV7 +0.00
		6	AV2 -0.07	122	83	13	AV5 -0.05			7	AV6 +0.00
120	87	12	AV7 +0.00			17	AV3 -0.05			9	AV3 +0.00
		18	AV6 +0.00			11	AV2 +0.00			6	AV2 +0.00
		16	AV5 +0.00			7	AV1 -0.05	123	92	8	AV7 +0.00
		15	AV4 +0.00	122	87	8	AV8 +0.00			6	AV6 +0.00
120	89	7	AV8 +0.00			7	AV7 +0.02			6	AV3 +0.00
		7	AV7 +0.00			18	AV3 +0.02			7	AV2 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
123	94	8	AV5 +0.00	4		AV1 +0.21		18		AV4 +0.00	
	16		AV4 +0.00	125	92	5	AV7 +0.10	13		AV3 +0.00	
	9		AV3 +0.00		6		AV3 -0.07	13		AV2 +0.00	
	9		AV2 +0.00	125	94	8	AV5 +0.00	127	86	13	AV6 +0.00
123	98	7	AV7 +0.00		6		AV4 +0.00	13		AV4 +0.00	
	11		AV6 +0.00		6		AV3 +0.00	15		AV3 +0.00	
	5		AV5 +0.00		6		AV2 -0.14	7		AV2 +0.00	
	14		AV4 +0.00	125	96	16	AV4 +0.00	127	88	6	AV7 +0.00
	18		AV3 +0.00		18		AV3 +0.00	10		AV6 +0.00	
	11		AV2 +0.00		10		AV1 +0.00	8		AV2 +0.00	
124	55	6	AV3 +0.00	125	98	17	AV6 +0.00	127	90	8	AV8 +0.00
	7		AV4 +0.00		13		AV4 +0.00	11		AV7 +0.00	
	6		AV5 +0.00		6		AV3 +0.00	10		AV5 +0.00	
	6		AV6 +0.00	125	100	6	AV4 +0.00	13		AV4 +0.00	
	6		AV7 +0.00		7		AV5 +0.00	7		AV3 -0.23	
124	69	7	AV5 +0.05		8		AV8 +0.09	12		AV1 +0.00	
124	83	13	AV6 +0.00	125	102	7	AV1 +0.09	127	92	7	AV7 +0.00
	16		AV5 +0.00		8		AV2 +0.05	7		AV3 +0.00	
	15		AV4 +0.00		12		AV3 +0.07	127	94	6	AV2 +0.00
	8		AV3 +0.00		13		AV5 +0.07	127	96	6	AV5 +0.00
124	87	7	AV7 +0.00	126	55	6	AV3 +0.12	127	98	9	AV5 +0.00
	9		AV6 +0.00		8		AV4 +0.05	6		AV4 +0.00	
	11		AV3 +0.00		11		AV5 -0.03	9		AV3 +0.00	
	16		AV2 +0.00		14		AV6 +0.00	127	100	6	AV4 +0.05
	11		AV1 +0.00		7		AV7 +0.00	6		AV5 +0.05	
124	89	12	AV6 +0.00	126	69	8	AV4 +0.00	127	102	7	AV1 +0.09
	8		AV5 +0.00	126	83	5	AV7 +0.07	10		AV2 +0.07	
	6		AV3 +0.00		6		AV6 -0.07	7		AV3 +0.09	
124	91	16	AV6 +0.00		14		AV5 -0.13	12		AV4 +0.05	
	14		AV5 +0.00		12		AV4 -0.11	8		AV5 +0.00	
	6		AV2 +0.00		6		AV3 +0.00	127	104	6	AV3 +0.05
124	93	7	AV4 +0.00	126	87	14	AV7 -0.05	6		AV7 +0.02	
	6		AV3 +0.00		9		AV6 +0.12	127	106	11	AV4 +0.16
	6		AV2 +0.00		9		AV5 +0.00	127	108	6	AV4 +0.03
	6		AV1 +0.00		14		AV4 -0.05	8		AV5 +0.02	
124	95	6	AV3 +0.00		6		AV3 -0.18	127	118	5	AV6 +0.12
	7		AV2 +0.00		8		AV2 +0.00	128	53	18	AV4 +0.00
124	97	5	AV5 +0.05	126	89	13	AV6 -0.07	10		AV6 +0.00	
124	99	6	AV7 +0.11		10		AV5 -0.08	6		AV7 +0.00	
	5		AV2 -0.18	126	91	10	AV7 -0.21	128	67	7	AV3 +0.00
125	54	8	AV3 +0.00		11		AV5 -0.03	8		AV5 +0.00	
	7		AV4 +0.00		7		AV3 -0.21	8		AV6 +0.00	
	6		AV5 +0.00	126	93	6	AV6 +0.09	128	71	7	AV2 +0.05
	8		AV6 +0.00		6		AV3 -0.09	13		AV4 +0.08	
125	56	7	AV2 +0.07		9		AV2 +0.05	8		AV8 +0.05	
	6		AV3 -0.02	126	95	6	AV5 -0.08	128	73	8	AV4 +0.05
125	62	9	AV4 +0.00		5		AV2 +0.00	5		AV6 +0.02	
	8		AV5 +0.00	126	97	5	AV7 -0.05	6		AV8 +0.25	
125	68	7	AV2 +0.09	126	99	5	AV4 -0.14	128	75	6	AV5 +0.00
	7		AV3 +0.19	126	101	8	AV3 +0.00	7		AV4 +0.00	
	9		AV4 +0.10		7		AV4 +0.00	128	77	7	AV4 +0.00
	7		AV5 +0.05	126	103	7	AV1 +0.05	6		AV3 +0.00	
125	72	6	AV1 +0.09		7		AV4 +0.05	128	79	6	AV2 +0.00
	8		AV2 +0.12	126	105	9	AV4 +0.00	128	81	5	AV6 +0.00
	10		AV3 +0.09	126	119	7	AV4 +0.08	8		AV4 +0.00	
	12		AV4 +0.13	127	66	8	AV6 +0.00	128	83	6	AV7 +0.00
125	82	8	AV4 +0.10	127	68	7	AV2 +0.00	7		AV6 +0.00	
	6		AV6 +0.00		8		AV3 +0.00	7		AV4 +0.00	
	10		AV7 +0.00		9		AV4 +0.00	6		AV3 +0.00	
125	84	6	AV6 +0.00		14		AV6 +0.00	128	85	8	AV6 +0.00
	17		AV5 +0.00		7		AV5 +0.02	10		AV2 +0.00	
	19		AV4 +0.00		9		AV7 +0.00	128	87	10	AV6 +0.00
	13		AV3 +0.00	127	74	9	AV3 -0.02	7		AV5 +0.00	
125	88	6	AV8 +0.00		6		AV6 +0.00	128	89	7	AV7 +0.00
	13		AV6 +0.00		7		AV4 +0.08	6		AV6 +0.00	
	6		AV2 +0.00	127	82	6	AV7 +0.00	128	91	10	AV3 +0.00
125	90	7	AV8 +0.00		5		AV6 +0.00	8		AV2 +0.00	
	16		AV7 -0.02		6		AV4 +0.00	7		AV8 +0.00	
	14		AV6 -0.12		6		AV3 +0.00	13		AV7 +0.00	
	10		AV5 -0.05	127	84	8	AV7 +0.00	13		AV6 +0.00	
	16		AV4 -0.05		18		AV6 +0.00	10		AV5 +0.00	
	6		AV2 -0.21		15		AV5 +0.00	12		AV4 +0.00	

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
128	97	6	AV5 +0.00	14			AV5 +0.00	11			AV2 +0.00
	6		AV4 +0.00	129	112	6	AV7 +0.00	6			AV1 +0.00
	7		AV3 +0.00	8			AV6 +0.00	131	88	6	AV7 +0.00
	9		AV2 +0.00	6			AV4 +0.00	10			AV6 +0.00
	5		AV1 +0.00	130	67	12	AV3 +0.07	7			AV5 +0.00
128	99	6	AV7 -0.21	8			AV7 +0.12	7			AV2 +0.00
128	101	7	AV4 +0.00	130	69	7	AV1 +0.09	131	90	8	AV7 +0.00
	7		AV6 +0.00	11			AV2 +0.02	9			AV6 +0.00
	13		AV7 +0.00	7			AV3 +0.05	9			AV3 -0.25
	7		AV8 +0.00	12			AV4 +0.08	8			AV2 +0.00
128	103	13	AV2 +0.00	15			AV5 +0.02	17			AV1 +0.00
	18		AV3 +0.00	7			AV6 +0.09	131	92	5	AV8 -0.16
	19		AV4 +0.00	130	73	8	AV3 +0.00	9			AV7 +0.00
	19		AV5 +0.00	7			AV4 +0.00	10			AV6 +0.00
128	105	7	AV4 +0.00	130	83	6	AV5 +0.00	6			AV3 +0.00
	8		AV3 +0.00	7			AV3 -0.05	131	94	7	AV5 +0.00
128	107	9	AV7 +0.07	6			AV2 +0.00	7			AV4 +0.00
128	109	8	AV5 +0.12	130	87	7	AV7 +0.00	11			AV3 +0.00
	7		AV3 +0.05	10			AV6 +0.00	7			AV2 +0.00
	7		AV4 +0.16	13			AV5 +0.00	7			AV1 +0.00
128	111	8	AV3 +0.00	130	89	10	AV6 -0.05	131	96	4	AV7 +0.00
	7		AV4 +0.00	13			AV5 -0.08	7			AV5 +0.00
	13		AV5 +0.00	14			AV4 -0.09	6			AV4 -0.28
	10		AV6 +0.00	11			AV2 -0.05	131	98	8	AV5 +0.00
128	117	9	AV8 +0.05	130	91	6	AV7 +0.16	8			AV4 +0.00
	14		AV7 +0.00	10			AV6 -0.05	11			AV3 +0.00
	9		AV6 +0.00	17			AV5 -0.05	4			AV2 +0.00
	6		AV5 +0.00	6			AV4 -0.14	131	100	5	AV2 +0.00
	12		AV4 +0.00	8			AV2 -0.09	131	102	8	AV1 +0.00
129	66	9	AV5 +0.02	130	93	6	AV7 +0.00	11			AV2 +0.05
	10		AV6 +0.05	9			AV4 -0.09	16			AV6 +0.07
129	68	11	AV2 +0.02	13			AV2 +0.00	16			AV7 +0.11
	18		AV3 +0.00	130	95	13	AV8 +0.00	14			AV8 +0.14
129	72	7	AV2 -0.09	12			AV7 +0.00	131	104	15	AV6 +0.09
129	74	7	AV6 +0.00	6			AV6 -0.05	10			AV5 +0.00
129	76	9	AV4 +0.00	6			AV5 +0.12	5			AV4 +0.00
	6		AV3 +0.00	7			AV4 +0.00	9			AV3 +0.00
129	78	12	AV6 +0.00	8			AV3 +0.00	132	67	7	AV3 +0.09
129	80	6	AV4 +0.00	130	97	13	AV5 +0.00	7			AV5 +0.00
129	82	6	AV4 +0.13	13			AV4 -0.02	132	69	8	AV4 +0.00
129	84	10	AV7 +0.00	7			AV3 +0.00	11			AV5 +0.00
	7		AV6 +0.00	7			AV2 +0.00	7			AV7 +0.00
	18		AV5 +0.00	4			AV1 +0.00	132	71	12	AV4 +0.00
	13		AV4 +0.00	130	99	8	AV4 +0.00	7			AV5 +0.00
	17		AV3 +0.00	7			AV2 +0.00	15			AV7 +0.00
129	86	18	AV7 +0.00	130	101	6	AV1 +0.09	6			AV8 +0.00
	14		AV5 +0.00	9			AV4 +0.08	132	73	6	AV2 +0.00
129	88	6	AV7 +0.00	130	103	7	AV8 +0.00	8			AV4 +0.00
	7		AV5 +0.00	13			AV7 +0.00	18			AV5 +0.00
	7		AV4 -0.07	6			AV5 +0.00	8			AV7 +0.05
	6		AV2 -0.21	12			AV4 +0.00	132	75	8	AV8 +0.00
129	90	6	AV8 +0.00	14			AV3 +0.00	6			AV5 +0.00
	13		AV7 -0.05	14			AV2 +0.00	6			AV2 +0.00
	10		AV6 +0.02	8			AV1 +0.00	132	77	14	AV6 +0.00
	12		AV5 -0.05	131	68	15	AV4 +0.03	6			AV4 +0.00
	16		AV4 -0.02	10			AV5 +0.05	132	79	5	AV6 +0.00
	12		AV3 -0.07	7			AV6 +0.02	6			AV4 +0.00
129	92	9	AV7 +0.00	131	70	7	AV3 +0.12	132	81	5	AV7 +0.00
	4		AV6 +0.18	13			AV6 +0.09	10			AV6 +0.00
	7		AV5 +0.05	7			AV7 +0.11	7			AV5 +0.00
	6		AV3 -0.16	11			AV8 +0.07	8			AV4 +0.00
	6		AV2 +0.11	131	72	7	AV6 +0.28	132	85	6	AV5 +0.00
129	94	7	AV4 -0.12	6			AV8 +0.07	8			AV3 +0.00
	9		AV3 +0.00	131	74	7	AV2 +0.00	132	89	7	AV7 +0.00
	6		AV2 -0.23	8			AV4 +0.00	8			AV6 +0.00
129	96	6	AV7 +0.00	8			AV5 +0.12	8			AV5 +0.00
	6		AV6 +0.00	131	78	7	AV6 +0.00	12			AV4 +0.00
	7		AV5 +0.00	131	82	12	AV4 +0.00	8			AV3 +0.00
	6		AV4 +0.00	7			AV3 +0.00	132	91	6	AV8 +0.00
129	98	7	AV6 +0.00	131	84	6	AV6 +0.00	9			AV7 +0.00
129	102	8	AV2 +0.00	131	86	13	AV8 +0.00	14			AV6 +0.00
	12		AV3 +0.00	15			AV3 +0.00	6			AV4 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 1-19%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
			7 AV3 +0.00				6 AV7 +0.00	135	98	5	AV2 +0.05
			6 AV2 +0.00				8 AV8 +0.00	136	73	8	AV8 -0.02
132	93	7	AV7 +0.00	134	77	9	AV4 +0.00	136	75	7	AV8 +0.00
			6 AV6 +0.00	134	79	8	AV4 +0.00	136	79	8	AV6 +0.00
			6 AV5 +0.00				9 AV6 +0.00	136	83	19	AV6 +0.00
			8 AV4 +0.00	134	81	7	AV4 -0.25			14	AV4 +0.00
132	95	6	AV6 +0.00				7 AV5 +0.00			7	AV3 +0.00
			9 AV5 +0.00				12 AV6 +0.00	136	87	11	AV7 +0.00
			7 AV4 +0.00				6 AV7 +0.00			10	AV6 -0.07
			7 AV3 +0.00	134	83	5	AV8 +0.00			17	AV5 -0.13
132	97	6	AV7 +0.00				5 AV6 +0.00			7	AV3 -0.11
			6 AV5 +0.00				11 AV4 -0.25			7	AV2 -0.11
132	99	6	AV6 -0.28				7 AV2 -0.05			5	AV1 +0.00
			6 AV4 -0.23	134	87	6	AV5 +0.14	136	91	16	AV8 +0.00
			8 AV3 +0.00	134	89	5	AV7 -0.18			19	AV3 +0.00
			6 AV2 -0.16				8 AV6 -0.09			14	AV2 -0.09
132	101	8	AV2 +0.00				11 AV5 -0.11			10	AV1 -0.09
			10 AV3 +0.00				11 AV4 -0.14	136	93	6	AV7 +0.00
			10 AV4 +0.00				8 AV3 -0.11			6	AV6 +0.00
133	62	6	AV6 +0.14				6 AV2 +0.14			10	AV5 +0.00
			8 AV7 +0.00	134	91	12	AV7 -0.02			8	AV4 +0.00
133	70	8	AV4 +0.00				7 AV6 -0.05	136	95	6	AV7 +0.00
			7 AV5 +0.00				7 AV3 -0.27			7	AV6 +0.00
			18 AV6 +0.00	134	93	6	AV7 +0.00			6	AV4 +0.00
			11 AV7 +0.00				7 AV4 -0.02	136	99	7	AV7 -0.16
			6 AV8 +0.00				8 AV3 -0.09	137	80	5	AV8 +0.00
133	72	14	AV5 +0.00	134	95	9	AV5 +0.00	137	82	11	AV8 +0.00
133	74	7	AV4 -0.05	134	97	7	AV7 -0.07	137	84	6	AV6 +0.14
			10 AV5 -0.03	135	72	7	AV8 -0.14	137	86	5	AV7 +0.00
133	76	5	AV2 -0.25	135	76	9	AV7 +0.00	137	90	5	AV8 -0.18
133	78	7	AV6 -0.14				7 AV6 +0.00			16	AV7 +0.09
133	80	7	AV4 +0.00				7 AV5 +0.00			10	AV6 +0.05
133	82	7	AV6 +0.00				6 AV4 +0.00			6	AV5 +0.00
133	84	8	AV6 +0.00				7 AV3 +0.00			17	AV4 +0.00
133	86	5	AV6 -0.02	135	78	8	AV4 +0.00			5	AV3 -0.18
133	88	6	AV6 +0.00				6 AV2 +0.00			14	AV2 +0.02
			8 AV5 +0.05	135	80	7	AV8 +0.00			5	AV1 +0.21
			10 AV2 +0.00				7 AV7 +0.00	137	92	8	AV7 +0.24
133	90	13	AV7 +0.00				13 AV5 +0.00			7	AV5 +0.14
			15 AV6 -0.07				7 AV4 +0.00	138	85	9	AV8 -0.16
			18 AV5 -0.03				8 AV2 +0.00			7	AV7 -0.09
			19 AV4 -0.09				11 AV6 +0.00			11	AV5 -0.18
			11 AV3 -0.23	135	82	14	AV8 +0.00			7	AV3 -0.07
			10 AV2 -0.05				18 AV7 +0.00			6	AV2 -0.07
			4 AV1 +0.25				14 AV2 +0.00			6	AV1 +0.00
133	92	14	AV5 +0.00	135	84	5	AV8 +0.00	138	91	6	AV7 +0.17
			8 AV4 +0.00				6 AV7 +0.00	139	92	10	AV7 -0.21
			6 AV2 +0.14				11 AV6 +0.00				
133	94	6	AV5 -0.31				12 AV5 +0.00				
			4 AV3 +0.09	135	86	9	AV6 +0.00				
133	96	10	AV7 +0.00				8 AV5 +0.00				
			10 AV6 +0.00				12 AV4 +0.00				
			5 AV5 +0.00				9 AV3 +0.00				
			4 AV4 +0.00				6 AV2 +0.00				
			8 AV3 +0.00	135	90	18	AV8 +0.00				
			7 AV2 +0.00				9 AV5 +0.00				
			4 AV1 +0.00				9 AV3 +0.00				
133	102	8	AV1 +0.00				8 AV2 +0.00				
			19 AV2 +0.00	135	92	8	AV8 +0.00				
			8 AV3 +0.00				11 AV6 +0.00				
134	69	6	AV2 +0.05				8 AV4 +0.00				
			7 AV7 +0.11				7 AV3 +0.00				
134	71	7	AV3 +0.12	135	94	8	AV6 +0.00				
			11 AV5 +0.00				6 AV5 +0.00				
			16 AV6 +0.00				8 AV4 +0.00				
			14 AV7 +0.00				9 AV3 +0.00				
			7 AV8 -0.28	135	96	5	AV7 +0.00				
134	73	9	AV5 +0.00				7 AV6 +0.00				
			6 AV6 +0.02				7 AV5 +0.00				
			9 AV7 +0.05				7 AV4 +0.00				
			6 AV8 +0.16				11 AV3 +0.00				
134	75	6	AV4 +0.00				12 AV2 +0.00				

Total Tubes : 2045
 Total Records: 5591

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - EOC22
 Bobbin AVB Wear 20-39%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
54	9	22	AV7 +0.28	32			AV6 +0.00	95	80	20	AV7 +0.00
63	158	26	AV2 +0.00	36			AV7 +0.00			25	AV6 +0.00
65	14	20	AV6 +0.00	90	97	22	AV8 +0.00			27	AV5 +0.00
65	158	23	AV2 +0.09			22	AV7 +0.00			22	AV4 +0.00
		24	AV3 +0.38			27	AV6 +0.00	95	84	31	AV5 +0.00
		23	AV7 +0.23	91	66	24	AV4 +0.05			31	AV4 +0.00
66	13	20	AV3 +0.35			22	AV5 +0.02			26	AV3 +0.00
		22	AV6 +0.00			23	AV6 +0.05	95	86	20	AV7 +0.00
67	14	23	AV6 +0.00	91	76	23	AV7 -0.05			29	AV5 +0.00
69	14	22	AV3 +0.00			27	AV6 -0.02			25	AV4 +0.00
		21	AV6 +0.00			36	AV5 -0.03			20	AV3 +0.00
70	15	20	AV6 +0.00			20	AV4 -0.05	95	88	23	AV7 +0.00
76	63	22	AV6 +0.00			22	AV3 +0.00	95	92	22	AV5 +0.00
76	69	27	AV4 +0.00	91	80	20	AV6 +0.00	95	96	21	AV6 +0.00
76	75	21	AV5 +0.00	91	82	22	AV5 +0.00			25	AV5 +0.00
78	99	20	AV4 +0.00	91	84	20	AV5 +0.00			20	AV4 +0.00
		29	AV5 +0.00	91	86	21	AV3 +0.00	95	104	26	AV7 +0.00
		24	AV6 +0.00	91	92	20	AV6 +0.00	96	71	22	AV7 +0.00
79	66	20	AV4 +0.00			23	AV5 +0.00	96	77	26	AV3 +0.00
79	98	21	AV6 +0.00	91	98	20	AV6 +0.00	96	79	24	AV6 +0.00
81	66	22	AV5 +0.00	92	77	24	AV7 +0.00			20	AV5 +0.00
		22	AV6 +0.00			28	AV6 +0.00			20	AV4 +0.00
82	75	21	AV5 +0.00			23	AV5 +0.00	96	83	21	AV4 +0.00
		21	AV6 +0.00			21	AV4 +0.00	96	87	26	AV6 +0.00
82	99	25	AV6 +0.00	92	79	22	AV6 +0.00	96	89	23	AV6 +0.00
		25	AV5 +0.00			24	AV5 +0.00	96	93	20	AV7 +0.00
83	66	21	AV5 +0.00			21	AV4 +0.00			23	AV6 +0.00
83	78	21	AV5 +0.00	92	81	20	AV7 +0.00			24	AV5 +0.00
		20	AV6 +0.00			20	AV6 +0.00	96	97	22	AV6 +0.00
83	84	20	AV6 +0.00	92	83	33	AV5 +0.00			21	AV5 +0.00
84	73	20	AV4 +0.00	92	85	26	AV7 +0.00	96	105	22	AV3 +0.00
84	77	22	AV6 +0.00			33	AV6 +0.00	97	66	22	AV6 +0.05
85	100	20	AV5 +0.00			25	AV5 +0.00			20	AV7 +0.09
86	75	23	AV2 +0.00	92	95	23	AV4 +0.00	97	76	25	AV3 +0.00
		23	AV5 +0.00	92	99	25	AV6 +0.05			24	AV4 +0.00
		21	AV6 +0.00			24	AV5 -0.03			32	AV5 +0.00
86	85	25	AV4 +0.00	92	103	21	AV4 +0.00			22	AV6 +0.00
86	97	20	AV5 +0.00	93	72	20	AV5 +0.00	97	84	21	AV6 -0.02
		21	AV3 +0.00	93	82	24	AV5 +0.00			24	AV5 +0.00
87	70	24	AV5 +0.00	93	84	23	AV6 -0.02	97	86	23	AV4 -0.09
		20	AV6 +0.00			27	AV5 +0.00			22	AV3 +0.00
87	76	23	AV4 +0.00			27	AV4 +0.00			29	AV7 +0.00
		29	AV5 +0.00	93	86	21	AV7 -0.07			21	AV5 -0.08
87	84	23	AV4 +0.00			20	AV6 -0.07	97	92	20	AV5 +0.00
		21	AV5 +0.00			22	AV5 -0.08			28	AV4 -0.09
87	98	23	AV6 +0.00			21	AV4 +0.00			22	AV3 -0.07
88	71	25	AV6 +0.00	93	94	23	AV6 -0.02	97	96	23	AV6 +0.00
88	85	20	AV5 +0.00			22	AV5 +0.00	97	98	22	AV5 +0.00
88	95	20	AV5 +0.00	93	98	30	AV7 +0.00	97	104	20	AV4 +0.05
		20	AV6 +0.00			24	AV6 -0.02	98	85	21	AV7 -0.07
		22	AV7 +0.00			21	AV5 +0.00			31	AV4 -0.02
88	97	22	AV3 +0.00			20	AV4 +0.00			32	AV3 -0.05
		24	AV5 +0.00	93	100	21	AV4 +0.00			27	AV2 -0.05
		22	AV6 +0.00	94	69	20	AV4 +0.00	98	87	26	AV7 -0.02
88	99	23	AV4 +0.00	94	77	23	AV6 +0.00			32	AV6 -0.02
		31	AV5 +0.00	94	81	20	AV4 +0.00	98	91	29	AV4 +0.00
		25	AV6 +0.00			21	AV6 +0.00	98	97	20	AV4 +0.00
88	103	23	AV5 +0.00	94	83	27	AV3 +0.00	98	103	20	AV3 +0.00
		23	AV6 +0.00			23	AV6 +0.00	99	64	20	AV7 +0.14
89	82	24	AV3 +0.00			32	AV5 +0.00	99	66	28	AV4 +0.11
		23	AV5 +0.00			30	AV4 +0.00			33	AV5 +0.07
		22	AV6 +0.00	94	85	28	AV4 -0.05			22	AV6 +0.02
89	84	25	AV4 +0.00			23	AV3 -0.05	99	82	25	AV5 -0.10
		27	AV5 +0.00			21	AV2 +0.00			21	AV4 -0.09
		22	AV6 +0.00	94	87	22	AV5 +0.00			26	AV3 -0.09
89	98	20	AV2 +0.00			21	AV4 -0.05	99	84	30	AV6 +0.00
90	77	22	AV5 +0.00			20	AV3 -0.07			32	AV5 +0.00
		32	AV6 +0.00	94	91	22	AV6 +0.00			26	AV4 +0.00
		23	AV7 +0.00	94	95	20	AV4 +0.00	99	86	33	AV7 +0.00
90	83	20	AV4 +0.00			22	AV3 +0.00			20	AV6 +0.00
		22	AV5 +0.00			26	AV2 +0.00			23	AV4 +0.00
90	85	22	AV5 +0.00	95	66	20	AV4 +0.00			25	AV3 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
 Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
 Component: S/G B

03/17 - BOC22
 Bobbin AVB Wear 20-39%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
		22	AV2 +0.00			28	AV6 -0.05			20	AV5 +0.00
99	92	29	AV6 +0.00			29	AV3 +0.00	117	86	20	AV7 +0.00
		26	AV4 +0.00	106	87	20	AV3 -0.07			32	AV5 +0.00
		24	AV5 +0.12	106	91	20	AV5 +0.00	117	90	20	AV5 -0.08
		26	AV3 +0.00	106	97	25	AV3 +0.00	118	83	31	AV5 +0.00
		20	AV2 +0.00	107	82	20	AV4 +0.00	118	87	26	AV5 -0.08
99	96	25	AV5 +0.00	107	84	29	AV6 +0.00			25	AV4 -0.07
		25	AV4 +0.00			32	AV5 -0.10	119	82	20	AV6 +0.00
99	98	22	AV3 +0.00			27	AV4 -0.05			27	AV5 +0.00
99	104	20	AV4 +0.11	107	92	24	AV4 +0.00	119	84	20	AV2 +0.00
100	77	20	AV7 +0.00			25	AV3 +0.00	120	85	28	AV7 -0.05
		23	AV6 +0.00	107	98	25	AV5 +0.00			29	AV5 -0.08
		22	AV5 +0.00	108	83	28	AV6 +0.00			23	AV4 -0.09
		25	AV3 +0.00			27	AV5 +0.00			23	AV3 -0.09
100	81	22	AV5 +0.00			20	AV4 +0.00	120	91	21	AV6 +0.00
100	85	24	AV7 +0.00	108	91	23	AV5 +0.00	121	84	25	AV6 +0.00
		22	AV6 +0.00			29	AV4 +0.03	121	90	24	AV4 -0.12
		23	AV4 +0.00	108	95	20	AV4 +0.00	121	100	31	AV5 +0.00
100	87	26	AV6 +0.00			21	AV3 +0.00	122	83	23	AV4 -0.05
		30	AV5 +0.00	108	99	26	AV5 +0.00	122	87	27	AV6 +0.00
100	93	20	AV5 +0.00	109	72	21	AV5 +0.00			30	AV5 +0.00
101	74	23	AV3 +0.09	109	84	23	AV7 +0.00			32	AV4 -0.02
101	76	23	AV4 +0.00			31	AV5 +0.00	123	84	23	AV7 +0.00
101	86	21	AV7 -0.07			29	AV4 +0.00			24	AV6 +0.00
		28	AV5 +0.00	109	86	22	AV7 +0.00			21	AV4 +0.00
		22	AV4 +0.00			29	AV6 +0.00	123	86	21	AV5 +0.00
101	98	20	AV3 +0.00			28	AV5 +0.00	123	90	24	AV5 +0.00
101	104	25	AV5 +0.00			33	AV4 +0.00			30	AV4 +0.00
		27	AV4 +0.00	109	98	22	AV4 +0.00	124	87	24	AV5 +0.00
102	81	20	AV3 +0.00			25	AV3 +0.00			23	AV4 +0.00
		20	AV4 +0.00			20	AV2 +0.00	124	91	20	AV7 +0.00
		22	AV5 +0.00	109	100	23	AV6 +0.12	125	86	33	AV6 +0.00
		21	AV6 +0.00	110	83	23	AV5 +0.00			24	AV5 -0.08
102	83	27	AV5 +0.00			24	AV4 +0.00			29	AV4 -0.02
		24	AV4 +0.00	110	85	31	AV7 -0.05			21	AV3 -0.05
102	85	34	AV7 +0.00			32	AV5 -0.08	125	98	24	AV5 +0.00
		35	AV6 +0.00			22	AV4 -0.09	125	102	21	AV4 +0.10
		25	AV3 +0.00			21	AV3 +0.00	126	103	21	AV5 +0.05
102	87	28	AV7 -0.05	110	87	22	AV6 +0.07	127	86	35	AV5 +0.00
		35	AV6 +0.00	110	95	24	AV4 +0.00	128	53	29	AV5 +0.00
		28	AV5 -0.08	110	101	24	AV5 +0.14	128	85	29	AV5 -0.05
102	89	23	AV6 -0.07	111	84	25	AV5 +0.00			23	AV3 -0.05
		27	AV5 -0.05			26	AV4 +0.00	129	68	24	AV4 +0.00
		28	AV3 -0.09			26	AV3 +0.00	129	86	21	AV6 +0.00
		21	AV2 -0.05	111	86	24	AV7 -0.09			22	AV4 +0.00
102	91	27	AV7 +0.00			34	AV6 -0.07	129	102	23	AV4 +0.00
		24	AV6 +0.00			25	AV4 +0.00	130	67	21	AV4 +0.08
		28	AV5 -0.11	111	94	25	AV5 +0.00			26	AV5 +0.12
102	97	23	AV4 -0.09	111	102	32	AV5 +0.00			29	AV6 -0.02
103	84	20	AV7 +0.00	113	68	23	AV3 +0.09	131	70	20	AV5 +0.14
		20	AV6 +0.00			34	AV4 +0.11	131	86	32	AV7 +0.00
		25	AV5 +0.00	113	88	23	AV5 -0.05			27	AV6 +0.00
		20	AV4 +0.00	114	83	24	AV6 -0.02			20	AV5 +0.00
		29	AV3 +0.00			32	AV5 -0.03			25	AV4 +0.00
103	86	28	AV5 -0.13	114	87	24	AV5 +0.00	131	90	20	AV4 +0.00
		28	AV4 -0.09			22	AV4 +0.00	131	102	20	AV4 +0.00
104	83	23	AV5 +0.00			23	AV3 -0.02	132	67	34	AV4 +0.13
		25	AV4 +0.00	114	89	22	AV6 -0.09			21	AV6 +0.00
104	87	25	AV5 +0.00	114	99	21	AV3 +0.00			22	AV7 +0.00
104	91	22	AV5 +0.00	115	82	20	AV5 +0.00			33	AV8 +0.00
		22	AV4 -0.02	115	84	30	AV7 +0.00	132	71	24	AV6 +0.00
		27	AV3 +0.02			27	AV4 +0.00	132	91	22	AV5 +0.00
104	97	27	AV4 +0.00			20	AV1 +0.00	133	90	27	AV8 +0.00
105	72	21	AV3 +0.07	115	88	23	AV5 +0.00	133	92	20	AV7 +0.00
		21	AV4 +0.13			20	AV4 +0.00	133	102	28	AV4 +0.00
105	86	21	AV7 +0.00	115	94	24	AV5 +0.00			20	AV5 +0.00
		21	AV6 -0.05	115	96	22	AV4 +0.00	134	91	31	AV8 +0.00
		28	AV5 -0.03			20	AV3 +0.00			23	AV5 -0.11
		29	AV4 -0.02	116	83	22	AV4 +0.00			20	AV4 -0.09
105	96	25	AV5 +0.00	116	87	29	AV7 +0.00	135	82	21	AV6 +0.00
106	83	22	AV4 -0.02			24	AV6 +0.00			22	AV5 +0.00
106	85	29	AV7 -0.07	117	84	21	AV6 +0.00			33	AV4 +0.00

Appendix F: AVB Wear (<40% TW)

AREVA NP Inc.
Customer: FPL Plant: St Lucie Unit: 2

3/7/2017 3:19:15 PM
Component: S/G B

03/17 - EOC22
Bobbin AVB Wear 20-39%

ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION	ROW	COL	%TW	LOCATION
			32	AV3			+0.00				
135	84	25	AV4				+0.00				
135	90	22	AV7				+0.00				
			34	AV6			+0.00				
			24	AV4			+0.00				
135	92	25	AV7				+0.00				
			24	AV5			+0.00				
136	87	21	AV4				-0.16				
136	91	35	AV7				+0.00				
			20	AV6			+0.00				
			21	AV5			+0.00				
			29	AV4			+0.00				
138	85	23	AV6				-0.12				
			26	AV4			-0.26				

Total Tubes : 227
Total Records: 446