

We have completed our review of TMI Action Plan Item II.E.4.2(5), Minimum Containment Pressure Setpoint, for the R. E. Ginna Nuclear Power Plant. Based on your commitment to reduce the setpoint to 4.0 psig, as documented in your letter dated December 30, 1980, we consider that the requirements of Item II.E.4.2(8) have been met. However, we note that Technical Specification Table 3.5-5, Item 1.b (page 3.5-12) still contains the original 5.0 psig setpoint value and therefore must be changed. Accordingly, we request that you submit the necessary change within 90 days of receipt of this letter.

The applicable Safety Evalaution Report and its supporting Technical Evaluation Report from our consultant are enclosed.

Sincerely,

Original signed by

Dennis M. Crutchfield, Chief Operating Reactors Branch #5 Division of Licensing

Enclosures: As stated cc w/enclosures: See next page

B108060043 PDR ADDCK	3 810715 05000244 PDR					
· Muz			Lead I.E. DLSOZOW	<i>4,</i> 2	1.	
OFFICED .DL : ORB #5.	DL DBB# 5	A DLC/ ORB #5	E. Recves			
surname) RSnaider:cc	HSmith	ADCrutchfield	DOIShing	k.		
DATE 7 7 81	1/08		2715/8/	н Л	· · · · · · · · · · · · · · · · · · ·	•••••
NRC FORM 318 (10/80) NRCM	0240	OFFICIAL	RECORD C	ΟΡΥ	l.	n USGPO: 1980-329-824

3



н. М ۰ ۴.

م، کې د ا

н на селото на селот На селото на

, , •

. :



UNITED STATES NUCLEAR REGULATORY COMMISSION: WASHINGTON, D. C. 20555

July 15, 1981

Docket No. 50-244 LS05-81-07-046

> Mr. John Maier Vice President Electric and Steam Production Rochester Gas & Electric Corporation 89 East Avenue Rochester, New York 14649

Dear Mr. Maier:

SUBJECT: TMI ACTION PLAN ITEM II.E.4.2(5), MINIMUM CONTAINMENT PRESSURE SETPOINT (GINNA)

We have completed our review of TMI Action Plan Item II.E.4.2(5), Minimum Containment Pressure Setpoint, for the R. E. Ginna Nuclear Power Plant. Based on your commitment to reduce the setpoint to 4.0 psig, as documented in your letter dated December 30, 1980, we consider that the requirements of Item II.E.4.2(5) have been met. However, we note that Technical Specification Table 3.5-5, Item 1.b (page 3.5-12) still contains the original 5.0 psig setpoint value and therefore must be changed. Accordingly, we request that you submit the necessary change within 90 days of receipt of this letter.

The applicable Safety Evaluation Report and its supporting Technical Evaluation Report from our consultant are enclosed.

Sincerely,

Comas V. Wambach

Dennis M. Crutchfield, Chief Operating Reactors Branch #5 Division of Licensing

Enclosures: As. stated cc w/enclosures: See next page

Mr. John E. Maier

- 2 -

July 15, 1981

CC

Harry H. Voigt, Esquire LeBoeuf, Lamb, Leiby and MacRae 1333 New Hampshire Avenue, N. W. Suite 1100 Washington, D. C. 20036

Mr. Michael Slade 12 Trailwood Circle Rochester, New York 14618

Ezra Bialik Assistant Attorney General Environmental Protection Bureau New York State Department of Law 2 World Trade Center New York, New York 10047

Jeffrey Cohen New York State Energy Office Swan Street Building Core 1, Second Floor Empire State Plaza Albany, New York 12223

Director, Bureau of Nuclear Operations State of New York Energy Office Agency Building 2 Empire State Plaza Albany, New York 12223

Rochester Public Library 115 South Avenue Rochester, New York 14604

Supervisor of the Town of Ontario 107 Ridge Road West Ontario, New York 14519

Resident Inspector R. E. Ginna Plant c/o U. S. NRC 1503 Lake Road Ontario, New York 14519 Mr. Thomas B. Cochran Natural Resources Defense Council, Inc. 1725 I Street, N. W. Suite 600 Washington, D. C. 20006

U. S. Environmental Protection Agency Region II Office ATTN: EIS COORDINATOR 26 Federal Plaza New York, New York 10007

Herbert Grossman, Esq., Chairman Atomic Safety and Licensing Board U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Dr. Richard F. Cole Atomic Safety and Licensing Board U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Dr. Emmeth A. Luebke Atomic Safety and Licensing Board U. S. Nuclear Regulatory Commission Washington, D. C. 20555