Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards Thermal Hydraulic Phenomena Subcommittee Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date:

Monday, August 21, 2017

Work Order No.: NRC-3236

Pages 1-95

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005 (202) 234-4433

	1
1	
2	
З	
4	DISCLAIMER
5	
6	
7	UNITED STATES NUCLEAR REGULATORY COMMISSION'S
8	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
9	
10	
11	The contents of this transcript of the
12	proceeding of the United States Nuclear Regulatory
13	Commission Advisory Committee on Reactor Safeguards,
14	as reported herein, is a record of the discussions
15	recorded at the meeting.
16	
17	This transcript has not been reviewed,
18	corrected, and edited, and it may contain
19	inaccuracies.
20	
21	
22	
23	
	1323 RHODE ISLAND AVE., N.W.
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

1 UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION + + + + +ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS) + + + + +THERMAL-HYDRAULIC PHENOMENA SUBCOMMITTEE + + + + +MONDAY AUGUST 21, 2017 + + + + +OPEN SESSION + + + + +ROCKVILLE, MARYLAND + + + + +The Subcommittee met at the Nuclear Regulatory Commission, Two White Flint North, Room T2B1, 11545 Rockville Pike, at 8:30 a.m., Jose March-Leuba, Chairman, presiding. COMMITTEE MEMBERS: JOSE MARCH-LEUBA, Chairman RONALD G. BALLINGER, Member MICHAEL L. CORRADINI, Member* WALTER L. KIRCHNER, Member JOY L. REMPE, Member

ACRS CONSULTANT:

KORD SMITH

DESIGNATED FEDERAL OFFICIAL:

ZENA ABDULLAHI

ALSO PRESENT:

HEUMING CHOW, AREVA*

KEN GEELHOOD, PNNL*

RALPH GRUMMER, AREVA

KEVIN HELLER, NRR

JOSH KAIZER, NRR

ALAN MCGINNIS, AREVA

TOM MICHENER, PNNL

DOUG PRUITT, AREVA

KEVIN QUICK, AREVA

JONATHAN ROWLY, NRR

ANDREA D. VEIL, Executive Director, ACRS

REED ANZALONE, NRR

*Present via telephone

CONTENTS

Opening Remarks	
Introduction to	ANP-10300P, AURORA-B 6
Overview of NRC	Staff's Review32
Opportunity for	public comment60
Adjourn	61

	4
1	PROCEEDINGS
2	(8:30 a.m.)
3	CHAIRMAN MARCH-LEUBA: Okay, so we're
4	going to start, okay? Even though we don't have a court
5	reporter, everything is being recorded, so make sure
6	you talk to the microphone because there is nobody to
7	tell us that they're not listening.
8	We're in session now. This meeting will
9	come to order. This is a meeting on the
10	thermal-hydraulic subcommittee advisory committee on
11	reactor safeguards. I am Jose March-Leuba,
12	subcommittee chair of the AURORA-B topical report
13	review.
14	ACRS members in attendance today are Walt
15	Kirchner, Joy Rempe, and Ron Ballinger. Member
16	Corradini is joining us through teleconference. We
17	also are supposed to have here with us Dr. Kord Smith
18	as a consultant, which hopefully will come a little
19	later, and Zena Abdullahi is the designated federal
20	official for this meeting.
21	The topic of this information meeting is
22	AREVA's topical report ANP-10300P entitled, "AURORA-B:
23	An Evaluation Model for Boiling Water Reactors;
24	Application to Transient and Accident Scenarios." The
25	according staff review is limited to application of

(202) 234-4433

	5
1	the AURORA-B evaluation framework to transients and
2	(inaudible) which is intended to be applicable to
3	(inaudible) plants up to the extended operating power
4	flow main which includes CPU.
5	Today the staff, AREVA, and their
6	consultants will brief us on the AURORA-B evaluation
7	framework, the supporting modifications, and the basis
8	for the safety findings. Part of this committee
9	meeting is closed to the public in order to protect
10	information that is proprietary to AREVA.
11	We have one bridge line arranged for
12	interested members of the public to listen in. In order
13	to minimize noise, this line will be kept in mute.
14	At the end of the open portion of the meeting, we will
15	request if anyone listening would like to make any
16	comments.
17	We have received no written comments or
18	requests for time to make oral statements from members
19	of the public regarding today's meeting. A separate
20	closed bridge number is available for Member Corradini
21	of NRC and AREVA staff and consultants.
22	Everybody, please place your phones in mute
23	to minimize interference during the meeting. As the
24	being is being transcribed, I request that the
25	participants use the microphones located in this room

(202) 234-4433

	6
1	while addressing the subcommittee. Participants
2	should first identify themselves and speak with
3	sufficient clarity and volume so that they can be really
4	heard.
5	Typically, when the court reporter is
6	sitting in that corner, you don't have to identify
7	yourselves because you have a name, but because we want
8	to record it, please identify yourselves at least the
9	first couple of times. Afterwards, they will know
10	depending on which microphone comes - each microphone
11	has a different tape recorder.
12	Let me remind you to please ensure that
13	all devices have been placed in silent mode to minimize
14	disturbance of the meeting. We will now proceed with
15	the meeting. I call upon Mr. Ralph Grummer? No,
16	sorry, there's been a change, Jonathan Rowly from NRR
17	will make some introductory remarks.
18	MR. ROWLY: Yes, good morning, Jonathan
19	Rowly. I'm the project manager, AREVA project manager
20	for the NRC. Before I actually hand it over to Shana
21	Helton for opening remarks, I just want to let everybody
22	know a few administrative things.
23	For our guests and visitors, you're on the
24	second floor of Two White Flint North and you need to
25	be escorted at all times. So if you need to leave the

(202) 234-4433

	7
1	room for any reason, to use the restroom, answer a call,
2	or get some water, or whatever it may be, please let
3	a member of the staff know and we'll escort you out
4	so that you can conduct whatever business that needs
5	to be handled.
6	In case there is an alarm, we're going to
7	go out in the hallway to your first right, and another
8	right, there is a stairwell, and we're going to take
9	the stairwell down. We're going to bypass the
10	elevators and we're going to meet in front of One White
11	Flint at the flagpole and account for everyone there,
12	and then move away and do whatever we have to do
13	according to what's going on.
14	Also, safety issues, there's a lot of
15	people in the room, so be aware as you're walking around
16	not to trip over anything or anyone's feet, so please
17	be cautious as you move around the room, so thank you.
18	
19	As Chairman March-Leuba mentioned, please
20	silence your cell phones. Put them on vibrate or
21	whatever just so that if you do receive a call, we're
22	not bothered during the meeting, so thank you.
23	MS. HELTON: Thank you, Jonathan. My name
24	is Shana Helton. I'm the Deputy Division Director in
25	the Division of Safety Systems in NRR, and I'll be making

(202) 234-4433

1 some opening remarks for us on this eclipse day. Ι 2 see it's a full agenda for a full day's subcommittee, 3 so I'd first like to thank everybody for being here. I recognize it's probably a cloudy day, but I also 4 recognize a lot of people are trying to avoid doing 5 6 any sort of work related activities so they could get 7 out and see the eclipse this afternoon, so I appreciate 8 everybody being here. 9 Leading our AURORA-B AOO review, you'll 10 be hearing from Dr. Kevin Heller today. He's sitting 11 right behind me along with John Lehning, and I believe 12 we'll also be hearing from Tom Michener from PNNL who 13 is the technical group leader and provided some contract 14 support for the evaluation of the topical report from 15 AREVA. 16 Just to give you a broad overview of the 17 AURORA-B topical report before we get into it, AURORA-B 18 is what AREVA named their next generation multi-physics 19 code system for the analysis of a wide array of transient 20 and accident scenarios. 21 This is a suite of topical reports. Todav 22 we're just mainly focusing on the AOO topical, but this 23 is - AURORA-B does refer to a suite of topical reports 24 that the staff has for review right now. 25 It's interdisciplinary review an

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

8

encompassing a large number of scenario, and many of the models and methods that we're going to be discussing today are also used in the AURORA-B control rod drop accident and LOCA analyses. So you'll get kind of a snapshot of the entire suite today of the AURORA-B codes, and we'll focus in and do a deep dive on the AOO for the analysis of transients and some accident scenarios.

1

2

3

4

5

6

7

8

9

10

11

That's all I'll say. I'll make my opening remarks brief since it is a good agenda, and thank you again for your time.

12 Could I PARTICIPANT: ask а process 13 question? I looked through the slides and I can't find 14 a better place to do this, but how will updates be 15 I mean, you've mentioned there are a lot of handled? 16 components that are approved, but approved codes 17 sometimes have errors and they do corrections, or they 18 decide to update for whatever reason, and how do you 19 assure that there's not some unknown interaction when 20 you do an update for this higher level framework? 21 MS. HELTON: I think you're referring to 22 in general a change process for topical reports. Is that what you're asking? 23 24 PARTICIPANT: Yeah, well, I mean, you've 25 got a bunch of approved -

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

9

	10
1	MS. HELTON: Right.
2	PARTICIPANT: - or soon to be approved
3	components with a big high-level framework that will
4	be approved with this action that we're doing now, or
5	reviewing now, but what if the RELAP component, for
6	example, they find errors in that sometimes I know from
7	the years gone by and so they correct it, and then
8	sometimes would that change make the interactions with
9	the other codes, because there's this data being passed
10	back and forth, and trigger some other problem, and
11	how do you check that you've not messed up your higher
12	level approved framework because one of the little
13	components managed to trigger another component to go
14	into an area that you didn't expect and you get an error?
15	MS. HELTON: I understand. I'll give it
16	a shot and then I'll turn it over to staff to give a
17	more detailed - in general, we don't have a - so I'll
18	talk to the change process first, and then I think what
19	your question is really getting at is for a suite of
20	codes that are related, if you change one thing, does
21	that change something else in something you've already
22	approved?
23	PARTICIPANT: So you run through a bunch
24	of test cases -
25	MS. HELTON: Right.

(202) 234-4433

	11
1	PARTICIPANT: - for example, to say the
2	higher level framework's still valid even though I found
3	that error in Component A.
4	MS. HELTON: Got it, so for in general,
5	we don't have a generic change process for topical
6	reports yet, but we're starting to do them on a case
7	by case basis by writing a change process into our safety
8	evaluations for topicals.
9	This is an area that we've had some public
10	dialogue on, I believe, in the context of the
11	(inaudible) 500 or office instruction for reviewing
12	topical reports. We had a discussion at the regulatory
13	information conference last year and we want to move
14	forward.
15	I think industry is interested in some sort
16	of a generic change process, and that's certainly one
17	of the types of issues that we need to look at as part
18	of the change process. For this specific AOO topical
19	which is part of this broader suite of AURORA-B codes
20	and how we look at the interrelation, I think you've
21	got something you want to say on that.
22	MR. LEHNING: Yeah, so this is John Lehning
23	from the NRC staff. So we will talk a little bit, and
24	not in a lot of detail, but toward the end of the day,
25	we will touch on the change process a little bit and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	12
1	talk about what types of code changes are permissible
2	under the topical report and safety evaluation.
3	In general, I'd say just until we get to
4	that point, there's a quality assurance program that
5	vendors use when they develop their codes that they
6	use for regulatory actions.
7	So if it's an error or some such thing as
8	that sort, then the quality assurance program would
9	govern corrections. If the error or change was at such
10	a level that it impacted the information in the topical
11	report, like it may be a small issue -
12	CHAIRMAN MARCH-LEUBA: Please talk closer
13	to the microphone.
14	MR. LEHNING: Sorry about that. If it
15	doesn't really affect the outcomes of the validation
16	and things like that, then that's different and probably
17	wouldn't require something like a topical report
18	update, but if it were something that caused the topical
19	report validation or assessment cases to change, then
20	that's something - and the demonstration analyses and
21	the plan analyses to change, that's something that might
22	be a supplement or something like that.
23	PARTICIPANT: So just to make sure I
24	understand, so let's again pick on RELAP. They find
25	an error. They correct it in RELAP, so they fix that

(202) 234-4433

	13
1	and it still goes through its validation cases and
2	that's fine, but now since we have AURORA that relies
3	on RELAP, S-RELAP, then you're going to have to run
4	the AURORA validation cases too because both framework
5	as well as the component will be impacted?
6	MR. LEHNING: That's correct. I mean -
7	PARTICIPANT: Good, okay.
8	MR. LEHNING: And it would be obviously
9	- for different evaluation models under AURORA-B, you
10	might use different model assumptions in some of these,
11	for example, control rod drop, LOCA, and AOO. So it
12	might be that one or more of them are affected, and
13	so there would be an extended condition that would need
14	to be done for any of the effected evaluation models
15	to determine whether or not some change needs to be
16	made.
17	PARTICIPANT: Great, thank you.
18	MS. HELTON: I'd just like to emphasize
19	the point about Appendix B, so that's something that
20	we're starting to look at more as a staff is the 10
21	CFR Part 50 Appendix B. There's a number of criterion
22	there, Criterion 3, Criterion 8.
23	Those would pull in topical reports, we
24	think, so we're starting to look at more for a change
25	process especially. With the change process, you want

(202) 234-4433

	14
1	to make sure you have appropriate oversight, and that's
2	kind of the link to oversight that we're looking at.
3	PARTICIPANT: Thank you.
4	CHAIRMAN MARCH-LEUBA: So following up on
5	that topic, and sorry AREVA, we'll - let us while we
6	have them on the microphone. Yeah, I'm also interested
7	on this topic a lot because typically we think about
8	(inaudible) causing errors, or you find that the
9	correlation you put into (inaudible) when you meant
10	(inaudible) six because you read it wrong from the
11	paper.
12	But there's also other changes like
13	improvements on correlations that you got new data from
14	an experimental facility and you want to reuse the
15	uncertainty because now you have better data. There
16	has to be clarity from the staff at which point you
17	allow them to run loose and use Appendix B for qualifying
18	it, and we, the staff, review it to make sure it's okay.
19	
20	Because obviously if a correlation had a
21	coefficient at this (inaudible) go ahead and change
22	and run your validation and you're fine, but if you
23	want to use new data, there has to be clarity from the
24	staff what they can do and they cannot do because often
25	they are making the decision themselves, and more often

(202) 234-4433

	15
1	than not, they tend to be too conservative because they
2	don't want to be caught.
3	So if you guys, and you don't need to give
4	me an answer now, but keep in mind there has to be clarity
5	on what they're allowed to do and what they're not.
6	MS. HELTON: We agree.
7	CHAIRMAN MARCH-LEUBA: Okay, so with this
8	in mind, now AREVA. I believe Ralph is going to make
9	a presentation or Alan?
10	MR. McGINNIS: I'm Alan McGinnis. I'm
11	Licensing Manager for AREVA and I'm just going to make
12	a couple of opening remarks. We want to thank the ACRS
13	for having us here today and allowing us the opportunity
14	to provide you with information to utilize in evaluating
15	the staff's safety evaluation for AURORA-B, and I thank
16	Shana. She did an excellent job of summing up what
17	the AURORA-B suite of codes is all about, so I don't
18	need to go back over that.
19	I would like to say that we're very anxious
20	to begin utilizing this new methodology. It resolves
21	a number of legacy issues like thermal conductivity
22	degradation, and allows us to move forward with an
23	integrated solution for those legacy issues.
24	And in fact, we anticipate having a license
25	amendment request submitted to the NRC within a year
	NEAL R. GROSS

(202) 234-4433

	16
1	of approval of this method, so we're going to begin
2	implementing it immediately, so we're very anxious to
3	get these new codes and methods approved and in use.
4	So I guess I'm going to keep my remarks
5	that short. I'm going to go ahead and introduce my
6	presenters here today. I've got Doug Pruitt who has
7	over 40 years of experience in the industry in thermal
8	hydraulics and codes and methods development, and is
9	also an expert in stability, and I've got Ralph Grummer
10	here with me today who also has over 40 years of
11	experience in the industry in neutronics, core
12	monitoring, and codes and methods development. I'm
13	just going to turn it over to Doug now.
14	CHAIRMAN MARCH-LEUBA: Let me, since you
15	gave me an opening and I'm the boss of the microphone
16	today, I'll be responsible for running over past 5:00
17	p.m. today. Given some requests for the staff, we will
18	be having a full committee meeting on this topic in
19	a couple of weeks if everything runs correctly in this
20	subcommittee and we don't have any serious problems.
21	One concern I have is that this methodology
22	was submitted originally in 2009 and we are now
23	approving the SER (phonetic). So, and I realize there
24	have been some changes of the staff. Things have been
25	resubmitted a couple of times, but if during the full

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

17 1 committee we could address what lessons we have learned 2 for taking seven, eight years to make a review of this 3 methodology that is not groundbreaking. I mean, this is just an incremental 4 methodology. For God's sake, the plants have only a 5 6 four-year lifetime. If we take nine years to review 7 things, we'll never make or have any progress, so if 8 during the full committee you guys can address what lessons have been learned so that AREVA can do a better 9 10 job and the staff can do a better job to get it done 11 in 18 months preferably. Okay, Doug, your turn. 12 MR. PRUITT: Okay, Doug Pruitt, consultant to AREVA, and it's my pleasure to give an introduction 13 14 I'm going to talk a little bit about the here. evaluation model development, the application domain, 15 16 and the summary of the application to a plant. 17 So as has already been stated, AURORA-B 18 consists of a best estimate multi-physics code system 19 for simulating a coupled fuel, neutronic, and thermal 20 hydraulic BWR system response. 21 Within that structure, we consider four calculational devices, the MICROBURN-B2 steady-state 22 23 core simulator that provides the bulk of the information 24 that comes into the system, the MB2-K which is the 25 kinetics equivalent to MICROBURN-B2, RODEX4 which

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

18 1 provides the historic impact of depletion on the fuel 2 rods as well as the closure relationships and dynamic 3 modeling in S-RELAP5, and then S-RELAP5 is the host code that's the two-fluid thermal hydraulic system 4 model that's been approved previously for PWR non-LOCA 5 6 and Realistic large break LOCA evaluations. So fundamentally, there's one code, S-RELAP5, 7 8 which embedded in that is the MB2-K kinetics that can 9 operate as an alternative to the point kinetics model 10 that is in S-RELAP5, as well as the relevant portions 11 of RODEX4 for the transient simulation. 12 CHAIRMAN MARCH-LEUBA: When you're 13 reading this, I have a question that Dr. Corradini sent 14 in my email because I think his phone is on mute. He is not - I haven't heard him yet. I know he's on the 15 16 line. He wanted to know what are the high-level, 20 17 second, differences between S-RELAP5 and RELAP 3.0? 18 I can't answer that. MR. PRUITT: We 19 start with 2.5. That's where the starting point for 20 our jumping off in S-RELAP5. 21 So what are the CHAIRMAN MARCH-LEUBA: differences? 22 23 MEMBER CORRADINI: Can you hear me? 24 CHAIRMAN MARCH-LEUBA: Yes, now we hear 25 you.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	19
1	MEMBER CORRADINI: Okay good, so let me
2	expand. There's a 2000 ACRS report that analyzed
3	S-RELAP, which I assume S stands for Siemens.
4	MR. PRUITT: Right.
5	CHAIRMAN MARCH-LEUBA: Mike, Mike? We
6	don't have a court reporter. Can you identify
7	yourself?
8	CHAIRMAN MARCH-LEUBA: Excuse me, I'm
9	sorry, Corradini, member of - ACRS member. I just
10	wanted to make sure what the take off point was where
11	S-RELAP was being developed versus what we know to be
12	RELAP5 Mod 3 because there's a 2000 ACRS memo that
13	analyzes it, and I assume that's the take off point,
14	but maybe the AREVA folks can help us.
15	MR. PRUITT: I probably want to defer that
16	until the closed session when we have our S-RELAP5 main
17	programmer here but -
18	MEMBER CORRADINI: That's fine. That's
19	fine.
20	MR. PRUITT: - we did take off because I
21	think our LB (phonetic) LOCA was submitted in 2000,
22	so it was prior to 3.0.
23	MEMBER CORRADINI: Okay, fine, all right.
24	We can come back to it if necessary. That helps me
25	though. And then I sent Jose a web address which is

(202) 234-4433

	20
1	with one of the ACRS consultant's analysis at that time
2	in 2000 of S-RELAP. Thank you.
3	MR. PRUITT: Okay.
4	CHAIRMAN MARCH-LEUBA: I will give you
5	that. We don't need to put it on the record.
6	MR. PRUITT: Okay, so the development
7	summary, primarily the neutron kinetics, it starts with
8	MICROBURN-B2 steady-state equations and adds the
9	temporal, creates the temporal kinetics equations.
10	It's integrated within S-RELAP5.
11	All the nodal depletion, spectral history,
12	and other information is passed from MB2 or from CASMO-4 $$
13	directly into MB2-K for the transient simulation, and
14	it uses the same cross section lookup strategy and form
15	of the cross sections as MICROBURN-B2 uses for
16	consistency.
17	In the fuel rod performance area, there's
18	a subset of RODEX -
19	PARTICIPANT: Pardon me.
20	MR. PRUITT: Yes?
21	PARTICIPANT: So what version? I should
22	have looked this up in advance, but I'll just ask you
23	in real time. What version of ENDF (phonetic) files
24	do you use for the cross sections?
25	MR.GRUMMER: This is Ralph Grummer. It's

(202) 234-4433

	21
1	primarily ENDF 4 with some modification on the fuel
2	of the isotopes.
3	PARTICIPANT: Okay.
4	CHAIRMAN MARCH-LEUBA: Sorry, now you've
5	got that one and maybe we can wait until the closed
6	session. Do you have a correction for gadolinium
7	isotopes? In there before it doesn't have isotope
8	gadolinium. It has elemental gadolinium, right?
9	PARTICIPANT: Elemental, right.
10	CHAIRMAN MARCH-LEUBA: Yeah, but -
11	PARTICIPANT: Or isotopic, yeah.
12	CHAIRMAN MARCH-LEUBA: Yeah, does it have
13	isotopic? In there before I didn't think it had it.
14	PARTICIPANT: I don't remember
15	specifically where those details were in the report.
16	CHAIRMAN MARCH-LEUBA: But you do
17	isotopic, right? Okay.
18	MR. PRUITT: Doug Pruitt. The subset of
19	RODEX4 routines are integrated within S-RELAP5, so that
20	includes all of the information from the irradiation
21	history by RODEX4 to the point of the initiation of
22	the event, and that is then read by S-RELAP5 for each
23	of the fuel rods that's modeled and then within S-RELAP5
24	which is used to evaluate the temporary transient
25	thermal-mechanical fuel rod, including the fuel/clad

(202) 234-4433

	22
1	gap and its evolution during the transient as well as
2	all the properties, the temperatures and things are
3	coming in from the RELAP5 fuel conduction solution,
4	and then it provides new heat capacities and thermal
5	conductivities and gap conductance.
6	S-RELAP5 models have been improved
7	primarily associated with pressure drop in the BWR
8	assembly, so interfacial drag for rod bundles and large
9	diameters have been refined a little bit. Reynolds
10	dependent losses, which is what we run in MICROBURN-B2,
11	are included, and single and two phase friction models
12	consistent with MICROBURN-B2 for the fuel.
13	PARTICIPANT: May I ask another question
14	here? And maybe it's more appropriate for the closed
15	session. With regard to spacer grids and just going
16	from the different rod bundle configurations, do you
17	see a big effect in your physical models as a result?
18	Do you have to change the models to go from 9x9, 10x10,
19	whatever bundle geometry you're using?
20	MR. PRUITT: I mean, the form of the
21	correlations are the same.
22	PARTICIPANT: The same, so you're not
23	changing the correlation.
24	MR. PRUITT: Yeah, if you change the size
25	of the veins, or the geometry, or the thickness, you're

(202) 234-4433

	23
1	going to get different loss coefficients, but the
2	correlations are all the same form.
3	PARTICIPANT: Okay, thank you.
4	CHAIRMAN MARCH-LEUBA: I was waiting to
5	ask more questions during the closed session, but I
6	think it's already open. Is there only one version
7	of S-RELAP5 for AREVA for both PWR and BWR now or have
8	you guys stopped?
9	MR. PRUITT: Yeah, it's actually branched
10	out now and the PWR version is primarily owned by the
11	group down in Lynchburg, so they have the same root.
12	There's a big overlap between the two.
13	CHAIRMAN MARCH-LEUBA: So, but does it
14	have a different name so we know, or you're using -
15	MR. PRUITT: The PWR version will be an
16	AURORA-B code set.
17	CHAIRMAN MARCH-LEUBA: Okay, so we have
18	branched out, so this and AURORA-B, S-RELAP5 version,
19	correct?
20	MR. PRUITT: We'll talk about it a little
21	bit more in the closed session -
22	CHAIRMAN MARCH-LEUBA: Okay.
23	MR. PRUITT: - with respect to code control
24	and things like that.
25	CHAIRMAN MARCH-LEUBA: While I have the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	24
1	microphone, Dr. Kord Smith has joined us, consultant
2	for ACRS.
3	MR. PRUITT: Okay, Doug Pruitt just
4	continuing. The component models that have been added
5	or improved, of course there's the jet-pump model, the
6	mechanistic separator model, and an addition of
7	critical power correlations, all that are required to
8	address BWR phenomena.
9	So AURORA-B in itself is, we have the
10	comprehensive code system for BWR applications, and
11	from that code system, you can pull various components
12	that may be appropriate for a particular evaluation
13	model. So today we'll be discussing the 10300 which
14	presents the fundamental foundational development and
15	qualification of AURORA-B for BWR applications, and
16	the AURORA-B AOO evaluation model for analyzing
17	predominantly core wide transients and accidents.
18	As noted before, it does not address a
19	control rod drop or control rod withdrawal errors, loss
20	of coolant accidents, late stages of anticipated
21	transients with scram after the Boron injection, and
22	instability events. There are -
23	MEMBER CORRADINI: So this is Corradini,
24	member. I want to make sure I understand. So is more
25	coming for AURORA-B for these other four, or what is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	25
1	now used in what I'll call in the AREVA toolkit for
2	those analyses?
3	CHAIRMAN MARCH-LEUBA: Doug, can you tell
4	him when you change the slides that we're on page nine?
5	MR. PRUITT: Oh, sorry, we're on page nine.
6	MEMBER CORRADINI: Yeah, I knew that.
7	Thank you.
8	MR. PRUITT: So in anticipation of that,
9	we have both the LOCA evaluation model 10332 and 10333
10	for the control rod drop analysis that are under NRC
11	review currently. So instability events we analyze
12	with the RAMONA5-FA code and that will not change, and
13	then control rod withdrawal errors we typically analyze
14	in a steady-state methodology with MICROBURN-B2.
15	CHAIRMAN MARCH-LEUBA: How about the
16	long-term ATWS?
17	MR. PRUITT: Long-term ATWS we do not do
18	currently.
19	CHAIRMAN MARCH-LEUBA: Oh, that's why you
20	just take advantage of the existing plans?
21	MR. PRUITT: The same plants and the fuel,
22	minimal changes due to the fuel design differences.
23	Okay, the application domain of course is all BWRs 2
24	through 6, and the entire power/flow operating map from
25	low power conditions at which core monitoring commences

(202) 234-4433

	26
1	up to and including operation at extended power flow
2	operating domain which is the extended power flow
3	upright with expanded flow domain.
4	CHAIRMAN MARCH-LEUBA: Mike, do you want
5	to ask the question about ABWR? Okay, or let me ask
6	it for you.
7	MEMBER CORRADINI: Yeah.
8	CHAIRMAN MARCH-LEUBA: Yeah, go ahead.
9	MEMBER CORRADINI: Well, that's okay. Go
10	ahead, Jose. You know what I was going to ask. You
11	go ahead.
12	CHAIRMAN MARCH-LEUBA: Right, yeah, why
13	not ABWR?
14	MR. PRUITT: Well, we submitted for ABWR,
15	but basically that was going to be routed through the
16	new reactor branch, and since it doesn't exist in the
17	U.S. at this point, it was deemed to be too long of
18	a review in order to really - uncertain benefits to
19	the U.S. market.
20	CHAIRMAN MARCH-LEUBA: That's something
21	I would like to hear from the staff.
22	PARTICIPANT: Yeah, I guess I would too.
23	I want to understand the technical difficulties versus
24	it takes too long to review.
25	CHAIRMAN MARCH-LEUBA: It appears to be

(202) 234-4433

	27
1	a process difficulty that a different person has to
2	sign for it if it applies to ABWR. Is that correct?
3	That's the understanding.
4	MR. PRUITT: That's my understanding,
5	yeah.
6	CHAIRMAN MARCH-LEUBA: Whenever the staff
7	comes along and you guys can find out why is it a
8	different person has to sign for that methodology, and
9	if that's the case, let's find out about it.
10	MR. PRUITT: In interest, I won't go
11	through all of these events, but it is applicable to
12	the Chapter 15 events for cool down events, the heat
13	up events which are primarily pressurization events,
14	loss of coolant flow events whether that's a pump trip
15	or a pump seizure, reactivity events, increase in
16	inventory, decrease in inventory events, as well as
17	anticipated transients without scram, and one of the
18	primary transients there is the peak reactor pressure
19	and demonstration that would meet all of the criteria
20	for that as well as demonstration fuel integrity.
21	Figures of merit that are associated with
22	methodology are the delta MCPR which demonstrate the
23	event minimum critical power remains above the
24	appropriate limit for the scenario, so typically for
25	99 percent of our application, that's going to be the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1 safety limit MCPR, the peak system pressure to 2 demonstrate that the peak pressure is maintained below 3 prescribed limits for AOOs and the ATWS scenario, the time dependent nodal power which is used in conjunction 4 with our thermal-mechanical methods to evaluate 5 6 cladding strain and fuel centerline temperatures during 7 the event, and then the peak clad temperature and 8 maximum local oxidation to assure fuel integrity is 9 maintained for selected events. 10 So the event evaluation basically is 11 initiated from a steady-state condition defined by 12 MICROBURN-B2, MICROBURN-B2 depletion to the cycle 13 exposure and the power/flow condition of interest. 14 The AURORA-B input preparation is basically augmented 15 by certified automation codes. 16 Obviously with a code system this large 17 with the amount of data, almost everything is automated, 18 so the vessel, steam lines, recirc lines, control 19 systems, and protection systems are all constructed 20 from plant specific database. 21 Core geometry is constructed from 22 MICROBURN-B2 which has the core loading and the power 23 distribution. nodalization The core and 24 initialization is based on the MICROBURN-B2 state-point 25 solution.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

28

	29
1	So since S-RELAP5 does not model every
2	unique bundle within the system, it does some group
3	based on the powers and fuel types, so that's all
4	dependent on the particular state point, and then the
5	core fuel pins are initialized based on RODEX4 - I call
6	it depletions because that's the word I always use -
7	with MICROBURN-B2 power histories and state-point
8	nodalization, so not only the cycle of interest, but
9	the previous cycle of operation in order to characterize
10	the power history for the second cycle fuel or even
11	maybe third cycle fuel if any of that's in there.
12	So the plant application, the 10300 system
13	was submitted to establish the foundation methods to
14	address shorter regulatory changes associated with
15	reactivity insertion events and revised LOCA criteria.
16	The key components of the methodology are
17	the well founded and qualified models and methods for
18	BWR transient applications, conservative benchmarks
19	to reactor turbine trip measurements. The highly
20	ranked plant parameters or parameters that exhibit a
21	range of operating conditions are treated
22	conservatively.
23	Conservative biasing of transient
24	simulations to bound modeling uncertainties for figures
25	of merit outcomes are based on Monte-Carlo techniques

(202) 234-4433

	30
1	and approved uncertainties, and the resultant change
2	in MCPR is added to the statistical MCPR safety limit
3	to establish MCPR operating limit, and limiting event
4	boundary conditions are utilized within the RODEX4
5	statistical methodology to demonstrate fuel centerline
6	melt and clad strain criteria.
7	PARTICIPANT: May I just ask you to explain
8	your terminology?
9	MR. PRUITT: Okay.
10	PARTICIPANT: The first bullet, what is
11	a short term regulatory change?
12	MR. PRUITT: Well, we were looking out,
13	you know, three or four years thinking that in order
14	to address the CRDA requirements, we really need to
15	have a full three-dimensional model, and so we needed
16	to get that in and get it moving so that we'd be able
17	to address that when it was approved, and same with
18	the dealing with the high cladding embrittlement for
19	LOCA.
20	PARTICIPANT: Thank you.
21	MR. PRUITT: So submitted documents, the
22	primary documentation of course is the LTR, the
23	acceptance review questions which clarified the
24	submitted methodology as well as provided validation
25	for the application of MICROBURN-B2 to extended power

(202) 234-4433

uprates with extended flow windows, and then the request for additional information associated with the review itself which really quantify the model uncertainties. That was the primary things that were changed as far as the review, quantifying the model uncertainties and the associated impact on the computed events figures of merit.

8 The supporting documents, following the 9 EMDAP process, we had a host of documents, BWR design 10 and event descriptions, control system and reactor 11 protection system requirements, the code capabilities 12 PIRT development, as well as the underlying and 13 documents associated with each of the components, the 14 MICROBURN-B2, MB2-K, RODEX4, and S-RELAP5.

So the basic methodology of AURORA-B and developed AURORA-B AOO methodology was the and documented consistent with the EMDAP process delineated in NRC Req Guide 1.203, and that closes my introduction. Any questions further?

20 CHAIRMAN MARCH-LEUBA: No, let's move onto 21 the staff presentation. And we are still in open 22 session, so be mindful of proprietary information. 23 PARTICIPANT: I'm not sure where to start. 24 CHAIRMAN MARCH-LEUBA: The same rules Make sure to push the push button. 25 The green

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

apply.

1

2

3

4

5

6

7

15

16

17

18

19

	32
1	light should be on, and say your name a couple of times
2	so the court recorder can identify them.
3	MR. HELLER: Testing, all right. Good
4	morning, my name is Kevin Heller. I'm with the Nuclear
5	Performance and Code Review Branch in DSS, and I'll
6	introduce -
7	MR. LEHNING: John Lehning, also from the
8	Nuclear Performance and Code Review Branch.
9	MR. HELLER: So what I'm going to be
10	presenting is really a high-level overview of the
11	staff's review of the AURORA-B AOO evaluation model,
12	so I figure we'll just jump right into it.
13	PARTICIPANT: Before you get going, just
14	a general question because we are going to be looking
15	at research activities in the next couple of months,
16	to what event is research involved in your review of
17	these kinds of submittals of major code developments
18	like this or is that done entirely in NRR?
19	MR. LEHNING: This is John Lehning. I'll
20	take the first shot at that. So generally, these types
21	of reviews are done by NRR. However, if there are
22	certain aspects that we may need help in the general
23	sense - I don't think we got research involved on this
24	particular review, but there could be a need.
25	For example, if NRR wanted research to perform

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

confirmatory analysis of a certain type, I've always done that for some instability type reviews or if we needed input decks prepared for a LOCA application, we would get them involved at that point if we needed to, but that has not occurred on this review to my knowledge.

PARTICIPANT: Thank you.

PARTICIPANT: So along those lines, something that came to my mind when I was looking at this, why didn't you ask to have a trace comparison analysis done? I mean, you went through and looked at particular aspects with good diligence and, you know, (inaudible) different and things like that.

But at the top level, would it have been smart to have had a trace comparison now rather than to wait when a plant comes in and do it, and then say, "Well, jeepers, it's predicting a lot differently," than to have it benchmarked like against some of the data like at this point? What was the motivation for not doing it?

MR. LEHNING: That's a good question, and let me speak in general again, and I'll let Kevin talk to the particulars about this review. But as far as a modeling of these type of events in particular, it's very intricate, and it depends in great detail on the

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

	34
1	details of the fuel and the specific correlations that
2	are input into the codes.
3	And my understanding of what, for example,
4	TRACE has, it doesn't have AREVA's particular CPR
5	correlations installed. It doesn't have the - we would
6	need to request quite a lot of information, not only
7	in this case because we're talking multi-physics, so
8	not only for the thermal hydraulic pieces, but also
9	for the MICROBURN type applications, the kinetics, and
10	so there's an awful lot of information.
11	I mean, and the timing of the review and
12	how long it ended up taking, I think things like that
13	could have been done, but, you know, the need for it
14	depends on the newness of it, the uniqueness, and things
15	like that.
16	So our feeling was that we could handle
17	the review by the normal types of review that NRR does
18	just by looking at their reviews of the models and the
19	methods of AREVA's that comparative analysis with TRACE
20	wasn't necessary in this case.
21	MEMBER CORRADINI: So this is Corradini,
22	Member. So let me go back to Walt's original question.
23	Is the normal process for NRR to stay within your team
24	of individuals and do audits that involve looking at
25	documentation and calculations and maybe asking the

(202) 234-4433
applicant to do additional calculations, or is the process that you always look to, perhaps if appropriate, you do audit calculations yourselves? I'm trying to get the overall process.

MR. LEHNING: Yeah, I think you nailed it and that's what we do. I guess there are alternatives that we or the NRC could internally do additional sensitivities of our own with our own codes, and obviously there are some benefits for that in the right applications although it is a pretty high resource amount to do that in every single review, but we often do, and requesting as RAIs and the applicant or the vendor do these additional cases.

And in fact, we asked AREVA to do quite a lot of additional work in the RAIs that we issued to them, and furthermore, we did do with PNNL and with our - we did do some individual confirmatory type calculations ourselves, although it wasn't generally doing full-blown code calculations and so forth. And I think Shana wanted to add a point here too.

MS. HELTON: Yeah, I'll just pipe in and 22 I'll ask the staff to speak to more detail, but we did, 23 as the member question alluded to, take advantage of the audit process throughout this review.

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

In general with these topical reports,

(202) 234-4433

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

24

25

	36
1	they're so complex and so detailed, we've been finding
2	that communicating on paper back and forth isn't
3	necessarily the most efficient or effective way to
4	conduct the review, and that getting together under
5	the audit process so that we can really have the
6	technical people on AREVA's side talk to the technical
7	people on NRC's side, and we get a better understanding
8	of what they're asking for and what the scope of the
9	problem is, and we can work that out. So that was quite
10	effective from a general process standpoint, and maybe
11	you want to speak to the audit a little bit more.
12	MEMBER CORRADINI: But at least for me,
13	that answers the process question. I think that's kind
14	of where Walt was going.
15	CHAIRMAN MARCH-LEUBA: Yeah, roughly how
16	many audits did you have?
17	MR. HELLER: This is Kevin Heller. We had
18	at least two audits. It's been a long review. I'm
19	trying to remember. We may have had three. We
20	definitely had two. I do remember that.
21	And I just wanted to add on to what Shana
22	was saying, and that's those audits allowed us, and
23	by us, I mean both the NRC technical staff, the PNNL
24	technical staff, and the AREVA technical staff to get
25	into a single room and pour over a wealth of calculation

(202) 234-4433

	37
1	notebooks.
2	CHAIRMAN MARCH-LEUBA: Before I say what
3	I want to say, let me give you the standard disclosure
4	that this is a subcommittee meeting, and what we're
5	saying are impressions of individual members and not
6	ACRS positions.
7	That said, I strongly support audits, and
8	the more, the better, and you should have one at the
9	beginning, one in the middle, and one at the end even
10	on the small reviews. There's always a lot of push
11	from management about the travel money. It's
12	irrelevant compared to the amount of time you save,
13	so please back to have more audits instead of less.
14	MS. HELTON: Oh, we are.
15	CHAIRMAN MARCH-LEUBA: The industry will
16	support you too.
17	MS. HELTON: I agree completely and we've
18	been looking for areas where we can because we recognize
19	that you might spend a little bit in the travel dollars,
20	but the efficiency that you gain overall is well worth
21	it. I see Dr. Lukes up at the mic.
22	MR. LUKES: This is Bob Lukes. I'm the
23	Chief of the Nuclear Performance and Codes Review
24	Branch, and I'd say in the past, other - I've been a
25	branch chief and I've worked in other branches within

(202) 234-4433

	38
1	the NRC, and there always has been push back against
2	audits. That is not the case with our management at
3	NRR.
4	We've also been, you know, looking at some
5	of the data and how much audits actually make our process
6	much more efficient in the RAI process. I mean, I think
7	that we're seeing possibly a 50 percent reduction in
8	RAIS.
9	When we take those RAIs, we go meet with
10	them and discuss them because most of the technical
11	information is like a miscommunication, right. When
12	you see the written word, it's not really - the
13	understanding of that written word is not as easy to
14	do if you can just say, "Well, what did you mean by
15	this? What did you mean by that?" and then we still
16	document those questions as part of our audit plans,
17	but I'd just like to again reinforce that our NRR
18	management is fully supportive of these audits and
19	encouraging them, which is unusual at the NRC like you
20	said.
21	CHAIRMAN MARCH-LEUBA: Yeah, and this is
22	Jose, and not only do you have the RAIs, the 50 percent
23	RAIs that you send, the licensee understands what you're
24	asking.
25	MEMBER CORRADINI: This is Member
	NEAL R. GROSS

	39
1	Corradini. Jose, I think you've raised a very
2	important point that ought to be somewhere in our final
3	letter because I totally agree with how you've
4	characterized it.
5	CHAIRMAN MARCH-LEUBA: This is Jose.
6	It's already written on my notes, on my to-do notes.
7	MR. HELLER: This is Kevin Heller. Just
8	to, I guess, put a final point on that and characterize
9	it a little bit more, the first audit that we had with
10	AREVA is what we call an audit for understanding where
11	basically when we perform our review, we go down through
12	and we read through the documentation, and we come up
13	with a list of not what I would call RAIs, but questions.
14	Some of these are clarification. Some of them might
15	be technical nature.
16	But we had the opportunity to get together
17	with AREVA then and discuss what it was that we were
18	asking, receive some clarification on things, and
19	ultimately distilled down what was going to become an
20	RAI. And through that, we saw in this particular review
21	a reduction of about 50 questions through that first
22	audit for understanding.
23	CHAIRMAN MARCH-LEUBA: And often my
24	experience, since we all relate, is that the RAI that
25	you issued was only for the (inaudible) for the record

(202) 234-4433

	40
1	because you already knew the answer -
2	PARTICIPANT: In a lot of cases.
3	CHAIRMAN MARCH-LEUBA: - when you left the
4	RAI -
5	MR. HELLER: Exactly.
6	CHAIRMAN MARCH-LEUBA: - the audit.
7	MR. HELLER: Any other questions? Okay,
8	this is Kevin Heller continuing onto slide two. So
9	again what I'm going to be discussing is a high-level
10	overview of the staff's review of the AURORA-B AOO
11	evaluation model, and then when we move into the closed
12	session, we'll get more down into the nitty gritty of
13	the nuances of what it is that we ended up reviewing.
14	On slide three? So this has been discussed
15	or mentioned by both Shana and by AREVA. I'm just going
16	to mention a couple of high points here though to kind
17	of illustrate some of the needs that we had on this
18	review.
19	So AURORA-B, again, is a multi-physics,
20	multi-code system, and it's comprised of what are known
21	as component calculational devices. There are other
22	codes, some of which have received prior NRC review
23	and approval. But because it had four of these
24	component calculational devices, and because it is
25	being applied to such a large range of transients, what

(202) 234-4433

	41
1	we really end up with is a large interdisciplinary
2	review scope.
3	I'm now on slide four. So the staff
4	recognized up front that this was going to require
5	multiple reviewers over the course of several years
6	in order to complete this complex review, and so as
7	a result, we decided that it would be prudent to contract
8	Pacific Northwest National Laboratory to act as a
9	consultant. And they put together a team of subject
10	matter experts that I quickly just want to read down
11	the names on this group.
12	Their help was invaluable towards
13	completing this review, Judy Cuta for the
14	thermal-hydraulics, Ken Geelhood, fuel
15	thermal-mechanical, and Ken will actually be joining
16	us later this afternoon via the call in number, Carl
17	Beyer, he was initially for the fuel
18	thermal-mechanical, but he ended up retiring shortly
19	after the review began and Ken came on and took his
20	place, Dr. Gregory Piepel for the statistics, assisted
21	by Dave Engel, Andrew Prichard for the neutronics, and
22	Bruce Schmitt for the thermal-hydraulic and system
23	modeling.
24	PARTICIPANT: Let me repeat my observation
25	or question from earlier. I have no problem with you

(202) 234-4433

	42
1	using PNNL as a consultant on this, but it just, when
2	I looked at the material in advance, it just occurred
3	to me that why am I not seeing anyone from RES?
4	MR. HELLER: This is Kevin Heller. Do you
5	mean in as far as requesting confirmatory calculations?
6	PARTICIPANT: Or just to assist you in the
7	review as subject matter experts.
8	PARTICIPANT: That's just not the normal
9	process that we use. We felt that we had the review
10	team, both from the qualified reviewers in NRR, as well
11	as the contractors done at PNNL, so with those people
12	on the team, we felt like we had the adequate review
13	capacity.
14	PARTICIPANT: I'm not questioning their
15	competence or the adequacy. I'm just raising perhaps
16	an issue that I'll bring up. It's off topic here.
17	But to the extent that we're reviewing RES programs
18	and involvement in regulatory actions, I'm just
19	surprised that RES isn't engaged.
20	MEMBER BALLINGER: Can I clarify that a
21	little bit? This is Ron Ballinger, ACRS member. Is
22	there not some default process by which you go through
23	to assign or identify people to help out with the review,
24	and shouldn't that default process have an initial step
25	of going around the NRC staff and seeing if there's

(202) 234-4433

	43
1	expertise there that could be used before going outside?
2	Is that what you're trying to get at?
3	MS. HELTON: I'll take a crack at this and
4	then I think - this is Shana Helton - and then I think
5	Josh Kaizer has something he'd like to add. But, you
6	know, for topical reports - and Jonathan Rowly, our
7	project manager is here, and he can talk to the process
8	probably better than I can - we look at the program
9	office to lead that technical review.
10	It's up to the program office to then decide
11	how we get the resources that we need to conduct that
12	review, be it through a user need to research or through
13	the use of contract expertise as we did in this case
14	in PNNL.
15	One thing, I would have to do some homework
16	to see if it played into this particular review or not,
17	but across the agency, we're resource constrained, and
18	we have to find a balance between using in-house
19	resources versus contract assistance. I see Dr. Kaizer
20	is nodding his head vociferously over there.
21	So I would suspect that, you know, with
22	all of the in-house activities that we've got going
23	on, we have to have a healthy balance of using the labs
24	and other technical contractors to help support our
25	technical reviews.

(202) 234-4433

PARTICIPANT: again, But would that healthy balance not include efforts to keep people involved on the staff to maintain expertise within the staff? I know resource constraints. Everybody that's absolutely true, but it's also true that you need to have people that are on the ball on the staff, so that's the balance that I'm wondering about.

MS. HELTON: Yeah, absolutely, and we do try to maintain our technical edge with a number of 9 knowledge management activities. Using topical report reviews as a way to keep those knowledge management activities up to speed is actually an idea that we've 13 been discussing at the management level.

We've been looking at, and we'll be starting it in the fall, with moving people between the offices, between NRO, NRR, and research on temporary assignments so that we can see how everybody does their work and bring knowledge to others in the organization. PARTICIPANT: But that's an ongoing process.

21 MS. HELTON: Yes. 22 PARTICIPANT: It always has been. 23 MS. HELTON: Yes. 24 PARTICIPANT: What I'm a little bit 25 concerned about is maintaining the expertise.

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

1

2

3

4

5

6

7

8

10

11

12

14

15

16

17

18

19

20

	45
1	MS. HELTON: I hear you.
2	MR. KAIZER: This is Josh Kaizer, NRC
3	staff. This was an interesting review actually from
4	the Office of Research side because they're the ones
5	that put us in this position in the first place. Dr.
6	Yarsky was the lead reviewer. He got promoted to the
7	Office of Research, and we do maintain a very close
8	contact with research, and I mean, generally it's a
9	staff level.
10	I mean, if I have a question on thermal
11	hydraulics, I can go to Dr. Bajorek, if I have a question
12	on neutronics, Andy Beland (phonetic). We have one
13	of the original VIPER authors whose name slips me right
14	now, but we maintain those levels of contact, and we
15	do go to the Office of Research when we feel like we
16	need to.
17	One of the things with PNNL, and it's a
18	very strange lab, I would argue they've been the sub
19	office of the NRC for many years, like Judy Cuta actually
20	was on the first review of a critical heat flux
21	correlation ever in the 1970s. It's the CE1
22	correlation, and so we have used PNNL to do this type
23	of work for a very long time.
24	They were the main reviewers for CHF, and
25	Gregory Piepel, Judy and Gregory did a really nice
	NEAL R. GROSS

(202) 234-4433

	46
1	document about how you should actually review these
2	correlations, and so it kind of depends on when you
3	have a review in front of you, do you feel like you
4	have the expertise?
5	And Shana had a really good comment. A
6	lot of time during this review, there was a big push
7	to say, "Hey, what can we do that's contracting?" and
8	so this kind of came into PNNL had the right people
9	with Carl Beyer and Ken Geelhood for the fuel side,
10	and they did a lot of that.
11	We do try to go to the Office of Research,
12	but also like Shana said, a lot of times they have their
13	own schedules and things and stuff they're busy with,
14	and you do try to work with them, but sometimes they
15	just can't fit you in.
16	PARTICIPANT: And just to add to that too,
17	we also have a more broad knowledge management in
18	maintaining the people at the labs and stuff, and the
19	infrastructure that's there that have been working with
20	us for a long time too is an important thing to continue
21	to keep those contacts active and keep those people
22	engaged on the work we do so they're there when we need
23	them.
24	PARTICIPANT: I think we've made our
25	point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	47
1	PARTICIPANT: Okay.
2	MR. HELLER: Okay, this is Kevin Heller.
3	On slide five, just throwing up a couple of bullets
4	here for the primary documents that the staff used for
5	their review, of course NUREG-0800, the standard review
6	plan, specifically Chapter 15.0.2, review of transient
7	and accident analysis methods, and of course Regulatory
8	Guide 1.203 was also used for guidance, specifically
9	because it does detail the EMDAP evaluation model
10	development and assessment process that the AURORA-B
11	AOO evaluation model was following in how it was
12	presented within the topical.
13	Slide six, so what I'm going to do in the
14	next couple of slides, or the next several slides
15	rather, is just go down the specific areas of review
16	within the SRP Chapter 15 and discuss what the staff
17	found as far as what was supplied in the documentation
18	and in the topical report and the staff's assessment
19	of it. And as a final bullet on slide six here, the
20	safety evaluation that the staff developed is based
21	on - this review structure is presented within the SRP.
22	So the first of the review areas in the
23	standard review plan documentation, acceptance
24	criteria. Submittals should identify specific
25	accident scenarios and plant configurations, and the

(202) 234-4433

	48
1	submittal of course should contain a complete
2	description of code assessment, theory manuals
3	describing field equations, user manuals discussing
4	code limitations, and what the staff found during the
5	review is the accident scenarios are identified and
6	the code assessments are described within the topical.
7	As I mentioned earlier, the AURORA-B AOO
8	evaluation model is comprised of a number of different
9	calculational devices, the primary one of which is
10	S-RELAP5. So really the S-RELAP5 theory manual is more
11	or less the backbone to the whole methodology, but it
12	does speak to the transfer of information between the
13	other component devices, and of course those theory
14	manuals needed to be examined and they were provided.
15	Code limitations were found within the
16	theory manuals as well as the user manuals, and of course
17	prior staff safety evaluations. So ultimately, we
18	found that the documentation supplied was adequate for
19	the review.
20	And the second area of review on slide

eight, evaluation models. There were four general areas of review, four phenomenological areas really, thermal-hydraulics, neutronics, primary system modeling, and fuel thermal-mechanical performance, so we of course took a look at those areas, but during

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

	49		
1	the staff's review, we identified that there were some		
2	areas of focus that were required, as an example,		
3	S-RELAP5. As AREVA mentioned earlier, it started out		
4	as a PWR code, and so new and existing models and methods		
5	were introduced or updated to make it applicable to		
6	BWRs, so those had to be examined.		
7	MB2K is a new neutron kinetics method		
8	that's based on MICROBURN-B2. It was not thoroughly,		
9	or to my knowledge, prior review and approval by the		
10	NRC staff, so that had to be examined. MICROBURN-B2		
11	information was supplied for its qualification to		
12	extended power uprates and extended flow window		
13	conditions.		
14	And I'm just going to pause to make a note		
15	here that AREVA was using the term EPFOD, extended power		
16	and flow operating domain. As far as the review and		
17	the documentation, that's a relatively more recent		
18	term. I've been using EFW, so I just want to point		
19	out those are equivalent, and I thought about changing		
20	the terminology over, but I realized I would just start		
21	saying EFW all the time, and I didn't want to confuse		
22	anyone.		
23	And of course RODEX4, the full RODEX4 code		
24	is part of the AURORA-B AOO evaluation methodology,		
25	but there's a subset of the methods that were		

(202) 234-4433

	50			
1	incorporated within S-RELAP5 for the calculation of			
2	fuel thermal-mechanical properties during the			
3	transients, and that's known as the RODEX4 kernel, so			
4	the staff identified that that would have to be examined			
5	and assessed.			
6	So with that said, slide nine, evaluation			
7	model. The review acceptance criteria is the model			
8	should be present for all phenomena and components			
9	determined important or necessary to simulate scenarios			
10	under consideration, and those models and associated			
11	numerical solutions should predict the important			
12	physical phenomena reasonably well.			
13	MEMBER KIRCHNER: Can I back you up again?			
14	MR. HELLER: Certainly.			
15	MEMBER KIRCHNER: This is Kirchner. I'm			
16	just curious why for MICROBURN-B2 qualification for			
17	EPU and EFW, I would think that qualification for EPU			
18	and EFW would be toward the entire code system, so what			
19	about MICROBURN-B2 in particular was a concern that			
20	you were qualifying it or looking at its qualifications			
21	for EPU and EFW versus RELAP, MB2-K, or RODEX4?			
22	MR. HELLER: So this is Kevin Heller.			
23	That's a good question. The AURORA-B AOO evaluation			
24	methodology when it was submitted, it was requested			
25	that it be reviewed and approved for application EPU			

(202) 234-4433

	51			
1	and EFW conditions, but the staff identified that			
2	MICROBURN-B2 during its original staff review and			
3	approval, it was not assessed on a generic level for			
4	EPU and EFW.			
5	There have been plant specific license			
6	amendment requests that have come through in recent			
7	years that have assessed its qualification on a plant			
8	specific basis, but not from a generic perspective.			
9	MEMBER KIRCHNER: Okay, I don't know			
10	MICROBURN-B2. I'm trying to think from a physics			
11	standpoint why would it, why EPU and EFW would be a			
12	stretch for that code?			
13	MR. HELLER: That, we do discuss that in			
14	later slides in the closed session, and I -			
15	MEMBER KIRCHNER: Okay, I'll wait for			
16	that. Thank you.			
17	MR. HELLER: I don't want to mention			
18	anything that might be proprietary, so. Okay, slide			
19	nine, so for the evaluation model acceptance criteria,			
20	the staff found that what was supplied in the			
21	documentation, support for performance of physical			
22	models and the numerical solutions were provided by			
23	comparisons to experimental data.			
24	There were numerical benchmarks that were			
25	supplied, and there was the use of comparisons to higher			

(202) 234-4433

order methods. The staff also examined the equations and relationships governing the models within the theory manuals and the prior staff safety evaluations for those codes that had received prior review and approval, and ultimately what the staff found is there was reasonable to excellent code-data comparisons and so the staff concluded that the evaluation models were reasonably predicting the phenomena of importance.

Slide 10, the next area of review was the accident scenario identification process. The acceptance criteria her, the process should identify and rank reactor component and physical phenomena modeling requirements, and the process should include evaluation of physical phenomena to identify those important in determining the figures of merit.

Primarily the staff's assessment, the manner in which the staff went about this is they recognized from SRP Chapter 15.0.2, Section III, it notes that a PIRT, or a phenomenon identification ranking table, is an example of an acceptable structured process for identifying and ranking phenomena.

And within the submittal, AREVA developed a PIRT through multiple iterations between development teams and BWR application engineers. And really the AURORA-B AOO evaluation model PIRT within the topical

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

	53			
1	itself is a summary level PIRT comprised of			
2	highly-ranked phenomena from a series of event level			
3	PIRTs which are documented in a separate document that			
4	was also supplied for the review.			
5	And the staff observed that there were a			
6	number of figures of merit that were supplied, and			
7	concluded that those figures of merit were adequate			
8	or acceptable for determining, or rather acceptable			
9	for the events for which the AURORA-B AOO was going			
10	to be applied.			
11	Slide 11, the next area of review was the			
12	code assessment, acceptance criteria being that models			
13	should be assessed over the entire range of conditions			
14	encountered, and the staff found that comparisons of			
15	predicted results against separate effects tests and			
16	integral effects tests from experimental facilities			
17	were supplied.			
18	There were code predictions compared to			
19	analytical solutions for the accuracy of numerical			
20	methods. Again, higher order methods and numerical			
21	benchmarks were used.			
22	The system interaction and global			
23	capability was also demonstrated through FIST test			
24	facility, or comparison to FIST test facility data,			
25	and also through the Peach Bottom Turbine Trip Tests,			

(202) 234-4433

	54			
1	and in all cases, the staff found there was reasonable			
2	to excellent code-data comparisons.			
3	Slide 12, the uncertainty analysis			
4	methodology, the acceptance criteria is it should			
5	address all important sources of code uncertainty,			
6	including mathematical models in the code and user			
7	modeling.			
8	The staff's assessment, AREVA classified			
9	or identified there were three areas of biases and			
10	uncertainties when it came to the AURORA-B AOO			
11	evaluation model, the first of those being due to model			
12	structure such as nodalization and time steps, the			
13	second being selection of plant parameters and initial			
14	conditions, and then lastly, biases and uncertainties			
15	in predicting highly ranked and pertinent medium ranked			
16	PIRT phenomena.			
17	So the structure and initial conditions			
18	the staff found was addressed via sensitivity analyses,			
19	and so the bulk of the staff's review efforts for the			
20	uncertainty analysis methodology were to examine the			
21	manner in which the uncertainties in high and medium			
22	ranked PIRT phenomena were addressed, and AREVA is using			
23	a non-parametric ordered statistic approach.			
24	A number of the - I have a few bullets			
25	underneath that just to kind of provide some additional			
	NEAL R. GROSS			

(202) 234-4433

	55			
1	detail. A number of the PIRT phenomena and the			
2	parameters of interest were addressed via conservative			
3	biasing. We'll discuss a couple of those during the			
4	closed session.			
5	The staff examined the parameters that were			
6	to be utilized within the non-parametric ordered			
7	statistic to make sure that the distributions and the			
8	sampling ranges were acceptable, and really the			
9	approach that AREVA is using is a univariate approach.			
10	So ultimately -			
11	MEMBER CORRADINI: If I might, Corradini,			
12	member. I'm not an expert in uncertainty. I noted			
13	a preponderance of the limitation and conditions were			
14	based on the uncertainty categories. Is there			
15	something unique about this, or is the uncertainty			
16	review similar to what has been done in the other areas,			
17	or is this the first multi-physics review that's been			
18	done in a while?			
19	CHAIRMAN MARCH-LEUBA: Mike, I'm			
20	concerned that this might be proprietary of the method.			
21	MEMBER CORRADINI: Okay, I'm sorry.			
22	CHAIRMAN MARCH-LEUBA: Can we wait half			
23	an hour?			
24	MEMBER CORRADINI: Sure, no problem,			
25	sorry.			
ļ	NEAL R. GROSS			

(202) 234-4433

	56			
1	CHAIRMAN MARCH-LEUBA: Because I do have			
2	concerns and I want to bring them up, but I think it			
3	will get proprietary.			
4	MR. HELLER: Okay, this is Kevin Heller.			
5	So just to conclude on this slide, the staff found			
6	that the uncertainty analysis methodology was			
7	acceptable.			
8	And then the final area of review according			
9	to the SRP, the quality assurance plan, acceptance			
10	criteria, the code should be maintained under a quality			
11	assurance program that meets the requirements of			
12	Appendix B to 10 CFR Part 50.			
13	And the staff found that AREVA has an			
14	established NRC-approved software quality assurance			
15	program, and that AURORA-B was developed and is			
16	maintained under this program, so the staff concluded			
17	that this was acceptable.			
18	So slide 14, in conclusion, the staff found			
19	that the AURORA-B AOO evaluation model is acceptable			
20	for simulation of AOOs and certain postulated			
21	accidents, and just a couple of bullet points here to			
22	kind of add some depth to that.			
23	It's applicable for BWRs with forced			
24	recirculation systems. Again, it's BWRs 2 through 6.			
25	The ABWR we can discuss during the closed session.			

(202) 234-4433

	57			
1	The standard operating domain, the extended power			
2	uprate, and EFW domains, it's applicable to those.			
3	Most of the data was supplied for support came			
4	from ATRIUM-10 and ATRIUM-10XM fuels, so really the			
5	staff - the AURORA-B AOO evaluation methodology			
6	approved for those fuels, but the staff did address			
7	whether or not other fuels were applicable, and there			
8	are methods in place to incorporate additional fuels.			
9	And then the conditions and limitations,			
10	this is a large complex review, so naturally the staff			
11	had a couple of conditions and limitations, and they			
12	fall into three primary different areas.			
13	MR. GRUMMER: The various component			
14	calculational device is being applied within limits,			
15	the limits from the individual codes and uncertainty			
16	distributions and sampling ranges is reviewed and			
17	conservative modeling justifications needing to be			
18	adhered to. So with that, are there any additional			
19	questions?			
20	MEMBER BLEY: Yes, I would like to ask.			
21	I note in the Areva presentation that they submitted			
22	their LOCA evaluation model in February 2014, and their			
23	control rod drop model in March 2014. What is the			
24	status of the review of those additions to this AOO			

(202) 234-4433

(202) 234-4433

evaluation model?

1

2 MR. LEHNING: This is John Lehning. So 3 the--as far as to my knowledge, the control rod drop 4 accident safety evaluation has been drafted and is 5 basically complete, and so that one ought to be in the 6 very near term, I think that there was maybe even efforts 7 to maybe schedule ACRS meetings for that already. And then the LOCA review, that--although it was submitted 8 9 in 2014, the staff began review in 2016, August 2016, 10 due to resources and the Fukushima event and staffing. 11 Actually, I'm the lead reviewer on that, and we've 12 just sent out our request for additional information 13 or we've sent out a draft, and the formal RAI hasn't 14 been sent out yet. So it's still in the stage of review, 15 and the date for the safety evaluation for the draft 16 is June 2018 is our target.

17 MR. HELLER: This is Kevin Heller, I just 18 want to add a couple of additional detailed points for 19 the control rod drop accident review. The SE for that 20 has been written, there have been some efforts made 21 to start scheduling for an ACRS subcommittee meeting. 22 The SE, the full submittal I quess of the SE has 23 been--I'm trying to figure out how to put this--I've 24 been working collaboratively with the reviewer on that,

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

58

because we recognize that some of the limitations and conditions present within the AURORA-B AOO evaluation model may impact the conclusions within the CRDA SE. I have supplied the list of conditions and So limitations that we have; we've just been waiting to make sure that nothing changes as a result of the ACRS meetings. MARCH-LEUBA: So bringing CHAIRMAN that--I know that Areva's modus operandi is to issue supplements to everything, and often the supplements (inaudible) to something. But is the plan to merge the CRs for the two, the CRD and the AOO so they're 13 consistent (inaudible)? Not issue a single CR, but make sure that the limitations and conditions (inaudible).

16 MR. HELLER: This is Kevin Heller. Yes, 17 the intent is to make sure that there's consistency 18 across the SEs.

19 CHAIRMAN MARCH-LEUBA: Anymore questions 20 At this point, we are going to from the members? 21 conclude the open session, so we are going to allow 22 members of the public in the room to make any comments 23 if they wish to do so. Anybody on the conference line, 24 in the open conference line, if somebody's there, can

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

9

10

11

12

14

15

	60			
1	you please say hello and identify yourself?			
2	MALE SPEAKER: It's open.			
3	CHAIRMAN MARCH-LEUBA: It's open.			
4	Anybody want to make any comments on the open part of			
5	the session? Hearing none, we are going to close the			
6	open session, and at this moment we will move to closed			
7	session.			
8	(Whereupon, the above-entitled matter went			
9	off the record.)			
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
	NEAL R. GROSS			

1 2

3

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

AREVA NP

Introduction to AURORA-B

ACRS Meeting

NRC Two White Flint North 11555 Rockville Pike Rockville, MD

August 21, 2017



AREVA NP

Introduction to AURORA-B

Ralph G. Grummer Supervisor BWR Codes & Methods Douglas W. Pruitt Consultant to AREVA





TOPIC		PRESENTER(S)	TIME
	Opening Remarks	ACRS	8:30 AM - 8:35 AM
Ш	Introduction to ANP-10300P, "AURORA-B" (Open)	AREVA	8:35 AM - 9:00 AM
Ш	Overview of NRC Staff's review (Open)	NRC	9:00 AM - 9:15 AM
IV	Opportunity for public comment	Public	9:15 AM - 9:30 AM
	CLOSED SESSION BEGINS		
V	AURORA-B Evaluation Model Structure	AREVA	9:30 AM - 10:15 AM
	Break		10:15 AM - 10:30 AM
VI	AURORA-B Qualification of Models and Methods	AREVA	10:30 AM - 11:30 AM
	(Closed)		
VII	AURORA-B Modeling Uncertainties	AREVA	11:30 AM - 12:30 PM
	LUNCH BREAK		12:30 PM - 1:30 PM
VIII	Technical Evaluation of AURORA-B	PNNL	1:30 PM - 2:50 PM
IX	Assessment of AURORA-B Uncertainty Analysis Methodology	NRC	2:50 PM - 3:50 pm
	BREAK		3:50 PM - 4:05 PM
Х	MICROBURN-B2 Qualification for Extended Power	NRC	4:05 PM - 4:35 PM
	Uprates and Expanded Flow Windows		
XI	Conditions and Limitations and Conclusions	NRC	4:35 PM - 4:45 PM
XII	Response to Open Items	AREVA/NRC/PNNL	4:45 PM - 5:15 PM
XIII	ACRS Members Closing Remarks	ACRS	5:15 PM - 5:30 PM
XIV	Adjourn	ACRS	5:30 PM



AREVA

Introduction to AURORA-B - RG Grummer/DW Pruitt - 8/21/2017

Presentation Outline

Introduction to AURORA-B (Open)

- Evaluation model development
- AURORA-B AOO Application Domain
- Summary of the AURORA-B AOO Plant Application
- AURORA-B AOO Evaluation Model Development (Closed)
- AURORA-B AOO BWR Components & Qualification (Closed)
- AURORA-B AOO Modeling Uncertainties (Closed)





- AURORA-B consists of a best-estimate multi-physics code system for simulating the coupled fuel, neutronic, and thermal hydraulic BWR system response
 - ◆ MICROBURN-B2 Approved, steady-state core simulator
 - MB2-K 3D kinetics equivalent of the approved MICROBURN-B2 neutronics solution
 - RODEX4 Approved, best estimate steady-state & transient fuel performance predictions
 - S-RELAP5 Two-fluid T/H system code approved for PWR non-LOCA and Realistic LOCA evaluations
- Event simulations are performed by S-RELAP5 in which MB2-K and relevant kernels of RODEX4 have been incorporated



AURORA-B Development Summary

Neutron Kinetics

Starting with the MICROBURN-B2 steady-state equations, temporal kinetics equations were developed to create the MB2-K kinetics code

- MB2-K is integrated within S-RELAP5
- Nodal depletion, spectral history, and other information passed from MB2 to MB2-K for transient initiation
- MB2-K uses the same cross section lookup strategy and other features found in MB2 for consistency



AREVA

AURORA-B Development Summary

Fuel Rod Performance

A subset of the RODEX4 routines are integrated within S-RELAP5

- Significant amount of data transferred from the "full" version of RODEX4 includes material properties that reflect the "permanent effects" on the fuel at the desired level of burnup (e.g. molar fission gas content, cladding corrosion, fuel pellet degradation)
- The subset within S-RELAP5 is used to evaluate the "temporary" transient thermal-mechanical fuel rod (including fuel/clad gap) properties as a function of temperature, rod internal pressure, etc.



AREVA

AURORA-B Development Summary

S-RELAP5

S-RELAP5 physical models have been improved

- Interfacial drag for rod bundles and large diameters
- Reynolds dependent form losses for spacer grids
- Single and two phase friction models consistent with MICROBURN-B2 for the fuel

S-RELAP5 component models have been added or improved

- Jet-pump model
- Mechanistic separator model
- Critical power correlations



AURORA-B Evaluation Models

AURORA-B is a comprehensive code system for BWR analysis

 ANP-10300P presents the foundational development and qualification of AURORA-B for BWR applications and the <u>AURORA-B AOO</u> Evaluation Model (EM) for analyzing "core wide" transients and accidents

ANP-10300P does not address

- Control Rod Drop and Control Rod Withdrawal Error Accidents
- Loss Of Coolant Accidents
- Late Stages of the Anticipated Transients Without Scram (after initiation of Boron Injection)
- Instability Events
- ANP-10332P, Revision 0 submitted in February 2014, presents the <u>AURORA-B LOCA</u> EM
- ANP-10333P, Revision 0, submitted in March 2014, presents the <u>AURORA-B CRDA</u> EM



AREVA
AURORA-B AOO Application Domain

- AURORA-B AOO was submitted to address all forced circulation BWR plant types over the full domain of operating conditions:
 - BWR product lines 2-6 (BWR/2-6)
 - Entire Power/Flow operating map from low power conditions at which core monitoring commences up to and including operation at Extended Power Flow Operating Domain (EPFOD)



AURORA-B AOO Target Scenarios

SRP 15.1 Cool Down Events:

- SRP 15.1.1 Feedwater system malfunctions that result in a decrease in feedwater temperature (LFWH)
- SRP 15.1.2 Feedwater system malfunctions that result in an increase in feedwater flow (FWCF)
- SRP 15.1.3 Steam pressure regulator malfunctions or failures that result in increased steam flow (PRFO)

SRP 15.2 Heat Up Events:

- SRP 15.2.1 Loss of external load (generator load rejection)
- SRP 15.2.2 Turbine trip
- SRP 15.2.3 Loss of condenser vacuum
- SRP 15.2.4 Closure of main steam isolation valve
- SRP 15.2.5 Steam pressure regulator failure (closed)
- SRP 15.2.6 Loss of non-emergency ac power to the station auxiliaries
- SRP 15.2.7 Loss of normal feedwater flow

AREVA



Introduction to AURORA-B – RG Grummer/DW Pruitt – 8/21/2017

AURORA-B AOO Target Scenarios

SRP 15.3 Loss of Coolant Flow Events:

- SRP 15.3.1 Recirculation pump trip
- SRP 15.3.2 Recirculation flow controller malfunction (decreasing flow)
- SRP 15.3.3 Reactor coolant pump rotor seizure
- SRP 15.3.4 Reactor coolant pump shaft break

SRP 15.4 Reactivity Events:

- SRP 15.4.4 Startup of an idle recirculation loop
- SRP 15.4.5 Recirculation flow controller malfunction which results in increased core flow rate

SRP 15.5 Increasing Inventory Events:

 SRP 15.5.1 Inadvertent operation of an Emergency Core Cooling System (ECCS) that increases reactor coolant inventory, including high pressure core spray, high pressure coolant injection, or reactor core isolation cooling system



AREVA

AURORA-B AOO Application Domain Target Scenarios

SRP 15.6 Decreasing Inventory Events:

SRP 15.6.1 Inadvertent opening of a pressure relief valve

SRP 15.8 Anticipated Transients without Scram:

- Protection of the reactor pressure vessel and associated piping from failure due to over pressurization
- Demonstration that fuel integrity is maintained



AREVA

Target Scenario Figures of Merit

- ΔMCPR, demonstrate that the event minimum critical power ratio (MCPR) remains above the appropriate limit for the scenario
- Peak System Pressure, to demonstrate that the peak pressure is maintained below prescribed limits for AOOs and the ATWS scenario
- Time dependent nodal power, used in conjunction with thermalmechanical methods to evaluate cladding strain and fuel centerline temperatures during the event
- Peak Clad Temperature and maximum local oxidation, assure fuel integrity is maintained for selected events



AURORA-B AOO Event Evaluation

The AURORA-B event analyses is initiated from the steadystate condition defined by MICROBURN-B2

- MICROBURN-B2 depletion to the cycle exposure and power/flow condition of interest
- AURORA-B input preparation is augmented by certified automation tools
 - Vessel, Steam lines, recirculation lines, control systems and protection systems constructed from plant specific database
 - S-RELAP5 core geometry constructed from MICROBURN-B2
 - Core nodalization and initialization based on MICROBURN-B2 state-point solution
 - Core fuel pins initialized based on RODEX4 depletions with MICROBURN-B2 power histories and state-point nodalization



AURORA-B AOO Plant Application

ANP-10300P was submitted to establish the foundation methods to address short term regulatory changes associated with reactivity insertion events and revised LOCA criteria.

Key components of the methodology are:

- Well founded and qualified models and methods for BWR transient applications
- Conservative benchmarks to reactor turbine trip measurements
- Highly ranked plant parameters or parameters that exhibit a range of operating conditions treated conservatively
- Conservative biasing of transient simulations to bound modeling uncertainties for Figure of Merit (FoM) outcomes based on Monte-Carlo techniques and approved uncertainties
- Resultant change in MCPR added to the statistical MCPR Safety Limit (SLMCPR) to establish the MCPR Operating Limits (OLMCPR)
- Limiting event boundary conditions are utilized within the RODEX4 statistical methodology to demonstrate fuel centerline melt and clad strain criteria



AREVA

AURORA-B AOO Document Roadmap

Submitted Documents

- ANP-10300, AURORA-B: An Evaluation Model for Boiling Water Reactors; Application to Transient and Accident Scenarios
- ANP-10300Q1P Acceptance Review Questions clarified the submitted methodology and validated the application of MICROBURN-B2 to Extended Power Uprates with Extended Flow Windows
- ANP-10300Q2P Requests for Additional Information served to quantify model uncertainties and the associated impact on computed event figures of merit.

Supporting documents

- General BWR Design and Event Descriptions, ANP-2829(P)
- Control System and Reactor Protection System Requirements for Modeling BWR Events, ANP-2830(P)
- Identification of Code Capabilities and PIRT Development for BWR Transient Analyses, ANP-2831(P)
- Underlying documents supporting AURORA-B (MICROBURN-B2, MB2-K, RODEX4, S-RELAP5)

AURORA-B and the AURORA-B AOO methodology was developed and documented consistent with the EMDAP process delineated in the NRC Regulation Guide 1.203



AREVA



NRC Staff's Review of ANP-10300P

AURORA-B: An Evaluation Model for Boiling Water Reactors; Application to Transient and Accident Scenarios

ACRS Subcommittee Meeting Overview

A. Kevin Heller, PhD John Lehning Nuclear Performance and Code Review Division of Safety Systems Office of Nuclear Reactor Regulation

Tom Michener

Pacific Northwest National Laboratory



Presentation Outline

- Overview (Open Session)
 - Describe NRC staff's review of ANP-10300P
- NRC Staff's assessment of ANP-10300P (Closed Session)
 - Technical evaluation: model and code qualification
 - -MICROBURN-B2 Qualification for EPU and EFW
 - Uncertainty analysis
 - Conditions and Limitations and Conclusions



Introduction

AURORA-B

- Multi-physics, multi-code system
 - S-RELAP5 thermal-hydraulic system code
 - MB2-K neutron kinetics code
 - CASMO-4/MICROBURN-B2 lattice physics/core neutronics code system
 - RODEX4 fuel thermal-mechanical code
- ANP-10300P applicability
 - BWRs/2-6
 - Standard operating domain, EPU and EFW (i.e., MELLLA+)
 - Anticipated Operational Occurrences and Postulated accidents
 - Exceptions: (addressed in other applications)
 - LOCA
 - Control rod withdraw error and CRDA
 - Instability and later stages of ATWS



Introduction

- Best estimate with conservatism + uncertainty
- Large, interdisciplinary review scope
 - -Multiple reviewers over several years
- Pacific Northwest National Laboratory acted as a consultant
 - Judith Cuta thermal-hydraulics
 - -Ken Geelhood fuel thermal-mechanical
 - Carl Beyer fuel thermal-mechanical
 - Gregory Piepel statistics
 - Dave Engel statistics
 - -Andrew Prichard neutronics
 - Bruce Schmitt thermal-hydraulics and system modeling



Review Guidance

- NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR Edition."
 - Chapter 15.0.2, "Review of Transient and Accident Analysis Methods."
- Regulatory Guide 1.203, "Transient and Accident Analysis Methods"
 - Evaluation Model Development and Assessment Process (EMDAP)



Review Scope

SRP Chapter 15.0.2

- Documentation
- Evaluation Models
- Accident Scenario Identification Process
- Code Assessment
- Uncertainty Analysis
- Quality Assurance Plan

Safety Evaluation

Based on, and follows, the SRP structure



Documentation

Acceptance Criteria

- Submittal should identify specific accident scenarios and plant configurations
- Submittal should contain:
 - Complete description of code assessment
 - Theory manuals describing field equations and closure relationships
 - User manuals discussing code limitations

- Accident scenarios identified and code assessment described in LTR
- Unitary S-RELAP5 theory manual and supporting code theory manuals
- Code limitations within theory manuals, user manuals, staff SEs



Evaluation Models

General areas of review:

- Thermal-Hydraulics (S-RELAP5)
- Neutronics (MICROBURN-B2 and MB2-K)
- Primary System Modeling (S-RELAP5)
- Fuel thermal-mechanical performance (RODEX4)

Focused areas of review

- S-RELAP5 new and existing models and methods BWR applicability
- MB2-K new neutron kinetics methods
- MICROBURN-B2 qualification for EPU and EFW conditions
- RODEX4 "kernel" subset of RODEX4 models in S-RELAP5



Evaluation Models

Acceptance Criteria

- Models should be present for all phenomena and components determined important or necessary to simulate scenario under consideration
- Chosen models and associated numerical solutions should predict important physical phenomena reasonably well

- Support for performance of physical models and numerical solutions provided by comparison to experimental data (e.g., KATHY test facility void fraction measurement), numerical benchmarks (e.g., Industry Standard Problems) and higher order methods (e.g., MCNP)
- Examination of equations and relationships governing models via theory manuals and staff SEs for acceptability and range of validity
- Reasonable to excellent code-data comparisons



Accident Scenario Identification Process

Acceptance Criteria

- Process should identify and rank reactor component and physical phenomena modeling requirements
- Process should include evaluation of physical phenomena to identify those important in determining figures of merit

- SRP Chapter 15.0.2, Section III notes that a PIRT is an example of an acceptable structured process for identifying and ranking phenomena
- AREVA developed PIRT through multiple iterations between development teams and BWR application engineers
- Summary-level PIRT comprised of highly-ranked phenomena from series of event-PIRTs
- 5 figures of merit: ΔMCPR, peak system pressure, time-dependent nodal power, peak cladding temperature, max local oxidation.



Code Assessment

Acceptance Criteria

 Models should be assessed over entire range of conditions encountered in transient or accident scenarios

- Comparison of predicted results against separate effects tests and integral effects tests from experimental facilities (e.g., KATHY, FRIGG)
- Code predictions compared to analytical solutions for accuracy of numerical methods (e.g., numerical benchmarks, higher order methods)
- System interaction and global capability via prediction of FIST test facility operational transients and Peach Bottom Turbine Trip Tests
- Reasonable to excellent code-data comparisons



Uncertainty Analysis

Acceptance Criteria

• Should address all important sources of code uncertainty, including mathematical models in the code and user modeling (e.g., nodalization)

- AREVA classified three areas of biases and uncertainties:
 - Model structure (e.g., nodalization and time steps size sensitivities)
 - Selection of plant parameters and initial conditions
 - Biases and uncertainties in predicting highly ranked, and pertinent medium ranked, PIRT phenomena
- Structure and initial conditions determined via sensitivity analyses
- Uncertainties in high (and medium) ranked PIRT via non-parametric ordered statistics
 - Conservative biasing of subset of parameters
 - Acceptable parameter distributions and sampling ranges
 - Predominantly univariate approach



Quality Assurance Plan

Acceptance Criteria

 Code should be maintained under a quality assurance program that meets the requirements of Appendix B to 10 CFR Part 50

- AREVA has an established NRC-approved software quality assurance program
- AURORA-B developed and maintained under this program



Conclusion

- The staff found AURORA-B acceptable for simulation of AOOs and certain postulated accidents
 - -BWRs with forced recirculation systems
 - Standard operating domain, EPU and EFW (e.g., MELLLA+)
 - -ATRIUM-10 and ATRIUM-10XM fuels (with justification for others)
 - Conditions and Limitations
 - Applied within limits of individual code approvals
 - Uncertainty distributions and sampling ranges as-reviewed
 - Conservative modeling justifications



Nomenclature

<u>Acronym</u>	Definition
A00	Anticipated Operational Occurrences
ATWS	Anticipated transient without scram
BWR	Boiling water reactor

- CFR Code of Federal Regulations
- CRDA Control rod drop accident
- EFW Expanded flow window
- EMDAP Evaluation Model Development and Assessment Process
- EPU Extended power uprate
- LOCA Loss of coolant accident
- LWR Light water reactor
- MELLLA+ Maximum extended load line limit analysis plus
- MCNP Monte Carlo N-Particle
- PIRT Phenomena identification and ranking table
- SRP Standard review plan
- SE Safety evaluation
- ΔMCPR Transient change in Minimum critical power ratio