

Central files

September 18, 1981

Docket No. 50-244  
LS05-81-09-04B

Mr. John E. Maier  
Vice President  
Electric and Steam Production  
Rochester Gas & Electric Corporation  
89 East Avenue  
Rochester, New York 14649



Dear Mr. Maier:

SUBJECT: SEP TOPIC VI-7.B: ESF (ENGINEERED SAFETY FEATURES) SWITCHOVER FROM INJECTION TO RECIRCULATION MODE, AUTOMATIC ECCS REALIGNMENT, GINNA

The enclosed staff safety evaluation report is based on the information provided in your letter of August 16, 1981. This evaluation is the staff's position regarding design of your facility in the subject area. With regard to the referenced topic, the staff has concluded your facility meets current licensing criteria.

Sincerely,

Dennis M. Crutchfield, Chief  
Operating Reactors Branch #5  
Division of Licensing

Enclosure:  
As stated

cc:  
See next page

SEP 04  
s  
1/1  
DS4 USE (7)

8109220391 810918  
PDR ADOCK 05000244  
PDR

OFFICE	SEP B: DL	SEP B: DL	SEP B: DL	ORB #5: DL: PM	ORB #5: DL: C	AD SA: DL
SURNAME	Russell	RHermann	WRussell	RSnaider	DCrutchfield	GLainas
DATE	9/9/81	9/9/81	9/15/81	9/15/81	9/15/81	9/14/81

Faint, illegible text scattered across the page, possibly bleed-through from the reverse side. The text is too light to transcribe accurately but appears to be organized into paragraphs or sections.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555  
September 18, 1981

Docket No. 50-244  
LS05-81-09-048

Mr. John E. Maier  
Vice President  
Electric and Steam Production  
Rochester Gas & Electric Corporation  
89 East Avenue  
Rochester, New York 14649

Dear Mr. Maier:

SUBJECT: SEP TOPIC VI-7.B: ESF (ENGINEERED SAFETY FEATURES) SWITCHOVER FROM INJECTION TO RECIRCULATION MODE, AUTOMATIC ECCS REALIGNMENT, GINNA

The enclosed staff safety evaluation report is based on the information provided in your letter of August 16, 1981. This evaluation is the staff's position regarding design of your facility in the subject area. With regard to the referenced topic, the staff has concluded your facility meets current licensing criteria.

Sincerely,

A handwritten signature in cursive script that reads "Dennis M. Crutchfield".

Dennis M. Crutchfield, Chief  
Operating Reactors Branch #5  
Division of Licensing

Enclosure:  
As stated

cc:  
See next page

Mr. John E. Maier

CC

Harry H. Voigt, Esquire  
LeBoeuf, Lamb, Leiby and MacRae  
1333 New Hampshire Avenue, N. W.  
Suite 1100  
Washington, D. C. 20036

Mr. Michael Slade  
12 Trailwood Circle  
Rochester, New York 14618

Ezra Bialik  
Assistant Attorney General  
Environmental Protection Bureau  
New York State Department of Law  
2<sup>nd</sup> World Trade Center  
New York, New York 10047

Jeffrey Cohen  
New York State Energy Office  
Swan Street Building  
Core 1, Second Floor  
Empire State Plaza  
Albany, New York 12223

Director, Bureau of Nuclear  
Operations  
State of New York Energy Office  
Agency Building 2  
Empire State Plaza  
Albany, New York 12223

Rochester Public Library  
115 South Avenue  
Rochester, New York 14604

Supervisor of the Town  
of Ontario  
107 Ridge Road West  
Ontario, New York 14519

Resident Inspector  
R. E. Ginna Plant  
c/o U. S. NRC  
1503 Lake Road  
Ontario, New York 14519

Mr. Thomas B. Cochran  
Natural Resources Defense Council, Inc.  
1725 I Street, N. W.  
Suite 600  
Washington, D. C. 20006

U. S. Environmental Protection Agency  
Region II Office  
ATTN: Regional Radiation Representative  
26 Federal Plaza  
New York, New York 10007

Herbert Grossman, Esq., Chairman  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Richard F. Cole  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Emmeth A. Luebke  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

TOPIC VI-7.B: ESF (ENGINEERED SAFETY FEATURES) SWITCHOVER FROM INJECTION TO RECIRCULATION MODE, AUTOMATIC ECCS REALIGNMENT

I. INTRODUCTION

Most Pressurized Water Reactors (PWRs) require operator action to realign the ECCS for the recirculation mode following a LOCA. The NRC staff has been requiring, on a case-by-case basis, some automatic features to assist in the realignment of the ECCS from the injection to the recirculation mode of operation. The safety objective of this requirement is to increase the reliability of long-term cooling by reducing the number of operator actions required to change system realignment to the recirculation mode.

The scope of this topic requires a review of the ECCS control system and the operator action required to realign the ECCS from injection to recirculation mode following a LOCA. The sequence of events from initiation of the injection mode to completion of the recirculation mode, the systems/components and instrumentation/controls utilized in the injection to recirculation process, and the automatic and/or manual process required to complete the switchover process are to be reviewed. The objective of this review is to determine if automatic switchover is necessary to protect public health and safety.

II. REVIEW CRITERIA

The current licensing criteria which govern the safety issue are identified in Table 7-1 of the Standard Review Plan. The most significant of these criteria are:

1. Branch Technical Position 1CSB 20,
2. IEEE Std. 279-1971, and
3. Regulatory Guide 1.62.

III. RELATED SAFETY TOPICS AND INTERFACES

The scope of review for this topic was limited to avoid duplication of effort since some aspects of the review were performed under related topics. The related topics and the subject matter are identified below. Each of the related topic reports contain the acceptance criteria and review guidance for its subject matter.

- III-6 Seismic Design Considerations
- III-10.A Thermal-overload protection for motor operated valves
- III-11 Component Integrity
- III-12 Environmental Qualification
- IV-1.A Operation with less than all reactor coolant loops in service
- V-10.B RHR Reliability
- V-11 High Pressure/Low Pressure Interface
- VI-7.A.3 ECCS Actuation System
- VI-7.C.1 Independence of Onsite Power
- VI-10.A Testing of ESF System
- VI-10.B Shared Systems

VIII-2 Onsite Emergency Power Systems  
VIII-3 Emergency dc Systems  
VIII-4 Containment Penetrations

The following topics are dependent on the present topic information for completion.

VI-4 Containment Isolation System  
VI-7.C.2 ECCS Single Failure Criterion

#### IV. REVIEW GUIDELINES

ICSB 20 states that automatic transfer to the recirculation mode is preferable to manual transfer and should be provided for standard plant designs submitted for review on a generic basis under the Commission's standardization policy.

ICSB 20 also states that a design that provides manual initiation at the system level of the transfer to the recirculation mode, while not ideal, is sufficient and satisfies the intent of IEEE Std. 279 provided that adequate instrumentation and information display are available to the operator so that he can make the correct decision at the correct time. Furthermore, it should be shown that, in case of operator error, there are sufficient time and information available so that the operator can correct the error, and the consequences of such an error are acceptable.

#### V. EVALUATION

Redundant and independent Refueling Water Storage Tank (RWST) level instrumentation is used to alert the operator when he must initiate a manual change over from the injection mode to the recirculation mode of emergency core cooling. The instrumentation is qualified for the worst environmental and seismic conditions. (The RWST is located in the auxiliary building). Each instrument channel is powered from a separate Class 1E bus. These buses are evaluated in SEP Topic VI-7.C.1.

By procedure, one train is to be stopped at 31% RWST level if both trains are operating.

If the operator should ignore this alarm (and his indicator from the other channel) he has 71,925 gallons or approximately 65 minutes until he reaches the 10% RWST level. Changeover normally occurs at 10%, but 34,250 gallons or 31 minutes additional injection on both trains is possible.

Redundant valves are used to close minimum flow lines (that may contain highly radioactive water) that return flow to the refueling water storage tank. However, two of these valves are in series and share the same motive power (air) and fail closed on loss of air. The staff's review of valve failures does not indicate a history of failures in air operated valves at the Ginna plant.

#### VI. CONCLUSION

As a result of our review, the staff concludes that:

1. ICSB 20 has been satisfied;
2. A recirculation path to the refueling water storage tank relies upon two air operated valves that share an air supply. Although these valves are not entirely independent, plant operating experience has demonstrated the acceptability of this design; and
3. Beyond the failures identified in Topic VI-7.C.1, there are no single failures within either ECCS train that could result in a simultaneous loss of both ECCS train nor in a significant release of fission products as a result of the changeover from the injection to the recirculation mode of ECCS at Ginna.