

REGULARY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8109220560. DOC. DATE: 81/09/17 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G. 05000244
 AUTH. NAME: AUTHOR AFFILIATION
 MAIER, J. E. Rochester Gas & Electric Corp.
 RECIPIENT AFFILIATION
 CRUTCHFIELD, D. Operating Reactors Branch 5

SUBJECT: Forwards response to NRC 810805. ltr re SEP Topic IX-5.
 "Ventilation," as discussed in 810828 telcons.

DISTRIBUTION CODE: A035S COPIES RECEIVED: LTR ☒ ENCL ☒ SIZE: ☒ ~~-----~~
 TITLE: SEP Topics

NOTES: 1 copy: SEP Sect. Ldr.

05000244

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
ACTION:	ORR #5 BC 04	7 7		
INTERNAL:	A/D MATL & QUAL 13	1 1	CONT SYS A 07	1 1
	HYD/GEO BR 10	2 2	I&E 06	2 2
	OR ASSESS BR 11	1 1	<u>REG FILE</u> 01	1 1
	SEP BR 12	3 3		
EXTERNAL:	ACRS 14	16 16	LPDR 03	1 1
	NRC PDRI 02	1 1	NSIC 05	1 1
	NTIS 1	1 1		

SEP 25 1981

TOTAL NUMBER OF COPIES REQUIRED: LTR ³⁹₃₈ ENCL ³⁹₃₈


QC



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

JOHN E. MAIER
VICE PRESIDENT

TELEPHONE
AREA CODE 716 546-2700



September 17, 1981

Director of Nuclear Reactor Regulation
Attention: Dennis M. Crutchfield, Chief
Operating Reactors Branch No. 5
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: SEP Topic IX-5, Ventilation
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Crutchfield:

This letter responds to the NRC's request for additional information for this SEP topic, transmitted to RG&E by letter of August 5, 1981. The response to the NRC questions was discussed between RG&E personnel, Mr. Clyde Herrick of FRC, and Mr. Stewart Brown of the NRC by telephone conversations on August 28, 1981. The attachment serves to document this conversation.

Very truly yours,

John E. Maier
John E. Maier

Attachment

A035
s
1/1

8109220560 810917
PDR ADDCK 05000244
PDR

1954 12 27 123

Attachment: Response to August 5, 1981 Letter,
SEP Topic IX-5, Ventilation Systems

1. Bypass Duct Damper, Auxiliary Building Main Exhaust Fan System

Dwg. 33013-533 indicates that the bypass damper is controlled by the Auxiliary Building charcoal filter fans. These are presumed to be the redundant fans on the lower floors of the auxiliary building. (1) Is this correct? (2) Please clarify the operation of the main fan bypass damper, and verify that it will be open for safe shutdown.

Response: The Auxiliary Building charcoal filter fans are redundant. The main bypass damper is activated by the charcoal filter fan's motor starters. Actuation of the fans causes opening of the damper.

2. Auxiliary Building Main Exhaust Line Positive Pressure

During shutdown of the reactor using onsite diesel generated power, the main exhaust fans, 1A and 1B will be shut down, their respective dampers will be closed and the main fan bypass duct damper will be open. The remaining exhaust fans on three separate lines leading to the main HEPA filter continue to operate. The loss of suction from the main exhaust fans now causes a positive back pressure on each line in the duct leading to the main HEPA filter. Please verify that the pressure produced here cannot cause backflow through any one operating fan. This is related to the flow vs. pressure characteristics of the fans used.

Response: The information is not available at this time. An evaluation of the flow vs. pressure characteristics of the respective fan will be undertaken shortly. It is expected that a response can be provided by 10/15/81.

3. Description, Auxiliary Building Exhaust Fan 1G

Please provide a complete description of Exhaust Fan 1G, including the variable blade angle or variable inlet vane control. How is its differential pressure control tied to the control of the exhaust system? What percentage of the flow area remains with the inlet vanes closed or the blades in flattest pitch?

Response: Exhaust fan 1G uses variable blade angle control. At its flattest pitch, 85½% of the inlet area is closed. Differential pressure control is via a venturi tube, which controls fan differential pressure to 4½ inches of water.

4. Auxiliary Building, Damper Control in Two Lines Leading to the New Charcoal-HEPA Filter

Drawing 33013-533 dated 1975 shows revisions to the system as compared to system descriptions in the FSAR. Dwg. 33013-533 shows a charcoal-HEPA filter fed by two exhaust lines, one from the general operating floor, boric acid, and drumming areas, and the other from a wide range of intermediate floor and basement areas. Both lines retain their respective actuator operated dampers just before the charcoal-HEPA filter. The drawing indicates "motor starter" as the controlling means for each damper. Since, in the system revision, the respective fans in each line were removed, what motor starter or starters are now used for each damper? Is it Fan 1G or some other control element?

Response: Fan 1G controls the dampers in both lines.

5. Hydrogen Recombiner Control Panel

Please describe the ventilation and cooling needs.

Response: Intermediate Building ventilation should maintain the environment in the area of the recombiner panel to less than 104°F.

6. Air Supply, Intermediate Building Fan 1C

It was not determined in the visit to Ginna whether the air source is from the turbine building or whether it is now outside air. Please indicate the present source.

Response: Outside air, drawn via louvres in the Intermediate Building, provide the necessary makeup air.

7. Response to Radiation Monitors R13 and R14

Please provide an outline of the exhaust system response to monitors R13 and R14, plus a brief statement as to the rationale.

Response: The following is a table of the plant ventilation system response for a high alarm on either R-13 or R-14: The general philosophy is to maintain the auxiliary building and the intermediate building at slightly negative pressures, to prevent out leakage of radioactivity, and to trip all fans except those exhausting to the plant vent via charcoal filters.

1. The first part of the document is a list of names and addresses of the members of the committee.

2. The second part of the document is a list of names and addresses of the members of the committee.

3. The third part of the document is a list of names and addresses of the members of the committee.

4. The fourth part of the document is a list of names and addresses of the members of the committee.

5. The fifth part of the document is a list of names and addresses of the members of the committee.

6. The sixth part of the document is a list of names and addresses of the members of the committee.

7. The seventh part of the document is a list of names and addresses of the members of the committee.

8. The eighth part of the document is a list of names and addresses of the members of the committee.

9. The ninth part of the document is a list of names and addresses of the members of the committee.

10. The tenth part of the document is a list of names and addresses of the members of the committee.

<u>VENTILATION EQUIPMENT</u>	<u>"FILTER- OUT"</u>	<u>"FILTER- IN"</u>
1A or 1B Auxiliary Building Main Exhaust Fan	X	
1C Auxiliary Building Exhaust Fan		
1G Auxiliary Building Exhaust Fan		
1F Auxiliary Building Exhaust Fan	X	X
1A Auxiliary Building Supply Air Handling Unit	X	
1B Auxiliary Building Supply Fan	X	
1A or 1B Intermediate Building Exhaust Fan	X	X
1C Intermediate Building Exhaust Fan	X	X
1A or 1B Controlled Access Exhaust Fan		
1A or 1B Auxiliary Building Charcoal Filter Fans		

X - Indicates the fan or Air Handling unit will trip

No marking - Indicates the fan or air handling unit will remain in service.

In addition, a high alarm on R-14 will close the Gas Decay Tank Release Valve RCV-014.