

APPENDIX A

NOTICE OF VIOLATION

Rochester Gas and Electric Corporation  
Ginna

Docket No. 50-244  
License No. DPR-18

As a result of the inspection conducted on November 1, 1981 through December 31, 1981 and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violations were identified:

- A. Technical Specification 6.8.1 states in part, "Written procedures shall be established, and maintained covering the activities referenced below:

... f. Fire Protection Program implementation."

Site Contingency (SC) Procedure-3.16.2.3, Satellite Station 'A' Startup Following Undervoltage Lockout, Revision 0, November 2, 1981, paragraph 5, provides steps such that following a loss of power to Satellite Station 'A' (SSA) the solenoid valve actuators associated with the fire suppression deluge valves be disconnected before re-energizing SSA. Paragraph 4, states this action is necessary, "... to prevent inadvertent actuation of Fire Suppression Systems due to transients when power is suddenly restored."

Administrative Procedure (A)-503, Plant Procedure Adherence Requirements, Revision 4, October 12, 1981, paragraph 3.1.1 states, in part, "For operation of systems, components or processes for which a procedure is provided... the procedure shall be completely filled out and signed off."

Contrary to the above, during system testing on November 14, 1981, SC-3.16.2.3 was not followed to reenergize SSA following a loss of power. Further, the solenoid valve actuators were not disconnected before re-energizing SSA and an inadvertent actuation of the Fire Suppression System resulted.


This is a Severity Level V Violation (Supplement 1).


- B. Technical Specification (TS) 3.14.3.1 requires, in part, that with a fire suppression spray/sprinkler system listed in TS 3.14.3 inoperable for greater than 14 days, a Thirty Day Written Report must be submitted outlining the cause of the inoperability and the plan for restoring the system to operable status.

Contrary to the above, as of November 12, 1981, a Thirty Day Written Report was not submitted describing several portions of the spray/sprinkler system which were taken out of service for modification from June-September 1981.

This is a Severity Level V Violation (Supplement 1).

Pursuant to the provisions of 10 CFR 2.201, Rochester Gas and Electric Corporation is hereby required to submit to this office within thirty days of the date of this Notice,






APPENDIX A

a written statement or explanation in reply including the corrective steps which have been taken and results achieved; corrective steps which will be taken to avoid further violations; and the date when full compliance will be achieved. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation. Where good cause is shown, consideration will be given to extending your response time.

Date JAN 12 1982

  
for Richard W. Starostecki, Director,  
Division of Resident and Project  
Inspection

