



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

ROCHESTER GAS AND ELECTRIC CORPORATION

DOCKET NO. 50-244

R. E. GINNA NUCLEAR POWER PLANT

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 47  
License No. DPR-18

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Rochester Gas and Electric Company (the licensee) transmitted by letter dated December 11, 1981, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8202080547 820113  
PDR ADDCK 05000244  
P PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and by changing Paragraph 2.C(2) of Provisional Operating License No. DPR-18 to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 47, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Dennis M. Crutchfield, Chief  
Operating Reactors Branch #5  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: January 13, 1982

ATTACHMENT TO LICENSE AMENDMENT NO. 47

PROVISIONAL OPERATING LICENSE-NO. DPR-18

DOCKET NO. 50-244

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed page. The revised page contains the captioned amendment number and marginal lines which indicate the area of change.

PAGE

3.5-12

TABLE 3.5-5

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES*</u>
1. SAFETY INJECTION AND FEEDWATER ISOLATION		
a. Manual Initiation	Not Applicable	Not Applicable
b. High Containment Pressure	≤ 4.0 psig	≤ 5.0 psig
c. Low Pressurizer Pressure	≥ 1723 psig	≥ 1715 psig
d. Low Steam Line Pressure	≥ 514 psig	≥ 500 psig
2. CONTAINMENT SPRAY		
a. Manual Initiation	Not Applicable	Not Applicable
b. High-High Containment Pressure	≤ 28 psig	≤ 30 psig
3. CONTAINMENT ISOLATION		
a. Containment Isolation		
1. Manual	Not Applicable	Not Applicable
2. From Safety Injection Automatic Actuation Logic	Not Applicable	Not Applicable
b. Containment Ventilation Isolation		
1. Manual	Not Applicable	Not Applicable
2. High Containment Radioactivity	Note 3	Not Applicable
3. From Safety Injection	Not Applicable	Not Applicable
4. Manual Spray	Not Applicable	Not Applicable

3.5-12

Amendment No. 42, 47