



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

ROCHESTER GAS AND ELECTRIC CORPORATION

DOCKET NO. 50-244

R. E. GINNA NUCLEAR POWER PLANT

AMENDMENT TO PROVISIONAL OPERATING LICENSE -

Amendment No. 52  
License No. DPR-18

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The facility will operate in conformity with the license amendment, the provisions of the Act, and the rules and regulations of the Commission;
  - B. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - C. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - D. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8202160044 820203  
PDR ADDCK 05000244  
P PDR

2. Accordingly, the license is amended by adding the following to Paragraph 2.C(9) of Provisional Operating License No. DPR-18 to read as follows:

20. Within six months, determine the criteria which should be provided in the steam generator tube rupture procedures for deciding when to discontinue the use of the main condenser in favor of the atmospheric steam dump.

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

*Dennis M. Crutchfield*  
Dennis M. Crutchfield, Chief  
Operating Reactors Branch #5  
Division of Licensing

Date of Issuance: June 2, 1982