OPERATING DATA REPORT

DOCKET NO. 50-244

DATE February 6, 1981

COMPLETED BY Livral E. McNamara

TELEPHONE 1(315)524-4446 Ext. 205, 293

OPERATING STATUS

1. Unit Name: GINNA STATION, UNIT #1 2. Reporting Period: January, 1981 3. Licensed Thermal Power (MWt): 1520 4. Nameplate Rating (Gross MWe): 490 5. Design Electrical Rating (Net MWe): 470 6. Maximum Dependable Capacity (Gross MWe): 7. Maximum Dependable Capacity (Net MWe): - 8. If Changes Occur in Capacity Ratings (Items	Notes The reactor power level was maintained at 100% with the exception of a power reduction and outage detailed on page 3. Since Last Report, Give Reasons:			
9. Power Level to Which Restricted, If Any (Net 10. Reasons For Restrictions, If Any:	t MWe):			
	This Month	Yrto-Date	Cumulative	
11. Hours In Reporting Period	744	744	98,040	
12. Number of Hours Reactor Was Critical	744	744	75,144.52	
13. Reactor Reserve Shutdown Hours	0	0	1,631.32 73,366.38 8.5 * 99,245,338 32,282,900 30,580,911 74.83	
14. Hours Generator On-Line	734.75 ⁻	734.75		
15. Unit Reserve Shutdown Hours	0	0		
16. Gross Thermal Energy Generated (MWH)	1,043,136	1,043,136		
17. Gross Electrical Energy Generated (MWH)	342,801	342,801		
18. Net Electrical Energy Generated (MWH)	325,368	325,368		
19. Unit Service Factor	98.76	98.76		
20. Unit Availability Factor	98.76	98.76	74.84	
21. Unit Capacity Factor (Using MDC Net)	93.05	93.05	68.61	
22. Unit Capacity Factor (Using DER Net)	93.05	93.05	68.61	
23. Unit Forced Outage Rate	1.2%	1.2%	9.01%	
24. Shutdowns Scheduled Over Next 6 Months (Tylender Refueling, maintenance and modern modern modern maintenance and modern modern modern maintenance and modern mo				
25. If Shut Down At End Of Report, Period, Estima	-		,	
26. Units In Test Status (Prior to Commercial Ope	eration):	Forecast	Achieved	
. INITIAL CRITICALITY		-,	•	
INITIAL ELECTRICITY	4	4		
COMMERCIAL OPERATION		 -		

* Cumulative total commencing January 1, 1975

49-88 (REV. 1/78)

Experience of the same of the

્ લકે.

and the second of the second of the second

attention of the second second

A CONTRACT OF THE STATE OF THE

The state of the s

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244

UNIT #1, Ginna Station

DATE February 6, 1981

COMPLETED BY Andrew E. McNamara

TELEPHONE 1(315)524-4446

Ext. 205, 293

MONTH	January, 1981
DAY AVE	ERAGE DAILY POWER LEVEL (MWe-Net)
1	476
2	476
3	476
4	476
5	³ 476 ·
6	150
7	313
8	295
9	
10	476
	476
12	476
13	476
14	476
15	476
16	477

DAY AVERAGE DAILY POWER LEVEL (MWe-Net)

17	477
18	475
	334
	263
21	169
22	368
23	475
24	475
	474
26	475
27	474
28	475
29	475
30	475
31	473

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

ام المراجعة ال

Samuel State of the Control of the C

The second of th

 $\mathbf{x} = \mathbf{x} + \mathbf{y} + \mathbf{x} + \mathbf{y} +$

por for the second of the seco

1. 9. 2 · 4. (1.2 · 1.4

, to it is a spatial to

and the state of t The second of th

group and projection of the first the first

and the state of t Fig. 1 Section 2. Section 2.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH January, 1981

50-244 DOCKET NO.

UNIT NAME #1, Ginna Station

February 6, 1981

Cherran E. Mikau

Andrew E. McNamara

TELEPHONE_

COMPLETED BY

1(315)524-4446 Ext. 205, 293

No.	Date	Type 1	Duration (Hours)	. Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
81-1	010781	F	0	A }	4 -		нг	MOTORX	Power reduction to ~48%. 1B Circulating Water Pump tripped due to suspected icing problems in Screenhouse. *
81-1	012081	F	9.25	A	4		нн	VALVEX	5B Heater Feedwater Drain Valve replacement. Reactor remained critical. *
			-		•				* Power increase was limited to 50% for a 24 hour period due to indicated axial flux difference exceeding the target band.

1

2

Reason:

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

Method: 1-Manual

2-Manual Scram.

3-Automatic Scram.

4-Other (Explain)

4

Exhibit G - Instructions for Preparation of Data **Entry Sheets for Licensee** Event Report (LER) File (NUREG-0161)

5

Exhibit 1 - Same Source

49-89 (REV. 1/78)

F: Forced

S: Scheduled

3 b) . я 4

- 4 -

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

. DOCKET NO50-244	_
UNIT Ginna Station, Unit #1	_
DATE February 6, 1981	1
COMPLETED BY dusters E. Myanian	=
Andrew E. McNamara	
TELEPHONE 1(315)524-4446	_
Page 205 202	

MONTH January, 1981

The unit power level was maintained at 100% for the report month, with the following exceptions: A power reduction to $\sim 49\%$ on 1/7 due to a trip of the 1B circulating water pump. The cause was suspected icing problems in the Screenhouse. On 1/20 the unit was taken out of service due to failure of the 5B feedwater heater feedwater drain valve. In both instances the reactor remained critical, and the resumption of fuel power was limited to 50% for a 24-hour period due to indicated axial flux difference exceeding the target band. (This is a technical specification limitation).

a market kind of the second of

and the state of t

NEW STATE

MAINTENANCE REPORT

JANUARY, 1981 .

During January normal maintenance and inspections were performed.

Major safety related maintenance included:

Repair of the condensate pressurization valve for the Standby Auxiliary Feedwater Pumps.

Replacement of a failed containment pressure transmitter.

• •

and the second of the second o

.

.

1

.