


Docket No. 50-244  
LS05-81-03-056

MAR 24 1981



Mr. John E. Maier  
Vice President  
Electric and Steam Production  
Rochester Gas & Electric Corporation  
89 East Avenue  
Rochester, New York 14649

Dear Mr. Maier:

SUBJECT: TOPIC III-3.A, EFFECTS OF HIGH WATER LEVEL ON STRUCTURES  
(R. E. GINNA)

Enclosed is a copy of our draft evaluation of Systematic Evaluation Program  
Topic III-3.A.

You are requested to examine the facts upon which the staff has based its  
evaluation and respond either by confirming that the facts are correct, or  
by identifying errors and supplying the corrected information. We encourage  
you to supply any other material that might affect the staff's evaluation of  
these topics or be significant in the integrated assessment of your facility.

Your response is requested within 30 days of receipt of this letter. If no  
response is received within that time, we will assume that you have no comments  
or corrections.

In future correspondence regarding Systematic Evaluation Program Topics, please  
refer to the topic numbers in your cover letter.

Sincerely,

Dennis M. Crutchfield, Chief  
Operating Reactors Branch No. 5  
Division of Licensing

Enclosure:  
As stated

cc w/enclosure:  
See next page

8103310636  
P

OFFICE	SEPB:DL DP	SEPB:DL:SL	SEPB:DL:C	ORB#5:DL:PM	ORB#5:DL:C	AD:SA:DL
SURNAME	DPersinko:dk	RHermann	WRussell	RSnaider	DCrutchfield	GZainas
DATE	3/2/81	3/17/81	3/17/81	3/17/81	3/10/81	2/23/81

1  
 2  
 3  
 4  
 5  
 6  
 7  
 8  
 9  
 10  
 11  
 12  
 13  
 14  
 15  
 16  
 17  
 18  
 19  
 20  
 21  
 22  
 23  
 24  
 25  
 26  
 27  
 28  
 29  
 30  
 31  
 32  
 33  
 34  
 35  
 36  
 37  
 38  
 39  
 40  
 41  
 42  
 43  
 44  
 45  
 46  
 47  
 48  
 49  
 50

1  
 2  
 3  
 4  
 5  
 6  
 7  
 8  
 9  
 10  
 11  
 12  
 13  
 14  
 15  
 16  
 17  
 18  
 19  
 20  
 21  
 22  
 23  
 24  
 25  
 26  
 27  
 28  
 29  
 30  
 31  
 32  
 33  
 34  
 35  
 36  
 37  
 38  
 39  
 40  
 41  
 42  
 43  
 44  
 45  
 46  
 47  
 48  
 49  
 50

1  
 2  
 3  
 4  
 5  
 6  
 7  
 8  
 9  
 10  
 11  
 12  
 13  
 14  
 15  
 16  
 17  
 18  
 19  
 20  
 21  
 22  
 23  
 24  
 25  
 26  
 27  
 28  
 29  
 30  
 31  
 32  
 33  
 34  
 35  
 36  
 37  
 38  
 39  
 40  
 41  
 42  
 43  
 44  
 45  
 46  
 47  
 48  
 49  
 50



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

Docket No. 50-244  
LS05-81-03-056

Mr. John E. Maier  
Vice President  
Electric and Steam Production  
Rochester Gas & Electric Corporation  
89 East Avenue  
Rochester, New York 14649

Dear Mr. Maier:

SUBJECT: TOPIC III-3.A, EFFECTS OF HIGH WATER LEVEL ON STRUCTURES  
(R. E. GINNA)

Enclosed is a copy of our draft evaluation of Systematic Evaluation Program  
Topic III-3.A.

You are requested to examine the facts upon which the staff has based its  
evaluation and respond either by confirming that the facts are correct, or  
by identifying errors and supplying the corrected information. We encourage  
you to supply any other material that might affect the staff's evaluation of  
these topics or be significant in the integrated assessment of your facility.

Your response is requested within 30 days of receipt of this letter. If no  
response is received within that time, we will assume that you have no comments  
or corrections.

In future correspondence regarding Systematic Evaluation Program Topics, please  
refer to the topic numbers in your cover letter.

Sincerely,

Dennis M. Crutchfield, Chief  
Operating Reactors Branch No. 5  
Division of Licensing

Enclosure:  
As stated

cc w/enclosure:  
See next page



Mr. John E. Maier

R. E. GINNA NUCLEAR  
POWER PLANT  
DOCKET NO. 50-244

cc  
Harry H. Voigt, Esquire  
LeBoeuf, Lamb, Leiby and MacRae  
1333 New Hampshire Avenue, N. W.  
Suite 1100  
Washington, D. C. 20036

Mr. Michael Slade  
12 Trailwood Circle  
Rochester, New York 14618

Rochester Committee for  
Scientific Information  
Robert E. Lee, Ph.D.  
P. O. Box 5236 River Campus  
Station  
Rochester, New York 14627

Jeffrey Cohen  
New York State Energy Office  
Swan Street Building  
Core 1, Second Floor  
Empire State Plaza  
Albany, New York 12223

Director, Technical Development  
Programs  
State of New York Energy Office  
Agency Building 2  
Empire State Plaza  
Albany, New York 12223

Rochester Public Library  
115 South Avenue  
Rochester, New York 14604

Supervisor of the Town  
of Ontario  
107 Ridge Road West  
Ontario, New York 14519

Resident Inspector  
R. E. Ginna Plant  
c/o U. S. NRC  
1503 Lake Road  
Ontario, New York 14519

Richard E. Schaffstall, Executive  
Director for SEP Owners Group  
1747 Pennsylvania Avenue, NW  
Washington, D.C. 20006

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection  
Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection  
Agency  
Region II Office  
ATTN: EIS COORDINATOR  
26 Federal Plaza  
New York, New York 10007

Herbert Grossman, Esq., Chairman  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Richard F. Cole  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Emmeth A. Luebke  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. Thomas B. Cochran  
Natural Resources Defense Council, Inc.  
1725 I Street, N. W.  
Suite 600  
Washington, D. C. 20006

Ezra I. Bialik  
Assistant Attorney General  
Environmental Protection Bureau  
New York State Department of Law  
2 World Trade Center  
New York, New York 10047

GINNA STATION  
SEP TOPIC III-3.A  
EFFECTS OF HIGH WATER LEVEL ON STRUCTURES

I. Introduction

The original design basis high water level including dynamic effects for nuclear power plants is reviewed in SEP topic II-3.A, B. Should the design basis level or dynamic effects increase from that assumed in the original design, the ability of plant structures to withstand this new loading is reviewed. The objective is to provide assurance that high water levels will not jeopardize the structural integrity of Seismic Category I structures and that seismic Category I systems and components located within these structures will be adequately protected.

II. Review Criteria

Standard Review Plan 3.4 defines analysis procedures for flood loadings and Regulatory Guide 1.102 defines acceptable flood protection.

III. Related Topics and Interfaces

1. Flood water levels and protection requirements are reviewed in SEP Topics II-3.A, B.
2. Inservice Inspection requirements for water control structures are reviewed in SEP Topic III-3.C.
3. Dam Integrity is reviewed in SEP Topic II-4.E
4. Classification of Structures which need be seismic Category I is reviewed in SEP Topic III-1.

IV. Review Guidelines

A review of the existing design basis (maximum flood level, highest ground water level...etc.) was conducted by searching the docket files and the responses received from the licensee and then comparing the design criteria with current criteria as stated in the Standard Review Plan and in the Draft Safety Evaluation Report on Topics II-3.A, B, C sent to Rochester Gas and Electric on December 12, 1980. This evaluation is contingent upon the acceptance of the Draft SER on SEP Topics II-3.A, B, C. Should that evaluation change, this Draft SER on Topic III-3.A may have to be modified accordingly.

V. Evaluation and Conclusions

1. Effect of Probable Maximum Flood

a. Current Requirements

The design basis for highest level of water during flood is 261.0 feet msl level on the northside of the plant. This position is included in the Draft Safety Evaluation for SEP Topics II-3.A, B, and C.

b. Ginna Station Design

The general plant grade is about 270 feet, with the exception of the area between Lake Ontario and the turbine building where the grade level is at elevation 253 feet. Because the plant is protected from the lake by breakwater with a top elevation of 261 feet and because of the elevation of the general plant, flooding was not considered a problem,

and the plant structures were, therefore, not designed for the dynamic effects of the flooding. Moreover, the licensee stated that the probable maximum flood considered originally in the design of Ginna was based on 250.0 feet and later (1973) revised to a level of 253.3 feet. This flood level was basically caused by Lake Ontario water. No other source of water was considered to produce water higher than this design level (253.3 feet).

c. Evaluation

Because the Draft SER on Topics II-3.A, B, C indicates that the probable maximum flood in Deer Creek could flood the site (253.3 feet msl level) to a depth of about 8.0 feet on the northside and about 4.0 feet on the southside, and because the licensee stated that the seismic Category I structures, systems and equipments were not designed for flood (the licensee only postulated flood due to Lake Ontario and not to Deer Creek), all Category I structures, systems and components should be reevaluated for this new higher level of flood. In the evaluation, the dynamic effects of waves should also be considered.

2. Effect of Ground Water on Structures

a. Current Requirements

The design basis for the highest still ground water is stated in the Draft SER on SEP Topics II-3.A, B, and C. In that evaluation, the recommended level for the highest ground water is at ground elevation. The acceptable analysis procedure for evaluating the effect of ground water is included in the SRP 3.4.2.



b. Ginna Station

Normal water loads from the highest still ground water were considered in the design of the structures. Of the safety class I structures, only the containment, auxiliary building and screen house are supported below a ground water table elevation of 250.0 feet. In the design of the screenhouse, the ground water loads were considered in the design by assuming complete internal dewatering of the facility and a groundwater elevation of 253.5 (grade) to determine lateral and uplift forces. (Ref: RGE letter to NRC - 1/28/81). The containment design provided for no backfill against the wall thus eliminating the external lateral loads. The auxiliary building was designed for lateral and uplift forces based on a groundwater elevation of 250.0.

c. Evaluation

Concerning the containment and auxiliary building, the recommended groundwater elevation is at ground level which is above Ginna design water table by about 20 feet. External lateral loads were not considered in the design of the containment because of an external ring wall around the containment; however, there is no provision to assure that groundwater loads will always be non-existent. The ring wall is not designed to be impervious and there is no requirement to maintain the water level between the ring wall and containment wall at a low level. Therefore, an evaluation of the effects of groundwater on the Containment and Auxiliary Building should be performed. The criteria used in the design of the screenhouse, namely assuming groundwater level at grade and complete internal dewatering, conforms with the recommendation in the Topic II-3.A, B, C review and is therefore acceptable.

