NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

79-008/03L-0

LICENSEE EVENT REPORT

(CAR 1218)

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	N Y R E G 1 (2)	0 0 - 0 0 0 0 0 - 0 0 (3)	4 1 1 1 1 (4)		(5)
7 8	9 LICENSEE CODE 14	15 LICENSE NUMBER 25	26 LICENSE TYPE 30	57 CAT 58	

CON'T

0 1	REPORT SOURCE L (6)	0 5 0 0 0 2 4 4 (7)	0 4 0 6 7 9 (8)	0 5 0 7 7 9 (9)
7 8	60	61 DOCKET NUMBER 68	69 EVENT DATE 74	75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During maintenance on boric acid flow control valve leak was noted on valve outlet 1"

0 3 nipple. (T.S. 6.9.2.b.(4)) Two flow paths from boric acid tanks to RCS were verified.

0 4

0 5

0 6

0 7

0 8

7 8 9 80

0 9	SYSTEM CODE P C (11)	CAUSE CODE E (12)	CAUSE SUBCODE C (13)	COMPONENT CODE P I P E X X (14)	COMP. SUBCODE A (15)	VALVE SUBCODE Z (16)
7 8	9 10	11 12	12 13	13 18	19	20

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	7 9	—	0 0 8	/	0 3	L	—	0
	21 22	23	24 26	27	28 29	30	31	32

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
C (18)	C (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	N (25)	Z 9 9 9 (26)
33	34	35	36	37 40	41	42	43	44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Internal weld flowthrough defects and deep external pitting. The 1" nipple is $3\frac{1}{2}$" long

1 1 sch 10 stainless. It is heat traced, and normal operating pressure is 100 psig. The

1 2 nipple was replaced with a sch 40 nipple. Later maintenance in this section of piping

1 3 resulted in replacement of the nipples, check valve and coupling from flow control

1 4 valve to the coupling.

7 8 9 80

1 5	FACILITY STATUS E (28)	% POWER 0 9 2 (29)	OTHER STATUS (30) NA	METHOD OF DISCOVERY A (31)	DISCOVERY DESCRIPTION (32) Noticed during maintenance on adjacent valve
7 8	9	10 12	13 44	45	46 80

1 6	ACTIVITY RELEASED Z (33)	CONTENT OF RELEASE Z (34)	AMOUNT OF ACTIVITY (35) NA	LOCATION OF RELEASE (36) NA.
7 8	9	10	11 44	45 80

1 7	PERSONNEL EXPOSURES NUMBER 0 0 0 (37)	TYPE Z (38)	DESCRIPTION (39) NA
7 8	9 11	12	13 80

1 8	PERSONNEL INJURIES NUMBER 0 0 0 (40)	DESCRIPTION (41) NA
7 8	9 11	12 80

1 9	LOSS OF OR DAMAGE TO FACILITY TYPE Z (42)	DESCRIPTION (43) NA
7 8	9 10	80

7905110104

2 0	PUBLICITY ISSUED N (44)	DESCRIPTION (45) NA	NRC USE ONLY
7 8	9 10	68	69 80

917-926

NAME OF PREPARER S. Spector PHONE: 716/546-2700, ext. 291-215