NRC FORM 366	79-021/03L-0	U. S. NUCLEAR REGULATORY COMMISSION
\$	CENSEE EVENT REPORT	(CAR 1240)
CONTROL BLOCK:	$ $ $ $ $ $ $ $ $ $ $ $ $ $ $ $ $ $	YPE ALL REQUIRED INFORMATION)
0 1 NYREG10 7 8 9 LICENSEE CODE 14 0 15	0 - 0 0 0 0 0 - 0 0 0 3 LICENSE NUMBER 25	$\begin{array}{c c c c c c c c c c c c c c c c c c c $
$ \begin{array}{c} \text{CON'T} \\ \hline 0 1 \\ 7 8 \end{array} \begin{array}{c} \text{REPORT} \\ \text{SOURCE} \\ \hline 60 \\ \hline 60 \\ \hline 61 \\ \hline 61 \\ \hline 0 \end{array} $	$\begin{array}{c c c c c c c c c c c c c c c c c c c $	9 8 1 1 1 6 7 9 9 74 75 REPORT DATE 80
	w of Plant Technical Specificatio	ns for coverage of test require-
0 3 ments it was discovere	d that Tech. Spec. requirement 4	.8.5 on stroking crossover
04 valves, issued 8/24/79), was not included in the proced	lure for testing the standby
0 5 auxiliary feedwater pum	ps (SBAFWP). Therefore the stro	oking of these valves, required
0 6 during September testin	g, was not accomplished at that	time. Nevertheless, the
0 7 SBAFWP main discharge	valves were operable. Also, pe	eriodic testing determined that
7 8 9	water system was operable at tha	80
0 9 0 10 0 10 0 10 0 10 7 8 9 10 11	$(12) \begin{array}{ c c c c c } & & & & & & \\ \hline 12 & \hline 2 & \hline 13 & \hline 2 & \hline 2 & \hline 2 & \hline 2 & \hline 13 & \hline 13 & \hline 18 &$	$ \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c}$
$\begin{array}{c c} 17 & LER/RO \\ \hline 17 & REPORT \\ NUMBER \\ \hline 21 & 22 \\ 23 \\ \hline 21 & 22 \\ 23 \\ \hline 21 & 22 \\ 23 \\ \hline 23 \\ 23 \\ \hline 23 \\ 23 \\ \hline 23 \\ 23 \\$	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	$\begin{array}{c cc} REPORT & REVISION \\ TYPE & NO, \\ 0 & L & 0 \\ 0 & 30 & 31 & 0 \\ 0 & 32 & 0 \\ 0 & 0 & 0 \\ 0 & 0 & 0 \\ 0 & 0 & 0$
CAUSE DESCRIPTION AND CORRECT	36 ³⁷ 40 41	
1 0 The SBAFWP's were per	odically tested in recirculation n	node since the time of accept-
1 ance. Due to the time	delay in issuance of Tech. Specs	s. for testing, a test procedure
	issuance of the Tech. Spec. the	
13 valve testing requireme	st with flow to the steam generate nt had been overlooked. The pro on the new requirement. Test pe	ocedure was corrected and test
14 the required tests.		
7 8 9 FACILITY STATUS * POWER (1 5 E (28) 1 0 0 (29)	NA Z (3)	BO DISCOVERY DESCRIPTION 32 NA
7 8 9 10 12 13	44 45 46	80
$\begin{bmatrix} 1 & 6 \\ 7 & 8 \end{bmatrix} \xrightarrow{1} (33) \begin{bmatrix} 2 \\ 10 \end{bmatrix} \xrightarrow{34} \begin{bmatrix} 1 \\ 11 \end{bmatrix}$	OF ACTIVITY (35) NA	LOCATION OF RELEASE (36)
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTIO	N 39 NA	
7 8 9 PERSONNEL INJURIES		, 80
7 8 0 11 12	NA	. 80
Loss of or DAMAGE TO FACILITY 43 TYPE DESCRIPTION	NA	
	NA 7911200	─────────────────────────────────────
7 8 9 10 NAME OF PREPARER	Dennis R. Gent	68 69 80 5 PHONE: <u>716/546-2700,ext.291-2</u> 16

¢

,

.