NRC FORM 366 (7-77)

80-002/03L-0

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT (CAR 1259)

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE: N Y R E G 1 (2)	LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3)	LICENSE TYPE: 4 1 1 1 1 (4)	CAT (5)	
CON'T 0 1	REPORT SOURCE: L (6)	DOCKET NUMBER: 0 5 0 0 0 2 4 4 (7)	EVENT DATE: 0 3 3 1 8 0 (8)	REPORT DATE: 0 4 1 4 8 0 (9)	

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During review of SI accumulator sample results it was noted that time from previous
0 3 sample exceeded 75 days. (T.S. 4.1-2) Boron concentration was within concentration
0 4 specification for both accumulators at both sample times, and they were capable of
0 5 performing their intended function.
0 6
0 7
0 8

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	S F (11)	D (12)	Z (13)	A C C U M U (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 0	—	0 0 2	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
G (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	N (25)	W 1 2 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Procedure for SI accumulator sample did not provide adequate guidance for bimonthly
1 1 sampling schedule. Plant analysis schedule has been changed to require monthly
1 2 samples.
1 3
1 4

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	D (28)	0 0 0 (29)	NA	B (31)	Staff review

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	NA

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	NA	

NAME OF PREPARER Duane Filkins PHONE: 315-524-4446

8004180471

GPO 917-926