

THIS DRAWING SUPERSEDES WESTINGHOUSE DRAWING 4998425 SH.254 REV 5

VALVE NO. B/M NO.	FIG. /SH	SW DEV.	OPER. MODE	CS/LGT LOCATION	INTERLOCKS	REFERENCE AND	DRAWING REMARKS
3503 TAFSV-1A RN21A	322	6/329	C/FAI	CB		SH. 317 TURB. DRY. STM. GEN. F.W. PUMP ADM. VALVE 1A	
3504 TAFSV-1B RN21B	322	6/329	C/FAI	CB		SH. 317 TURB. DRY. STM. GEN. F.W. PUMP ADM. VALVE 1B	
3996 TAFDV	293	C/12	C/FAI	CB		SH. 317 TURB. DRY. STM. GEN. F.W. PUMP DISCH. VALVE (WATER)	
3150 CWDV-1A	294	9/12	O/FAI	PB LOCAL 1/CWP 1A CB	SEE SH. 294	SH. 31 & 31G CIRC. WTR. PUMP DISCH. VALVE 1A	
3151 CWDV-1B	294	9/12	O/FAI	PB LOCAL 1/CWP -1B CB	SEE SH. 294	SH. 31 & 31G CIRC. WTR. PUMP DISCH. VALVE 1B	
5171 FSIV RNG3	292	9/12	O/FAI	CONT. RM FIRE CONT PANEL			

	CONSTRUCTION	
	LIMITED CONSTRUCTION: AS NOTED	
	PRELIMINARY NOT FOR CONSTRUCTION	
	BIDDING PURPOSES	
SEP 21 '81	FOR INFORMATION ONLY	pcr
DATE	RELEASED FOR	ENGR.

OPER. MODE
 O-NORMALLY OPER. OPEN
 C-NORMALLY OPER. CLOSED
 X-NORMALLY OPER. OPEN & CLOSED
 FC: FAILED CLOSED
 FO: FAILED OPEN
 FAI: FAILED AS IS

CONTROL SWITCH AND/OR POS. LGT. LOCATION:
 L-LOCAL
 CB-CONTROL BOARD
 SR-SAMPLE ROOM
 AP-AUXILIARY PANEL
 WP-WASTE DISPOSAL PANEL

TERA
APERTURE
CARD

REV.	△	AWH	8-5-76	8-10-76	9-2-76	9/10/76
ORIGINAL		D.H.	8-5-76	8-10-76	9-2-76	9/10/76
DRAWN BY		AWH	8-5-76	8-10-76	9-2-76	9/10/76
CHKD		BWD	8-5-76	8-10-76	9-2-76	9/10/76
RECD. ENGR'S		RPA	8-10-76	9-2-76	9-2-76	9/10/76
DATE						

ROCHESTER GAS & ELECTRIC CORP. ROCHESTER, NEW YORK	ROBERT EMMETT GINNA NUCLEAR POWER STATION UNIT NO. 1	DRAWN BY D.H.	DATE 10-75	SCALE
ENGR	ELEM. WIRING DIAGRAM	TRACED	CHECKED	APPROVED
NO. 10905-254 △	MOTOR OPERATED VALVES	ENG.		DECKET # 50-244
				Control # B109240350- Date 9-22-81 of Document REGULATORY DOCKET FILE

C
5