STANDBY AUX. F.W. PUMP C or D TRIP | SPARE | AUX. F.W. BYPASS SWITCH IN DEFEAT LOCKOUT 1A1/1B1 | COND. SYSTEM LOW PRESS. DROP | RCS OVERPRESS. ARM/INHIBIT LOOP A SELECT | N_2 ACCUMALATOR V801A LO PRESS.

LAP

LAP

CONTINUED ON DWG 10905-350

ISOLATING RELAY 516IR, 515IR

(DWG. B-281-122)

3 4 74 MCB

3 4 74 MCB

(DWG. B-281-123)

LO MFPX2 1A1 (1, 2)

LOCATED M.C.B.

LO MFPX2 1B1 (1, 2)

63X/CO PS-4026 COND. BOOSTER PUMPS RELAY PNL. AVC-5 (4, 5)

(DWG. B-281-217)

HIS 450 1/* HIS 453 1/*

HIS 450 1/* HIS 453 1/*

TC-409A-X RA-1

TC-409B-X RA-1

CONTACT #4

254 PC-455-X "RW-1" 253

TDL

TB2-13

TBI-5 (TR-5)

TBI-13 (TS-1)

TB2-5 (TU-5)

1-TV-1

TBI-6 TR-6

TBI-14 TS-2

THIS DWG. SUPERSEDES G.A.I. DWG. B-281-081 REV. 2

	CONSTRUCTION	
	LIMITED CONSTRUCTION: AS NOTED	
	PRELIMINARY NOT FOR CONSTRUCTION	
	BIDDING PURPOSES	
SEP 21 '81	FOR INFORMATION ONLY	
DATE	RELEASED FOR	ENGR.

NOTES:
1. LAST WIRE MARK USED: 1- (WIRE MARKS HAVE DRAWING SHT. NO. "081" SUFFIX)
2. -4- FIELD INSTALLED WIRE

ELEMENTARY WIRING DIAGRAM
ANNUNCIATOR PANEL 4A

ROCHESTER GAS & ELECTRIC CORP.
ROCHESTER, NEW YORK

FACILITY GINNA STA.
SCALE NONE
JOB NO.
DRAWING NO. 10905-349
REV. △

NUMBER	REVISION	INITIAL	DATE	DRAWN BY	CHECKED	RESP. ENG.	ENG. MANG'R.
○	ORIGINAL EWR 2499	AV	9/24/79		9/24/79	9/27/79	11/5/79
△							

H.H.S. 19 1153e

TERA APERTURE CARD

REGULATORY DOCKET FILE COPY

Docket # 50-244
Control # 8109290350
Date 9-22-81 of Document:
REGULATORY DOCKET FILE

-11C