

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8703260576 DOC. DATE: 87/03/18 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 KOBER, R. W. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 LEAR, G. E. Division of Boiling Water Reactor (BWR) Licensing

SUBJECT: Informs that modified emergency operating procedures containing reactor vessel level indication sys cannot be fully implemented in Mar 1987, per B70807 requirement. Implementation will be completed by Jul 1987.

DISTRIBUTION CODE: A002D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: DR Submittal: Inadequate Core Cooling (Item II.F.2) GL 82-28

NOTES: License Exp date in accordance with 10CFR2, 2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PWR-A PD1 LA	1	NRR SHEA, J	2 2
	PWR-A PD1 PD	1	STAHLE, C	2 2
	PWR-A RSB	1		
INTERNAL:	ADM/LFMB	1 0	NRR BWR DIR	1 1
	NRR BWR PD1	1 1	NRR PWR-A DIR	1 1
	NRR PWR-B DIR	1 1	NRR/DSRO EMRIT	1 1
	NRR/DSRO/RSIB	1 1	REG FILE 01.	1 1
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 17




1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is crucial for ensuring the integrity of the financial system and for providing a clear audit trail.

2. The second part of the document outlines the specific procedures that must be followed when recording transactions. It details the steps from initial identification of a transaction to its final entry into the accounting system, highlighting the need for consistency and precision.

3. The third part of the document addresses the challenges associated with maintaining accurate records, such as the risk of human error and the complexity of certain transactions. It offers practical solutions and best practices to minimize these risks and ensure the highest level of accuracy.

4. The final part of the document concludes by reiterating the overall importance of accurate record-keeping and the role of each individual in the organization. It encourages a culture of transparency and accountability, where every transaction is treated with the same level of care and attention.



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

ROGER W. KOBER
VICE PRESIDENT
ELECTRIC PRODUCTION

TELEPHONE
AREA CODE 716 546-2700

March 18, 1987

U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Mr. George E. Lear, Chief
PWR Project Directorate No. 1
Washington, D.C. 20555

Subject: Inadequate Core Cooling Instrumentation Implementation
Schedule Revision - NUREG-0737, Item II.F.2
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Reference: 1. RG&E Letter from R.W. Kober to Attention of W.A.
Paulson, NRR, Dated August 7, 1984
2. RG&E Letter from R.W. Kober to Attention of G.W.
Lear, NRR, Dated December 22, 1986

Dear Mr. Lear:

Reference 1 provided a schedule for implementation of the Reactor Vessel Level Indication System (RVLIS) at R.E. Ginna. The schedule called for installation of RVLIS by the end of the 1986 refueling outage and implementation of modified procedures one year later with intermediate milestones between installation and implementation.

The RVLIS, as described in Reference 2, was installed in March 1986. The RVLIS is available for operator use and is noted in emergency procedures. In addition, following functional testing and calibration, preliminary setpoints were generated to provide more detailed guidance in the Emergency Operating Procedures (EOPs). During the implementation process it became apparent that the original RVLIS estimated worst case uncertainties were larger than was judged acceptable for use in detection and mitigation of degraded core cooling. Therefore, the RVLIS algorithms have been modified, major sources of channel uncertainty have been determined, and an evaluation is in progress to reduce the channel uncertainties. The objective is to improve the RVLIS accuracy so that RVLIS can better aid in the detection and mitigation of inadequate core cooling.

8703260576 870318
PDR ADCK 05000244
F PDR

*Acc 2
AD 4/6
1/0*



1
2
3
4
5

1
2
3
4
5
6
7
8
9
10

1
2
3
4
5
6
7
8
9
10

1

1

1

1

1
2
3
4
5
6
7
8
9
10

1
2
3
4
5
6
7
8
9
10

1


1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20

The dominant source of channel uncertainty has been determined to be associated with the reactor vessel differential pressure transmitter. A detailed evaluation of transmitter errors from qualification tests and how they are applied to the RVLIS is in progress. Preliminary results indicate that the estimated RVLIS accuracy during adverse containment conditions can be improved. However, since this evaluation has not been completed, the modified EOPs containing RVLIS cannot be fully implemented in March 1987 as required by Reference 1. If the final evaluation yields acceptable results, draft EOPs containing the RVLIS setpoints will be implemented by mid June 1987 for operator training and validation and verification. Final approved EOPs will be implemented by the end of July 1987.

Currently, the RVLIS is operating and is available to the operators as additional guidance in responding to transient events. Our current EOPs note that it may be used for indication but do not require that any specific action be taken based on RVLIS. Other indicators, including core exit thermocouple temperatures, are used to assure an appropriate response to emergency conditions based on a validated non-RVLIS version of EOPs derived from the Westinghouse Owners Group Emergency Response Guidelines. Prior to revising the EOPs from the current version to include actions based on RVLIS, it is important to assure that the modified actions will improve upon the emergency response.

If the final evaluation indicates that hardware modifications are required, we will notify you by mid June 1987 and propose an implementation schedule. If hardware modifications are required, the earliest possible time for these modifications will be the spring 1988 refueling.

Very truly yours,

A handwritten signature in cursive script that reads "Roger W. Kober". The signature is written in black ink and includes a long horizontal flourish at the end.

Roger W. Kober