ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9008300144 DOC.DATE: 90/08/23 NOTARIZED: NO DOCKET #
FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
AUTH.NAME AUTHOR AFFILIATION
MECREDY,R.C. Rochester Gas & Electric Corp.
RECIP.NAME RECIPIENT AFFILIATION
MARTIN,T.T. Region 1 (Post 820201)

SUBJECT: Special rept:on 900717,fire suppression sys inoperable for more than 7 days w/redundant component.

DISTRIBUTION CODE: IE22D COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 2
TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL
	PD1-3 LA	1	1	PD1-3 PD	1	1
	JOHNSON,A	1	1			
INTERNAL:	ACNW	2	2	AEOD/DOA	1	1
	AEOD/DSP/TPAB	1	1	AEOD/ROAB/DSP	2	2
	NRR/DET/ECMB 9H	1	1	NRR/DET/EMEB9H3	1	1
	NRR/DLPQ/LHFB11	1	1	NRR/DLPQ/LPEB10	1	1
	NRR/DOEA/OEAB11	1	1	NRR/DREP/PRPB11	2	2
	NRR/DST/SELB 8D	1	1	NRR/DST/SICB 7E	1	1
	NRR/DST/SPLB8D1	1	1	NRR/DST/SRXB 8E	1	1
	REG FILE 02	1	0	RES/DSIR/EIB	1	1
	RGN1 FILE 01	1	1			
EXTERNAL:	EG&G BRYCE,J.H	3	3	L ST LOBBY WARD	1	1
	LPDR	1	1	NRC PDR	1	1
	NSIC MAYS,G	1	1	NSIC MURPHY,G.A	1	1
	NUDOCS FULL TXT	1	1			

Cont NO
P24919417O

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 32 ENCL ~~32~~ 0

FA-2
wb

RIDS/ADDS

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

TELEPHONE
AREA CODE 716 546-2700

August 23, 1990

Mr. Thomas T. Martin
Regional Administrator
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Subject: Thirty (30) Day Special Report
Fire Suppression System With An Inoperable Redundant Component
R.E. Ginna Nuclear Power Plant
Docket Number 50-244

Dear Mr. Martin:

In accordance with R.E. Ginna Nuclear Power Plant Technical Specifications 3.14.2.1a, this Thirty Day Special Report regarding an inoperable redundant fire system component (diesel fire pump) in excess of the seven day Limiting Condition for Operation (LCO) is hereby submitted.

On Tuesday, July 17, 1990, procedure EM-38, "Diesel Fire Pump Battery Charging and Surveillance", a weekly maintenance inspection activity implemented pending a defective battery charger replacement, revealed that the specific gravity of one of the "B" bank batteries was below acceptance limits. Operations was notified and procedure A-52.4.1, "Control of Limiting Conditions for Operations of Fire Suppression and Detection Equipment" was initiated at 0910 starting the seven day LCO.

Replacement batteries for the diesel fire pump had been ordered previously and were received during the seven day LCO period. Two of the batteries failed receipt inspection and were returned to the vendor for exchange. Replacement of the defective "B" batteries was delayed pending receipt of batteries for both banks to permit a single battery changeout and a single operability test after the battery exchange.

9008300144 900823
PDR ADOCK 05000244
S PDC

Cert No P249194170
IE22
1/0

At 0910 Tuesday, July 24, 1990, the seven day LCO ended. This required starting of the motor driven fire pump and running it continuously until the diesel fire pump was determined operable and returned to service. The diesel fire pump batteries were replaced and the unit tested in accordance with procedure PT-13.3, "Fire Pump Operation and System Alignment". The diesel fire pump was determined operable at 1313 on July 24, 1990.

Very truly yours,

Robert C. Mecredy
Vice-President
Ginna Nuclear Production

xc: U.S. Nuclear Regulatory Commission
Document Control Desk (Original)
Washington, D.C. 20555

NRC Senior Resident Inspector - Ginna Station