

Enhancements from NRC PREP week on JPM's and Simulator scenarios

1. NRC scenario 1
 - a. Changed initial conditions from 100% to 97% power
 - b. Added cue to event #1 to move to event #2 as directed by lead evaluator
 - c. Added EO roleplays for CRD pump in event #3
2. NRC scenario 2
 - a. Changed RBCCW pump from #2 to #1 in event #1
 - b. Updated which valves closed and didn't close report in event #2
 - c. Removed "places off-gas selector switch to isolate and bypass in event #5
 - d. Indicated which trigger number is assigned to event #6
 - e. Added action to "drive cram array first then normal pattern" in event #7/8
 - f. Added arrows to indicate actions of the critical task in event #7/8
 - g. Changed desired band from -20 to 20 to -20" to 30" in event #7/8
 - h. Fixed font on shift turnover page
3. NRC scenario 3
 - a. Reassigned trigger numbers to events #2,3,4.
 - b. Enhanced Cue of EMRV tailpipe temps in event #2
 - c. Removed action to refer to T.S 3.5.A.3
 - d. Added Booth action to re-initiate EMRV leak if switch was placed back in Auto in event #2
 - e. Removed reference to T.S. 3.4.B in SRO actions in event #2
 - f. Added step to perform SP-10 in event #6/7
 - g. Added words "And/Or" between SP-58 and SP-60 in event #8
4. NRC scenario 4
 - a. Swapped Event #4 and event #5 in the scenario
 - b. Changed BACP-1 to VACP-1 in actions in event #4
 - c. Changed trigger number in event #8
5. NRC control Room JPM 1
 - a. Added cue in step 7
6. NRC Control Room JPM 2
 - a. Added cue in step 4
 - b. Added reference to procedure 303
 - c. Added setup instructions to have copy of 303 pre-printed
7. NRC Control Room JPM 3
 - a. Removed step 12 and added cue to end JPM on step 11
 - b. Removed wording "and differential temperature <80F" from terminating cue

8. NRC Control Room JPM 4
 - a. Added cue for stop watch number on step 4
 - b. Update procedure step numbers on steps 8-16
 - c. Added cue for status of relays and SOE on step 16
 - d. Added cues on steps on step 19 and 20
9. NRC Admin JPM 4 (RO)
 - a. Removed duplicate word "hijacked" in initial conditions
 - b. Removed cue to provide candidate to obtains in binder in step 4
10. NRC Admin JPM 5
 - a. Provided larger RPS prints to applicant
11. NRC Admin JPM 1 SRO
 - a. Reworded Task Cue to perform uncompleted items in step 78 of the 201-2
 - b. Updated Step 78 of the 201-2 for pre supplied procedures
 - c. Added prepared copy of 201-6 for students
 - d. Changed SRM 22 reading on 201-2 to 1
12. NRC admin JPM 2 SRO
 - a. Added bypass APRM 5 to first bullet in step 8 on attachment 1 of MA-AA-716-004
 - b. Added words "and does not approve" to step 2 and made step 2 critical
13. NRC admin JPM 4 SRO
 - a. Developed prepared copies of EP-AA-113-F02 for students
14. NRC Admin JPM 5 SRO
 - a. Swapped whole JPM out. New JPM involves EAL classification after simulator scenario