

# FORD 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9201070038      DOC. DATE: 91/12/27      NOTARIZED: NO      DOCKET #  
FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G      05000244  
AUTH. NAME      AUTHOR AFFILIATION  
DURR, J.P.      Region 1 (Post 820201)  
RECIP. NAME      RECIPIENT AFFILIATION  
MERCREDY, R.C.      Rochester Gas & Electric Corp.

SUBJECT: Ack receipt of 911023 ltr re insp rept 50-244/91-13. Confirms licensee statement that studs subj to VT, MT & UT as required by licensee ISI/MSIP program. In future, licensing engineer will attend each exit meeting.

DISTRIBUTION CODE: IE01D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 3+1      F  
TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response      I

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72).      05000244      I

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
	PD1-3 PD	1 1	JOHNSON, A	1 1	E
INTERNAL:	AEOD	1 1	AEOD/DEIIB	1 1	C
	AEOD/DSP/TPAB	1 1	DEDRO	1 1	
	NRR HARBUCK, C.	1 1	NRR MORISSEAU, D	1 1	E
	NRR/DLPQ/LHFBPT	1 1	NRR/DLPQ/LPEB10	1 1	
	NRR/DOEA/OEAB	1 1	NRR/DREP/PEPB9H	1 1	I
	NRR/DST/DIR 8E2	1 1	NRR/PMAS/ILRB12	1 1	
	NUDOCS-ABSTRACT	1 1	OE DIR	1 1	
	OGC/HDS1	1 1	REG FILE 02	1 1	J
	RGN1 FILE 01	1 1			
EXTERNAL:	EG&G/BRYCE, J.H.	1 1	NRC PDR	1 1	I
	NSIC	1 1			C

TOTAL NUMBER OF COPIES REQUIRED: LTTR 22 ENCL 22

DEC 27 1991

Docket No. 50-244

Rochester Gas and Electric Corporation  
ATTN: Dr. Robert C. Mecredy  
Vice President  
Ginna Nuclear Production  
89 East Avenue  
Rochester, New York 14649

Dear Mr. Mecredy:

Subject: Inspection of "A" Steam Generator Manway Studs; Inspection Report  
50-244/91-13, dated July 30, 1991

We have reviewed your letter dated October 23, 1991, in regard to the inspection of the steam generator manway studs prior to their installation. On the basis of a materials engineering inspection report, dated 4/18/91, furnished by Mr. Paul J. Gorski, RG&E Mechanical Maintenance Manager, we have confirmed your statement that the studs were subject to VT, MT and UT as required by your ISI/MISIP program.

Additionally, Mr. G. Wrobel, RG&E Licensing Engineer, indicated to Mr. H. Kaplan (NRC) during a telephone call that, in the future, a licensing engineer will attend each exit meeting to assure that the appropriate disciplines are represented to provide accurate information regarding test data.

Thank you for your cooperation in this matter.

Sincerely,

Jacque P. Durr  
Jacque P. Durr

Jacque P. Durr, Chief  
Engineering Branch  
Division of Reactor Safety

9201070038 911227  
PDR ADOCK 05000244  
Q PDR

IE:01

DEC 27 1991

2

Rochester Gas and  
Electric Company

cc:

R. Smith, Senior Vice President, Production and Engineering  
Central Records (4 copies)  
Director, Power Division  
State of New York, Department of Law  
Ginna Service List  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
State of New York, SLO Designee

bcc:

Region I Docket Room (with concurrences)  
DRS SALP Coordinator  
J. Linville, DRP  
W. Lazarus, DRP  
W. Butler, NRR  
R. Lobel, EDO

RI:DRS  
Carrasco  
*[Signature]*  
11/27/91

RI:DRS  
Kaplan  
*[Signature]*  
11/27/91

RI:DRS  
Gray  
*[Signature]*  
12/3  
11/19/91

*[Signature]*  
RI:DRS  
Durr  
12/27/91

OFFICIAL RECORD COPY  
C:GINNA.HK



R. E. GINNA SERVICE LIST

Resident Inspector  
R. E. Ginna Plant  
U.S. Nuclear Regulatory Commission  
1503 Lake Road  
Ontario, New York 14519

Ms. Donna Ross  
Division of Policy Analysis &  
Planning  
New York State Energy Office  
Agency Building 2  
Empire State Plaza  
Albany, New York 12223

Nicholas S. Reynolds  
Winston & Strawn  
1400 L. Street, N.W.  
Washington, D.C. 20005-3502

Charlie Donaldson, Esq.  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, New York 10271

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406