



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

October 6, 1992

Docket No. 50-244

LICENSEE: Rochester Gas and Electric Corporation

FACILITY: R. E. Ginna Nuclear Power Plant

SUBJECT: SUMMARY OF MEETING WITH ROCHESTER GAS AND ELECTRIC CORPORATION
ON STEAM GENERATOR REPLACEMENT, SEPTEMBER 16, 1992
(TAC NO. M84004)

Rochester Gas and Electric Corporation (RG&E), in a Nuclear Regulatory Commission (NRC) meeting on September 16, 1992, at NRC Headquarters, presented their current plans for steam generator (SG) replacement at the Ginna plant. RG&E made the decision to continue nuclear power generation with the Ginna plant in mid June 1992, when filing a report with the New York State Public Service Commission. RG&E has been actively exploring procurement options since early July 1992, and determining costs and risks since early August 1992. RG&E's decisions to date are a result of their Integrated Resource Plan (IRP), which includes a conservative 15-year plan to the expiration of the Ginna operating license in September 2009. A copy of the meeting agenda and discussion material is included in Enclosure 2. Enclosure 1 is a list of meeting attendees.

RG&E's final decision however, to procure new SGs is targeted for sometime before the end of December 1992 (two bidders, Westinghouse and Babcock and Wilcox). RG&E's schedule would then include SG fabrication from January 1993 to January 1996, preliminary engineering and preparation for plant design/installation from January to June 1993, detail design engineering from July 1993 to January 1995, pre-outage modifications from March 1995 to February 1996, and SG installation from March to June 1996.

The major issue presented by RG&E in the September 16th meeting was SG replacement by new SGs, including SG transport, containment integrity, SG drop potential, effects on UFSAR/Technical Specifications, ALARA, and acceptance testing/examinations. RG&E also discussed the status of their existing Westinghouse Series 44 (Inconel 600) SGs.

RG&E discussed their evaluation of two potential options for SG replacement: (1) one-piece (full SG assembly) through the containment dome, and (2) two piece (steam drum separated from the "U" tube bundle) through the equipment hatch. Options applicable to other plants were not applicable for the Ginna plant. RG&E's current preference is one-piece SG replacement through the containment dome opening directly over each of two existing SG locations. RG&E's preference is based on minimizing containment handling and movement, shorter outage schedule (74 vs 84 days), less expensive, less radiation exposure (300 man-rem vs 400 man-rem), and installation of a full shop assembly. The removal and replacement would be accomplished using a large mobile crane. RG&E went on to discuss the potential containment roof construction openings, SG rigging and liner plate reinstallation weld details.

9210160107 921006
PDR ADOCK 05000244
P PDR

NRG FILE CENTER COPY

MEMO
11



12-9582

October 6, 1992

RG&E also discussed using principally a 10 CFR 50.59 review process (facility changes, tests and experiments conducted without prior Commission approval). RG&E discussed using a licensing approach where necessary, i.e., a license amendment per 10 CFR 50.90 and 50.91, to deal with essential Technical Specification changes, and appropriate NRC inspection/review of safety evaluations and responses to NRC questions.

Original signed by
Allen R. Johnson, Project Manager
Project Directorate I-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. List of Attendees
2. Meeting Agenda and Discussion Material

cc w/enclosures:
See next page

DISTRIBUTION w/Enclosures:

Docket File	A. Thadani	V. McCree
NRC & Local PDRs	J. Calvo	J. Durr, RI
PDI-3 Reading	G. Lainas	W. Hodges, RI
T. Murley	A. Johnson	J. Linville
F. Miraglia	T. Clark	R. Cooper, RI
J. Partlow	OGC	J. Strosnider
W. Russell	E. Jordan	R. Jones
S. Varga	G. Holahan	
J. Richardson	ACRS(10)	

DISTRIBUTION w/o Enclosures:

B. Liaw	G. Bagchi	F. Orr	E. Akstulewicz
R. Rothman	C. Tan	J. Cunningham	J. O'Brien
W. Butler	G. Johnson	T. Essig	K. Desai
E. Murphy	J. Guttmann	J. Lee	G. Hornseth
J. Caruso	H. Abelson	J. Craig	W. Lazarus, RI
T. Moslak, SRI			

OFFICE	LA: PDI-3	PM: PDI-3	PD: PDI-3		
NAME	T. Clark	A. Johnson	W. Butler		
DATE	10/06/92	10/06/92	10/6/92	/ /	/ /

OFFICIAL RECORD COPY
Document Name: MTGSUM.GI



11

.

.

.

.

.

.

11

11

11

.

.

11

11


11

11

.

October 6, 1992


RG&E also discussed using principally a 10 CFR 50.59 review process (facility changes, tests and experiments conducted without prior Commission approval). RG&E discussed using a licensing approach where necessary, i.e., a license amendment per 10 CFR 50.90 and 50.91, to deal with essential Technical Specification changes, and appropriate NRC inspection/review of safety evaluations and responses to NRC questions.


Allen R. Johnson, Project Manager
Project Directorate I-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. List of Attendees
2. Meeting Agenda and
Discussion Material

cc w/enclosures:
See next page



Dr. Robert C. Mecredy

R.E. Ginna Nuclear Power Plant

cc:

Thomas A. Moslak, Senior Resident Inspector
R.E. Ginna Plant
U.S. Nuclear Regulatory Commission
1503 Lake Road
Ontario, New York 14519

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Ms. Donna Ross
Division of Policy Analysis & Planning
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Charlie Donaldson, Esq.
Assistant Attorney General
New York Department of Law
120 Broadway
New York, New York 10271

Nicholas S. Reynolds
Winston & Strawn
1400 L St. N.W.
Washington, DC 20005-3502

Ms. Thelma Wideman
Director, Wayne County Emergency
Management Office
Wayne County Emergency Operations Center
7370 Route 31
Lyons, New York 14489

Ms. Mary Louise Meisenzahl
Administrator, Monroe County
Office of Emergency Preparedness
111 West Fall Road, Room 11
Rochester, New York 14620



11
12
13

14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100


101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

September 16, 1992

GINNA -- S.G. Replacement Meeting

List of Meeting Attendees

<u>Name/Title</u>	<u>Organization</u>	<u>Phone No.</u>
Al Johnson Project Manager	NRR/DRP/PD I-3	301-504-1497
Bob Mecredy, Vice President R. E. Ginna Nuclear Production	RG&E	716-724-8069
John F. Smith, Director S/G Replacement	RG&E	716-724-8863
George Wrobel, Manager Nuclear Safety & Licensing	RG&E	716-724-8070
Brian Flynn Engineer	RG&E	716-546-2700 Ext. 4805
Bill Papproth Bechtel Project Manager	Bechtel	301-417-5662
Steve Routh Project Engineer	Bechtel	301-417-5945
Lynn Connor	STS	301-652-2500
Geoff Hornseth Materials Engineer	NRR/DET/EMCB	301-504-2756
William Lazarus Section Chief	NRC-RI	215-337-5231
Tom Moslak SRI-Ginna	NRC-RI	315-524-6935
Kulin D. Desai	NRR/DST/SRXB	301-504-2835
Jim O'Brien	NRR/ADAR/PDLR	301-504-1134
Goutam Bagchi	NRR/DET/ESGB	301-504-2733
R. Rothman Section Chief	NRR/DET/ESGB	301-504-3306
Chen P. Tan	NRR/DET/ESGB	301-504-3315



**GINNA STATION
STEAM GENERATOR REPLACEMENT
NRC PRESENTATION**

SEPTEMBER 16, 1992


WASHINGTON, D.C.

**ROBERT C. MECREDDY
GEORGE J. WROBEL
JOHN F. SMITH**

2

AGENDA

- INTRODUCTION WROBEL
- STATUS OF EXISTING STEAM GENERATORS SMITH
- REPLACEMENT STATUS SMITH
- OVERVIEW OF DECISION MAKING PROCESS MECREDY
- EVALUATION OF REPLACEMENT METHODS SMITH
- LICENSING CONSIDERATIONS WROBEL
- SCHEDULE SMITH
- OPEN DISCUSSION ALL



.

..

..

..


.

.

.

INTRODUCTION

- **INFORMATIONAL MEETING**
- **DISCUSS CURRENT PLANS FOR S/G REPLACEMENT**
- **NO FORMAL ACTION REQUIRED BY NRC AT THIS TIME**
- **REPLACEMENT DECISION NOT YET MADE**



STATUS OF EXISTING SERIES 44 STEAM GENERATORS


- REPAIR STATUS
- 1992 DEFECTS
- PRESSURE LOSS
- TUBE SUPPORT PLATE DEFECTS
- DEFECT PROJECTIONS



254


REPAIR STATUS

	S/G-A	S/G-B
UNREPAIRED TUBES	2520 (77.3%)	1813 (55.6%)
PLUGGED TUBES	185 (5.7%)	313 (9.6%)
SLEEVED TUBES	555 (17.0%)	1134 (34.8%)
	3260 (100%)	3260 (100%)




1992 DEFECTS

DEFECT TYPE	S/G-A	S/G-B
ROLL TRANSITION	189	63
CREVICE	34	118
OTHER	<u>3</u>	<u>5</u>
TOTAL	226	186



GINNA STATION SG PRESSURE HISTORY




SG PRESSURE — PLG'Ds — EQ PLG'D

▼ REFUELING

3/91

RGE



04

.

1

2

.

.

2

2

2

2

TUBE SUPPORT PLATE DEFECTS


- NO TSP DEFECTS FOUND TO DATE

- INSPECTION PROGRAM INCLUDES:
 - 20% FULL LENGTH BOBBIN COIL


 - SELECTED MRPC INSPECTION OF TSP NO. 1 AND NO. 6

- SIGNIFICANT TSP DEFECTS
 - REDUCED OUTPUT

 - EARLY RETIREMENT




STEAM GENERATOR TUBESHEET DEFECTS




JANUARY 18, 1991

FIGURE 9




STEAM GENERATOR TSP DEFECTS



JANUARY 18, 1991

FIGURE 10



.

.

.

.

.

.

.

.

./ . .

.

.

REPLACEMENT STATUS

- MEMBER OF STEAM GENERATOR REPLACEMENT GROUP
- BIDS RECEIVED IN JANUARY 1992
- SHORT LIST OF BIDDERS
- NEGOTIATING WITH B&W AND WESTINGHOUSE
- CURRENTLY NOT PLANNING TO UPRATE
- PLAN TO ADD ADDITIONAL SURFACE AREA
- REPLACEMENT DECISION BY 1/1/93



Small, faint, illegible marks or characters in the top right corner.

2 4

62

OVERVIEW OF DECISION MAKING PROCESS

- INTEGRATED RESOURCE PLAN
- RGE DECISION MAKING PROCESS
- COMPETITION FROM NUG'S AND IPP'S



11



14-D-1
504-1497

Post-it™ brand fax transmittal memo 7671		# of pages	11
To	W Johnson	From	Nedie
Co.	NRC	Co.	Roch Gas & Elec
Dept.		Phone	160 724 8070
Fax #	301 534 2210	Fax #	8405

INTEGRATED RESOURCE PLAN

Background

- electric generation planning
- long-range DSM plan
- October 1991 PSC letter
- 15 year planning period



2
4

4

.

.

.



INTEGRATED RESOURCE PLAN


Business Decisions

- long-range DSM plan
- industrial customer retention
- clean air act compliance
- Ginna steam generator replacement




Vertical text or markings along the left edge of the page, possibly bleed-through from the reverse side.

Small, faint markings or text at the bottom left corner of the page.



1991 PLAN SUMMER LOAD & CAPACITY Existing & Expected Resources



System	Hydro	Nuclear	Coal	Gas	Oil
Gilboa	Station 5	Genoa	Russell 1	Beebe 13	Oswego 6
Green Mountain	Station 2	Nine Mile	Russell 2	Station 9	
Hydro Quebec	Station 26	Fitzpatrick	Russell 3	Allegheny Cogan	
	Miscellaneous		Russell 4		
	Niagara		Beebe 12		

3/9/92/SUM-LOAD/owo



100

100

100

INTEGRATED RESOURCE PLAN

Existing Plant Options

Beebe
1-2

low S coal

scrubbers

repower

retire

Russell
1-2

low S coal

scrubbers

repower

retire

Russe
3-4

low S coal

scrubbers

repower

retire

Ginna
1

operate

replace SC


retire




7 4 25

GINNA IIRP INPUT

Non-Fuel Production Expense




* charges to Ginna production accounts




GINNA IRP INPUT

Annual Capital Expenditures



= does not include S.G. replacement



REF

INTEGRATED RESOURCE PLAN

Alternatives

- new coal-fired generation
- new gas-fired generation
- cogeneration technologies
- increased demand side management
- long-term capacity contracts



23

REF

INTEGRATED RESOURCE PLAN

Business Climate

- n industry regulation
- n limited growth opportunities
- n environmental concerns
- n technological changes



24


1950



INTEGRATED RESOURCE PLAN

Proposed IRP

<u>Ginna</u>	<u>DSM</u>	<u>Russell 1-2</u>	<u>Russell 3-4</u>
continue operation	base 140 Mw	low sulfur coal 2000	low sulfur coal 2000
and		or	
decide		natural gas	
steam gen		or	
replace		retire	





INTEGRATED RESOURCE PLAN

Proposed IRP

<u>Beebe 1</u>	<u>contract</u>	<u>cogeneration</u>	<u>new gas</u>
retire by 2000	no new	up to 186 Mw	80 CT 2000
but retain site			or 80 CT 2007



4

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

INTEGRATED RESOURCE PLAN

Action Items - Ginna Steam Generators

- | | | |
|-------------------------------|----------|---|
| • explore procurement options | 07/01/92 | ✓ |
| • determine costs and risks | 08/01/92 | ✓ |
| • replacement decision | 12/31/92 | ✓ |




2

148

EVALUATION OF REPLACEMENT METHODS

- **POTENTIAL OPTIONS**
- **TWO-PIECE**
- **ONE-PIECE**
- **CURRENT PREFERENCE**



3

4

5

6

7

8

9

10

11

12

POTENTIAL OPTIONS

- ONE-PIECE THRU CONTAINMENT ROOF
- TWO-PIECE THRU EQUIPMENT HATCH
- ONE-PIECE THRU EQUIPMENT HATCH
- ONE-PIECE THRU CONTAINMENT WALL
- TWO-PIECE THRU CONTAINMENT WALL
- LAST THREE OPTIONS NOT FEASIBLE FOR GINNA
- OPTIONS ONE AND TWO FEASIBLE FOR GINNA





Figure 4.3.1
TWO-PIECE STEAM GENERATOR RIGGING





1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

TWO-PIECE STEAM GENERATOR REPLACEMENT

● REMOVAL SEQUENCE

- AUXILIARY LIFTING DEVICE INSTALLED ON TOP OF EXISTING BRIDGE CRANE
- VESSELS SEVERED AT TRANSITION CONE AND RCS NOZZLES
- EVALUATE THE NEED FOR PIPING RESTRAINTS
- STEAM DRUMS REMOVED AND STORED INSIDE CONTAINMENT
- COVER PLATES INSTALLED ON LOWER ASSEMBLY TRANSITION CONE AND ALL NOZZLE OPENINGS
- DECON OF LOWER ASSEMBLY
- LOWER ASSEMBLIES REMOVED THRU EQUIPMENT HATCH
- LOWER ASSEMBLIES TRANSPORTED TO FINAL STORAGE LOCATION




100

100

TWO-PIECE REPLACEMENT CONT'D

● INSTALLATION SEQUENCE

- APPROXIMATELY THE REVERSE OF REMOVAL
- LOWER ASSEMBLIES MOVED FROM STORAGE LOCATION TO AREA NEAR EQUIPMENT HATCH
- LOWER ASSEMBLIES RIGGED INTO CONTAINMENT
- STEAM DRUMS WITH NEW MOISTURE SEPERATING EQUIPMENT RIGGED ONTO LOWER ASSEMBLIES
- DRUM WELDED TO LOWER ASSEMBLY
- PIPING WELDED
- PRIMARY/SECONDARY SIDE HYDRO'S
- INSULATION INSTALLED



.

.

.

.

.

.

.

.

.

.

.

ONE-PIECE STEAM GENERATOR REPLACEMENT

- ONE-PIECE S/G REPLACED THRU AN OPENING IN THE ROOF OF CONTAINMENT
- OPENING DIRECTLY OVER EACH STEAM GENERATOR
- S/G REMOVED WITH LARGE MOBILE CRANE
- REMOVAL SEQUENCE
- INSTALLATION SEQUENCE

100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

100

100

ONE-PIECE STEAM GENERATOR REPLACEMENT CONT'D

● REMOVAL SEQUENCE

- LAMPSON TRANSI-LIFT ASSEMBLED IN PARKING LOT AND LOAD TESTED
- TOWER CRANE ASSEMBLED ADJACENT TO CONTAINMENT
- TRANSI-LIFT MOVED TO AREA ADJACENT TO CONTAINMENT
- TRANSI-LIFT POSITIONED ON SPECIALLY DESIGNED FOUNDATION
- CONCRETE OPENINGS WIRE SAWED UP TO LINER PLATE
- CONCRETE CHIPPED BACK TO EXPOSE REBAR
- LINER PLATE CUT AND CONCRETE/LINER REMOVED
- SECOND LIFTING TRUNION INSTALLED ON EACH S/G
- S/G CONNECTED TO TRANSI-LIFT
- PIPING RESTRAINED (IF NECESSARY) AND CUT
- S/G REMOVED BY RAISING HOOK UNTILL S/G CLEARS CONTAINMENT
- S/G LOWERED BY LOWERING HOOK AND RAISING BOOM
- S/G DOWN ENDED AND LOWERED ONTO TRANSPORTER
- S/G TRANSPORTED TO STORAGE LOCATION

1000 1000 1000 1000 1000

ONE-PIECE STEAM GENERATOR REPLACEMENT CONT'D

- **INSTALLATION SEQUENCE**

- **ESSENTIALLY THE REVERSE OF THE REMOVAL PROCESS**
- **PIPE WELDING THE SAME AS THE TWO-PIECE**
- **VESSEL HYDROTESTED IN THE SHOP THEREFORE ONLY NEW WELDS REQUIRE TESTING IN FIELD**
- **INSULATION STARTS AS SOON AS VESSELS ARE SET**
- **ROOF LINER PLATE REINSTALLED AND TESTED**
- **REBAR REINSTALLED**
- **CONCRETE PLACED**
- **STRUCTURAL INTEGRITY TEST PREFORMED**





FIGURE 4.2-4







Figure 4.2.2
CONTAINMENT ROOF CONSTRUCTION OPENINGS
(Page 1 of 2)






11

11

Figure 4.2.3
CONTAINMENT ROOF OPENING CONSTRUCTION SEQUENCE





Small, illegible marks or characters in the top right corner.

A 111

Vertical text on the left side, including characters like '1', '2', '3', '4', '5', '6', '7', '8', '9', '0'.

PPPPPP

Figure 4.2.2
CONTAINMENT ROOF CONSTRUCTION OPENINGS
(Page 2 of 2)





FIGURE 4.2-1
ONE PIECE STEAM GENERATOR RIGGING
(Page 1 of 2)






11

11


FIGURE 4.2-1
ONE PIECE STEAM GENERATOR RIGGING
(Page 2 of 2)



100

100

Figure 4.2.4
LINER PLATE REINSTALLATION WELD DETAIL





2 43
2 43
2 43

1

2 43

2 43

2 43

CURRENT PREFERENCE

- ONE PIECE REPLACEMENT FOR THE FOLLOWING REASONS
- MINIMIZES IN CONTAINMENT HANDLING AND MOVEMENT
- SHORTER SCHEDULE (74 VS 84 DAYS)
- LESS EXPENSIVE (15 TO 20%)
- LESS RADIATION EXPOSURE (300R VS 400R)
- 100% SHOP ASSEMBLY

2000
1000
500

LICENSING APPROACHES

- LICENSE AMENDMENT

- 10CFR50.59

100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

100

LICENSING APPROACHES CONT'D

LICENSE AMENDMENT

- PER 10CFR 50.90 AND 50 .91
- SUBMITTAL OF SAFETY ANALYSIS REPORT
- RESPONSES TO FORMAL NRC QUESTIONS
- NO SIGNIFICANT HAZARDS DETERMINATION
- TECHNICAL SPECIFICATION CHANGES
- FACILITY CHANGE PACKAGES AND ASSOCIATED SAFETY EVALUATIONS (INCLUDING CHANGES TO THE UFSAR)
- PRESENTATIONS TO THE NRC ON SELECTED SUBJECTS, PROCESSES, TECHNIQUES, PROJECT STATUS, ETC
- APPROACH USED FOR EARLY S/G REPLACEMENTS:
 - SURRY 1 AND 2
 - TURKEY POINT 3 AND 4
 - ROBINSON 2
 - POINT BEACH 1
 - D.C. COOK 2

11

1

2

3

4

5

6

1000

1000

LICENSING APPROACHES CONT'D

10CFR50.59

- **COMPREHENSIVE SAFETY EVALUATION COVERING THE ENTIRE PROJECT**
- **SUPPORTING STUDIES, REPORTS, CALCULATIONS, ETC**
- **MINOR TECHNICAL SPECIFICATION CHANGES**
 - **SUBMITTED SEPERATELY, AS REQUIRED**
 - **FOR EXAMPLE, TRIP SETPOINT FOR S/G LEVEL MAY CHANGE**
- **PRESENTATIONS TO THE NRC ON SELECTED SUBJECTS, PROCESSES, TECHNIQUES, PROJECT STATUS, ETC.**
- **NRC INSPECTION/REVIEW OF SAFETY EVALUATION, RESPONSES TO NRC QUESTIONS**
- **APPROACH USED FOR ALL RECENT S/G REPLACEMENTS:**
 - **INDIAN POINT 3**
 - **PALISADES**
 - **MILLSTONE 2**
 - **NORTH ANNA 1 (PLANNED)**
 - **V.C.SUMMER (PLANNED)**

2000



10

11

12

13

MAJOR ISSUES TO BE ADDRESSED

- S/G TRANSPORT
- CONTAINMENT INTEGRITY
- S/G DROP POTENTIAL
- EFFECTS ON UFSAR/TECH SPECS
- ALARA
- ACCEPTANCE TESTING/EXAMINATIONS

100

5-4

SCHEDULE

- REPLACEMENT DECISION 9/92 - 1/93
- S/G FABRICATION 1/93 - 1/96
- RFP FOR DESIGN/INSTALLATION 1/93 - 6/93
- DETAIL DESIGN 7/93 - 1/95
- PRE OUTAGE MODIFICATIONS 3/95 - 2/96
- S/G INSTALLATION 3/96 - 6/96

