

DCS

OCT. 08 1992

Docket No. 50-244

Dr. Robert C. Mecredy
Vice President, Ginna Nuclear Production
Rochester Gas and Electric Corporation
89 East Avenue
Rochester, New York 14649

Dear Dr. Mecredy:

Subject: Inspection No. 50-244/92-14

This letter refers to the safety inspection conducted by Mr. J. Kottan and Ms. N. McNamara of this office on September 14 - 18, 1992 of activities authorized by NRC License No. DPR-18 at the R. E. Ginna Nuclear Generating Station, Ontario, New York, and to the discussions of our findings held by Mr. Kottan and Ms. McNamara with Mr. J. Widay and other members of your staff at the conclusion of the inspection.

Areas examined during this inspection are important to public health and safety and are described in the NRC Region I Inspection Report which is enclosed with this letter. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspectors.

In addition, our Mobile Laboratory was brought to your site and used by the inspectors to make certain independent measurements. The basic purpose of these independent measurements is to verify your capability for analyzing radioactive effluents, and to achieve and maintain comparable methods of analyses between your facility and the NRC. The complete data from these measurements are included in this report with the exception of the wet radiochemistry results, which will be documented in a subsequent inspection report.

OFFICIAL RECORD COPY G:GINA9214.IR October 1, 1992

9210200060 921008
PDR ADOCK 05000244
Q PDR

111
IE 06



OCT. 08 1992

Rochester Gas and Electric Corporation 2

Within the scope of this inspection, you had in place effective programs for measuring radioactivity in process and effluent samples and for measuring chemical parameters in plant systems samples. No safety concerns or violations of regulatory requirements were observed and no response to this letter is required.

Your cooperation with us in this matter is appreciated.

Sincerely,

**Original Signed By:
James H. Joyner**

James H. Joyner, Chief
Facilities Radiological Safety
and Safeguards Branch
Division of Radiation Safety
and Safeguards

Enclosure: Inspection Report No. 50-244/92-14

cc w/encl:

R. Smith, Senior Vice President, Production and Engineering
Central Records (4 copies)

Director, Power Division, Department of Public Service
State of New York, Department of Law

N. Reynolds, Esquire

Public Document Room (PDR)

Local Public Document Room (LPDR)

Nuclear Safety Information Center (NSIC)

K. Abraham, PAO (2)

NRC Resident Inspector

State of New York, SLO Designee



OCT. 08 1992

Rochester Gas and Electric Corporation

3

bcc w/encl:

Region I Docket Room (with concurrences) (w/cy of IFS Forms)

DRS/EB SALP Coordinator

J. Linville, DRP

W. Lazarus, DRP

T. Moslak, SRI - Ginna (w/cy of IFS Forms)

A. Johnson, PM, NRR

V. McCree, OEDO


RI:DRSS
Kottan/tmh

10/6/92


RI:DRSS
McNamara

10/6/92


RI:DRSS
Miller

10/8/92


RI:DRSS
Joyner

10/8/92

