

JSS

OCT 16 1992

Docket No. 50-244

Dr. Robert C. Mecredy  
Vice President, Ginna Nuclear Production  
Rochester Gas and Electric Corporation  
89 East Avenue  
Rochester, New York 14649

Dear Dr. Mecredy:

SUBJECT: INSPECTION 50-244/91-80, UNRESOLVED ITEM 91-80-06

This refers to your letter dated August 17, 1992, addressed to Mr. A. Johnson of the NRC.

You informed us that the completion date for the 4160 Vac breaker coordination analysis would be postponed from November 1992 to June 30, 1993, as the prerequisite tests for 4160 Vac motors would not be completed until the 1993 refueling outage. Based on your stated interim actions, your new completion date is acceptable.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By:  
P. K. Eapen

Jacque P. Durr, Chief  
Engineering Branch  
Division of Reactor Safety

cc:

R. Smith, Senior Vice President, Production and Engineering  
Central Records (4 copies)  
Director, Power Division  
State of New York, Department of Law  
N. Reynolds, Esquire  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
State of New York, SLO Designee

OFFICIAL RECORD COPY A:REPLY.GIN

9210280013 921016  
PDR ADDCK 05000244  
Q PDR

JF01  
11

OCT 16 1992

Dr. Robert C. Mecredy

2

bcc:

Region I Docket Room (with concurrences) (w/cy of IFS Forms)

DRS/EB SALP Coordinator

J. Linville, DRP

W. Lazarus, DRP

T. Moslak, SRI - Ginna (w/cy of IFS Forms)

A. Johnson, PM, NRR

R. Lobel, OEDO

*of use*  
RI:DRS  
Cheung

10/15/92

*[Signature]*  
RI:DRS  
Ruland

10/16/92

*[Signature]*  
RI:DRS  
Duff

10/16/92

OFFICIAL RECORD COPY  
A:REPLY.GIN

