ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9211240118 DOC.DATE: 92/10/31 NOTARIZED: NO DOCKET #
FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
AUTH.NAME AUTHOR AFFILIATION
DODGE,R.E. Rochester Gas & Electric Corp.
MECREDY,R.C. Rochester Gas & Electric Corp.
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Oct 1992 for RE Ginna Nuclear Power Plant.W/921115 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL
	PD1-3 LA	3	3	PD1-3 PD	1	1
	JOHNSON,A	1	1			
INTERNAL:	AEOD/DOA	1	1	AEOD/DSP/TPAB	1	1
	NRR/DLPQ/LPEB10	1	1	NRR/DOEA/OEAB	1	1
	REG FILE 01	1	1	RGN1	1	1
EXTERNAL:	EG&G BRYCE,J.H	1	1	NRC PDR	1	1
	NSIC	1	1			

Cont'd
p034044170

R I D S / A D D S

R I D S / A D D S

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK. ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

MDR

ROCHESTER GAS AND ELECTRIC CORPORATION ○ 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001

ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

November 15, 1992

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for October, 1992
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of October, 1992.

Very truly yours,

Robert C. Mecredy

RCM/

Attachments

cc: Mr. Thomas T. Martin NRC (1)

Cert # P034044170

9211240118 921031
PDR ADOCK 05000244
R PDR

IE24

OPERATING DATA REPORT

DOCKET NO. 50-244
DATE November 15, 1992
COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE (315) 524-4446 ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: October, 1992
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit operated at approx. 97% reactor power level for the entire report period.

9. Power Level to Which Restricted, If Any (Net MWe):
10. Reasons For Restrictions, If Any:

		This Month	Yr.-to-Date	Cumulative **	
11.	Hours In Report Period	745***	7,320	201,426.45	
12.	Number of Hours Reactor Was Critical	745	6,169.71	159,500.67	
13.	Reactor Reserve Shutdown Hours	0	0	1,687.55	*
14.	Hours Generator On-Line	745	6,073.75	156,779.13	
15.	Unit Reserve Shutdown Hours	0	0	8.5	*
16.	Gross Thermal Energy Generated (MWH)	1,103,684	8,677,792	221,892,305	
17.	Gross Electrical Energy Generated (MWH)	375,437	2,935,534	73,265,141	
18.	Net Electrical Energy Generated (MWH)	357,045	2,786,749	69,539,296	
19.	Unit Service Factor	100%	82.97%	77.99%	
20.	Unit Availability Factor	100%	82.97%	77.99%	
21.	Unit Capacity Factor (Using MDC Net)	101.97%	81.00%	74.80%	
22.	Unit Capacity Factor (Using DER Net)	101.97%	81.00%	74.80%	
23.	Unit Forced Outage Rate	0%	2.51%	5.92%	

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):
Refueling and Maintenance - March 19, 1993 45 days

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY		
INITIAL ELECTRICITY		
COMMERCIAL OPERATION		

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975
**CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969
***CHANGE FROM EASTERN DAYLIGHT SAVINGS TIME TO EASTERN STANDARD TIME

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE November 15, 1992
COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH October, 1992

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1.	478	17.	479
2.	478	18.	479
3.	478	19.	479
4.	478	20.	479
5.	478	21.	479
6.	478	22.	478
7.	478	23.	479
8.	478	24.	479
9.	479	25.	479
10.	479	26.	479
11.	479	27.	479
12.	478	28.	480
13.	478	29.	480
14.	478	30.	479
15.	478	31.	479
16.	478		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

DOCKET NO. 50-244
UNIT NAME R.E. GINNA NUCLEAR POWER PLANT
DATE November 15, 1992
COMPLETED BY Robert E. Dodge
Robert E. Dodge
TELEPHONE 315-524-4446 ext. 396
Ginna Station

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH OCTOBER 1992

No.	Date	Type [1]	Duration (Hours)	Reason [2]	Method of Shutting Down Reactor [3]	Licensee Event Report #	System Code [4]	Component Code [5]	Cause & Corrective Action to Prevent Recurrence
									No power reduction for the month of October.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
Exhibit 1 - Same Source

REV. 4/85 49-89

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE November 15, 1992
COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH October, 1992

The unit operated at approximately 97% Reactor Power Level for the month of October and remained there at the end of the report period.