

EOP: AP-CCW.2	TITLE: LOSS OF CCW DURING POWER OPERATION	REV: 10 PAGE 1 of 8
------------------	--	------------------------

ROCHESTER GAS AND ELECTRIC CORPORATION

GINNA STATION

CONTROLLED COPY NUMBER 23

TECHNICAL REVIEW

PORC REVIEW DATE 4-21-93

Thomas A. Marlow  
PLANT SUPERINTENDENT

4-23-93  
EFFECTIVE DATE

CATEGORY 1.0

REVIEWED BY: \_\_\_\_\_

EOP: AP-CCW.2	TITLE: LOSS OF CCW DURING POWER OPERATION	REV: 10 PAGE 2 of 8
------------------	--	------------------------

- A. PURPOSE - This procedure provides the steps necessary to respond to a loss of CCW while the plant is at power.
- B. ENTRY CONDITIONS/SYMP TOMS
1. ENTRY CONDITIONS - This procedure may be entered from:
    - a. AP-CCW.1, LEAKAGE INTO THE COMPONENT COOLING SYSTEM, when CCW surge tank level decrease indicated at power.
  2. SYMPTOMS - The symptoms of LOSS OF CCW DURING POWER OPERATION are;
    - a. Annunciator A-13 COMP COOLING SURGE TANK LO LEVEL 41.2%, lit, or
    - b. Annunciator A-22 CCW PUMP DISCHARGE LO PRESS 60 PSI, lit, or
    - c. Annunciator A-17, MOTOR OFF RCP CCWP, lit, or
    - d. Annunciator A-9, RHR PUMP COOLING WATER OUTLET LO FLOW 15 GPM, lit or
    - e. Annunciator A-6, CONT SPRAY PUMP COOLING WATER OUT LOW FLOW 15 GPM, lit or
    - f. Annunciator A-14, SAFETY INJ PUMPS COOLING WATER OUT LO FLOW 25 GPM, lit or
    - g. Annunciator A-7 (A-15), RCP A (B) CCW RETURN HI TEMP OR LO FLOW 165 GPM 125°F, lit or
    - h. Annunciator A-24 (A-32), RCP A (B) OIL LEVEL + 1.25, lit.

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

\*\*\*\*\*

CAUTION

- o IF CCW FLOW TO A RCP IS INTERRUPTED FOR GREATER THAN 2 MINUTES OR IF EITHER RCP MOTOR BEARING TEMPERATURE EXCEEDS 200°F, THEN TRIP THE AFFECTED RCP.
- o IF CCW IS LOST, THEN SEAL INJECTION SHOULD BE MAINTAINED TO THE RCP(S) UNTIL RCS TEMPERATURE IS LESS THAN 200°F, OR UNTIL CCW IS RESTORED.

\*\*\*\*\*

NOTE: If leakage from the CCW system is indicated, then refer to SC-6, HAZARDOUS AND MIXED WASTE MANAGEMENT AND CONTROL, for guidance.

1 Check CCW Pump Status:

Perform the following:

- |  |   |
|--|---|
| <ul style="list-style-type: none"> <li>o Both CCW pump breaker white disagreement lights - EXTINGUISHED</li> <li>o Annunciator A-17, Motor Off RCP CCP - EXTINGUISHED</li> </ul> | <ul style="list-style-type: none"> <li>a. Ensure standby CCW pump running.</li> <li>b. <u>IF</u> annunciator A-22, CCW PUMP DISCHARGE LO PRESS 60 PSI, lit, <u>THEN</u> check closed CCW to RHR HXs (MOV-738A and MOV-738B).</li> </ul> |
|--|---|

EOP:

AP-CCW.2

TITLE:

LOSS OF CCW DURING POWER OPERATION

REV: 10

PAGE 4 of 8

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

NOTE: CCW surge tank level should be verified locally in the AUX BLDG, if possible.

2 Verify CCW Surge Tank Level -  
APPROXIMATELY 50% AND STABLE

Perform the following:

- a. Open RMW to CCW surge tank, MOV-823.
- b. Start RMW pump(s).
- c. IF surge tank level stable or increasing, THEN go to Step 3.

IF CCW surge tank level can NOT be maintained greater than 10%, THEN perform the following:

- 1) Trip the reactor.
- 2) Trip the RCPs.
- 3) Place both CCW pumps in pull stop.
- 4) Go to E-0, REACTOR TRIP OR SAFETY INJECTION.

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p>*****  <u>CAUTION</u>            IF ANY RCP IS TRIPPED, THEN SHUTDOWN MARGIN REQUIREMENTS SHOULD BE VERIFIED            (REFER TO O-3.1, BORON CONCENTRATION FOR XENON FREE ALL RODS IN MOST REACTIVE            ROD STUCK OUT SHUTDOWN MARGIN).            *****</p>		
3	<p>Check CCW To Both RCPs:</p> <ul style="list-style-type: none"> <li>o Annunciator A-7 (A-15), RCP 1A (1B) CCW return Hi temp or low flow 165 gpm 125°F alarm - EXTINGUISHED</li> <li>o RCP motor bearings temperature (PPCS address GD-RCPS OR RCP temperature monitor RK-30A recorder) - ≤ 200°F</li> </ul>	<p><u>IF</u> CCW lost to RCP(s), <u>THEN</u> perform the following:</p> <ul style="list-style-type: none"> <li>a. Trip the Rx.</li> <li>b. Trip affected RCP(s).</li> <li>c. Go to E-0, REACTOR TRIP OR SAFETY INJECTION.</li> </ul>
4	<p>Check CCW Valve Alignment - NORMAL (Refer to Attachment AT POWER CCW ALIGNMENT)</p>	<p>Align CCW valves as necessary.</p>

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p><u>NOTE:</u></p> <ul style="list-style-type: none"> <li>o An evaluation must be made to determine if operation may continue while investigating a CCW leak in containment.</li> <li>o Operation may continue with the reactor support coolers isolated. If this occurs, notify higher supervision.</li> </ul>		
5	Check For CCW Leakage In CNMT:	
a.	Check CNMT sump A level: <ul style="list-style-type: none"> <li>o Level - STABLE</li> <li>o Sump A pumps - OFF</li> </ul>	a. <u>IF</u> abnormal increase in CNMT sump level, <u>THEN</u> perform the following: <ol style="list-style-type: none"> <li>1) Direct HP Tech to sample sump A for chromates.</li> <li>2) Prepare to make CNMT entry to check for CCW leak.</li> </ol>
b.	RCP oil levels - STABLE	b. <u>IF</u> any RCP oil level increasing uncontrollably, <u>THEN</u> perform the following: <ol style="list-style-type: none"> <li>1) Trip Reactor.</li> <li>2) Trip affected RCP(s).</li> <li>3) Close CCW supply and return for affected RCP(s).               <ul style="list-style-type: none"> <li>• RCP A, MOV-749A and MOV-759A</li> <li>• RCP B, MOV-749B and MOV-759B</li> </ul> </li> <li>4) Go to E-0, REACTOR TRIP OR SAFETY INJECTION.</li> </ol>

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
6	<p>Check for CCW Leakage In AUX BLDG:</p> <ul style="list-style-type: none"> <li>o Start frequency of AUX BLDG sump pump(s) - NORMAL (Refer to RCS daily leakage log)</li> <li>o Waste holdup tank level - STABLE OR INCREASING AS EXPECTED</li> </ul>	<p>Dispatch AO to investigate AUX BLDG for CCW leakage.</p>
7	<p>Verify CCW System Leak - IDENTIFIED AND ISOLATED</p>	<p>Perform the following:</p> <ul style="list-style-type: none"> <li>a. Direct HP Tech to sample CCW HX SW outlet for chromates.</li> <li>b. Return to Step 2.</li> </ul>
8	<p>Verify CCW Surge Tank Level - APPROXIMATELY 50% AND STABLE</p>	<p>Perform the following:</p> <ul style="list-style-type: none"> <li>a. Open RMW to CCW surge tank, MOV-823.</li> <li>b. Start RMW pump(s).</li> <li>c. Restore CCW surge tank level to 50%.</li> <li>d. Stop RMW pump and close MOV-823.</li> </ul>
9	<p>Direct HP To Sample CCW System For Chromates</p>	

EOP:

AP-CCW.2

TITLE:

LOSS OF CCW DURING POWER OPERATION

REV: 10

PAGE 8 of 8

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

10 Evaluate Plant Conditions:

a. CCW system malfunction - IDENTIFIED AND CORRECTED

a. Return to Step 1.

b. CCW system status adequate for power operation (Refer to Tech Spec Section 3.3.3).

b. IF shutdown required, THEN refer to 0-2.1, NORMAL SHUTDOWN TO HOT SHUTDOWN.

NOTE: Refer to 0-9.3, NRC IMMEDIATE NOTIFICATION, for reporting requirements.

11 Notify Higher Supervision

12 Return To Procedure Or Guidance In Effect

-END-





EOP: AP-CCW.2	TITLE: LOSS OF CCW DURING POWER OPERATION	REV: 10 PAGE 1 of 1
------------------	--	------------------------

AP-CCW.2 APPENDIX LIST

<u>TITLE</u>	<u>PAGES</u>
1) ATTACHMENT AT POWER CCW ALIGNMENT	1

