

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9308130032 DOC. DATE: 93/08/06 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 MECREDY, R.C. Rochester Gas & Electric Corp.
 RECIPIENT NAME RECIPIENT AFFILIATION
 JOHNSON, A.R. NRC - No Detailed Affiliation Given

SUBJECT: Responds to telcon on 930707 re previous administrative changes per application for amend to License DPR-18 on requirements for snubber visual insp intervals & Generic Ltr 90-09.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 32 + 54
 TITLE: OR Submittal: General Distribution

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES	L	T	E	N	C	L	R
	PD1-3 LA	1						1	
	JOHNSON, A	2						2	
INTERNAL:	NRR/DE/EELB	1						1	
	NRR/DRPW/OTSB	1						1	
	NRR/DSSA/SRXB	1						1	
	OC/LFDCB	1						0	
	<u>REG FILE</u> 01	1						1	
EXTERNAL:	NRC PDR	1						1	
									1
									1


NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 15 ENCL 13



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

August 6, 1993

TELEPHONE
AREA CODE 716 546-2700

U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Allen R. Johnson
Project Directorate I-3
Washington, D.C. 20555

Subject: Administrative Changes to a Previously Submitted
Application to Amend the Technical Specifications
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Ref. (a): Letter from R. C. Mecredy (RG&E) to A. R. Johnson (NRC),
"Application for Amendment to Operating License," dated
April 23, 1992

Dear Mr. Johnson:

This submittal is in response to a telecon between you and members of RG&E's staff on July 7, 1993. Submitted herewith are the proposed pages from a previously submitted application (Reference a) to amend the Ginna Technical Specifications regarding alternative requirements for snubber visual inspection intervals, made pursuant to Generic Letter 90-09, containing several administrative changes and minor corrections.

As agreed in our telecon the following changes have been made and are considered administrative in nature.

1. On proposed page 4.14-2 (line 11) the word "or" has been changed to "and", consistent with Generic Letter 90-09, Enclosure B, para. 4.7.9c.
2. On proposed page 4.14-2 (line 15) the word "in-operable" has been corrected to "inoperable."
3. On proposed page 4.14-2 a change bar has been added in the right hand margin, which was inadvertently left off in the Reference (a) submittal.
4. On proposed page 4.14-4 (Table 4.14-1), the word "acceptable" has been corrected to "unacceptable", in Note 4 consistent with Generic Letter 90-09, Enclosure B, Table 4.7-2, Note 4.


120029

9308130032	930806
PDR	ADOCK 05000244
P	PDR

Aool
11

In order to keep all proposed pages together, a complete ATTACHMENT A of our Reference (a) submittal is hereby submitted to replace the previous ATTACHMENT A in its entirety.

Very truly yours,


Robert C. Mecredy

GAH\295
Attachment

xc: Mr. Allen R. Johnson (Mail Stop 14D1)
Project Directorate I-3
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Ginna Senior Resident Inspector