

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9310190365 DOC.DATE: 93/09/30 NOTARIZED: NO DOCKET #
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH.NAME AUTHOR AFFILIATION
 DODGE;R.E. Rochester Gas & Electric Corp.
 WIDAY,J.A. Rochester Gas & Electric Corp.
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Sept 1993 for RE Ginna Nuclear
 Power Plant.W/931008 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: S
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD1-3 LA		3	3		PD1-3 PD		1	1
	JOHNSON,A		1	1					
INTERNAL:	AEOD/DOA		1	1		AEOD/DSP/TPAB		1	1
	NRR/DORS/OEAB		1	1		NRR/DRIL/RPEB		1	1
	REG FILE 01		1	1		RGN1		1	1
EXTERNAL:	EG&G BRYCE,J.H		1	1		NRC PDR		1	1
	NSIC		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

JOSEPH A. WIDAY
Plant Manager
Ginna Nuclear Plant

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

October 8, 1993

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for September, 1993
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1,
attached herewith is the monthly operating status report
for Ginna Station for the month of September, 1993.


Very truly yours,

Joseph A. Widay
Joseph A. Widay
Plant Manager

JAW:clp

Attachments

c: Mr. Thomas T. Martin NRC (1)



IF24
11

OPERATING DATA REPORT

-1-

DOCKET NO. 50-244

DATE Oct. 8, 1993

COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE (315) 524-4446 Ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: September, 1993
3. Licensed Thermal Power (Mwt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit operated at approximately 98% power level for the month of September.

9. Power Level to Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative **
11. Hours In Report Period	720	6,551	209,441.45
12. Number of Hours Reactor Was Critical	720	5,498.29	166,462.96
13. Reactor Reserve Shutdown Hours	0	0	1,687.55 *
14. Hours Generator On-Line	720	5,462.25	163,705.38
15. Unit Reserve Shutdown Hours	0	0	8.5 *
16. Gross Thermal Energy Generated (MWH)	1,068,747	7,974,162	232,017,915
17. Gross Electrical Energy Generated (MWH)	357,925	2,688,237	76,686,041
18. Net Electrical Energy Generated (MWH)	339,761	2,552,768	72,788,699
19. Unit Service Factor	100%	83.38%	78.31%
20. Unit Availability Factor	100%	83.38%	78.32%
21. Unit Capacity Factor (Using MDC Net)	100.40%	82.91%	75.24%
22. Unit Capacity Factor (Using DER Net)	100.40%	82.91%	75.24%
23. Unit Forced Outage Rate	0 %	0 %	5.68%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):
Refueling and maintenance March 4, 1994. Duration-40 days.

25. If Shut Down At End Of Report Period, Estimated Date of Startup
26. Units In Test Status (Prior to Commercial Operation):

Forecast Achieved

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975
**CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE Oct. 8, 1993
COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE (315) 524-4446

Ext. 396

MONTH September, 1993

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>465</u>
2.	<u>466</u>
3.	<u>469</u>
4.	<u>467</u>
5.	<u>467</u>
6.	<u>468</u>
7.	<u>469</u>
8.	<u>469</u>
9.	<u>470</u>
10.	<u>470</u>
11.	<u>472</u>
12.	<u>472</u>
13.	<u>472</u>
14.	<u>472</u>
15.	<u>471</u>
16.	<u>472</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>471</u>
18.	<u>471</u>
19.	<u>472</u>
20.	<u>471</u>
21.	<u>474</u>
22.	<u>476</u>
23.	<u>476</u>
24.	<u>474</u>
25.	<u>474</u>
26.	<u>476</u>
27.	<u>475</u>
28.	<u>476</u>
29.	<u>477</u>
30.	<u>477</u>
31.	<u> </u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole metgawatt.



VIA



11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH September 1993

DOCKET NO. 50-244

UNIT NAME R.E. GINNA NUCLEAR POWER PLANT

DATE 10/8/93

COMPLETED BY Robert E. Dodge

TELEPHONE 315-524-4446 ext 396

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
									No shutdown or power reduction for the month of September.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE Oct. 8, 1993

COMPLETED BY


Robert E. Dodge

TELEPHONE (315) 524-4446 Ext. 396

MONTH September, 1993

The unit operated at approximately 98% reactor power level for the month of September and remained there at the end of the report period.

