ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9404190284 DOC.DATE: 94/03/31 NOTARIZED: NO DOCKET #
FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
AUTH.NAME AUTHOR AFFILIATION
PLOOF,R. Rochester Gas & Electric Corp.
WIDAY,J.A. Rochester Gas & Electric Corp.
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Mar 1994 for Ginna Nuclaer Power Plant.W/940411 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL
	PD1-3 PD	1	1	JOHNSON,A	1	1
INTERNAL:	AEOD/DOA	1	1	AEOD/DSP/TPAB	1	1
	NRR/DORS/OEAB	1	1	NRR/DRIL/RPEB	1	1
	REG FILE 01	1	1	RGN1	1	1
EXTERNAL:	EG&G BRYCE,J.H	1	1	NRC PDR	1	1
	NSIC	1	1			

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 11 ENCL 11

RIDS/ADDS

RIDS/ADDS

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

JOSEPH A. WIDAY
Plant Manager
Ginna Nuclear Plant

GINNA STATION

TELEPHONE
AREA CODE 716 546-2700

April 11, 1994

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for March, 1994
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of March, 1994.

Very truly yours,

Joseph A. Widay

Joseph A. Widay
Plant Manager

JAW:tjn

Attachments

c: Mr. Thomas T. Martin NRC (1)

200010

9404190284 940331
PDR ADOCK 05000224
R PDR

IE24
1/1

OPERATING DATA REPORT

DOCKET NO. 50-244
DATE April 11, 1994
COMPLETED BY
Ronald Ploof
TELEPHONE (315) 524-4446 Ext. 673

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: March, 1994
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit entered its annual refueling outage as scheduled.

9. Power Level to Which Restricted, If Any (Net MWe):
10. Reasons For Restrictions, If Any:

		This Month	Yr.-to-Date	Cumulative **	
11.	Hours In Report Period	744	2160	213,408	
12.	Number of Hours Reactor Was Critical	83	1499	170,026	
13.	Reactor Reserve Shutdown Hours	0	0	1,688	*
14.	Hours Generator On-Line	83	1499	167,251.38	
15.	Unit Reserve Shutdown Hours	0	0	8.5	*
16.	Gross Thermal Energy Generated (MWH)	116,893	2,203,684	237,159,697	
17.	Gross Electrical Energy Generated (MWH)	39,702	750,070	78,433,429	
18.	Net Electrical Energy Generated (MWH)	37,476	712,434	74,447,807	
19.	Unit Service Factor	11.16%	69.40%	78.37%	
20.	Unit Availability Factor	11.16%	69.40%	78.38%	
21.	Unit Capacity Factor (Using MDC Net)	10.72%	70.18%	75.36%	
22.	Unit Capacity Factor (Using DER Net)	10.72%	70.18%	70.18%	
23.	Unit Forced Outage Rate	0%	0 %	5.64%	

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):
Refueling and Maintenance, March 4, 1994 - duration: 41 days.

25. If Shut Down At End of Report Period, Estimated Date of Startup: April 14, 1994
26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY		
INITIAL ELECTRICITY		
COMMERCIAL OPERATION		

* CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975
** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: April 11, 1994

COMPLETED BY: Ronald Ploof

TELEPHONE: (315) 524-4446 Ext. 673

MONTH March, 1994

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1.	480	17.	0
2.	479	18.	0
3.	476	19.	0
4.	290	20.	0
5.	0	21.	0
6.	0	22.	0
7.	0	23.	0
8.	0	24.	0
9.	0	25.	0
10.	0	26.	0
11.	0	27.	0
12.	0	28.	0
13.	0	29.	0
14.	0	30.	0
15.	0	31.	0
16.	0		

INSTRUCTIONS
On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole megawatt.

DOCKET NO. 50-244
UNIT NAME R.E. GINNA NUCLEAR POWER PLANT
DATE 4/11/94
COMPLETED BY

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH March

TELEPHONE (315) 524-4446 Ext. 673

No.	Date	Type [1]	Duration (Hours)	Reason [2]	Method of Shutting Down Reactor [3]	Licensee Event Report #	System Code [4]	Component Code [5]	Cause & Corrective Action to Prevent Recurrence
94-03	4/4/94	S	1681	C	1	---	--	---	Annual Refueling

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
Exhibit 1 - Same Source

REV. 4/85 49-89

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO: 50-244
UNIT: R.E. Ginna Nuclear Power Plant
DATE: April 11, 1994
COMPLETED BY: Ronald Ploof
TELEPHONE: (315) 524-4446 Ext. 673

MONTH March, 1994

During the first 4 days of March the average power level was 98%. On March 4, the unit was taken off line as scheduled for its annual maintenance and refueling outage.