PRIORITY 1

(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9508150168 DOC.DATE: ~~95/07/31~~ NOTARIZED: NO DOCKET #
FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
AUTH.NAME AUTHOR AFFILIATION
WALDEN,J.V. Rochester Gas & Electric Corp.
WIDAY,J.A. Rochester Gas & Electric Corp.
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating ~~rept~~ for Jul 1995 for RE Ginna Nuclear Power Plant.W/950809 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL
	PD1-1 PD	1	1	JOHNSON,A	1	1
INTERNAL:	AEOD/SPD/RRAB	1	1	~~FILE CENTER~~ 01	1	1
	NRR/DISP/PIPB	1	1	~~NRR/DRPM/PECB~~	1	1
	RGN1	1	1			
EXTERNAL:	LITCO BRYCE,J H	1	1	NOAC	1	1
	NRC PDR	1	1			

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM OWFN 5D8 (415-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

MR

P R I O R I T Y 1 D O C U M E N T

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

August 9, 1995

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for July, 1995
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of July, 1995.

Very truly yours,

Joseph A. Widay
Plant Manager

JAW:tjn

Attachments

c: Mr. Thomas T. Martin NRC (1)

150122

9508150168 950731
PDR ADOCK 05000244
R PDR

JE24

OPERATING DATA REPORT

50-244

August 9, 1995

COMPLETED BY: John V. Walden

TELEPHONE (716) 771-3588

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT Notes: Notes:
2. Reporting Period: July, 1995
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electric Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Rating (Items Number 3 Through 7) Since Last Report, Give Reason:

9. Power Level to Which Restricted, If Any (Net MWe):
10. Reason For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative**
11. Hours In Reported Period	744.0	5087.0	225095.0
12. Number of hours Reactor Was Critical	744.0	4210.5	180026.2
13. Reactor Reserve Shutdown Hours	0.0	0.0	1687.6 *
14. Hours Generator On-line	744.0	4149.3	177121.6
15. Unit Reserve Shutdown Hours	0.0	0.0	8.5 *
16. Gross Thermal Energy Generated (MWH)	1085722.0	6069254.0	251584491.0
17. Gross Electrical Energy Generated (MWH)	360925.0	2046316.0	83280368.0
18. Net Electrical Energy Generated (MWH)	342637.0	1944703.0	79053933.0
19. Unit Service Factor (%)	100.0	81.6	78.7
20. Unit Availability Factor (%)	100.0	81.6	78.7
21. Unit Capacity Factor (using MDC Net) (%)	98.0	81.3	75.8
22. Unit Capacity Factor (using DER Net) (%)	98.0	81.3	75.8
23. Unit Forced Outage Rate (%)	0.0	0.0	5.6

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shutdown At End of Report Period, Estimate Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):	Forcast	Achieved
INITIAL CRITICALITY		
INITIAL ELECTRICITY		
COMMERCIAL OPERATION		

* CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-244
UNIT: R.E. Ginna Nuclear Power Plant
DATE: August 9, 1995
COMPLETED BY: John V. Walden
John Walden
TELEPHONE: (716) 771-3588

MONTH July, 1995

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1.	476	17.	462
2.	475	18.	462
3.	471	19.	362
4.	467	20.	459
5.	467	21.	460
6.	466	22.	461
7.	466	23.	461
8.	465	24.	461
9.	466	25.	460
10.	465	26.	460
11.	465	27.	459
12.	464	28.	461
13.	465	29.	461
14.	463	30.	458
15.	461	31.	458
16.	462		

INSTRUCTIONS
On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole megawatt.

DOCKET NO. 50-244
UNIT NAME R.E. GINNA NUCLEAR POWER PLANT
DATE August 9, 1995
COMPLETED BY John V. Walden
John V. Walden
TELEPHONE (716) 771-3588

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH July, 1995

No.	Date	Type [1]	Duration (Hours)	Reason [2]	Method of Shutting Down Reactor [3]	Licensee Event Report #	System Code [4]	Component Code [5]	Cause & Corrective Action to Prevent Recurrence
95-06	7/19/95	F	13.8	A	--	-----	---	----	Power reduction due to Main Feedwater pump oil cooler leak.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
Exhibit 1 - Same Source

REV. 4/85 49-89

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO: 50-244
UNIT: R.E. Ginna Nuclear Power Plant
DATE: August 9, 1995
COMPLETED BY: John Walden
TELEPHONE: (716) 771-3588

MONTH July, 1995

On July 19, power was reduced to 48% capacity due to an oil cooler leak on the "B" Main Feedwater pump. This reduction in power lasted for 13.8 hours. Average power for the month was 96%.