REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

DOC.DATE: 95/09/20 NOTARIZED: NO ACCESSION NBR:9509260255 DOCKET # FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244 AUTHOR AFFILIATION AUTH.NAME MECREDY, R.C. Rochester Gas & Electric Corp. RECIP.NAME RECIPIENT AFFILIATION JOHNSON, A.R. SUBJECT: Submits addl info re environ gulification of neutron flux instrumentation. DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR I ENCL OTITLE: OR Submittal: General Distribution NOTES: License Exp date in accordance with 10CFR2, 2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME PD1-1 LA JOHNSON,A	COPIE LTTR 1		RECIPIENT ID CODE/NAME PD1-1 PD	COPI LTTR 1	
INTERNAL	FILE CENTER 01 NRR/DRCH/HICB NRR/DSSA/SRXB OGC/HDS3	1 1 1	7770	NRR/DE/EMCB NRR/DSSA/SPLB NUDOCS-ABSTRACT	1 1 1	1
EXTERNAL:	NOAC	1	1	NRC PDR	1	4

(at # 2074669861

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM OWFN 5D8 (415-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 12 ENCL 11

may



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



AREA CODE 716 546-2700

ROBERT C. MECREDY Vice President **Nuclear Operations**

September 20, 1995

U.S. Nuclear Regulatory Commission

Document Control Desk

Attn: Allen R. Johnson

Project Directorate I-1

Washington, D.C. 20555

Neutron Flux Submittal Regarding Subject: Supplemental

> Instrumentation (TAC No. M90036) R.E. Ginna Nuclear Power Plant

Docket No. 50-244

Letter from Robert C. Mecredy, RG&E, to Allen R. Johnson, Ref.(a): NRC, "Use of Neutron Flux Instrumentation During Post-

Accident Severe Accident Conditions," February 3, 1995

Dear Mr. Johnson:

As a result of NRC staff review of information submitted in Reference (a), a conference call was held between Rochester Gas and Electric and NRC staff on June 30, 1995. During that call, the NRC staff discussed additional information needed to conclude that environmental qualification of neutron flux instrumentation is not necessary. Accordingly, we are providing the following information which we believe satisfies the remaining staff concern regarding this issue:

Concern: Ensure that, in the event of an accident resulting in a harsh containment environment (for which source range neutron flux is not environmentally qualified), boration, as required to mitigate the accident, is being delivered to the core.

Response: RG&E agrees that boric acid injection is required in such circumstances. Our plant design provides for the automatic initiation of the engineered safety features (including boric acid addition via the safety injection pumps) upon receipt of an adverse containment signal of 4 psig. A review of our Emergency Operating Procedures (EOP's) indicates that actions are presently specified to direct the operator to restore safety injection if initiation is For postulated accidents where the RCS is not not obtained. depressurized below the shutoff head of the safety injection pumps, the operator is directed to align boric acid injection using the charging pumps.

We believe that our current arrangement of EOPs and Critical Safety Function Status Trees, allowing for optimal recovery procedures to

9509260255 950920 PDR ADDCK 05000244

be exercised prior to reliance on Functional Restoration Procedures (FRs), combined with timely use of appropriate FRs as needed, provides the actions needed to address the NRC's concern.

Even though we believe that the current procedures acceptably address the NRC's concern, we are emphasizing this issue, including a caution to the operators to not rely on neutron flux during a harsh environment condition, in our latest operator requalification training cycle session, which began on August 8, 1995.

Very truly yours,

Robert C. Mecredy/

GJW\388 Attachment

xc: Mr. Allen R. Johnson (Mail Stop 14B2)
Project Directorate I-1
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission Region I 475 Allendale Road King of Prussia, PA 19406

Ginna Senior Resident Inspector