

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9603010220 DOC. DATE: 96/02/22 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME: WIDAY, J.A. AUTHOR AFFILIATION: Rochester Gas & Electric Corp.
 RECIP. NAME: RECIPIENT AFFILIATION: *REV- 3/16/96*

JOHNSON, A.R.

SUBJECT: Rev 11 to AP-CCW.1, "Leakage into Component Cooling Loop."
W/960222 ltr.

DISTRIBUTION CODE: A003D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 17
 TITLE: OR/Licensing Submittal: Suppl 1 to NUREG-0737(Generic Ltr 82-33)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244


	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID	CODE/NAME	LTR	ENCL		ID	CODE/NAME	LTR	ENCL	
	LA		1	1		PD		1	1	
	PM		1	1						
INTERNAL:	<u>FILE CENTER 01</u>		1	1		NRR/DRCH/HHFB		1	1	
	NRR/DRPM/PECB		1	1		RES/DSIR/EIB		1	1	
EXTERNAL:	NOAC		1	1		NRC PDR		1	1	

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 9 ENCL 9

MAY

C
A
T
E
G
O
R
Y
1
D
O
C
U
M
E
N
T





ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

JOSEPH A. WIDAY
Plant Manager
Ginna Nuclear Plant

TELEPHONE
AREA CODE 716 546-2700

February 22, 1996

U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Allen R. Johnson
Project Directorate I-1
Washington, D.C. 20555

Subject: Emergency Operating Procedures
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Johnson:

As requested, enclosed are Ginna Station Emergency Operating Procedures.

Very truly yours,

Joseph A. Widay
Joseph A. Widay

JAW/jdw

xc: U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406-1415

Ginna USNRC Senior Resident Inspector

Enclosure(s):

- | | | | |
|--------------------|-------------------|-------------------|--------------------|
| AP-CCW.1, Rev. 11 | AP-ELEC.3, Rev. 2 | AP-RCC.3, Rev. 1 | AP-TURB.2, Rev. 14 |
| AP-CCW.2, Rev. 12 | AP-PRZR.1, Rev. 8 | AP-RCP.1, Rev. 9 | |
| AP-CVCS.1, Rev. 10 | AP-RCC.1, Rev. 6 | AP-RCS.1, Rev. 10 | |
| AP-ELEC.1, Rev. 12 | AP-RCC.2, Rev. 6 | AP-SW.1, Rev. 10 | |

~~50-244~~

116
A003
111

9603010220 960222
PDR ADDOCK 05000244
P PDR

.....

340018

EOP:

AP-CCW.1

TITLE:

LEAKAGE INTO THE COMPONENT COOLING LOOP

REV: 9

PAGE 1 of 14

ROCHESTER GAS AND ELECTRIC CORPORATION

GINNA STATION

CONTROLLED COPY NUMBER 23

TECHNICAL REVIEW

PORC REVIEW DATE 6-8-94


PLANT SUPERINTENDENT

6-9-94
EFFECTIVE DATE

CATEGORY 1.0

REVIEWED BY: _____

EOP: AP-CCW.1	TITLE: LEAKAGE INTO THE COMPONENT COOLING LOOP	REV: 9 PAGE 2 of 14
------------------	---	------------------------

A. PURPOSE - This procedure provides the actions required to identify and isolate leakage into the CCW system and to control the plant during the course of the event.

B. ENTRY CONDITIONS/SYMPTOMS

1. ENTRY CONDITIONS - This procedure is entered from;

- a. AP-CVCS.1, CVCS LEAK, or,
- b. AP-RCS.1, RCS LEAK, or,
- c. AP-RCP.1 RCP SEAL MALFUNCTION, when CCW surge tank level increasing.

2. SYMPTOMS - The symptoms of LEAKAGE INTO THE COMPONENT COOLING LOOP are;

- a. Annunciator A-5, CCW SURGE TANK HI LEVEL 58.8%, lit or
- b. CCW radiation monitor (R-17) alarm, or
- c. Annunciator A-7 (15), RCP A (B) CCW RETURN HI TEMP OR LO FLOW 165 GPM 125°F, lit or
- d. Erratic RCP labyrinth seal D/P.

2023 1000 1000

1000 1000 1000

1000 1000 1000

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

CAUTION
 o IF, AT ANY TIME DURING THIS PROCEDURE, A REACTOR TRIP OR SI OCCURS, THEN E-0, REACTOR TRIP OR SAFETY INJECTION, SHALL BE PERFORMED.
 o IF CCW SYSTEM RADIATION MONITOR ALARMS, THEN VERIFY CCW SURGE TANK VENT, RCV-017, CLOSES.

1 Check CCW Indications

- | | |
|---|--|
| a. Check CCW surge tank level - INCREASING | a. <u>IF</u> level decreasing, <u>THEN</u> go to AP-CCW.2, LOSS OF CCW DURING POWER OPERATION or AP-CCW.3, LOSS OF CCW - PLANT SHUTDOWN as necessary. <u>IF</u> level stable, <u>THEN</u> return to procedure or step in effect. |
| b. Direct RP tech to perform PG-12.3, DETERMINATION OF CCW SYSTEM LEAKAGE | |
| c. CCW radiation monitor, R-17; - INCREASING | c. Check RCS leakrate. <u>IF</u> RCS leakrate increasing, <u>THEN</u> go to Step 2 (Refer to RCS Leakage Surveillance Sheet)

<u>IF</u> RCS leakage and R-17 indication normal, <u>THEN</u> go to Step 13. |

EOP:
AP-CCW.1

TITLE:
LEAKAGE INTO THE COMPONENT COOLING LOOP

REV: 9
PAGE 4 of 14

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

CAUTION

IF EITHER RCP #1 SEAL OUTLET TEMPERATURE EXCEEDS 215°F, THEN THE AFFECTED RCP(S) SHOULD BE STOPPED.

NOTE: RCPs may be safely operated without CCW to the thermal barrier if seal injection flow is maintained.

2 Check RCP Thermal Barrier Indications:

- o Labyrinth seal D/Ps - GREATER THAN 15 INCHES OF WATER AND APPROXIMATELY EQUAL
- o RCP #1 seal leak off flows - BETWEEN 0.25 GPM AND 5.5 GPM
- o Annunciator A-7 (15), RCP A (B) CCW RETURN HI TEMP OR LO FLOW 165 GPM 125°F - EXTINGUISHED

IF either pump has indication of a thermal barrier leak, THEN perform the following:

- a. Verify seal injection flow to affected RCP.
- b. Close CCW return from affected RCP thermal barrier (labyrinth seal D/P should increase).
 - RCP A, AOV-754A
 - RCP B, AOV-754B
- c. Evaluate CCW surge tank level trend. IF leakage into the CCW system has stopped, THEN go to Step 17.

3 Check RCS temperature - GREATER THAN 350°F

Go to Step 7.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

CAUTION

CLOSELY MONITOR PRZR LEVEL WHILE LETDOWN IS ISOLATED.

4 Check NRHX For Leakage:

a. Normal letdown - IN SERVICE

a. IF excess letdown in service, THEN perform the following:

- 1) Close excess letdown flow control valve, HCV-123.
- 2) Close EXCESS LTDN LOOP A COLD TO Hx, AOV-310.
- 3) Go to Step 5.


b. Check Letdown Indications:

b. Isolate Normal Letdown:

- o Letdown line flow - APPROXIMATELY 40 GPM
- o Low press LTDN pressure - APPROXIMATELY 250 PSIG
- o Letdown pressure control valve, PCV-135, demand - APPROXIMATELY 35% OPEN

- 1) Close loop B cold leg to REGEN Hx, AOV-427.
- 2) Close letdown orifice valves (AOV-200A, AOV-200B, and AOV-202).
- 3) Place letdown pressure controller, PCV-135, in MANUAL and close valve (demand at 100%).
- 4) Control charging pump speed as necessary to maintain RCP labyrinth seal D/P less than 80 inches.
- 5) Close charging flow control valve, HCV-142.
- 6) Go to Step 5.

c. Go to Step 6



EOP:

AP-CCW.1

TITLE:

LEAKAGE INTO THE COMPONENT COOLING LOOP

REV: 9

PAGE 6 of 14

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

5 Check If CCW Inleakage Has Stopped:

a. CCW surge tank level - STABLE

a. IF CCW surge tank level still increasing, THEN perform the following:

1) Restore letdown flowpath previously isolated (Refer to Attachment LETDOWN).

2) Adjust charging as necessary to restore PRZR level.

3) Go to Step 13.

b. Restore an intact letdown flowpath if available (Refer to Attachment LETDOWN)

c. Check any letdown flowpath - RESTORED

c. IF no letdown flowpath available, THEN consult Plant Staff.

d. Adjust charging as necessary to restore PRZR level

EOP:

AP-CCW.1

TITLE:

LEAKAGE INTO THE COMPONENT COOLING LOOP

REV: 9

PAGE 7 of 14


STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

6 Establish Stable Plant Conditions:

- | | |
|--|--|
| a. Check Tavg - TRENDING TO TREF | a. Insert/withdraw control rods or, if necessary, adjust turbine load to match Tavg to Tref. |
| b. Check PRZR pressure - TRENDING TO 2235 PSIG | b. Verify proper operation of PRZR heaters and spray or take manual control of PRZR pressure controller 431K. |
| c. Check PRZR level - TRENDING TO PROGRAM | c. Verify proper operation of charging pump speed controllers or take manual control of speed controllers to control PRZR level. |
| d. Go to Step 17 | |



STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

CAUTION

- o CLOSELY MONITOR PRZR LEVEL AND RCS PRESSURE WHILE LETDOWN IS ISOLATED.
- o UNFILTERED WATER MAY DAMAGE RCP SEAL SURFACES.

7 Check NRHX For Leakage:

- | | |
|--|---|
| <p>a. Narrow range PRZR level - ON SCALE</p> | <p>a. <u>IF</u> the RCS is solid, <u>THEN</u> perform the following:</p> <ol style="list-style-type: none"> 1) Stop any running RCP. 2) <u>WHEN</u> RCPs stopped, <u>THEN</u> stop any running charging pump. |
|--|---|
- b. Isolate letdown flow to NRHX:
- o Ensure the following valves - CLOSED
 - Loop B cold leg to REGEN Hx, AOV-427
 - Letdown orifice valves (AOV-200A, AOV-200B, and AOV-202)
 - RHR letdown flow control valve, HCV-133
 - o Close letdown isolation valve, AOV-371
 - o Place letdown pressure controller, PCV-135, in MANUAL and close valve (demand at 100%).

EOP:
AP-CCW.1

TITLE:
LEAKAGE INTO THE COMPONENT COOLING LOOP

REV: 9
PAGE 9 of 14

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

CAUTION

IF THE RCS IS WATER SOLID, THEN ANY INCREASE IN RCS TEMPERATURE MAY RESULT IN A SIGNIFICANT RCS PRESSURE INCREASE. RCS HEATUP SHOULD BE PREVENTED.

8 Check If CCW Inleakage Has Stopped:

- a. CCW surge tank level - STABLE
- a. IF CCW inleakage continues, THEN go to Step 9.
- b. Narrow range PRZR level - ON SCALE
- b. IF RCS is solid, THEN perform the following:
 - 1) Ensure both RCPs off.
 - 2) Cycle charging pumps as necessary to control RCS pressure.
- c. Establish excess letdown (Refer to Attachment LETDOWN)
- d. Start one charging pump
- e. Adjust charging flow as necessary to restore PRZR level
- f. Check RCS temperature - STABLE
- f. Adjust RHR cooling as necessary.
- g. Go to Step 17

1957

1957

1957

1957

1957

1957

1957

EOP:

AP-CCW.1

TITLE:

LEAKAGE INTO THE COMPONENT COOLING LOOP

REV: 9

PAGE 10 of 14

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

9 Restore Letdown:

- a. Check RHR - IN SERVICE
- b. Open letdown isolation valve, AOV-371
- c. Place letdown controllers in MANUAL at 40% open
 - TCV-130
 - PCV-135
- d. Manually open RHR LETDOWN TO CVCS, HCV-133
- e. Place TCV-130 in AUTO at 105°F
- f. Place PCV-135 in AUTO at desired pressure
- g. Start one charging pump
- h. Adjust charging flow as necessary to restore PRZR. pressure/level

a. Perform the following:

- 1) Establish normal letdown (Refer to Attachment LETDOWN).
- 2) Go to Step 10.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

CAUTION

- o ONE TRAIN OF RHR SHALL BE OPERABLE AT ALL TIMES.
- o IF AN RHR PUMP OR HX IS REMOVED FROM SERVICE, THEN OPERABILITY REQUIREMENTS SHOULD BE EVALUATED (REFER TO TECH SPEC SECTIONS 3.1.1.1 AND 3.3.1).

10 Check RHR System For Leakage:

- a. Both RHR loops - ALIGNED AND OPERABLE
 - a. IF any loop isolated for this leak investigation, THEN perform the following:
 - 1) Restore isolated loop to service (Refer to Attachment RHR ISOL and S-13A, RHR LINEUP FOR SAFETY INJECTION).
 - 2) WHEN loop restored, THEN isolate other RHR loop (Refer to Attachment RHR ISOL).
 - 3) Go to Step 11.
- b. Isolate selected RHR loop (Refer to Attachment RHR ISOL)

11 Verify RCS temperature - STABLE OR DECEASING

Increase cooling from available RHR loop. Attempt to establish S/G cooling if necessary.

Vertical text on the left side of the page, possibly a page number or header.

Faint text at the top center of the page.

Faint text in the middle of the page.

Faint text at the bottom left of the page.



STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
12	Check If CCW Inleakage Has Stopped:	
	a. CCW surge tank level - STABLE	a. <u>IF</u> any RHR loop has <u>NOT</u> been checked for leakage, <u>THEN</u> return to Step 10.
		<u>IF</u> both RHR loops have been checked, <u>THEN</u> restore RHR loops to operable and go to Step 13.
	b. Go to Step 17	
13	Check RMW to CCW Surge Tank:	
	o Verify CCW surge tank fill valve, MOV-823 - CLOSED	<u>IF</u> RMW to CCW surge tank, MOV-823, open <u>OR</u> RMW pump running, <u>THEN</u> perform the following:
	o Verify RMW pump(s) - OFF	a. Close CCW surge tank fill valve, MOV-823.
		b. Shut off running RMW pumps.
		c. <u>IF</u> CCW inleakage stops, <u>THEN</u> go to Step 17.

EOP:

AP-CCW.1

TITLE:

LEAKAGE INTO THE COMPONENT COOLING LOOP

REV: 9

PAGE 13 of 14

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

14 Check For Sample Hx Leaks:

- a. Direct AO to locally check nuclear sample room Hxs
 - o Sample Hx (TI-602) common CCW return temperature from sample Hxs - NORMAL (Refer to Aux Bldg log sheet, 3 of 3)
 - o Sample Hx (FI-603) common CCW return flow from sample Hxs - NORMAL (Refer to Aux Bldg log sheet, 3 of 3)
- b. Direct RP Tech to check PASS - SAMPLING IN PROGRESS
- c. Direct RP Tech to terminate PASS sampling
- d. Verify CCW inleakage - STOPPED

- a. Determine which sample Hx CCW outlet temperature is high, THEN perform the following:
 - 1) Isolate the affected Hx.
 - 2) IF CCW inleakage has stopped, THEN go to Step 17.
- b. Go to Step 15.

15 Check SW Header Pressure - LESS THAN 60 PSIG

Dispatch AO to check CCW pump discharge pressure. IF SW pressure greater than CCW pressure, THEN investigate possible SW leak into CCW system.


CAUTION

IF A SAFEGUARDS PUMP IS TO BE REMOVED FROM SERVICE DURING AN EMERGENCY CONDITION, THEN CONSULT WITH PLANT STAFF PRIOR TO STOPPING PUMP.

16 Check Safeguards Pump Status - ALL SAFEGUARDS PUMPS OFF

- SI pumps
- RHR pumps
- CS pumps

IF any event in progress requiring safeguards pump operation, THEN consult Plant Staff for guidance on checking safeguards pumps for CCW leakage.



STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
17 Evaluate Plant Conditions:	<ul style="list-style-type: none"> a. CCW inleakage - IDENTIFIED AND ISOLATED b. Determine if operation can continue (Consult Plant staff if necessary) - OPERATION CAN CONTINUE 	<ul style="list-style-type: none"> a. Return to Step 2. b. <u>IF</u> plant shutdown is required, <u>THEN</u> refer to 0-2.1, NORMAL SHUTDOWN TO HOT SHUTDOWN.
18 Check CCW Surge Tank Level - APPROXIMATELY 50%	Consult RP tech to determine method to drain and dispose of excess CCW.	
<p><u>NOTE:</u> Refer to 0-9.3, NRC IMMEDIATE NOTIFICATION, for reporting requirements.</p>		
19 Notify Higher Supervision		
20 Return To Procedure Or Guidance In Effect		

-END-

11
12
13
14

EOP: AP-CCW.1	TITLE: LEAKAGE INTO THE COMPONENT COOLING LOOP	REV: 9 PAGE 1 of 1
------------------	---	-----------------------

AP-CCW.1 APPENDIX LIST

<u>TITLE</u>	<u>PAGES</u>
1) ATTACHMENT RHR ISOL	1
2) ATTACHMENT LETDOWN	1

