CATEGORY 1

REGULATO INFORMATION DISTRIBUTION STEM (RIDS)

ACCESSION NBR:9708270207 DOC.DATE: 97/08/19 NOTARIZED: YES DOCKET #
FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
AU\$A.NAME AUTHOR AFFILIATION
MECREDY R.C. Rochester Gas & Electric Corp.
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Forwards application for amend to FOL DPR-18, requesting to allow testing of three ECCS motor-operated valves in Mode

4.

VISSING, G.S.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR \bot ENCL \bot SIZE: 2+22. TITLE: OR Submittal: General Distribution

C

Α

T

E

G

0

R

Y

1

D

0

C

U

M

E

N

T

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		
	PD1-1 LA	1	1	PD1-1 PD	1	1	
	VISSING, G.	1	1				
INTERNAL:	FILE CENTER 01	1	1	NRR/DE/ECGB/A	1	1	
	NRR/DE/EMCB	1	1	NRR/DRCH/HICB	1	1	
	NRR/DSSA/SPLB	1	1	NRR/DSSA/SRXB	1	1	
	NUDOCS-ABSTRACT	1	1	OGC/HDS3	1	0	•
EXTERNAL:	NOAC	ı	1	NRC PDR	1	1	•

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS
OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 12







AREA CODE 716 546-2700

ROBERT C. MECREDY Vice President Nuclear Operations

August 19, 1997

U.S. Nuclear Regulatory Commission

Document Control Desk

Attn: Guy S. Vissing

Project Directorate I-1

Washington, D.C. 20555

Subject:

Application for Amendment to Facility Operating License

Testing of Emergency Core Cooling System (ECCS) Valves

Rochester Gas & Electric Corporation

R.E. Ginna Nuclear Power Plant

Docket No. 50-244

Dear Mr. Vissing,

The enclosed license amendment request (LAR) proposes to revise the Ginna Station Improved Technical Specifications (ITS) to allow testing of three ECCS motor-operated valves (MOVs) in MODE 4. Specifically, the MOVs which provide suction capability from the containment sump for the safety injection pumps during high-head recirculation would be allowed to be tested for Ginna Station MOV Program requirements and to ensure operability of associated interlocks. Performance of this testing in MODE 4 currently requires entry into Limiting Condition for Operation (LCO) 3.0.3. Approval of this LAR would provide specific time limits for performance of this testing before LCO 3.0.3 would have to be entered.

RG&E is currently planning on performing this testing on or about November 8, 1997. To prevent unnecessary entry into LCO 3.0.3, and to allow sufficient time to implement the subject LAR, RG&E requests that approval be provided by October 27, 1997.

Very truly yours,

9708270207 970819 PDR ADOCK 05000244 P PDR

Subscribed and sworn to before me on this 19th day of August 1997.

Robert C. Mecredy

100A

Notary Public

DEBORAH A.PIPERNI

Notary Public in the State of New York
ONTARIO COUNTY

Commission Expires Nov. 23, 19.97

ı jim İm İm İm İm İm İm İm İm İm

MDF\953 Attachments

xc: U.S. Nuclear Regulatory Commission Mr. Guy Vissing (Mail Stop 14B2) PWR Project Directorate I-1 Washington, D.C. 20555

> U.S. Nuclear Regulatory Commission Region I 475 Allendale Road King of Prussia, PA 19406

Ginna Senior Resident Inspector

Mr. F. William Valentino, President New York State Energy, Research, and Development Authority 2 Empire State Plaza Albany, NY 12223-1253