

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9801050023 DOC.DATE: 97/12/19 NOTARIZED: YES DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH: NAME AUTHOR AFFILIATION
 MECREDDY, R.C. Rochester Gas & Electric Corp.
 RECIP: NAME RECIPIENT AFFILIATION
 VISSING, G.S.

SUBJECT: Notifies of completion of requested actions ^{for} 1996, testing of safety-related logic circuits IAW GL-96-01.

DISTRIBUTION CODE: A067D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: GL 96-01 Response-Testing of Safety-Related Logic

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
NRR/PD3-3	1 1	VISSING, G.	1 1
INTERNAL: <u>FILE CENTER</u> 01	1 1	NRR/DRCH/HICB	1 1
EXTERNAL: NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 6 ENCL 2

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



AREA CODE 716 546-2700

ROBERT C. MECREDY
Vice President
Nuclear Operations

December 19, 1997

U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Guy S. Vissing
Project Directorate I-1
Washington, D.C. 20555

Subject: Notification of Completion of Requested Actions for
1996, Testing of Safety-Related Logic Circuits
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Vissing:

In accordance with GL 96-01, the RG&E Nuclear Operations Group reviewed safety related logic circuits and Technical Specifications Surveillance Requirements (SRs) to ensure that all portions of safety related logic circuitry are adequately tested and that all SRs are formalized in plant procedures. The GL 96-01 Review identified 16 cases (deficiencies) where untested logic components could have failed in an undetected manner and adversely affected a required safety function. Those were subsequently tested and found to be operational with no failures. These actions were reported to the NRC in LER 96-005 dated June 17, 1996. To date, no additional deficiencies have been identified, and all previously identified untested logic components are now permanently incorporated into plant surveillance procedures.

Very truly yours,


Robert C. Mecredy

GT\485

Subscribed and sworn to before me
on this 19th day of December, 1997.



Notary Public

DEBORAH A. PIPERNI
Notary Public in the State of New York
ONTARIO COUNTY
Commission Expires Nov. 23, 1999

310051



9801050023 971219
PDR ADDCK 05000244
PDR

xc: Mr. Guy S. Vissing (Mail Stop 14B2)
Project Directorate I-1
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

US NRC Ginna Senior Resident Inspector

