NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | F L S L S 1 ② | 0 0 - 0 0 0 0 0 - 0 0 ③ | 4 1 1 1 1 ④ | ⑤
LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T 01 REPORT SOURCE L ⑥ | 0 5 0 0 0 3 3 5 ⑦ | 0 3 1 6 7 9 ⑧ | 0 4 1 3 7 9 ⑨
DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

02 During full power operation, CEA 30 slipped 10 inches while selecting
03 CEA position readout on the CEA Secondary Position Display Backup. Ac-
04 tion per T.S. 3. 1. 3.1d was initiated and CEA 30 was quickly restored
05 to its original position. This is the third occurrence of slipped CEAs
06 (See LERs 335-78-43 and -79-10).
07
08

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
R B ⑪	E ⑫	X ⑬	C R D R V E ⑭	Z ⑮	Z ⑯

⑰ LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	7 9	—	0 1 2	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS ㉒	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
X ⑱	Z ⑲	Z ⑳	Z ㉑	0 0 0 0	N ㉓	N ㉔	N ㉕	C 4 9 0 ㉖

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ㉗

10 No apparent cause for the slipped CEA could be determined. CEA 30 was
11 quickly returned to its original position following the slip. The pre-
12 sent 15 volt power supply units will be replaced with modified ones as
13 spare parts and plant conditions permit. Also, we have requested the
14 vendor review the CEDM control design from a reliability standpoint.

	FACILITY STATUS	% POWER	OTHER STATUS ㉚	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION ㉜
15	E ㉘	1 0 0 ㉙	NA	A ㉛	Operator Observation

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY ㉟	LOCATION OF RELEASE ㊱
16	Z ㉝	Z ㉞	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION ㊴
17	0 0 0 ㊲	Z ㊳	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION ㊶
18	0 0 0 ㊵	NA

LOSS OF OR DAMAGE TO FACILITY ㊸

	TYPE	DESCRIPTION
19	Z ㊷	NA

PUBLICITY

	ISSUED	DESCRIPTION ㊺	NRC USE ONLY
20	N ㊹	NA	

NAME OF PREPARER M. A. Schoppman PHONE: (305) 552-3802

7904230320