

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | F | I | S | I | S | I | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 37 38 39

CON'T
01 | L | 0 | 5 | 1 | 0 | 1 | 0 | 1 | 3 | 1 | 5 | 7 | 1 | 1 | 2 | 3 | 7 | 9 | 8 | 1 | 1 | 2 | 2 | 6 | 7 | 9 | 9
7 8 9 30 31 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 | While performing an ARMS monthly functional test in accordance with Oper-
03 | ating Procedure 1120050, it was discovered that the "MB" CIS Channel would
04 | not trip on a high radiation signal. The MB CIS channel was declared
05 | inoperable and placed in bypass in accordance with TS 3.3.2.1. The MB
06 | channel was repaired, functionally tested and restored to operable status
07 | within the time limits specified. The other three channels remained oper-
08 | able and would have initiated CIS had a high radiation condition occurred.

09 | S | I | D | 11 | E | 12 | G | 13 | I | N | I | S | I | T | I | R | U | 14 | I | 15 | Z | 16
7 8 9 10 11 12 13 18 19 20
17 | 7 | 1 | 9 | 21 | 22 | 0 | 3 | 4 | 24 | 26 | 0 | 3 | 28 | 29 | L | 30 | 0 | 32
23 | 24 | 26 | 27 | 28 | 29 | 30 | 31
18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
18 | C | 18 | Z | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | 22 | N | 23 | N | 24 | N | 25 | X | 9 | 9 | 9 | 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 | The "MB" CIS channel failed due to a failed "Action-Pak" Model 4300-159
11 | MV/I converter. Specific cause for the action-pac failure was not deter-
12 | mined. Immediate corrective action was to replace the action-pac. No
13 | further action was required.

14 | _____
15 | E | 23 | 1 | 1 | 0 | 0 | 29 | NA | 30 | B | 31 | Operator Observation | 32
7 8 9 10 12 13 44 45 46 80

16 | Z | 33 | Z | 34 | NA | 35 | NA | 36
7 8 9 10 11 44 45 80

17 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39
7 8 9 10 11 12 13 30

18 | 0 | 0 | 10 | 40 | NA | 41
7 8 9 10 11 12 30

19 | Z | 42 | NA | 43
7 8 9 10 30

20 | N | 44 | NA | 45
7 8 9 10 30

NAME OF PREPARER: M. A. Schoppman PHONE: 305-552-3802

8001110582