## LICENSEE EVENT REPORT

	CONTROL BLCCX: [
01	FILIS   L   S  1   2   0   0   -   0   0   0   0   -   0   0
CONT	REPORT L 6 0 15 10 10 1 01 3 1 3 15 7 01 1 3 10 1 8 1 0 3 012 1 2 1 9 8 0 9  EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2	While operating at 100% power, CEA #41 dropped to the bottom of the core.
03	Action was initiated in accordance with T.S. 3.1.3.1. Power was reduced
94	to 70% and the rod was returned to its normal position. On 1-31-80, CEA
05	[#41 again dropped to the bottom of the core and proper action was again ]
0 5	taken. The 15V power supply to the CPC was replaced and the CEA was
07	Ireturned to its normal position. This was the first occurrence of a CEA
<u>[013]</u>	Idropping to the bottom due to this reason (loose lead).
09	SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBC
·	17 AEPORT   SVENT YEAR   REPORT NO.   COOR   TYPE   NO.   NO.   NUMBER   21   22   23   24   26   27   23   29   30   31   32
	ACTION FUTURE CAPECT SHUTOOWN HOURS (22) ATTACHMENT NAROL PRIME COMP. COMPONENT TAXEN ACTION CAPCOLING METHOD HOURS (22) ATTACHMENT NAROL SUPPLIER MANUFACTURER MANUFACTURER (23) [X] (3) [X] (3) [X] (3) [X] (3) [X] (42) [X] (43)
10	[No cause was determined for CEA #41 dropping on 1-30-80. It was restored ]
	to its normal position and remained there for about 10 hours. After the
112	second drop it was decided to change the 15V power supply. While changing I
13	Lout the power supply a loose lead was found. This was determined to be the
	cause for both occurrences.
1 5	FACILITY SPOWER OTHER STATUS (30) METHOD OF OISCOVERY DESCRIPTION (32)  [E] (32) [10   0] (39) NA   [A] (31) Operator Observation
	CONTENT CONTENT  ELEASED OF RELEASE MOUNT OF ACTIVITY (15)  A COCATION OF RELEASE (16)  NA N
ŢŢ	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39  O O O O O O O O O O O O O O O O O O O
13	PERSONNEL INJURIES NUMBER CESCRIPTION (4) NA 10 10 10 10 12
19	COSS OF OR DAMAGE TO FACILITY 43  TYPE DESCRIPTION  NA  NA
<u> </u>	PUBLICITY ISSUED DESCRIPTION (S)  NAC USE ONLY  NAC USE ONLY  NAC USE ONLY  NAC USE ONLY
	NAME OF PREPARER M. A. Schoppman PHONE: (305) 552-3802