

REPORTABLE OCCURRENCE 335-80-14
LICENSEE EVENT REPORT
PAGE TWO.

ADDITIONAL EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

The SBVS 6B2 heater is the 1.5 Kw heater provided for humidity control of the 300 cfm cooling air flow through the 'A' SBVS train when the train is idle. The 30 Kw (6A1) heater which provides humidity control for the 6000 cfm system operating flow was fully operational at all times. Thus, the engineered safety feature function of the 'A' SBVS train was not significantly degraded. Additionally, the 'B' SBVS train was fully operational at all times.

OFFICIAL COPY