NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | F L S L S 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | | (5)
LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T 0 1 | REPORT SOURCE L (6) | 0 5 0 0 0 3 3 5 (7) | 0 5 3 1 8 0 (8) | 0 6 3 0 8 0 (9)
DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During normal steady-state operation, Channel "A" of the 1A Steam Genera-
0 3 tor low pressure trip failed. The minimum number of operable channels
0 4 was available in accordance with Table 3.3-1 of T.S. 3.3.1.1. The channel
0 5 was subequently placed in the tripped condition as specified by action
0 6 step 2 of Table 3.3-1. This is the second such event (See LER 335-78-10).
0 7
0 8

0 9 | SYSTEM CODE: I A (11) | CAUSE CODE: E (12) | CAUSE SUBCODE: A (13) | COMPONENT CODE: I N S T R U (14) | COMP. SUBCODE: P (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER | EVENT YEAR: 8 0 | – | SEQUENTIAL REPORT NO.: 0 2 8 | / | OCCURRENCE CODE: 0 3 | REPORT TYPE: L | – | REVISION NO.: 0

ACTION TAKEN: C (18) | FUTURE ACTION: Z (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0 0 0 0 | ATTACHMENT SUBMITTED: N (23) | NPRD-4 FORM SUB.: N (24) | PRIME COMP. SUPPLIER: N (25) | COMPONENT MANUFACTURER: P 3 1 4 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Investigation showed that the power supply associated with Channel "A"
1 1 had failed. The vendor was contacted and a replacement power supply was
1 2 obtained, installed, and tested within 18 hours. The inoperable channel
1 3 was then returned to service.
1 4

1 5 | FACILITY STATUS: E (28) | % POWER: 1 0 0 (29) | OTHER STATUS (30): NA | METHOD OF DISCOVERY: A (31) | DISCOVERY DESCRIPTION (32): OPERATOR OBSERVATION

1 6 | ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: A (34) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

PERSONNEL EXPOSURES
1 7 | NUMBER: 0 0 0 (37) | TYPE: Z (38) | DESCRIPTION (39): NA

PERSONNEL INJURIES
1 8 | NUMBER: 0 0 0 (40) | DESCRIPTION (41): NA

LOSS OF OR DAMAGE TO FACILITY (43)
1 9 | TYPE: Z (42) | DESCRIPTION: NA

PUBLICITY
2 0 | ISSUED: N (44) | DESCRIPTION (45): NA | NRC USE ONLY

NAME OF PREPARER: M. A. Schoppman PHONE: 305-552-3802

8007140 372