



POOR ORIGINAL

Point 3  
 Approved by  
 Date  
 E

- 1. FOR ADDITIONAL WASTE MANAGEMENT SHEETS, SEE DWG. E-3172-310-142, 141, 143, 144, 145, 146, 148.
- 2. LETTERS IN DIAMONDS REFER TO CONNECTION POINTS IN AQUA CHEM DRAWING 634-83-01-000.
- 3. ALL PIPING IS OF SAFETY CLASS "D", WITHOUT SEISMIC CLASSIFICATION.
- 4. ALL PIPING, TUBING AND ARMING IN AUXILIARY EQUIPMENT RACK SUPPLIED AND INSTALLED BY EBASCO. EQUIPMENT ON AUXILIARY EQUIPMENT RACK IS SUPPLIED BY VENDOR AND INSTALLED BY EBASCO.
- 5. AUXILIARY EQUIPMENT RACK SUPPLIED BY EBASCO.
- 6. ALL HEAT TRACING IS SUPPLIED AND INSTALLED BY EBASCO.
- 7. ALL TUBING, WIRING AND PIPING IN THE MAIN SAID DISTILLATE PUMP SKID, CONCENTRATE PUMP SKID AND CONCENTRATOR PANEL ARE INSTALLED BY VENDOR. ALL TUBING, WIRING AND PIPING SHOWN EXTERNAL TO SKIDS OR PANEL ARE BY EBASCO.

DESIGN FOR	DISCIPLINE FOR
<input checked="" type="checkbox"/> INFO COMM	<input checked="" type="checkbox"/> MECHANICAL
<input checked="" type="checkbox"/> ARCH	<input checked="" type="checkbox"/> STRUCT
<input checked="" type="checkbox"/> INSTR	<input checked="" type="checkbox"/> CONTROL
<input checked="" type="checkbox"/> PLUMBING	<input checked="" type="checkbox"/> ELECTRICAL
<input checked="" type="checkbox"/> HVAC	<input checked="" type="checkbox"/> WATER TREAT
<input checked="" type="checkbox"/> ROBOTICS	<input checked="" type="checkbox"/> STRESS
<input checked="" type="checkbox"/> SHIELDING	<input checked="" type="checkbox"/> MATERIALS
<input checked="" type="checkbox"/> CONST	<input checked="" type="checkbox"/> LICENSING
<input checked="" type="checkbox"/> PORT SECT	
<input checked="" type="checkbox"/> ELEC	
<input checked="" type="checkbox"/> STAND. DISTRIBUTION	

E-3172-310-167  
 CERTIFIED FOR CONSTRUCTION

TERA APERTURE CARD

2998-3733 R 3/2/77  
 FLORIDA POWER & LIGHT COMPANY  
 ST LUCIE PLANT  
 1981 - 895,000 KW EXTENSION - UNIT 2

NO.	DATE	BY	REVISION
1	11/27/76	764/H/M	ISSUED FOR CONSTRUCTION

REVISIONS:  
 1. REVISED TO REFLECT VENDOR COMMENTS.  
 2. REVISED TO REFLECT VENDOR COMMENTS.  
 3. REVISED TO REFLECT VENDOR COMMENTS.  
 4. REVISED TO REFLECT VENDOR COMMENTS.  
 5. REVISED TO REFLECT VENDOR COMMENTS.

APPROVED BY:   
 DATE:   
 TITLE:   
 SIGNATURE:   
 TITLE:   
 SIGNATURE:   
 TITLE:   
 SIGNATURE:   
 TITLE:

EBASCO SERVICES INCORPORATED  
 3000 ST. JOHN AVENUE, SUITE 100  
 TAMPA, FLORIDA 33604

REV.	DESCRIPTION	DATE	BY	CHKD.	APP'D.	DESCRIPTION	DATE	BY	CHKD.	APP'D.	DESCRIPTION
1	REVISED TO REFLECT VENDOR COMMENTS AND ASSOCIATED INFORMATION. SEE REV. 1572-4.	11/27/76	764/H/M			INITIAL RELEASE UPGRADES TO APPROVED BY PLANT ENGINEER PER VENDOR REQ. 1572-1.	11/27/76	764/H/M			
2	REVISED TO REFLECT VENDOR COMMENTS AND ASSOCIATED INFORMATION. SEE REV. 1572-4.	11/27/76	764/H/M			ADDED VALVE 68011E TO CONCENTRATOR PANEL. SEE VENDOR DRAWING 634-83-01-000 FOR DETAILS. THIS VALVE IS TO BE INSTALLED BY VENDOR.	11/27/76	764/H/M			
3	REVISED TO REFLECT VENDOR COMMENTS AND ASSOCIATED INFORMATION. SEE REV. 1572-4.	11/27/76	764/H/M			ADDED VALVE 68011E TO CONCENTRATOR PANEL. SEE VENDOR DRAWING 634-83-01-000 FOR DETAILS. THIS VALVE IS TO BE INSTALLED BY VENDOR.	11/27/76	764/H/M			