

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | |

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	F	I	L	S		L	S	1	③	0	0	1	0	0	1	0	-	0	0	③	4	1	1	1	1	③	0	1	5
7 3	LICENSEE CODE	14	15	LICENSE NUMBER	25	26	LICENSE TYPE	30	37	CAT	18																		

CONT'

0 1	REPORT SOURCE	L	⑥	0	5	0	0	0	3	3	5	⑦	1	1	2	0	3	8	0	⑧	1	2	3	1	8	0	⑨
7 3	60	61	SOCKET NUMBER	68	69	EVENT DATE	74	75	REPORT DATE	80																	

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During normal full power operation containment radiation channel MD failed
 0 3 high. Channel MD was immediately placed in the bypassed condition and
 0 4 troubleshooting commenced. When it was determined that the detector had
 0 5 failed, channel MD radiation was placed in the tripped condition per Tech
 0 6 Spec 3.3.2.1. This occurred less than 10 hours after the channel had
 0 7 failed. No threat to the public health or safety existed. No safety limits
 0 8 were exceeded. Previous LER's of this nature are 80-37, 78-04 and 76-05.

0 9	SYSTEM CODE	I	B	⑪	CAUSE CODE	E	⑫	CAUSE SUBCODE	E	⑬	COMPONENT CODE	I	N	S	T	R	U	⑭	COMP. SUBCODES	E	⑮	Z	⑯	VALVE SUBCODE				
7 3 9	17 LER/RO REPORT NUMBER	8	0	21	EVENT YEAR	22	23	SEQUENTIAL REPORT NO.	0	6	8	24	25	26	27	OCCURRENCE CODE	0	3	28	29	REPORT TYPE	L	30	REVISION NO.	0	31	32	33
18 ACTION TAKEN	19 FUTURE ACTION	A	20 EFFECT ON PLANT	Z	21 SHUTDOWN METHOD	Z	22 HOURS	0	0	0	0	23	24	25	26	ATTACHMENT SUBMITTED	N	23	27	28	VENDOR SOURCE	N	29	PRIME COMP SUPPLIER	N	30	31	32
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	COMPONENT MANUFACTURER	V	1	1	1	5	25	33	34	35	36	37	38	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The radiation detector is in a high radiation field during normal plant
 1 1 operation and cannot be replaced without a plant outage. The detector will
 1 2 be replaced during an upcoming plant outage. A replacement detector has
 1 3 been obtained and calibrated. Channel MD CIS radiation will be maintained
 1 4 in accordance with T.S. 3.3.2.1 until the detector is replaced.

1 5	FACILITY STATUS	E	⑬	X POWER	1	0	0	⑭	OTHER STATUS	NA	44	45	46	METHOD OF DISCOVERY	A	⑮	DISCOVERY DESCRIPTION	Operator Observation	30
-----	-----------------	---	---	---------	---	---	---	---	--------------	----	----	----	----	---------------------	---	---	-----------------------	----------------------	----

1 6	ACTIVITY CONTENT	Z	⑯	RELEASED OF RELEASE	Z	⑰	AMOUNT OF ACTIVITY	⑯	44	45	46	47	LOCATION OF RELEASE	NA	35	36	37	38	39
-----	------------------	---	---	---------------------	---	---	--------------------	---	----	----	----	----	---------------------	----	----	----	----	----	----

1 7	PERSONNEL EXPOSURES NUMBER	0	0	0	⑯	Z	⑰	DESCRIPTION	⑯	44	45	46	47	NA	35	36	37	38	39
-----	----------------------------	---	---	---	---	---	---	-------------	---	----	----	----	----	----	----	----	----	----	----

1 8	PERSONNEL INJURIES NUMBER	0	0	0	⑯	DESCRIPTION	⑯	44	45	46	47	NA	35	36	37	38	39
-----	---------------------------	---	---	---	---	-------------	---	----	----	----	----	----	----	----	----	----	----

1 9	LOSS OF CHARGE/DAMAGE TO FACILITY TYPE	Z	⑯	DESCRIPTION	⑯	44	45	46	47	NA	35	36	37	38	39
-----	--	---	---	-------------	---	----	----	----	----	----	----	----	----	----	----

2 0	PUBLICITY ISSUED	N	⑯	DESCRIPTION	⑯	44	45	46	47	NA	35	36	37	38	39	NRC USE ONLY	30
-----	------------------	---	---	-------------	---	----	----	----	----	----	----	----	----	----	----	--------------	----

2 1	NAME OF PREPARED	P.L. Pace	44	45	46	47	PHONE:	(305) 552-3801	35	36	37	38	39	40	41	42	43	44	45	46	47	30
-----	------------------	-----------	----	----	----	----	--------	----------------	----	----	----	----	----	----	----	----	----	----	----	----	----	----

8102030407

