

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 3 3 14 15 25 26 30 37 38
[0] [1] [F] [L] [S] [L] [S] [1] [2] [0] [0] [-] [0] [0] [0] [0] [-] [0] [0] [3] [4] [1] [1] [1] [1] [4] [5]7 3 30 61 68 69 74 75 80
CONIT [0] [1]
REPORT SOURCE [1] [5] [0] [5] [0] [0] [0] [3] [3] [5] [7] [0] [2] [1] [4] [8] [1] [3] [0] [3] [1] [6] [8] [1] [9]
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[0] [2] During full power operation, the primary DDPS line printer
[0] [3] experienced intermittent operation over a period of 16 hrs. The DDPS moni-
[0] [4] tors incore neutron detectors. No loss of alarm function occurred.
[2] [5] Manual alarm printout was still possible via the Programmers
[3] [5] console. No threat to public health or safety existed.
[0] [7] This is the first LER of this type.

7 3 30
[0] [3]
SYSTEM CODE [1] [E] [11]
CAUSE CODE [E] [12]
CAUSE SUBCODE [B] [13]
COMPONENT CODE [I] [N] [S] [T] [R] [U] [14]
COMP. SUBCODE [R] [15]
VALVE SUBCODE [Z] [16]
[17] CENRO REPORT NUMBER [8] [1]
EVENT YEAR [8] [1]
SEQUENTIAL REPORT NO. [0] [0] [9]
OCCURRENCE CODE [0] [3]
REPORT TYPE [L]
REVISION NO. [0]
ACTION TAKEN [A] [18]
FUTURE ACTION [Z] [19]
EFFECT ON PLANT [Z] [20]
SHUTDOWN METHOD [Z] [21]
HOURS [0] [0] [0] [0]
ATTACHMENT SUBMITTED [N] [23]
NPRO- FORM SUB. [N] [24]
PRIME COMP. SUPPLIER [N] [25]
COMPONENT MANUFACTURER [F] [1] [2] [0] [29]

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
[1] [1] [0] The dampener in the DDPS line printer
[1] [1] failed. The dampener was replaced and the line
[1] [2] printer returned to service.

7 3 30
[1] [5] [E] [23]
FACILITY STATUS [E] [23]
% POWER [1] [0] [0] [29]
OTHER STATUS [NA]
METHOD OF DISCOVERY [A] [31]
DISCOVERY DESCRIPTION [Operator Observation] [32]7 3 30
[1] [5] [Z] [33]
ACTIVITY CONTENT [Z] [33]
RELEASED OR RELEASE [Z] [33]
AMOUNT OF ACTIVITY [NA]
LOCATION OF RELEASE [NA] [35]7 3 30
[1] [7] [0] [0] [0] [37]
PERSONNEL EXPOSURES [0] [0] [0] [37]
DESCRIPTION [Z] [38]
NA7 3 30
[1] [2] [0] [0] [0] [40]
PERSONNEL INJURIES [0] [0] [0] [40]
DESCRIPTION [NA]7 3 30
[1] [9] [Z] [42]
LOSS OF OR DAMAGE TO FACILITY [Z] [42]
DESCRIPTION [NA]7 3 30
[2] [5] [N] [44]
PUBLISHED DESCRIPTION [N] [44]
NA

NAME OF PREPARED Ken Simmons

PHONE: (305) 552-3815

8104140552