



September 27, 2017  
RC-17-0134

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Subject: VIRGIL C. SUMMER NUCLEAR STATION, UNIT 1  
DOCKET NO. 50-395  
OPERATING LICENSE NO. NPF-12  
LICENSE AMENDMENT REQUEST – LAR-15-01424  
IMPLEMENTATION OF WCAP-15376-P-A, REVISION 1  
RESPONSE TO REQUEST FOR SUPPLEMENTAL INFORMATION

Reference: 1. T. D. Gatlin, SCE&G, letter to Document Control Desk, NRC, "License Amendment Request – LAR-15-01424 Implementation of WCAP-15376-P-A, Revision 1 – 'Risk-Informed Assessment of the RTS and ESFAS Surveillance Test Intervals and Reactor Trip Breaker Test and Completion Times'," dated December 16, 2015 [ML15356A048]

2. S.A. Williams, NRC e-mail to B. Thompson, SCE&G, "V.C. Summer Nuclear Station, Unit 1 - TSTF-411 application TS page 3/4 3-37" Supplemental Information Needed to correct Typographical error, dated September 13, 2017

South Carolina Electric & Gas Company (SCE&G), acting for itself and as agent for South Carolina Public Service Authority pursuant to 10 CFR 50.90, submitted License Amendment Request per Reference 1 concerning the implementation of WCAP-15376-P-A, Revision 1. During NRC staff review of the Technical Specification (TS) pages provided with the application dated December 16, 2015 (Reference 1), NRC staff identified an administrative error in Table 4.3-2 on TS Page 3/4 3-37 (Reference 2). This submittal contains SCE&G's corrected TS page.

This letter does not contain any new regulatory commitments.

If there are any questions or if additional information is needed, please contact Bruce L. Thompson at (803) 931-5042.

I certify under penalty of perjury that the foregoing is correct and true.

9/27/17

Executed on



George A. Lippard

BD/GAL/hk

Attachments:

Enclosure 1: Description of Technical Specification Administrative Error

Enclosure 2: Mark-Up Technical Specification Page Correcting the Administrative Error

Enclosure 3: Clean Copy of Technical Specification Page Correcting the Administrative Error

c: K. B. Marsh  
S. A. Byrne  
J. B. Archie  
N. S. Carns  
J. H. Hamilton  
G. J. Lindamood  
W. M. Cherry  
C. Haney  
S. A. Williams  
NRC Resident Inspector  
K.M. Sutton  
S.E. Jenkins  
Paulette Ledbetter  
NSRC  
RTS (CR-15-01424)  
Files (813.20)  
PRSF (RC-17-0134)

Document Control Desk  
Enclosure 1  
CR-15-01424  
RC-17-0134  
Page 1 of 2

---

---

**VIRGIL C. SUMMER NUCLEAR STATION (VCSNS) UNIT 1  
DOCKET NO. 50-395  
OPERATING LICENSE NO. NPF-12**

**ENCLOSURE 1**

**DESCRIPTION OF TECHNICAL SPECIFICATION ADMINISTRATIVE ERROR**

---

---

1. Description of Typographical Error

During NRC staff review of the Technical Specification (TS) pages provided with the application dated December 16, 2015 (Reference 1), NRC staff identified an administrative error in Table 4.3-2 Engineered Safety Feature Actuation System Instrumentation Surveillance Requirements on TS Page 3/4 3-37.

The administrative error is a duplicate line item in Table 4.3-2 Functional Unit 4.d. "Steam Flow in Two Steam Lines -- High Coincident with  $T_{avg}$  --Low-Low". Only one line is required to specify the surveillance requirements for Functional Unit 4.d. This error has been in the VCSNS TSs since the issuance of the facility operating license on August 6, 1982.

This request is specific to deleting the duplicate line in Table 4.3-2 Functional Unit 4.d on TS Page 3/4 3-37.

2. Corrections to the Affected TS Pages

The Mark-Up of Technical Specification Page Correcting the Administrative Error is found in Enclosure 2. The Clean Copy of Technical Specification Page Correcting the Administrative Error is found in Enclosure 3.

Document Control Desk  
Enclosure 2  
CR-15-01424  
RC-17-0134  
Page 1 of 2

---

---

**VIRGIL C. SUMMER NUCLEAR STATION (VCSNS) UNIT 1  
DOCKET NO. 50-395  
OPERATING LICENSE NO. NPF-12**

**ENCLOSURE 2**

**MARK-UP TECHNICAL SPECIFICATION PAGE CORRECTING THE ADMINISTRATIVE ERROR**

---

---

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION  
SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>ANALOG CHANNEL OPERATIONAL TEST</u>	<u>TRIP ACTUATING DEVICE OPERATIONAL TEST</u>	<u>ACTUATION LOGIC TEST</u>	<u>MASTER RELAY TEST</u>	<u>SLAVE RELAY TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
4. STEAM LINE ISOLATION								
a. Manual	N.A.	N.A.	N.A.	R	N.A.	N.A.	N.A.	1, 2, 3
b. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	M(1)	M(1)	R(3)	1, 2, 3
c. Reactor Building Pressure-High-2	S	R	Q	N.A.	N.A.	N.A.	N.A.	1, 2, 3
d. Steam Flow in Two Steam Lines--High Coincident with T <sub>avg</sub> --Low-Low	S	R	Q	N.A.	N.A.	N.A.	N.A.	1, 2, 3
e. Steam Line Pressure Low	S	R	Q	N.A.	N.A.	N.A.	N.A.	1, 2, 3
5. TURBINE TRIP AND FEEDWATER ISOLATION								
a. Steam Generator Water Level--High-High	S	R	Q	N.A.	N.A.	N.A.	N.A.	1, 2
b. Automatic Actuation Logic and Actuation Relay	N.A.	N.A.	N.A.	N.A.	M(1)	M(1)	R(3)	1, 2
6. EMERGENCY FEEDWATER								
a. Manual	N.A.	N.A.	N.A.	R	N.A.	N.A.	N.A.	1, 2, 3
b. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	M(1)	M(1)	R(3)	1, 2, 3
c. Steam Generator Water Level--Low-Low	S	R	Q	N.A.	N.A.	N.A.	N.A.	1, 2, 3

1, 2, 3 Remove duplicate line

Document Control Desk  
Enclosure 3  
CR-15-01424  
RC-17-0134  
Page 1 of 2

---

---

**VIRGIL C. SUMMER NUCLEAR STATION (VCSNS) UNIT 1  
DOCKET NO. 50-395  
OPERATING LICENSE NO. NPF-12**

**ENCLOSURE 3**

**CLEAN COPY OF TECHNICAL SPECIFICATION PAGE CORRECTING THE ADMINISTRATIVE  
ERROR**

---

---

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION  
SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>ANALOG CHANNEL OPERATIONAL TEST</u>	<u>TRIP ACTUATING DEVICE OPERATIONAL TEST</u>	<u>ACTUATION LOGIC TEST</u>	<u>MASTER RELAY TEST</u>	<u>SLAVE RELAY TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
4. STEAM LINE ISOLATION								
a. Manual	N.A.	N.A.	N.A.	R	N.A.	N.A.	N.A.	1, 2, 3
b. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	Q(1)	Q(1)	R(3)	1, 2, 3
c. Reactor Building Pressure-High-2	S	R	SA	N.A.	N.A.	N.A.	N.A.	1, 2, 3
d. Steam Flow in Two Steam Lines--High Coincident with T <sub>avg</sub> --Low-Low	S	R	SA	N.A.	N.A.	N.A.	N.A.	1, 2, 3
e. Steam Line Pressure Low	S	R	SA	N.A.	N.A.	N.A.	N.A.	1, 2, 3
5. TURBINE TRIP AND FEEDWATER ISOLATION								
a. Steam Generator Water Level--High-High	S	R	SA	N.A.	N.A.	N.A.	N.A.	1, 2
b. Automatic Actuation Logic and Actuation Relay	N.A.	N.A.	N.A.	N.A.	Q(1)	Q(1)	R(3)	1, 2
6. EMERGENCY FEEDWATER								
a. Manual	N.A.	N.A.	N.A.	R	N.A.	N.A.	N.A.	1, 2, 3
b. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	Q(1)	Q(1)	R(3)	1, 2, 3
c. Steam Generator Water Level--Low-Low	S	R	SA	N.A.	N.A.	N.A.	N.A.	1, 2, 3